## PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-86-17A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

FACILITY: Carolina Power & Light Company
Brunswick Unit 2
Docket No. 50-324
Southport, North Carolina

Licensee Emergency Classification:

X Notification of Unusual Event

Alert

Site Area Emergency

General Emergency

Not Applicable

SUBJECT: TRANSPORTATION OF INJURED WORKER TO HOSPITAL - UPDATE

This PN updates PNO-II-86-17, issued on February 24.

Additional information from Carolina Power & Light indicates that there was some contamination on the protective clothing and on a stretcher used to transport to a hospital a contract construction worker who fell while working inside the Brunswick Unit 2 drywell on February 23.

Surveys showed that the contamination amounted to about 25,000 disintegrations per minute (dpm) on the protective clothing removed from the worker at the hospital, and about 270 dpm on the stretcher. The site release limit is 1000 dpm. In both cases, contamination was confined to a single spot. The protective clothing and stretcher were bagged and returned to the plant. No other contamination was found.

CP&L is prepared to respond to media inquiries.

The State of North Carolina has been informed.

This information is current as of 1:30 p.m. (EST) today.

Contact: B. Revsin, 242-2686

T. Decker, 242-2600

DISTRIBUTION:

H. Street MNBB Phillips E/W Willste MAIL: Chairman Palladino EDO NMSS ADM: DMB Comm. Roberts PA OIA RES DOT: Trans Only Comm. Asselstine MPA AEOD Applicable State Comm. Bernthal ELD Comm. Zech -2:21 22 2:33 2:30 RIF RIT INPO- 2:30 Air Rights INPO SECY NSAC ACRS CA PDR Regions: Licensee: Z:40 (Reactor Licensees) Applicable Resident Site 2 46

> 8603040250 860225 PDR I&E PNO-II-86-017A PDR

DMB-1