




NUCLEAR POWER BUSINESS UNIT
CALCULATION DOCUMENT FORM

Calculation Number: 98-0132, Revision 0	Title of Calculation: Evaluation of 23.6 EFPY P-T Limit and LTOP Applicability Date and Pressurized Thermal Shock at 32 EFPY					
<input type="checkbox"/> Original Calculation <input checked="" type="checkbox"/> Supersedes Calculation # N-92-066, Rev. 0 # N-92-067, Rev. 0						
<input type="checkbox"/> Revised Calculation. Revision # _____						
<input checked="" type="checkbox"/> QA-Scope <input type="checkbox"/> Non - QA-Scope	Governing Calculation: N/A Title: N/A					
	Associated Modification or Procedure: N/A Title: N/A					
This Calculation has been reviewed in accordance with NP 7.2.4. The review was accomplished by one or a combination of the following (as checked):						
<table style="width:100%; border:none;"> <tr> <td style="width:50%; border:none;"> <input type="checkbox"/> A review of a representative sample of repetitive calculations. </td> <td style="width:50%; border:none;"> <input checked="" type="checkbox"/> A detailed review of the original calculation. </td> </tr> <tr> <td style="border:none;"> <input type="checkbox"/> A review of the calculation against a similar calculation previously performed. </td> <td style="border:none;"> <input type="checkbox"/> A review by an alternate, simplified, or approximate method of calculation. </td> </tr> </table>			<input type="checkbox"/> A review of a representative sample of repetitive calculations.	<input checked="" type="checkbox"/> A detailed review of the original calculation.	<input type="checkbox"/> A review of the calculation against a similar calculation previously performed.	<input type="checkbox"/> A review by an alternate, simplified, or approximate method of calculation.
<input type="checkbox"/> A review of a representative sample of repetitive calculations.	<input checked="" type="checkbox"/> A detailed review of the original calculation.					
<input type="checkbox"/> A review of the calculation against a similar calculation previously performed.	<input type="checkbox"/> A review by an alternate, simplified, or approximate method of calculation.					
Page Inventory: Page 1 - 4 Form PBF-1608 Page 5 - 17 Calculation						
Attachments: Framatome Technologies, Inc. letter FTI-98-2563, "Reevaluation of Weld Wire Heat 61782," August 26, 1998: Pages 18 through 25						
Prepared By: Thomas D. Spry	 _____ Signature	Date: 9/15/98				
Reviewed By: James R. Pfefferle	 _____ Signature	Date: 9/15/98				
Approved By: Victoria A. Walther	 _____ Signature	Date: 9/23/98				

NUCLEAR POWER BUSINESS UNIT
CALCULATION DOCUMENT FORM

Calculation #:98-0132, Rev. 0

Page 2 of 25

Preparer: T.D. Spry TDS

Date: 9/15/98

Calculation Checklist (Optional for Non-QA Scope)

Item No.	Attribute Description	N/A	Author	Reviewer
1.	Purpose			
a.	Is the purpose clearly stated indicating issue to be resolved or information to be determined?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
2.	Methodology and Acceptance Criteria			
a.	Has the method/approach been described?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
b.	Have appropriate acceptance criteria and their sources been identified?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
3.	Assumptions			
a.	Are the assumptions provided with sufficient rationale to permit verification?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
b.	Have assumptions associated with pending plant or procedure changes that require verification been identified?	N/A	<input type="checkbox"/>	<input type="checkbox"/> yes N/A <input type="checkbox"/> no
c.	Have the requirements to revise governing calculations or verify pending assumptions been documented in a modification or an EWR?	N/A	<input type="checkbox"/>	<input type="checkbox"/> yes N/A <input type="checkbox"/> no
5.	References			
a.	Have all the appropriate references, including revisions and/or dates, been identified?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
b.	Are all references readily available in the PBNP Records System, as public documents, or attached?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
4.	Inputs			
a.	Have the applicable inputs and sources been identified?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
6.	Calculation			
a.	Have formulae and inputs been provided consistent with the source document, including engineering units?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
7.	Computer-Aided Design Calculations (NP 7.2.4 Attachment A)			
a.	Has the computer program been validated per the requirements of Attachment A?	N/A	<input type="checkbox"/>	<input type="checkbox"/> yes N/A <input type="checkbox"/> no
b.	Have the program version and revision been identified on the computer run and in the calculation?	N/A	<input type="checkbox"/>	<input type="checkbox"/> yes N/A <input type="checkbox"/> no

NUCLEAR POWER BUSINESS UNIT
CALCULATION DOCUMENT FORM

Calculation #: 98-0132, Rev. 0

Page 3 of 25

Preparer: T.D. Spry *TDS*

Date: 9/15/98

Item No.	Attribute Description	N/A	Author	Reviewer
c.	Is the input to the computer program adequately documented?	N/A	<input type="checkbox"/>	<input type="checkbox"/> yes N/A <input type="checkbox"/> no
d.	If spreadsheet or other simple computer aided tools are used in the calculation, have the formulae been documented in the calculation?	N/A	<input type="checkbox"/>	<input type="checkbox"/> yes N/A <input type="checkbox"/> no
e.	Have the attributes been documented in the calculation for any input or output data files supporting the calculation, including file name, date stamp, time stamp (hour and minute only), and file size?	N/A	<input type="checkbox"/>	<input type="checkbox"/> yes N/A <input type="checkbox"/> no
8.	Summary of Results and Conclusions			
a.	Do the summary of results and conclusions clearly state the calculation results and respond to the purpose?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
b.	Do the conclusions address the acceptability/ unacceptability of the results?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
c.	Has a CR been initiated to identify any unsatisfactory conditions?		<input checked="" type="checkbox"/> CR 98-2340	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
d.	Have all engineering judgments been provided with sufficient rationale?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
9.	Administrative			
a.	Have calculation format and content as noted in NP 7.2.4 been followed?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
b.	Have all required attachments been included in the document and numbered appropriately?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
c.	Has the calculation been prepared neatly and legibly with sufficient contrast to allow satisfactory record copies to be produced?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
d.	Are the calculation number, preparer's initials, preparation date, and page number provided on each page?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
e.	Have revisions been clearly identified by revision bars or other appropriate means (for revised calculations only)?	N/A	<input type="checkbox"/>	<input type="checkbox"/> yes N/A <input type="checkbox"/> no
f.	If the calculation supersedes a previous calculation, is this noted on the cover sheet?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no

NUCLEAR POWER BUSINESS UNIT
CALCULATION DOCUMENT FORM

Calculation #:98-0132, Rev. 0

Page 4 of 25

Preparer: T.D. Spry *TDS*

Date: 9/15/98

Item No.	Attribute Description	N/A	Author	Reviewer
g.	Has the calculation been appropriately identified as QA or Non-QA scope?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
h.	Has the review method been clearly identified on the cover page?			<input checked="" type="checkbox"/> yes <input type="checkbox"/> no
i.	Is all information requested by PBF-1620 entered on the form?		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> no

COMMENTS AND RESOLUTION

Reviewer Comments:	Resolution:
<p>No outstanding comments. <i>Jep</i> <i>9/15/98</i></p>	<p>N/A</p>



TDS

TITLE Evaluation of 23.6 EFPY P-T Limit and LTOP Applicability Date and Pressurized Thermal Shock at 32 EFPY MADE BY T.D. Spry DATE 9/15/98 REV'D. BY J.R. Pfefferle DATE 9/15/98

Purpose:

This calculation provides an evaluation of Unit 1 and Unit 2 vessel beltline material adjusted reference temperatures (ARTs) and their inputs, currently used as input to P-T limits (in Calculation #N-94-058, Revision 2, with a stated applicability date of 23.6 EFPY) and LTOP setpoints (in Calculation No. 98-0046, Revision 0, calculated for the fluence projected as of January 1, 2001). The latest available best-estimate chemistry values and all applicable surveillance data for all vessel beltline materials will be utilized. A revised applicability date in terms of effective full power years (EFPY) is provided for the most limiting vessel, Unit 2. This calculation also provides a pressurized thermal shock evaluation for Unit 1 and 2 at 32 EFPY in accordance with 10 CFR 50.61, using the latest available best-estimate chemistry values and all applicable surveillance data for all vessel beltline materials.

This calculation was prepared to formally document the assessment of additional weld chemistry data recently obtained from the B/WOG and CEOG, to determine if this data affects previous RPV integrity analyses.

Table of Contents:

Purpose 5
References 6
Methods & Acceptance Criteria 6
Assumptions 7
Inputs 7
Calculations I. (see table below) 7

Table with 3 columns: Table Number, Table Description, Page Number. Contains 8 rows of table data.

II. Fluence Projection to January 2001 16
Results and Conclusions 16
Attachments - FTI Letter FTI-98-2563, August 26, 1998 17



TITLE Evaluation of 23.6 EFPY P-T Limit and LTOP Applicability Date and MADE BY T.D. Spry DATE 9/15/98
Pressurized Thermal Shock at 32 EFPY REV'D. BY J.R. Pfefferle DATE 9/15/98

References:

1. Instruction Manual 132-Inch I.D. Reactor Pressure Vessel, Babcock & Wilcox, September 1969.
2. Instruction Manual, Reactor Vessel, Point Beach Nuclear Plant No. 2, Combustion Engineering, CE Book #4869, October 1970.
3. NRC Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials," May 1988.
4. 10 CFR 50.61, "Fracture toughness requirements for protection against pressurized thermal shock events."
5. WCAP-12794, "Reactor Cavity Neutron Measurement Program for Point Beach Unit 1," Rev. 3, December 1995.
6. WCAP-12795, "Reactor Cavity Neutron Measurement Program for Point Beach Unit 2," Rev. 3, August 1995.
7. CEOG Report "Best Estimate Copper and Nickel Values in CE Fabricated Reactor Vessel Welds," CE NPSD-1039, Revision 2, Final Report, June 1997.
8. BAW-2325, "Response to Request for Additional Information (R.A.I.) Regarding Reactor Pressure Vessel Integrity," May 1998.
9. Framatome Technologies, Inc. Letter FTI-98-2563, "Reevaluation of Weld Wire Heat 61782," August 26, 1998 (see attachment).
10. ASTM E 29-93a, "Standard Practice for Using Significant Digits in Test Data to Determine Conformance with Specifications."
11. WEPCO Letter NPL 98-0159, "Monthly Operating Reports," March 6, 1998.
12. Point Beach Nuclear Plant Unit Nos. 1 and 2 Final Safety Analysis Report.
13. WEPCO Calculation No. N-94-058, Revision 2, "Reactor Coolant System Calculations - Effective Through January 2001," 1/23/96.
14. WEPCO Calculation No. 98-0046, Revision 0, "Determination of PBNP LTOP Setpoint Using ASME Code Case N-514 (applicable through appx. Jan. 2001)," 4/27/98.

Methods & Acceptance Criteria:

The methodology of this calculation follows the steps listed below:

P-T and LTOP Limits

- I. Using References 5 and 6, determine the projected fluence for the limiting reactor vessel materials at the reactor vessel inside surface (clad-base metal interface) at 23.6 EFPY. See Tables 1 and 2 for a description of the methodology used.
- II. Determine the corresponding reactor vessel fluence and fluence factors at the one-fourth thickness (1/4T) and three-fourths thickness (3/4T) location from the clad-base metal interface. See Tables 1 and 2 for a description of the methodology used.
- III. Determine the chemistry factor, initial properties, and margin term for the PBNP reactor vessel beltline materials using the latest available best-estimate chemistry values and all applicable surveillance data for all vessel beltline materials.
- IV. Determine the projected adjusted reference temperature at the 1/4T and 3/4T location for the reactor vessel beltline materials at 23.6 EFPY. See Tables 3 through 6 for a description of the methodology used.



TITLE Evaluation of 23.6 EFPY P-T Limit and LTOP Applicability Date and MADE BY T.D. Spry DATE 9/15/98
Pressurized Thermal Shock at 32 EFPY REV'D. BY J.R. Pfefferle DATE 9/15/98

- V. Compare the projected ARTs at the 1/4T and 3/4T location for the reactor vessel beltline materials to the values used for the calculation of current licensing basis P-T limits. If the projected ART values at a given thickness are less than the values used for the calculation of current P-T limits, current P-T limits are conservative. If the projected ART values at a given thickness are greater than the values used for the calculation of current licensing basis P-T limits, determine the applicability date using the latest available best-estimate chemistry values and all applicable surveillance data for the most limiting vessel beltline material. See Tables 4 and 6 for a description of the methodology used.
- VI. Compare newly determined applicability dates against the EFPY projected to occur through January 1, 2001. If the newly determined applicability date is beyond the projected value on January 1, 2001, current licensing basis P-T limits, LTOP pressure setpoints, and Tenable temperature are acceptable through that date.

PTS Evaluation

- VII. Using References 5 and 6, determine projected fluence for the limiting reactor vessel materials at the reactor vessel inside surface (clad-base metal interface) at 32 EFPY.
- VIII. Determine the corresponding reactor vessel fluence factors at the clad-base metal interface. See Tables 7 and 8 for a description of the methodology used.
- IX. Using the chemistry factor, initial properties, and margin term for the PBNP reactor vessel beltline materials identified in Step III (above), determine the projected RT_{PTS} value at the reactor vessel inside surface at 32 EFPY. See Tables 7 and 8 for a description of the methodology used.
- X. Compare the projected RT_{PTS} value to the PTS Screening Criteria of 10 CFR 50.61. If the projected RT_{PTS} value is less than the screening criteria, no submittal to NRC pursuant to 10 CFR 50.61 is required.

Assumptions:

1. A capacity factor of 80% is assumed for future plant operation. This is a standard industry value for reactor vessel evaluations and will be verified against future plant performance.
2. Changes in core design will not increase vessel inner-surface fluence beyond the values provided at specific vessel altitude and azimuth locations in WCAPs 12794, Rev. 3 and 12795, Rev. 3.
3. Reactor vessel thickness is based on the distance from the clad-base metal interface to the outside diameter.

Inputs:

Specified in Tables 1 through 8.

Calculations:

- I. Fluence, Adjusted Reference Temperature (ART), and Pressurized Thermal Shock (PTS) Evaluations (Tables 1 through 8)

Table 1. Point Beach Unit 1 RPV Beltline 23.6 EFPY Fluence Values

Based on WCAP-12794, "Reactor Cavity Neutron Measurement Program For Wisconsin Electric Power Company Point Beach Unit 1," Rev. 3, December 1995. Note that the estimated fluence at a specific point in time is not linearly interpolated between zero and the estimated fluence at 32 EFPY, due to changes in core design at certain points in the operating history of the unit. As intermediate input to further calculations, these values are not rounded in accordance with ASTM E29.

Vessel Manufacturer:	Babcock & Wilcox
Plate and Weld Thickness (without cladding):	6.5" without clad (D)

Component Description	Heat or Heat/Lot	32 EFPY Inside Surface Fluence (E19 n/cm ²)	23.6 EFPY Inside Surface Fluence (E19 n/cm ²) (A)	23.6 EFPY 1/4T Fluence (E19 n/cm ²) (B)	23.6 EFPY 1/4T Fluence Factor (C)	23.6 EFPY 3/4T Fluence (E19 n/cm ²) (B)	23.6 EFPY 3/4T Fluence Factor (C)
Nozzle Belt Forging	122P237	0.547	0.4166	0.2821	0.6545	0.1293	0.4702
Intermediate Shell Plate	A9811-1	2.91	2.22	1.503	1.113	0.689	0.8955
Lower Shell Plate	C1423-1	2.46	1.971	1.335	1.08	0.6117	0.8623
Nozzle Belt to Intermed. Shell Circ Weld (100%)	8T1762 (SA-1426)	0.547	0.4166	0.2821	0.6545	0.1293	0.4702
Intermediate Shell Long Seam (ID 27%)	1P0815 (SA-812)	1.87	1.425	0.9648	0.99	N/A	N/A
Intermediate Shell Long Seam (OD 73%)	1P0661 (SA-775)	1.87	1.425	N/A	N/A	0.4423	0.7731
Intermed. to Lower Shell Circ. Weld (100%)	71249 (SA-1101)	2.46	1.971	1.335	1.08	0.6117	0.8623
Lower Shell Long Seam (100%)	61782 (SA-847)	1.66	1.309	0.8863	0.9662	0.4063	0.7502

Footnotes:

- (A) Interpolation of neutron exposure (in units of E19 n/cm², E > 1 MeV) to a particular value of effective full power years (EFPY) is performed based on WCAP-12794, Revision 3. For example, for the nozzle belt forging, heat no. 122P237,

$$\text{fluence} = 0.339 + \left(\frac{0.547 - 0.339}{32 \text{ EFPY} - 18.6 \text{ EFPY}} \right) \times (23.6 \text{ EFPY} - 18.6 \text{ EFPY}) = 0.4166 \text{ E19 n/cm}^2$$

- (B) From an inside surface fluence value (not including cladding), fluence is attenuated to a desired thickness using equation (3) of Regulatory Guide 1.99, Revision 2: $f = f_{\text{surf}} \times e^{-0.24x}$, where f_{surf} is expressed in units of E19 n/cm², E > 1 MeV, and x is the desired depth in inches into the vessel wall. For example, for the nozzle belt forging, heat no. 122P237, at 23.6 EFPY, at a depth of 1/4 of the 6.5" vessel wall (1.625"), $f = 0.4166 \times e^{-0.24(1.625)} = 0.2821 \text{ E19 n/cm}^2$.

- (C) The dimensionless fluence factor is calculated using the fluence factor formula from equation (2) of Regulatory Guide 1.99, Revision 2: $ff = f^{(0.28 - 0.10 \log f)}$, where f is the fluence in units of E19 n/cm². For example, the 23.6 EFPY 1/4T fluence factor for nozzle belt forging, heat no. 122P237, $ff = 0.2821^{(0.28 - 0.10 \log 0.2821)} = 0.6545$.

- (D) Instruction Manual, 132-Inch I.D. Reactor Pressure Vessel, Babcock & Wilcox, September 1969.

Table 2. Point Beach Unit 2 RPV Beltline 23.6 EFPY Fluence Values

Based on WCAP-12795, "Reactor Cavity Neutron Measurement Program For Wisconsin Electric Power Company Point Beach Unit 2," Rev. 3, August 1995. Note that the estimated fluence at a specific point in time is not linearly interpolated between zero and the estimated fluence at 32 EFPY, due to changes in core design at certain points in the operating history of the unit. As intermediate input to further calculations, these values are not rounded in accordance with ASTM E29.

Vessel Manufacturer:	Babcock & Wilcox and Combustion Engineering
Plate and Weld Thickness (without cladding):	6.5", without clad (D)

Component Description	Heat or Heat/Lot	32 EFPY Inside Surface Fluence (E19 n/cm ²)	23.6 EFPY Inside Surface Fluence (E19 n/cm ²) (A)	23.6 EFPY 1/4T Fluence (E19 n/cm ²) (B)	23.6 EFPY 1/4T Fluence Factor (C)	23.6 EFPY 3/4T Fluence (E19 n/cm ²) (B)	23.6 EFPY 3/4T Fluence Factor (C)
Nozzle Belt Forging	123V352	0.548	0.4244	0.2873	0.6592	0.1317	0.4742
Intermediate Shell Forging	123V500	3.01	2.322	1.572	1.125	0.7207	0.9081
Lower Shell Forging	122W195	2.52	2.015	1.364	1.086	0.6254	0.8685
Nozzle Belt to Intermed. Shell Circ Weld (100%)	21935	0.548	0.4244	0.2873	0.6592	0.1317	0.4742
Intermed. to Lower Shell Circ. Weld (100%)	72442 (SA-1484)	2.49	2.003	1.356	1.085	0.6217	0.8668

Footnotes

(A) Interpolation of neutron exposure (in units of E19 n/cm², E > 1 MeV) to a particular value of effective full power years (EFPY) is performed based on WCAP-12795, Revision 3. For example, for the nozzle belt forging, heat no. 123V352,

$$\text{fluence} = 0.345 + \left(\frac{0.548 - 0.345}{32 \text{ EFPY} - 18.2 \text{ EFPY}} \right) \times (23.6 \text{ EFPY} - 18.2 \text{ EFPY}) = 0.4244 \text{ E19 n/cm}^2$$

(B) From an inside surface fluence value (not including cladding), fluence is attenuated to a desired thickness using equation (3) of Regulatory Guide 1.99, Revision 2: $f = f_{\text{surf}} \times e^{-0.24x}$, where f_{surf} is expressed in units of E19 n/cm², E > 1 MeV, and x is the desired depth in inches into the vessel wall. For example, for the nozzle belt forging, heat no. 123V352, at 23.6 EFPY, at a depth of 1/4 of the 6.5" vessel wall (1.625"), $f = 0.4244 \times e^{-0.24(1.625)} = 0.2873 \text{ E19 n/cm}^2$.

(C) The dimensionless fluence factor is calculated using the fluence factor formula from equation (2) of Regulatory Guide 1.99, Revision 2: $ff = f^{(0.28 - 0.10 \log f)}$, where f is the fluence in units of E19 n/cm². For example, the 23.6 EFPY 1/4T fluence factor for nozzle belt forging, heat no. 123V352, $ff = 0.2873^{(0.28 - 0.10 \log 0.2873)} = 0.6592$.

(D) Instruction Manual, Reactor Vessel, Point Beach Nuclear Plant No. 2, Combustion Engineering, CE Book #4869, October 1970.

Table 3.

Point Beach Unit 1 RPV 1/4T Beltline Material Adjusted Reference Temperatures at 23.6 EFPY

Unless otherwise noted, all ART input data obtained from BAW-2325, "Response to Request for Additional Information (RAI) Regarding Reactor Pressure Vessel Integrity," May 1998, including the most recent best-estimate chemistry values for welds, applying current B&WOG mean-of-the-sources approach. All beltline materials are included for comparison.

Vessel Manufacturer:	Babcock & Wilcox
Plate and Weld Thickness (without cladding):	6.5", without clad (F)

Component Description	Heat or Heat/Lot	Initial RT _{NDT} (°F)	%Cu	%Ni	CF	CF Method	1/4T 23.6 EFPY Fluence Factor (A)	ΔRT _{NDT} (°F)	σ _t	σ _A	Margin (°F)	ART (°F) (E)
Nozzle Belt Forging	122P237	+50	0.11	0.82	77	Table	0.6545	50.4	0	17	34	134
Intermediate Shell Plate	A9811-1	+1	0.20	0.06	88	Table	1.113	97.94	26.9	17	63.64	163
"	"	"	"	"	79.3	Surv. Data (B)	"	88.26	"	8.5	56.42	146
Lower Shell Plate	C1423-1	+1	0.12	0.07	55.3	Table	1.08	59.74	26.9	17	63.64	124
"	"	"	"	"	35.8	Surv. Data (B)	"	38.67	"	8.5	56.42	96
Nozzle Belt to Intermed. Shell Circ Weld (100%)	8T1762 (SA-1426)	-5	0.19	0.57	152.4	Table	0.6545	99.75	19.7	28	68.47	163
Intermediate Shell Long Seam (ID 27%)	1P0815 (SA-812)	-5	0.17	0.52	138.2	Table	0.99	136.82	19.7	28	68.47	200
Intermediate Shell Long Seam (OD 73%)	1P0661 (SA-775)	-5	0.17	0.64	157.6	Table	N/A	N/A	19.7	N/A	N/A	N/A
Intermed. To Lower Shell Circ. Weld (100%)	71249 (SA-1101)	+10	0.23	0.59	167.6	Table (C)	1.08	181.01	0	28	56	247 (G)
Lower Shell Long Seam (100%)	61782 (SA-847)	-5	0.23	0.52	157.4	Table	0.9662	152.08	19.7	28	68.47	216
"	"	"	"	"	161.1	Surv. Data (D)	"	155.65	"	14	48.34	199

Footnotes:

- (A) See Table 1.
- (B) Credible Surveillance Data; see BAW-2325 for evaluation.
- (C) Non-credible surveillance data; see BAW-2325 for evaluation. Table CF conservative because difference between ratio-adjusted measured ΔRT_{NDT} and predicted ΔRT_{NDT} based on Table CF is less than 2σ (56°F).
- (D) Credible Surveillance Data; see Framatome Technologies, Inc. letter FTI-98-2563, August 26, 1998, "Reevaluation of Weld Wire Heat 61782," utilizing latest time-weighted temperature data for Point Beach Unit 1, which supersedes BAW-2325.
- (E) Adjusted reference temperature (ART) calculated per Regulatory Guide 1.99, Rev. 2. $ART = Initial\ RT_{NDT} + \Delta RT_{NDT} + Margin$, where $\Delta RT_{NDT} = Chemistry\ Factor \times Fluence\ Factor$, and $Margin = 2(\sigma_t^2 + \sigma_A^2)^{0.5}$, with σ_t defined as the standard deviation of the Initial RT_{NDT}, and σ_A defined as the standard deviation of ΔRT_{NDT}. For example, for nozzle belt forging, heat no. 122P237, $ART = 50 + (77 \times 0.6545) + 34 = 134^\circ F$. Calculated ART values are rounded to the nearest °F in accordance with the rounding-off method of ASTM Practice E29.
- (F) Instruction Manual, 132-Inch I.D. Reactor Pressure Vessel, Babcock & Wilcox, September 1969.
- (G) By inspection, for these limiting material properties, the applicability date of 23.6 EFPY for P-T limits in Calculation N-94-058 Revision 2 based on a 1/4T ART of 258.4°F is conservative for Unit 1, since the newly calculated value of 247°F is lower.

Table 4.

Point Beach Unit 2 RPV 1/4T Beltline Material Adjusted Reference Temperatures at 23.6 EFPY

Unless otherwise noted, all ART input data obtained from BAW-2325, "Response to Request for Additional Information (RAI) Regarding Reactor Pressure Vessel Integrity," May 1998, including the most recent best-estimate chemistry values for welds, applying current B&WOG mean-of-the-sources approach. All beltline materials are included for comparison.

Vessel Manufacturer:	Babcock & Wilcox and Combustion Engineering
Plate and Weld Thickness (without cladding):	6.5", without clad (F)

Component Description	Heat or Heat/Lot	Initial RT _{NDT} (°F)	%Cu	%Ni	CF	CF Method	1/4T 23.6 EFPY Fluence Factor (A)	ΔRT _{NDT} (°F)	σ _i	σ _Δ	Margin (°F)	ART (°F) (E)
Nozzle Belt Forging	123V352	+40	0.11	0.73	76	Table	0.6592	50.1	0	17	34	124
Intermediate Shell Forging	123V500	+40	0.09	0.70	58	Table (B)	1.125	65.25	0	17	34	139
Lower Shell Forging	122W195	+40	0.05	0.72	31	Table	1.086	33.67	0	17	34	108
"	"	"	"	"	42.8	Surv. Data (C)	"	46.48	"	8.5	17	103
Nozzle Belt to Intermed. Shell Circ Weld (100%)	21935	-56	0.18	0.70	170	Table (H)	0.6592	112.1	17	28	65.51	122
Intermed. To Lower Shell Circ. Weld (100%)	72442 (SA-1484)	-5	0.26	0.60	180	Table (D)	1.085	195.3	19.7	28	68.47	259 (G)

Footnotes:

- (A) See Table 2.
- (B) Non-credible surveillance data; see BAW-2325 for evaluation. Table CF conservative because difference between measured ΔRT_{NDT} and predicted ΔRT_{NDT} based on Table CF is less than 2σ (34°F).
- (C) Credible surveillance data; see BAW-2325 for evaluation.
- (D) Non-credible surveillance data; Table CF value based on best-estimate chemistry is higher than best fit calculated using surveillance data, and therefore conservative.
- (E) Adjusted reference temperature (ART) calculated per Regulatory Guide 1.99, Rev. 2. ART = Initial RT_{NDT} + ΔRT_{NDT} + Margin, where ΔRT_{NDT} = Chemistry Factor x Fluence Factor, and Margin = $2(\sigma_i^2 + \sigma_\Delta^2)^{0.5}$, with σ_i defined as the standard deviation of the Initial RT_{NDT}, and σ_Δ defined as the standard deviation of ΔRT_{NDT}. For example, for nozzle belt forging, heat no. 123V352, ART = 40 + (76 x 0.6592) + 34 = 124°F. Calculated ART values are rounded to the nearest °F in accordance with the rounding-off method of ASTM Practice E29.
- (F) Instruction Manual, Reactor Vessel, Point Beach Nuclear Plant No. 2, Combustion Engineering, CE Book #4869, October 1970.
- (G) For these limiting material properties, based on Reg. Guide 1.99 Rev. 2 and Table 2, Footnote (A), the applicability date for P-T limits in Calculation N-94-058, Revision 2, based on a 1/4T ART of 258.4°F would be:

$$258.4^\circ\text{F} = \text{Initial RT}_{\text{NDT}} + \Delta\text{RT}_{\text{NDT}} + \text{Margin} = -5 + (180 \times \text{Applicable EFPY 1/4T Fluence Factor}) + 68.47$$

$$\text{Applicable EFPY 1/4T (1.625") Fluence Factor} = 1.0829444 = (1/4T f)^{(0.28 - 0.10 \log 1/4T f)}$$

$$1/4T f = 1.3475 = f_{\text{surf}} \times e^{-0.24(1.625)}$$

$$f_{\text{surf}} = 1.9902 = 1.69 + \frac{2.49 - 1.69}{32 - 18.2} \times (\text{Applicable EFPY} - 18.2)$$

$$\text{Applicable EFPY} = 23.4$$

- (H) Table CF value based on best-estimate chemistry data from CEOG Report "Best Estimate Copper and Nickel Values in CE Fabricated Reactor Vessel Welds," CE NPSD-1039, Revision 2, Final Report, June 1997.

Table 5.

Point Beach Unit 1 RPV 3/4T Beltline Material Adjusted Reference Temperatures at 23.6 EFPY

Unless otherwise noted, all ART input data obtained from BAW-2325, "Response to Request for Additional Information (RAI) Regarding Reactor Pressure Vessel Integrity," May 1998, including the most recent best-estimate chemistry values for welds, applying current B&WOG mean-of-the-sources approach. All beltline materials are included for comparison.

Vessel Manufacturer:	Babcock & Wilcox
Plate and Weld Thickness (without cladding):	6.5", without clad (F)

Component Description	Heat or Heat/Lot	Initial RT _{NDT} (°F)	%Cu	%Ni	CF	CF Method	3/4T 23.6 EFPY Fluence Factor (A)	ΔRT _{NDT} (°F)	σ _I	σ _A	Margin (°F)	ART (°F) (E)
Nozzle Belt Forging	122P237	+50	0.11	0.82	77	Table	0.4702	36.21	0	17	34	120
Intermediate Shell Plate	A9811-1	+1	0.20	0.06	88	Table	0.8955	78.8	26.9	17	63.64	143
"	"	"	"	"	79.3	Surv. Data (B)	"	71.01	"	8.5	56.42	128
Lower Shell Plate	C1423-1	+1	0.12	0.07	55.3	Table	0.8623	47.69	26.9	17	63.64	112
"	"	"	"	"	35.8	Surv. Data (B)	"	30.87	"	8.5	56.42	88
Nozzle Belt to Intermed. Shell Circ Weld (100%)	8T1762 (SA-1426)	-5	0.19	0.57	152.4	Table	0.4702	71.66	19.7	28	68.47	135
Intermediate Shell Long Seam (ID 27%)	1P0815 (SA-812)	-5	0.17	0.52	138.2	Table	N/A	N/A	19.7	N/A	N/A	N/A
Intermediate Shell Long Seam (OD 73%)	1P0661 (SA-775)	-5	0.17	0.64	157.6	Table	0.7731	121.84	19.7	28	68.47	185
Intermed. To Lower Shell Circ. Weld (100%)	71249 (SA-1101)	+10	0.23	0.59	167.6	Table (C)	0.8623	144.52	0	28	56	211 (G)
Lower Shell Long Seam (100%)	61782 (SA-847)	-5	0.23	0.52	157.4	Table	0.7502	118.08	19.7	28	68.47	182
"	"	"	"	"	161.1	Surv. Data (D)	"	120.86	"	14	48.34	164

Footnotes:

- (A) See Table 1.
- (B) Credible Surveillance Data; see BAW-2325 for evaluation.
- (C) Non-credible surveillance data; see BAW-2325 for evaluation. Table CF conservative because difference between ratio-adjusted measured ΔRT_{NDT} and predicted ΔRT_{NDT} based on Table CF is less than 2σ (56°F).
- (D) Credible Surveillance Data; see Framatome Technologies, Inc. letter FTI-98-2563, August 26, 1998, "Reevaluation of Weld Wire Heat 61782," utilizing latest time-weighted temperature data for Point Beach Unit 1, which supersedes BAW-2325.
- (E) Adjusted reference temperature (ART) calculated per Regulatory Guide 1.99, Rev. 2. ART = Initial RT_{NDT} + ΔRT_{NDT} + Margin, where ΔRT_{NDT} = Chemistry Factor x Fluence Factor, and Margin = $2(\sigma_I^2 + \sigma_A^2)^{0.5}$, with σ_I defined as the standard deviation of the Initial RT_{NDT}, and σ_A defined as the standard deviation of ΔRT_{NDT}. For example, for nozzle belt forging, heat no. 122P237, ART = 50 + (77 x 0.4702) + 34 = 120°F. Calculated ART values are rounded to the nearest °F in accordance with the rounding-off method of ASTM Practice E29.
- (F) Instruction Manual, 132-Inch I.D. Reactor Pressure Vessel, Babcock & Wilcox, September 1969.
- (G) By inspection, for these limiting material properties, the applicability date of 23.6 EFPY for P-T limits in Calculation N-94-058 Revision 2 based on a 3/4T ART of 219.5°F is conservative for Unit 1, since the newly calculated value of 211°F is lower.

Table 6.

Point Beach Unit 2 RPV 3/4T Beltline Material Adjusted Reference Temperatures at 23.6 EFPY

Unless otherwise noted, all ART input data obtained from BAW-2325, "Response to Request for Additional Information (RAI) Regarding Reactor Pressure Vessel Integrity," May 1996, including the most recent best-estimate chemistry values for welds, applying current B&WOG mean-of-the-sources approach. All beltline materials are included for comparison.

Vessel Manufacturer:	Babcock & Wilcox and Combustion Engineering
Plate and Weld Thickness (without cladding):	6.5", without clad (F)

Component Description	Heat or Heat/Lot	Initial RT _{NDT} (°F)	%Cu	%Ni	CF	CF Method	3/4T 23.6 EFPY Fluence Factor (A)	ΔRT _{NDT} (°F)	σ _i	σ _Δ	Margin (°F)	ART (°F) (E)
Nozzle Belt Forging	123V352	+40	0.11	0.73	76	Table	0.4742	36.04	0	17	34	110
Intermediate Shell Forging	123V500	+40	0.09	0.70	58	Table (B)	0.9081	52.67	0	17	34	127
Lower Shell Forging	122W195	+40	0.05	0.72	31	Table	0.8685	26.92	0	17	34	101
"	"	"	"	"	42.8	Surv. Data (C)	"	37.17	"	8.5	17	94
Nozzle Belt to Intermed. Shell Circ Weld (100%)	21935	-56	0.18	0.70	170	Table (H)	0.4742	80.61	17	28	65.51	90
Intermed. To Lower Shell Circ. Weld (100%)	72442 (SA-1484)	-5	0.26	0.60	180	Table (D)	0.8668	156.02	19.7	28	68.47	219 (G)

Footnotes:

- (A) See Table 2.
- (B) Non-credible surveillance data; see BAW-2325 for evaluation. Table CF conservative because difference between measured ΔRT_{NDT} and predicted ΔRT_{NDT} based on Table CF is less than 2σ (34°F).
- (C) Credible surveillance data; see BAW-2325 for evaluation.
- (D) Non-credible surveillance data; Table CF value based on best-estimate chemistry is higher than best fit calculated using surveillance data, and therefore conservative.
- (E) Adjusted reference temperature (ART) calculated per Regulatory Guide 1.99, Rev. 2. $ART = \text{Initial } RT_{NDT} + \Delta RT_{NDT} + \text{Margin}$, where $\Delta RT_{NDT} = \text{Chemistry Factor} \times \text{Fluence Factor}$, and $\text{Margin} = 2(\sigma_i^2 + \sigma_\Delta^2)^{0.5}$, with σ_i defined as the standard deviation of the Initial RT_{NDT}, and σ_Δ defined as the standard deviation of ΔRT_{NDT}. For example, for nozzle belt forging, heat no. 123V352, $ART = 40 + (76 \times 0.4742) + 34 = 110^\circ\text{F}$. Calculated ART values are rounded to the nearest °F in accordance with the rounding-off method of ASTM Practice E29.
- (F) Instruction Manual, Reactor Vessel, Point Beach Nuclear Plant No. 2, Combustion Engineering, CE Book #4869, October 1970.
- (G) By inspection, for these limiting material properties, the applicability date of 23.6 EFPY for P-T limits in Calculation N-94-058 Revision 2 based on a 3/4T ART of 219.5°F is conservative for Unit 2, since the newly calculated value of 219°F is lower.
- (H) Table CF value based on best-estimate chemistry data from CEOG Report "Best Estimate Copper and Nickel Values in CE Fabricated Reactor Vessel Welds," CE NPSD-1039, Revision 2, Final Report, June 1997.

Table 7. Point Beach Unit 1 RPV Beltline Material RT_{PTS} Values at 32 EFPY

Unless otherwise noted, all RT_{PTS} input data obtained from BAW-2325, "Response to Request for Additional Information (RAI) Regarding Reactor Pressure Vessel Integrity," May 1998, including the most recent best-estimate chemistry values for welds, applying current B&WOG mean-of-the-sources approach. All beltline materials are included for comparison.

Vessel Manufacturer:	Babcock & Wilcox
Plate and Weld Thickness (without cladding):	6.5", without clad (G)

Component Description	Heat or Heat/Lot	RT _{NDT(U)} (°F)	%Cu	%Ni	CF	CF Method	32 EFPY Inner Surface Fluence (E19 n/cm ²) (A)	32 EFPY Inner Surface Fluence Factor (B)	ΔRT _{PTS} (°F)	σ _U	σ _A	Margin (°F)	RT _{PTS} (°F) (F)	PTS Screening Criteria
Nozzle Belt Forging	122P237	+50	0.11	0.82	77	Table	0.547	0.8313	64.01	0	17	34	148	270
Intermediate Shell Plate	A9811-1	+1	0.20	0.06	88	Table	2.91	1.2834	112.94	26.9	17	63.64	178	270
"	"	"	"	"	79.3	Surv. Data (C)	"	"	101.77	26.9	8.5	56.42	159	270
Lower Shell Plate	C1423-1	+1	0.12	0.07	55.3	Table	2.46	1.2422	68.69	26.9	17	63.64	133	270
"	"	"	"	"	35.8	Surv. Data (C)	"	"	44.47	26.9	8.5	56.42	102	270
Nozzle Belt to Intermed. Shell Circ Weld (100%)	8T1762 (SA-1426)	-5	0.19	0.57	152.4	Table	0.547	0.8313	126.69	19.7	28	68.47	190	300
Intermediate Shell Long Seam (ID 27%)	1P0815 (SA-812)	-5	0.17	0.52	138.2	Table	1.87	1.1715	161.9	19.7	28	68.47	225	270
Intermediate Shell Long Seam (OD 73%)	1P0661 (SA-775)	-5	0.17	0.64	157.6	Table	N/A	N/A	N/A	19.7	N/A	N/A	N/A	N/A
Intermed. To Lower Shell Circ. Weld (100%)	71249 (SA-1101)	+10	0.23	0.59	167.6	Table (D)	2.46	1.2422	208.19	0	28	56	274	300
Lower Shell Long Seam (100%)	61782 (SA-847)	-5	0.23	0.52	157.4	Table	1.66	1.1397	179.39	19.7	28	68.47	243	270
"	"	"	"	"	161.1	Surv. Data (E)	"	"	183.61	19.7	14	48.34	227	270

Footnotes:

- (A) Based on WCAP-12794, "Reactor Cavity Neutron Measurement Program For Wisconsin Electric Power Company Point Beach Unit 1," Rev. 3, December 1995. As intermediate input to further calculations, these values are not rounded in accordance with ASTM E29.
- (B) The dimensionless fluence factor is calculated using the fluence factor for μla from equation (2) of Regulatory Guide 1.99, Revision 2: $ff = f^{(0.28 - 0.10 \log f)}$, where f is the fluence in units of E19 n/cm². For example, the 32 EFPY inner surface fluence factor for nozzle belt forging, heat no. 122P237, $ff = 0.547^{(0.28 - 0.10 \log 0.547)} = 0.8313$.
- (C) Credible surveillance data; see BAW-2325 for evaluation.
- (D) Non-credible surveillance data; see BAW-2325 for evaluation. Table CF conservative because difference between ratio-adjusted measured ΔRT_{NDT} and predicted ΔRT_{NDT} based on Table CF is less than 2σ (56°F).
- (E) Credible Surveillance Data; see Framatome Technologies, Inc. letter FTI-98-2563, August 26, 1998, "Reevaluation of Weld Wire Heat 61782," utilizing latest time-weighted temperature data for Point Beach Unit 1, which supersedes BAW-2325.
- (F) RT_{PTS} calculated per 10 CFR 50.61. $RT_{PTS} = RT_{NDT(U)} + \Delta RT_{NDT} + \text{Margin}$, where $RT_{NDT(U)} = \text{unirradiated initial } RT_{NDT}$, $\Delta RT_{NDT} = \text{Chemistry Factor} \times \text{Fluence Factor}$, and $\text{Margin} = 2(\sigma_U^2 + \sigma_A^2)^{0.5}$, with σ_U defined as the standard deviation of the $RT_{NDT(U)}$, and σ_A defined as the standard deviation of ΔRT_{NDT} . For example, for nozzle belt forging, heat no. 122P237, $RT_{PTS} = 50 + (77 \times 0.8313) + 34 = 148^\circ\text{F}$. Calculated RT_{PTS} values are rounded to the nearest °F in accordance with the rounding-off method of ASTM Practice E29.
- (G) Instruction Manual, 132-Inch I.D. Reactor Pressure Vessel, Babcock & Wilcox, September 1969.

Table 8. Point Beach Unit 2 RPV Beltline Material RT_{PTS} Values at 32 EFPY

Unless otherwise noted, all RT_{PTS} input data obtained from BAW-2325, "Response to Request for Additional Information (RAI) Regarding Reactor Pressure Vessel Integrity," May 1998, including the most recent best-estimate chemistry values for welds, applying current B&WOG mean-of-the-sources approach. All beltline materials are included for comparison.

Vessel Manufacturer:	Babcock & Wilcox and Combustion Engineering
Plate and Weld Thickness (without cladding):	6.5", without clad (G)

Component Description	Heat or Heat/Lot	RT _{NDT(U)} (°F)	%Cu	%Ni	CF	CF Method	32 EFPY Inner Surface Fluence (E19 n/cm ²) (A)	32 EFPY Inner Surface Fluence Factor (B)	ΔRT _{PTS} (°F)	σ _U	σ _Δ	Margin (°F)	RT _{PTS} (°F) (F)	PTS Screening Criteria
Nozzle Belt Forging	123V352	+40	0.11	0.73	76	Table	0.548	0.8318	63.22	0	17	34	137	270
Intermediate Shell Forging	123V500	+40	0.09	0.70	58	Table (C)	3.01	1.292	74.94	0	17	34	149	270
Lower Shell Forging	122W195	+40	0.05	0.72	31	Table	2.52	1.248	38.69	0	17	34	113	270
"	"	"	"	"	42.8	Surv. Data (D)	"	"	53.41	"	8.5	17	110	270
Nozzle Belt to Intermed. Shell Circ. Weld (100%)	21935	-56	0.18	0.70	170	Table (H)	0.548	0.8318	141.41	17	28	65.51	151	300
Intermed. To Lower Shell Circ. Weld (100%)	72442 (SA-1484)	-5	0.26	0.60	180	Table (E)	2.49	1.245	224.1	19.7	28	68.47	288	300

Footnotes:

- (A) Based on WCAP-12795, "Reactor Cavity Neutron Measurement Program For Wisconsin Electric Power Company Point Beach Unit 2," Rev. 3, August 1995. As intermediate input to further calculations, these values are not rounded in accordance with ASTM E29.
- (B) The dimensionless fluence factor is calculated using the fluence factor formula from equation (2) of Regulatory Guide 1.99, Revision 2: $ff = f^{(0.28 - 0.10 \log f)}$, where f is the fluence in units of E19 n/cm². For example, the 32 EFPY inner surface fluence factor for nozzle belt forging, heat no. 123V352, $ff = 0.548^{(0.28 - 0.10 \log 0.548)} = 0.8318$.
- (C) Non-credible surveillance data; see BAW-2325 for evaluation. Table CF conservative because difference between measured ΔRT_{NDT} and predicted ΔRT_{NDT} based on Table CF is less than 2σ (34°F).
- (D) Credible surveillance data; see BAW-2325 for evaluation.
- (E) Non-credible surveillance data; Table CF value based on best-estimate chemistry is higher than best fit calculated using surveillance data, and therefore conservative.
- (F) RT_{PTS} calculated per 10 CFR 50.61. $RT_{PTS} = RT_{NDT(U)} + \Delta RT_{NDT} + \text{Margin}$, where $RT_{NDT(U)}$ = unirradiated initial RT_{NDT}, ΔRT_{NDT} = Chemistry Factor x Fluence Factor, and $\text{Margin} = 2(\sigma_U^2 + \sigma_\Delta^2)^{0.5}$, with σ_U defined as the standard deviation of the RT_{NDT(U)}, and σ_Δ defined as the standard deviation of ΔRT_{NDT}. For example, for nozzle belt forging, heat no. 123V352, $RT_{PTS} = 40 + (76 \times 0.8318) + 34 = 137^\circ\text{F}$. Calculated RT_{PTS} values are rounded to the nearest °F in accordance with the rounding-off method of ASTM Practice E29.
- (G) Instruction Manual, Reactor Vessel, Point Beach Nuclear Plant No. 2, Combustion Engineering, CE Book #4869, October 1970.
- (H) Table CF value based on best-estimate chemistry data from CEOG Report "Best Estimate Copper and Nickel Values in CE Fabricated Reactor Vessel Welds," CE NPSD-1039, Revision 2, Final Report, June 1997.



TITLE Evaluation of 23.6 EFPY P-T Limit and LTOP Applicability Date and Pressurized Thermal Shock at 32 EFPY

MADE BY ^{TDS} T.D. Spry DATE 9/15/98
 REV'D. BY J.R. Pfefferle DATE 9/15/98

Calculations (cont'd):

II. Fluence Projection to January 1, 2001 (Calendar Date Used as Input to LTOP Setpoints in Calculation No. 98-0046, Revision 0)

A) Maximum rated reactor thermal output: 1518.5 MWTh (Ref. 12)

The total thermal output for each unit as of March 1, 1998, is (Ref. 11):

Unit 1: Total thermal output = 273,540,535 MW hours - thermal

Unit 2: Total thermal output = 266,886,275 MW hours - thermal

Converting to EFPY:

Unit 1:

$$273,540,535 \text{ MWTh} \times \frac{\text{eff. full power}}{1518.5 \text{ MWTh}} \times \frac{1 \text{ day}}{24 \text{ hrs.}} \times \frac{1 \text{ year}}{365.25 \text{ days}} = 20.5 \text{ EFPY}$$

Unit 2:

$$266,886,275 \text{ MWTh} \times \frac{\text{eff. full power}}{1518.5 \text{ MWTh}} \times \frac{1 \text{ day}}{24 \text{ hrs.}} \times \frac{1 \text{ year}}{365.25 \text{ days}} = 20.0 \text{ EFPY}$$

B) EFPY until 1/1/2001

Calendar years from 3/1/1998 to 1/1/2001 is 2.83 years; an 80% capacity factor is assumed (Assumption 1):

$$2.83 \text{ years} \times 0.80 = 2.3 \text{ EFPY}$$

C) Total EFPY through 1/1/2001:

$$\text{Unit 1: } 20.5 \text{ EFPY} + 2.3 \text{ EFPY} = 22.8 \text{ EFPY}$$

$$\text{Unit 2: } 20.0 \text{ EFPY} + 2.3 \text{ EFPY} = 22.3 \text{ EFPY}$$

Results and Conclusions:

This calculation demonstrates that the current Technical Specification P-T limits are conservative through the current licensing basis applicability date of 23.6 EFPY for Unit 1.

For Unit 2, as a result of small, conservative changes from the inputs used in Calculation N-94-058 Revision 2, based on the latest understanding of initial RT_{NDT} and σ_I for limiting beltline weld SA-1484, the applicability date of the current licensing basis P-T limits is reduced slightly, to 23.4 EFPY. Administrative requirements to restrict operation of the



TITLE Evaluation of 23.6 EFPY P-T Limit and LTOP Applicability Date and
Pressurized Thermal Shock at 32 EFPY

MADE BY T.D. Spry DATE 9/15/98
REV'D. BY J.R. Pfefferle DATE 9/15/98

Unit 2 reactor vessel to no more than 23.4 EFPY using the current licensing basis P-T limits must be established. This calculation demonstrates that this value of EFPY will not be exceeded before the January 1, 2001 calendar applicability date used in Calculation No. 98-0046, Revision 0, for LTOP pressure setpoints and enable temperature.

This calculation demonstrates that the PTS Screening Criteria are not exceeded through 32 EFPY.

The LTOP pressure setpoint and enable temperature established in Calculation No. 98-0046, Rev. 0 are unchanged through January 1, 2001, because that calculation used the same material property inputs and fluence estimation bases as this calculation.



August 26, 1998
FTI-98-2563

Mr. J. R. Pfefferle
Wisconsin Electric Power Company
231 W. Michigan Street
P. O. Box 2046
Milwaukee, WI 53201

Subject: Reevaluation of Weld Wire Heat 61782

Attachment: FTI Calculation 32-5002184-00

Dear Mr. Pfefferle:

The attached calculation summarizes the reevaluation of weld wire heat 61782 for Point Beach 1 for an irradiation temperature of 538°F.

If you should have any questions regarding this calculation summary, please feel free to call me at 804/832-3293 or Matt Devan at 804/832-3160.

Sincerely,

A handwritten signature in cursive script that reads 'D. L. Howell'.

D. L. Howell
Project Manager
B&W Owners Group Management

DLH/mcl
Attachment



CALCULATIONAL SUMMARY SHEET (CSS)

DOCUMENT IDENTIFIER 32-5002184-00

TITLE Chemistry Factor For Weld Wire Heat 61782

PREPARED BY:

REVIEWED BY:

NAME M. J. DeVan

NAME J. B. Hall

SIGNATURE *MJD*

SIGNATURE *JBH*

TITLE Engineer IV DATE 8/21/98

TITLE Engineer III DATE 8-21-98

COST CENTER 41020 REF. PAGE(S) 7

TM STATEMENT: REVIEWER INDEPENDENCE *JBH*

PURPOSE AND SUMMARY OF RESULTS:

PURPOSE:

The purpose of this calculation is to provide an evaluation of the weld wire heat 61782 surveillance data for assessing the integrity of the Point Beach Unit 1 reactor vessel.

SUMMARY OF RESULTS

In accordance with the NRC guidelines provided at the November 12, 1997 meeting, the surveillance data for weld wire heat 61782 was evaluated with respect to the Point Beach Unit 1 reactor vessel. The R. E. Ginna plant-specific weld metal surveillance data was used in the assessment because it requires the least amount of adjustments to the measured data. The plant-specific weld metal surveillance data from R. E. Ginna was determined to be credible with respect to the five criteria specified in both Regulatory Guide 1.99, Revision 2 and 10 CFR 50.61. Using the R. E. Ginna plant-specific weld metal data and making the required adjustments to the data, the surveillance data chemistry factor was calculated to be 161.1°F.

THE FOLLOWING COMPUTER CODES HAVE BEEN USED IN THIS DOCUMENT:

CODE / VERSION / REV

CODE / VERSION / REV

THIS DOCUMENT CONTAINS ASSUMPTIONS THAT MUST BE VERIFIED PRIOR TO USE ON SAFETY-RELATED WORK

YES () NO (X)

RECORD OF REVISIONS

REVISION	DESCRIPTION
00	Original Release

TABLE OF CONTENTS

<u>TITLE</u>	<u>PAGE</u>
1.0 Introduction	4
2.0 Summary of Results	4
3.0 Assumptions	4
4.0 Evaluation and Use of Weld Wire Heat 61782 Surveillance Data	4
4.1. Credibility Assessment	5
4.2. Determination of Chemistry Factor	6
5.0 References	7

1.0 Introduction

Both Regulatory Guide 1.99, Revision 2⁽¹⁾ and 10 CFR 50.61⁽²⁾ state that surveillance data (if available) be considered in evaluating reactor vessel integrity. The best-estimate copper and nickel chemical compositions are used in the evaluation of the surveillance data. The process of evaluating surveillance data includes a credibility assessment against five criteria and the calculation of the chemistry factor based on the surveillance data. The NRC provided guidance on performing evaluation of surveillance data in a public meeting between the Staff, Nuclear Energy Institute (NEI), and industry representatives on November 12, 1997. A summary of this meeting is documented in a meeting summary dated November 19, 1997.⁽³⁾

This calculation provides the evaluation and use of weld wire heat 61782 surveillance data for assessing the integrity of the Point Beach Unit 1 reactor vessel. The guidelines, provided by the Staff in the November 12, 1997 meeting, are used to determine the chemistry factor.

2.0 Summary of Results

In accordance with the NRC guidelines provided at the November 12, 1997 meeting, the surveillance data for weld wire heat 61782 was evaluated with respect to the Point Beach Unit 1 reactor vessel. The R. E. Ginna plant-specific weld metal surveillance data was used in the assessment because it requires the least amount of adjustments to the measured data. The plant-specific weld metal surveillance data from R. E. Ginna was determined to be credible with respect to the five criteria specified in both Regulatory Guide 1.99, Revision 2 and 10 CFR 50.61. Using the R. E. Ginna plant-specific weld metal data and making the required adjustments to the data, the surveillance data chemistry factor was calculated to be 161.1°F.

3.0 Assumptions

No major assumptions are contained in this report.

4.0 Evaluation and Use of Weld Wire Heat 61782 Surveillance Data

The lower shell longitudinal weld, found in the Point Beach Unit 1 reactor vessel, was fabricated using the weld wire heat 61782. The best estimate copper and nickel chemical compositions for this wire heat are as follows:

Cu = 0.23 wt%

Ni = 0.52 wt%

Weld wire heat 61782 surveillance data are not available from the Point Beach Unit 1 plant-specific surveillance program, but are available from other sources. The available weld wire heat 61782 surveillance data are presented in Table 4-1.

Table 4-1. Available Surveillance Data For Weld Wire Heat 61782

Capsule ID (including source)	Cu wt%	Ni wt%	Irradiation Temperature (°F)	Fluence ($\times 10^{19}$ n/cm ²)	Measured ΔRT_{NDT} (°F) (TANH)
B&WOG: Capsule DB1-LG1 SA-1135: ONS-2 Nozzle Belt Dropout Matl.	0.27	0.59	556	1.03	141
R. E. Ginna: Capsule V SA-1036: Plant Specific RVSP Material	0.24	0.52	545	0.556	146
R. E. Ginna: Capsule R SA-1036: Plant Specific RVSP Material	0.24	0.52	545	1.15	167
R. E. Ginna: Capsule T SA-1036: Plant Specific RVSP Material	0.24	0.52	545	1.97	169
R. E. Ginna: Capsule S SA-1036: Plant Specific RVSP Material	0.24	0.52	545	3.87	222

The B&WOG Capsule DB1-LG1 was irradiated in the Davis-Besse reactor vessel which Babcock & Wilcox is the NSSS vendor. The weld metal surveillance data for R. E. Ginna was irradiated as part of their plant-specific surveillance program.

Examination of the available surveillance data for weld wire 61782 reveals that the magnitude of the temperature adjustment with respect to Point Beach Unit 1 is lower for R. E. Ginna than Davis-Besse. In addition, Point Beach Unit 1 and R. E. Ginna have the same NSSS vendor, Westinghouse. Therefore, only the R. E. Ginna weld metal 61782 surveillance data is used in assessing the integrity of the Point Beach Unit 1 vessel.

4.1. Credibility Assessment

Since the R. E. Ginna weld metal 61782 surveillance data are from one (1) source, a best-fit line is determined relating the measured (unadjusted) ΔRT_{NDT} to the fluence factor (determined from the capsule fluence). Table 4-2 presents the credibility assessment for weld wire heat 61782 using only the R. E. Ginna plant-specific weld metal surveillance data.

$$\text{Slope of the Best-Fit Line} = 159.0 \text{ } ^\circ\text{F}$$

Table 4-2 Credibility Assessment for Weld Wire Heat 61782

Capsule Designation	Cu wt%	Ni wt%	Chem. Factor	Irrad. Temp. (°F)	Fluence Factor	Meas. ΔRT_{NDT} (°F) (TANH)	Predicted ΔRT_{NDT} from Best Fit Line (°F)	(Measured - Predicted) ΔRT_{NDT} (°F)
R. E. Ginna: Capsule V Plant-Specific RVSP Material	0.24	0.52	161.4	545	0.836	146	132.9	13.1
R. E. Ginna: Capsule R Plant-Specific RVSP Material	0.24	0.52	161.4	545	1.039	167	165.2	1.8
R. E. Ginna: Capsule T Plant-Specific RVSP Material	0.24	0.52	161.4	545	1.185	169	188.4	-19.4
R. E. Ginna: Capsule S Plant-Specific RVSP Material	0.24	0.52	161.4	545	1.349	222	214.5	7.5

where: $Predicted \Delta RT_{NDT} = (Slope_{best\ fit}) * Fluence\ Factor$

These data are credible since the scatter is less than $\pm 28^\circ F$ for all surveillance capsule data points.

4.2. Determination of Chemistry Factor

The surveillance data chemistry factor is determined from a best-fit line through the surveillance data adjusted to account for differences in chemical composition (i.e., copper and nickel contents) and irradiation environment (i.e., irradiation temperature) between the capsules and the vessel being assessed (i.e., Point Beach Unit 1).

The operating cold leg temperature (T_{Plant}) for the Point Beach Unit 1 reactor vessel is $538^\circ F$, and the R. E. Ginna surveillance capsules have a irradiation temperature ($T_{Capsule}$) of $545^\circ F$ that is greater than T_{Plant} . Therefore for the capsules with $T_{Capsule}$ greater than $538^\circ F$ (i.e., T_{Plant}), the $\Delta RT_{NDT, measured}$ must be adjusted by increasing the measured ΔRT_{NDT} by $1.0^\circ F$ for each degree difference in irradiation temperature to yield the temperature adjusted ΔRT_{NDT} (i.e., $\Delta RT_{NDT, Temp. Adjusted}$).

To account for the differences in chemical compositions between the surveillance data and the weld wire heat best estimate, the surveillance data are normalized to the best estimate of the vessel being assessed (i.e., Point Beach Unit 1). To obtain the "ratio and temperature" adjusted ΔRT_{NDT} , the surveillance data are adjusted as follows:

$$Ratio / Temperature Adjusted \Delta RT_{NDT} = \left(\frac{CF_{Table, Vessel Chem.}}{CF_{Table, Surv. Chem.}} \right) * \Delta RT_{NDT, Temp. Adjusted}$$

The assessment of the surveillance data for weld wire heat 61782 with respect to Point Beach Unit 1 using the R. E. Ginna plant-specific weld metal surveillance data is presented in Table 4-3.

Table 4-3. Surveillance Data Assessment for Weld Wire Heat 61782
For Point Beach Unit 1

Capsule	Cu	Ni	CF	Irrad. Temp. (F)	Capsule Fluence (n/cm ²)	Fluence Factor (ff)	Meas. ΔRT_{NDT} (F) (TANH)	Temp. Adjusted ΔRT_{NDT} (F)	Temp. Ratio Adjusted ΔRT_{NDT} (F)
R. E. Ginna: Capsule V Plant-Specific RVSP Matl.	0.24	0.52	161.4	545	0.556	0.836	146	153	149.2
R. E. Ginna: Capsule R Plant-Specific RVSP Matl.	0.24	0.52	161.4	545	1.15	1.039	167	174	169.7
R. E. Ginna: Capsule T Plant-Specific RVSP Matl.	0.24	0.52	161.4	545	1.97	1.185	169	176	171.6
R. E. Ginna: Capsule S Plant-Specific RVSP Matl.	0.24	0.52	161.4	545	3.87	1.349	222	229	223.3
Point Beach Unit 1: Vessel Average	0.23	0.52	157.4	538					

The best-fit line is determined relating the "ratio and temperature" adjusted ΔRT_{NDT} to the fluence factor (determined from the capsule fluence). The slope of this best-fit line is the chemistry factor calculated from surveillance data, $CF_{Surv. Data}$.

$$CF_{Surv. Data} = 161.1^{\circ}F$$

5.0 REFERENCES

1. U. S. Nuclear Regulatory Commission, "Radiation damage to Reactor Vessel Material," Regulatory Guide 1.99, Revision 2, May 1988.
2. Code of Federal Regulations, Title 10, "Domestic Licensing of production and Utilization Facilities," Part 50.61, "Fracture Toughness Requirements for Protection Against Pressurized Thermal Shock," Federal Register, December 19, 1995.
3. Memorandum from Keith R. Wichman to Edmund J. Sullivan, "Meeting Summary for November 12, 1997, Meeting with Owners Group Representatives and NEI Regarding Review of Responses to Generic Letter 92-01, Revision 1, Supplement 1 Responses," dated November 19, 1997.