



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

STP NUCLEAR OPERATING COMPANY

DOCKET NO. 50-498

SOUTH TEXAS PROJECT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 97
License No. NPF-76

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by STP Nuclear Operating Company* acting on behalf of itself and for Houston Lighting & Power Company (HL&P), the City Public Service Board of San Antonio (CPS), Central Power and Light Company (CPL), and City of Austin, Texas (COA) (the licensees), dated December 31, 1997, as supplemented by letters dated June 30, August 6, August 18, and August 27, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended provisions of the Act, and the rules and regulations of the Commission
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

*STP Nuclear Operating Company is authorized to act for Houston Lighting & Power Company (HL&P), the City Public Service Board of San Antonio, Central Power and Light Company and City of Austin, Texas and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

9810060073 980929
PDR ADOCK 05000498
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-76 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 97 , and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance to be implemented prior to startup from the October 1998 refueling outage for Unit 2.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas W. Alexion, Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: September 29, 1998



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

STP NUCLEAR OPERATING COMPANY

DOCKET NO. 50-499

SOUTH TEXAS PROJECT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 84
License No. NPF-80

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by STP Nuclear Operating Company* acting on behalf of itself and for Houston Lighting & Power Company (HL&P), the City Public Service Board of San Antonio (CPS), Central Power and Light Company (CPL), and City of Austin, Texas (COA) (the licensees), dated December 31, 1997, as supplemented by letters dated June 30, August 6, August 18, and August 27, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

*STP Nuclear Operating Company is authorized to act for Houston Lighting & Power Company (HL&P), the City Public Service Board of San Antonio, Central Power and Light Company and City of Austin, Texas and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-80 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 84, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance to be implemented prior to startup from the October 1998 refueling outage for Unit 2.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas W. Alexion, Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: September 29, 1998

ATTACHMENT TO LICENSE AMENDMENT NOS. 97 AND 84

FACILITY OPERATING LICENSE NOS. NPF-76 AND NPF-80

DOCKET NOS. 50-498 AND 50-499

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain marginal lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE

iii
2-1

2-4
2-7
2-8
2-9
2-10
3/4 2-11
B 3/4 2-6

INSERT

iii
2-1
2-2(A)
2-4
2-7
2-8
2-9
2-10
3/4 2-11
B 3/4 2-6

INDEX

2.0 SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

<u>SECTION</u>	<u>PAGE</u>
<u>2.1 SAFETY LIMITS</u>	
2.1.1 REACTOR CORE	2-1
2.1.2 REACTOR COOLANT SYSTEM PRESSURE	2-1
FIGURE 2.1-1 REACTOR CORE SAFETY LIMIT - FOUR LOOPS IN OPERATION .	2-2
FIGURE 2.1-2 REACTOR CORE SAFETY LIMIT-FOUR LOOPS IN OPERATION (ALTERNATE)	2-2(A)
 <u>2.2 LIMITING SAFETY SYSTEM SETTINGS</u>	
2.2.1 REACTOR TRIP SYSTEM INSTRUMENTATION SETPOINTS	2-3
TABLE 2.2-1 REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS ..	2-4

BASES

<u>SECTION</u>	<u>PAGE</u>
<u>2.1 SAFETY LIMITS</u>	
2.1.1 REACTOR CORE	B 2-1
2.1.2 REACTOR COOLANT SYSTEM PRESSURE	B 2-2
 <u>2.2 LIMITING SAFETY SYSTEM SETTINGS</u>	
2.2.1 REACTOR TRIP SYSTEM INSTRUMENTATION SETPOINTS	B 2-3

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.0 APPLICABILITY</u>	3/4 0-1
<u>3/4.1 REACTIVITY CONTROL SYSTEMS</u>	
3/4.1.1 BORATION CONTROL	
Shutdown Margin - T_{avg} Greater Than 200°F.....	3/4 1-1
FIGURE 3.1-1 REQUIRED SHUTDOWN MARGIN VERSUS RCS CRITICAL BORON CONCENTRATION (MODES 1, 2, 3, AND 4).....	3/4 1-3
Shutdown Margin - T_{avg} Less Than or Equal to 200°F.....	3/4 1-4
FIGURE 3.1-2 REQUIRED SHUTDOWN MARGIN VERSUS RCS CRITICAL BORON CONCENTRATION (MODE 5).....	3/4 1-5
Moderator Temperature Coefficient.....	3/4 1-6
FIGURE 3.1-2a BOL MODERATOR TEMPERATURE COEFFICIENT VERSUS POWER....	3/4 1-7a
Minimum Temperature for Criticality.....	3/4 1-8
3/4.1.2 BORATION SYSTEMS	
Flow Paths - Shutdown.....	3/4 1-9
Flow Paths - Operating.....	3/4 1-10
Charging Pumps - Shutdown.....	3/4 1-11
Charging Pumps - Operating.....	3/4 1-12
Borated Water Sources - Shutdown.....	3/4 1-13
Borated Water Sources - Operating.....	3/4 1-14
3/4.1.3 MOVABLE CONTROL ASSEMBLIES	
Group Height.....	3/4 1-16
TABLE 3.1-1 ACCIDENT ANALYSES REQUIRING REEVALUATION IN THE EVENT OF AN INOPERABLE FULL-LENGTH ROD.....	3/4 1-18
Position Indication Systems - Operating.....	3/4 1-19
Position Indication Systems - Shutdown.....	3/4 1-20
Rod Drop Time.....	3/4 1-21
Shutdown Rod Insertion Limit.....	3/4 1-22
Control Rod Insertion Limits.....	3/4 1-23
FIGURE 3.1-3 (Deleted)	

2.0 SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.1 SAFETY LIMITS

REACTOR CORE

2.1.1 The combination of THERMAL POWER, pressurizer pressure, and the highest operating loop coolant temperature (T_{avg}) shall not exceed the limits shown in Figure 2.1-1, or in Figure 2.1-2 when operating under alternate operating criteria consistent with reduced Reactor Coolant System flow as addressed in Technical Specification 3.2.5.

APPLICABILITY: MODES 1 and 2.

ACTION:

Whenever the point defined by the combination of the highest operating loop average temperature and THERMAL POWER has exceeded the appropriate pressurizer pressure line, be in HOT STANDBY within 1 hour, and comply with the requirements of Specification 6.7.1.

REACTOR COOLANT SYSTEM PRESSURE

2.1.2 The Reactor Coolant System pressure shall not exceed 2735 psig.

APPLICABILITY: MODES 1, 2, 3, 4, AND 5.

ACTION:

MODES 1 and 2:

Whenever the Reactor Coolant System pressure has exceeded 2735 psig, be in HOT STANDBY with the Reactor Coolant System pressure within its limit within 1 hour, and comply with the requirements of Specification 6.7.1.

MODES 3, 4 and 5:

Whenever the Reactor Coolant System pressure has exceeded 2735 psig, reduce the Reactor Coolant System pressure to within its limit within 5 minutes, and comply with the requirements of Specification 6.7.1.




FIGURE 2.1-1
 REACTOR CORE SAFETY LIMIT - FOUR LOOPS IN OPERATION




Figure 2.1-2

Reactor Core Safety Limit - Four Loops in Operation (Alternate)

SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.2 LIMITING SAFETY SYSTEM SETTINGS

REACTOR TRIP SYSTEM INSTRUMENTATION SETPOINTS

2.2.1 The Reactor Trip System Instrumentation and Interlock Setpoints shall be set consistent with the Trip Setpoint values shown in Table 2.2-1.

APPLICABILITY: As shown for each channel in Table 3.3-1.

ACTION:

- a. With a Reactor Trip System Instrumentation or Interlock Setpoint less conservative than the value shown in the Trip Setpoint column but more conservative than the value shown in the Allowable Value column of Table 2.2-1, adjust the Setpoint consistent with the Trip Setpoint value.
- b. With the Reactor Trip System Instrumentation or Interlock Setpoint less conservative than the value shown in the Allowable Value column of Table 2.2-1, either:
 1. Adjust the Setpoint consistent with the Trip Setpoint value of Table 2.2-1 and determine within 12 hours that Equation 2.2-1 was satisfied for the affected channel, or
 2. Declare the channel inoperable and apply the applicable ACTION statement requirement of Specification 3.3.1 until the channel is restored to OPERABLE status with its Setpoint adjusted consistent with the Trip Setpoint value.

Equation 2.2-1

$$Z + R + S \leq TA$$

Where:

Z = The value from Column Z of Table 2.2-1 for the affected channel,

R = The "as-measured" value (in percent span) of rack error for the affected channel,

S = Either the "as-measured" value (in percent span) of the sensor error, or the value from Column S (Sensor Error) of Table 2.2-1 for the affected channel, and

TA = The value from Column TA (Total Allowance) of Table 2.2-1 for the affected channel.

TABLE 2.2-1

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNCTIONAL UNIT		TOTAL ALLOWANCE (TA)		SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE VALUE
		(TA)	Z			
1. Manual Reactor Trip	N.A.	N.A.	N.A.		N.A.	N.A.
2. Power Range, Neutron Flux						
a. High Setpoint		7.5	6.1	0	≤109% of RTP**	≤110.7% of RTP**
b. Low Setpoint		8.3	6.1	0	≤25% of RTP**	≤27.7% of RTP**
3. Power Range, Neutron Flux, High Positive Rate	2.1	0.5	0		≤5% of RTP** with a time constant ≥2 seconds	≤6.7% of RTP** with a time constant ≥2 seconds
4. Deleted						
5. Intermediate Range, Neutron Flux	16.7	8.4	0		≤25% of RTP**	≤31.1% of RTP**
6. Source Range, Neutron Flux		17.0	10.0	0	≤10 ⁵ CPS	≤1.4 X 10 ⁵ cps
7. Overtemperature ΔT		10.7	8.7	1.5 + 1.5#	See Note 1	See Note 2
8. Overpower ΔT		4.7	2.1	1.5	See Note 3	See Note 4
9. Pressurizer Pressure-Low		5.0	2.3	2.0	≥1870 psig	≥1860 psig
10. Pressurizer Pressure-High		5.0	2.3	2.0	≤2380 psig	≤2390 psig
11. Pressurizer Water Level-High		7.1	4.3	2.0	≤92% of instrument span	≤94.1% of instrument span
12. Reactor Coolant Flow-Low		4.0	2.1	0.6	≥91.8% of loop design flow*	≥90.5% of loop design flow*

* Loop design flow = 95,400 gpm (or 92,500 gpm for alternate operation with reduced RCS flow)

**RTP = RATED THERMAL POWER

1.5% span for ΔT; 1.5% span for Pressurizer Pressure

TABLE 2.2-1 (Continued)

TABLE NOTATIONS

NOTE 1: OVERTEMPERATURE ΔT

$$\Delta T \frac{(1 + \tau_1 S)}{(1 + \tau_2 S)} \left(\frac{1}{1 + \tau_3 S} \right) \leq \Delta T_0 \left\{ K_1 - K_2 \frac{(1 + \tau_4 S)}{(1 + \tau_5 S)} (T \left(\frac{1}{1 + \tau_6 S} \right) - T) + K_3(P - P') - f_1(\Delta I) \right\}$$

- Where:
- ΔT = Measured ΔT by RCS Instrumentation;
 - $\frac{1 + \tau_1 S}{1 + \tau_2 S}$ = Lead-lag compensator on measured ΔT ;
 - τ_1, τ_2 = Time constant utilized in lead-lag compensator for ΔT , $\tau_1 = 8$ sec, $\tau_2 = 3$ sec;
 - $\frac{1}{1 + \tau_3 S}$ = Lag compensator on measured ΔT ;
 - τ_3 = Time constant utilized in the lag compensator for ΔT , $\tau_3 = 0$ sec;
 - ΔT_0 = Indicated ΔT at RATED THERMAL POWER;
 - K_1 = 1.14, or 1.13 for alternate operation with reduced RCS flow;
 - K_2 = 0.028/°F;
 - $\frac{1 + \tau_4 S}{1 + \tau_5 S}$ = The function generated by the lead-lag compensator for T_{avg} dynamic compensation;
 - τ_4, τ_5 = Time constants utilized in the lead-lag compensator for T_{avg} , $\tau_4 = 28$ sec, $\tau_5 = 4$ sec;
 - T = Average temperature, °F;
 - $\frac{1}{1 + \tau_6 S}$ = Lag compensator on measured T_{avg} ;
 - τ_6 = Time constant utilized in the measured T_{avg} lag compensator, $\tau_6 = 0$ sec;

TABLE 2.2-1 (Continued)

TABLE NOTATIONS (Continued)

NOTE 1: (Continued)

T	≤ 593.0°F (Nominal T_{avg} at RATED THERMAL POWER) OR 590.0°F for alternate operation with reduced RCS flow;
K_3	= 0.00143/psig;
P	= Pressurizer pressure, psig;
P'	= 2235 psig (Nominal RCS operating pressure);
S	= Laplace transform operator, sec ⁻¹ ;

and $f_1(\Delta I)$ is a function of the indicated difference between top and bottom detectors of the power-range neutron ion chambers; with gains to be selected based on measured instrument response during plant startup tests such that:

- (1) For $q_t - q_b$ between -70% and +8%, or +6% for alternate operation with reduced RCS flow, $f_1(\Delta I) = 0$, where q_t and q_b are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and $q_t + q_b$ is total THERMAL POWER in percent of RATED THERMAL POWER;
- (2) For each percent that the magnitude of $q_t - q_b$ exceeds -70%, the ΔT Trip Setpoint shall be automatically reduced by 0.0% of its value at RATED THERMAL POWER; and
- (3) For each percent that the magnitude of $q_t - q_b$ exceeds +8%, or +6% for alternate operation with reduced RCS flow, the ΔT Trip Setpoint shall be automatically reduced by 2.65% of its value at RATED THERMAL POWER.

NOTE 2: The channel's maximum Trip Setpoint shall not exceed its computed Trip Setpoint by more than 1.6% ΔT span.

TABLE 2.2-1 (Continued)

TABLE NOTATIONS (Continued)

NOTE 3: OVERPOWER ΔT

$$\Delta T \frac{(1 + \tau_1 S)}{(1 + \tau_2 S)} \left(\frac{1}{1 + \tau_3 S} \right) \leq \Delta T_0 \left\{ K_4 - K_5 \left(\frac{\tau_7 S}{1 + \tau_7 S} \right) \left(\frac{1}{1 + \tau_6 S} \right) T - K_6 \left(T \left(\frac{1}{1 + \tau_6 S} \right) - T'' \right) - f_2(\Delta I) \right\}$$

Where: ΔT = As defined in Note 1.

$\frac{1 + \tau_1 S}{1 + \tau_2 S}$ = As defined in Note 1.

τ_1, τ_2 = As defined in Note 1.

$\frac{1}{1 + \tau_3 S}$ = As defined in Note 1.

τ_3 = As defined in Note 1.

ΔT_0 = As defined in Note 1.

K_4 = 1.08, or 1.07 for alternate operation with reduced RCS flow.

K_5 = 0.02/°F for increasing average temperature and 0 for decreasing average temperature.

$\frac{\tau_7 S}{1 + \tau_7 S}$ = The function generated by the rate-lag compensator for T_{avg} dynamic compensation.

τ_7 = Time constant utilized in the rate-lag compensator for T_{avg} . $\tau_7 = 10$ sec.

$\frac{1}{1 + \tau_6 S}$ = As defined in Note 1.

τ_6 = As defined in Note 1.

TABLE 2.2-1 (Continued)

TABLE NOTATIONS (Continued)

NOTE 3: (Continued)

$K_6 = 0.002/^{\circ}\text{F}$ for $T > T^m$ and $K_6 = 0$ for $T \leq T^m$,

$T =$ As defined in Note 1,

$T^m =$ Indicated T_{avg} at RATED THERMAL POWER (Calibration temperature for ΔT instrumentation, $\leq 593.0^{\circ}\text{F}$, or $\leq 590.0^{\circ}\text{F}$ for alternate operation with reduced RCS flow),

$S =$ As defined in Note 1, and

$f_2(\Delta I) = 0$ for all ΔI .

NOTE 4: The channel's maximum Trip Setpoint shall not exceed its computed Trip Setpoint by more than 1.9% ΔT span.

POWER DISTRIBUTION LIMITS

3/4.2.5 DNB PARAMETERS

LIMITING CONDITION FOR OPERATION

3.2.5 The following DNB-related parameters shall be maintained within the limits following:

- a. Reactor Coolant System T_{avg} , $\leq 598^{\circ}\text{F}$
(or $\leq 595^{\circ}\text{F}$ with reduced RCS flow of 3.2.5.c)
- b. Pressurizer Pressure, > 2189 psig*
- c. Reactor Coolant System Flow, $\geq 392,300$ gpm**
(or $\geq 380,500$ gpm** with reduced RCS T_{avg} of 3.2.5.a)

APPLICABILITY: MODE 1.

ACTION:

With any of the above parameters exceeding its limit, restore the parameter to within its limit within 2 hours or reduce THERMAL POWER to less than 5% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS


4.2.5.1 Each of the parameters shown above shall be verified to be within its limits at least once per 12 hours. The provisions of Specification 4.0.4 are not applicable for verification that RCS flow is within its limit.

4.2.5.2 The RCS flow rate indicators shall be subjected to a channel calibration at least once per 18 months.

4.2.5.3 The RCS total flow rate shall be determined by precision heat balance measurements at least once per 18 months. The provisions of Specification 4.0.4 are not applicable.

* Limit not applicable during either a Thermal Power ramp in excess of 5% of RTP per minute or a Thermal Power step in excess of 10% RTP.

**Includes a 2.8% flow measurement uncertainty.



POWER DISTRIBUTION LIMITS

BASES

HEAT FLUX HOT CHANNEL FACTOR and NUCLEAR ENTHALPY RISE HOT CHANNEL FACTOR (Continued)

When an F_Q measurement is taken, an allowance for both experimental error and manufacturing tolerance must be made. An allowance of 5% is appropriate for a full-core map taken with the Incore Detector Flux Mapping System, and a 3% allowance is appropriate for manufacturing tolerance.

The Radial Peaking Factor, $F_{xy}(Z)$, is measured periodically to provide assurance that the Hot Channel Factor, $F_Q(Z)$, remains within its limit. The F_{xy} limit for RATED THERMAL POWER (F_{xy}^{RTPQ}) as provided in the Core Operating Limits Report (COLR) per Specification 6.9.1.6 was determined from expected power control maneuvers over the full range of burnup conditions in the core.

3/4.2.4 QUADRANT POWER TILT RATIO

The QUADRANT POWER TILT RATIO limit assures that the radial power distribution satisfies the design values used in the power capability analysis. Radial power distribution measurements are made during STARTUP testing and periodically during power operation.

The limit of 1.02, at which corrective action is required, provides DNB and linear heat generation rate protection with x-y plane power tilts. A limit of 1.02 was selected to provide an allowance for the uncertainty associated with the indicated power tilt.

The 2-hour time allowance for operation with a tilt condition greater than 1.02 is provided to allow identification and correction of a dropped or misaligned control rod. In the event such action does not correct the tilt, the margin for uncertainty on F_Q is reinstated by reducing the maximum allowed power by 3% for each percent of tilt in excess of 1.

For purposes of monitoring QUADRANT POWER TILT RATIO when one excore detector is inoperable, the moveable incore detectors are used to confirm that the normalized symmetric power distribution is consistent with the QUADRANT POWER TILT RATIO. The incore detector monitoring is done with a full incore flux map or two sets of four symmetric thimbles. The two sets of four symmetric thimbles is a unique set of eight detector locations. These locations are C-8, E-5, E-11, H-3, H-13, L-5, L-11, N-8.

3/4.2.5 DNB PARAMETERS

The limits on the DNB-related parameters assure that each of the parameters are maintained within the normal steady-state envelope of operation assumed in the transient and accident analyses. The limits are consistent with the

POWER DISTRIBUTION LIMITS

BASES

3/4.2.5 DNB PARAMETERS (Continued)

initial FSAR assumptions and have been analytically demonstrated adequate to maintain a minimum DNBR of greater than or equal to the design limit throughout each analyzed transient. The T_{avg} value of 598°F and the pressurizer pressure value of 2189 psig are analytical values. The readings from four channels will be averaged and then adjusted to account for measurement uncertainties before comparing with the required limit. The flow requirement (392,300 gpm) includes a measurement uncertainty of 2.8%.

Technical Specification 3.2.5 provides for an alternate minimum measured Reactor Coolant System flow limit consistent with plugging up to 10% of steam generator tubes and Departure from Nucleate Boiling requirements. When using the alternate minimum flow limit, the T_{avg} limit is reduced to 595°F for Reactor Coolant System flow no less than 380,500 gpm. Setpoint and constant values for OPΔT and OTΔT are also revised accordingly when this alternate mode of operation is entered.

The 12-hour periodic surveillance of these parameters through instrument readout is sufficient to ensure that the parameters are restored within their limits following load changes and other expected transient operation.