



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 9, 1988

Docket Nos. 50-413
and 50-414

MEMORANDUM FOR: Sholly Coordinator

FROM: Kahtan N. Jabbour, Project Manager
Project Directorate II-3
Division of Reactor Projects-1/II

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE - NOTICE
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE
(TACS 67338/60931)

Duke Power Company, et al., Docket Nos. 50-413 and 50-414, Catawba Nuclear
Station, Units 1 and 2, York County, South Carolina

Date of application for amendments: March 15, 1985, as supplemented August
7 and November 8, 1985, March 7, April 14, and September 18, 1986, March 16
and August 11, 1987, and April 7, 1988.

Brief description of amendments: The amendments modified the Technical
Specifications to increase the interval for surveillance of the ice condenser
lower inlet doors.

Date of issuance: May 9, 1988

Effective date: May 9, 1988

Amendment Nos.: 44 and 37

Facility Operating License Nos. NPF-35 and NPF-52. Amendments revised the
Technical Specifications.

Date of initial notice in FEDERAL REGISTER: October 8, 1986 (51 FR 36087)

The Commission's related evaluation of the amendments is contained in a
Safety Evaluation dated May 9, 1988.

8805180026 880509
PDR ADDCK 05000413
P PDR

Sholly Coordinator

- 2 -

No significant hazards consideration comments received: No.

Local Public Document Room location: York County Library, 138 East Black
Street, Rock Hill, South Carolina 29730

Original signed by:

Karim N. Jabbour, Project Manager
Project Directorate II-3
Division of Reactor Projects-I/II

DISTRIBUTION:

Docket File
PDII-3 Reading
Catawba Reading
MRood
KJabbour
OGC
Sholly Coordinator (orig + 1 copy)

LA:PDII-3
MRood
4/12/88

KNT
PM:PDII-3
KJabbour:pw
4/12/88

DM
PL:PDII-3
DMatthews
5/4/88