



23
12-3

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA STREET, N.W.
ATLANTA, GEORGIA 30323

NOV 28 1984

MEMORANDUM FOR: Darrell G. Eisenhut, Director
Division of Licensing, NRR

FROM: John A. Olshinski, Director
Division of Reactor Projects

SUBJECT: STATUS OF ATOMIC SAFETY AND LICENSING BOARD PARTIAL
INITIAL DECISION REQUIREMENTS FOR CATAWBA NUCLEAR
STATION (Docket No. 50-413)

JA

The Atomic Safety and Licensing Board, in a Partial Initial Decision (PID) issued on June 22, 1984, required actions to be performed by Duke Power Company and/or staff concerning several areas at Catawba. These actions include upgrading of procedures for control of filler metal (PID p. 87), followup of recommendations concerning Welding Concern No. D-18 regarding socket weld sizes (PID pp. 106-107), followup of recommendations concerning Welding Concern No. E-2 regarding socket weld gaps (PID p. 121), modifications to procedures for walk-down inspections to remove limitations (PID pp. 172-173), modification of instructions and procedures relative to harassment (PID p. 181), and staff verification that remaining honeycombing of significance is adequately repaired prior to low-power testing (PID p. 242).

With the exception of harassment procedures modifications, the staff and Duke actions have been completed and Region II (RII) staff has verified that Duke actions are complete and adequate. Information relative to these items are contained in RII Report Nos. 50-413/84-82, 50-414/84-36, 50-413/84-49, and 50-414/84-23. Modification to the harassment procedures is presently a proposed licensed condition and is scheduled to be completed by December 22, 1984, or prior to authorization of full power operation (whichever is later). RII staff will verify the completion of this item.

John A. Olshinski
John A. Olshinski

cc: ~~R. C. DeYoung, DLE~~
H. L. Thompson, DHFS
T. M. Novak, NRR
E. G. Adensam, NRR
K. N. Jabbour, NRR
K. VanDoorn, Catawba

8603040568 860118
PDR FOIA
CARRB5-584 PDR

RII Release