

NPDES

DISCHARGE PERMIT NONCOMPLIANCE REPORTING FORM

Date: April 7, 1988
Applicable Permit No. CO-0001121
Discharge No. 00 2A

I. GENERAL

A. Company: PUBLIC SERVICE COMPANY OF COLORADO
Mailing Address: 16805 Weld County Road 19 1/2
Plant Name: Fort St. Vrain
Plant Location: Platteville, Colorado County Weld

II. Noncompliance Report

A. Description and Cause of Noncompliance:
A circulating expansion joint ruptured and flooded the adjacent pit and system 41 basin. High solids resulted in the discharge when the basin was pumped out at high volume causing sediments to be churned up in the discharge line. TSS 167 mg/l.

B. Noncompliance Period:
Started: 1038 A.M. P.M. 4/7/88 DATE
Ended: A.M. 2100 P.M. 4/7/88 DATE
Estimate of Return to Compliance: 2100 p.m. 4/7/88

C. Action Taken to Reduce, Eliminate, Prevent: _____

If future emergency problems like this arise, the water will be pumped at a lower volume, thus reducing the solids generated in the discharge line. Sample taken at 2100 pm on 4/7/88 revealed TSS to be well in compliance (34 mg/l)

D. Person Initiating Report Henry E. Adamski
Signature: _____
Signature of Plant Manager: _____
Person Authorized to File Report
With Regulatory Agencies: Pete Cohlma/George Vonesh/Bob Pearson

E. Water Quality Control Division Notification Requirements:

Telephone(24 hrs.) 4/8/88 Date Kathy Dolan Person Notified WQCD
Written(5 days) 4/12/88 Date Sandy Marek - WQCD
Copy: Pete Cohlma, Belleview S.C./Bob Pearson/George Vonesh,
Room 946 HQB Plant file

SUBMIT REPORT TO:


Ms Sandy Marek
Colorado Department of Health
Water Quality Control Division
Monitoring & Enforcement Section
4210 East 11th Avenue
Denver, Colorado 80220

Regional Administrator
U.S. Environmental Protection Agency
One Denver Place - Suite 500
999 18th Street 8WM-C
Denver, Colorado 80202-24 05
Attn: Enforcement - Permit Program

8805180073 880509
PDR ADOCK 05000267
S DCD

FSV-284-A

IE23
1/1



Public Service
Company of Colorado

16805 WCR 19 1/2, Platteville, Colorado 80651

May 9, 1988
Fort St. Vrain
Unit No. 1
P-88164

Director, Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docket No. 50-267


SUBJECT: NONCOMPLIANCE REPORT
PER NPDES PERMIT

Dear Sir:

In accordance with Appendix B to the Fort St. Vrain Technical Specifications, Section 3.2(a), Public Service Company is herein submitting a copy of the Discharge Noncompliance Report required by our NPDES Permit.

If you have any questions with regards to this report, please contact Mr. M. H. Holmes at (303) 620-6960.

Sincerely,

C.H. Fuller by 

C. H. Fuller
Manager, Nuclear Production

Enclosure

cc: Regional Administrator, Region IV
ATTN: Mr. T. F. Westerman, Chief
Projects Section B

Mr. R. E. Farrell
Senior Resident Inspector, FSV

CHF:MAJ:djm

IE23
11