

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) <b>Joseph M. Farley - Unit 1</b>	DOCKET NUMBER (2) <b>0 5 0 0 0 3 4 8 1</b>	PAGE (3) <b>1 OF 0 1</b>
---	---	-----------------------------

TITLE (4)  
**Special Report: Fire Hose Station Inoperable For More Than Fourteen Days**

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
<b>0 4</b>	<b>2 1</b>	<b>8 8</b>	<b>8 8</b>	<b>0 1 2</b>	<b>0 0</b>	<b>0 5</b>	<b>1 3</b>	<b>8 8</b>			<b>0 5 0 0 0</b>

OPERATING MODE (9) **6** THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)

POWER LEVEL (10) <b>0 0 0</b>	20.402(b)	20.405(c)	50.73(a)(2)(iv)	73.71(b)
	20.405(a)(1)(i)	50.38(c)(1)		73.71(c)
	20.405(a)(1)(ii)	50.38(c)(2)		<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 365A)
	20.405(a)(1)(iii)	50.73(a)(2)(i)		<b>Special Report per Tech. Spec. 3.7.11.4</b>
	20.405(a)(1)(iv)	50.73(a)(2)(ii)		
	20.405(a)(1)(v)	50.73(a)(2)		

LICENSEE / CONTACT FOR THIS LER (12)

NAME: **J. D. Woodard, General Manager-Nuclear Unit**

TELEPHONE NUMBER: **5 8 9 9 - 5 1 5 6**

COMPLETE ONE LINE FOR EACH EVENT FAILURE DESCRIBED IN THIS REPORT				
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRRDS

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE)  NO

EXPECTED SUBMISSION DATE (15)

MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

At 1500 on 4-7-88, fire hose station N1V43-D-128 was isolated because the packing follower on the valve was broken which caused excessive leakage. Repairs could not be completed within fourteen days. Technical Specification 3.7.11.4 requires the fire hose station to be returned to operable status within fourteen days or a Special Report must be submitted within the following 30 days. Therefore, this Special Report is being submitted.

Replacement parts for the fire hose station have been ordered. The repairs will be completed as soon as the parts are received.

Technical Specification action statement requirements for the inoperable fire hose station are being met.

8805180076 880513  
PDR ADOCK 05000348  
S DCD

Alabama Power Company  
600 North 18th Street  
Post Office Box 2641  
Birmingham, Alabama 35291-0400  
Telephone 205 250-1835

R. P. McDonald  
Senior Vice President



May 13, 1988

Docket No. 50-348

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555


Dear Sir:

Joseph M. Farley Nuclear Plant - Unit 1  
Licensee Event Report No. LER 88-012-00

Joseph M. Farley Nuclear Plant, Unit 1, Licensee Event Report No. LER 88-012-00 is being submitted in accordance with 10CFR50.73.

If you have any questions, please advise.

Respectfully submitted,

  
R. P. McDonald

RPM/JAR:dst-V8.43

Enclosure

cc: IE, Region II

IE22  
||