



Log # TXX-88457
File # 10110
910.4
Ref. # 10CFR50.55(e)

William G. Council
Executive Vice President

May 13, 1988

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
CONDENSATE STORAGE TANK OVERPRESSURIZATION
SDAR: CP-87-28 (SUPPLEMENTAL REPORT)

Gentlemen:

On December 2, 1987, we notified you by our letter logged TXX-6992 of a deficiency involving the capacity of the condensate storage tank (CST), which we determined to be reportable under the provisions of 10CFR50.55(e). Our most recent report on this issue, logged TXX-88272, was submitted on March 4, 1988. This report is submitted to update the corrective action completion schedule for this issue.

Actions taken to resolve this deficiency (described in TXX-6992) consist of adding a safety-related control feature for the CST level transmitters which isolates CST makeup using redundant safety grade valves when the CST high level setpoint is reached. Corrective actions for Unit 1 have been rescheduled for completion by July 25, 1988. The completion schedule for Unit 2 will be prior to Unit 2 hot functional testing.

Very truly yours,

W. G. Council

W. G. Council

By: *D. R. Woodlan*

D. R. Woodlan
Docket Licensing Manager

MCP/grr

c-Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

8805180091 880513
PDR ADOCK 05000445
S DCD

IE27
10