

May 10, 1988

Docket Nos. 50-317
and 50-318

DISTRIBUTION

Docket File

NRC-PDR
Local PDR
PDI-1 Rdg.
SVarga
BBoger
CVogan

SMcNeil
KNaidu
ETBahe
OGC-WF
EJordan
JPartlow
ACRS(10)
LTripp

Mr. J. A. Tiernan
Vice President-Nuclear Energy
Baltimore Gas and Electric Company
P.O. Box 1475
Baltimore, Maryland 21203

Dear Mr. Tiernan:

SUBJECT: NRC BULLETIN 88-03, "INADEQUATE LATCH ENGAGEMENT IN HFA TYPE
LATCHING RELAYS MANUFACTURED BY GENERAL ELECTRIC COMPANY

As your response to NRC Bulletin 88-03 stated that "Calvert Cliffs does not
have the HFA type latching relays that are subject to the bulletin," this
issue is now considered complete by the NRC staff with regards to Calvert
Cliffs Units 1 and 2.

Thank you for your timely response.

Sincerely,

Original signed by:

Scott Alexander McNeil, Project Manager
Project Directorate I-1
Division of Reactor Projects, I/II

cc: See next page

PDI-1
CVogan
5/10/88

PDI-1 *Sam*
SMcNeil:dlg
5/10/88

PDI-1 *for*
RCapre
5/10/88

BB05180106 880510
PDR ADOCK 05000317
Q PDR

Mr. J. A. Timman
Baltimore Gas & Electric Company Calvert Cliffs Nuclear Power Plant

cc:

Mr. John M. Gott, President
Calvert County Board of
Commissioners
Prince Frederick, Maryland 20768

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

D. A. Brune, Esq.
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Mr. Jay E. Silberg, Esq.
Shaw, Pittman, Potts and Trowbridge
1800 M Street, NW
Washington, DC 20036

Mr. M. E. Bowman, General Supervisor
Technical Services Engineering
Calvert Cliffs Nuclear Power Plant
MD Rts 2 & 4, P. O. Box 1535
Lusby, Maryland 20657-0073

Resident Inspector
c/o U.S. Nuclear Regulatory Commission
P. O. Box 437
Lusby, Maryland 20657-0073

Bechtel Power Corporation
ATTN: Mr. D. E. Stewart
Calvert Cliffs Project Engineer
15740 Shady Grove Road
Gaithersburg, Maryland 20760

Combustion Engineering, Inc.
ATTN: Mr. W. R. Horlacher, III
Project Manager
P. O. Box 500
1000 Prospect Hill Road
Windsor, Connecticut 06095-0500

Department of Natural Resources
Energy Administration, Power Plant
Siting Program
ATTN: Mr. T. Magette
Tawes State Office Building
Annapolis, Maryland 21204