

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

May 12, 1988

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Subject: Catawba Nuclear Station
Docket Nos. 50-413 and 50-414

Dear Sir:

As a followup to a telecon on May 10, 1988 with Dr. K. N. Jabbour and W. L. :ave, the attached page 9.2-7 will be submitted with this year's Final Safety Analysis Report (FSAR) update. As agreed, "loss of Lake Wylie" will be added back to the end of the first sentence of the second paragraph of section 9.2.1.3.

During the telecon, all agreed this statement does not imply the design bases is a simultaneous LOCA and seismic event. This was explained in our February 18, 1988 letter.

Therefore, it is again requested that the NRC Staff approve the Technical Specification changes and the proposed change in the design bases for the Nuclear Service Water System. Since this submittal supplements Duke's letter of October 16, 1987, no additional part 170 fees are included.

Very truly yours,

H. B. Tucker

Hal B. Tucker

PGL/15/sbn

Attachment

xc: Dr. J. Nelson Grace, Regional Administration
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. P. K. Van Doorn
NRC Resident Inspector
Catawba Nuclear Station

8805180111 880512
PDR ADOCK 05000413
P DCD

A053
1/1