



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

BOSTON EDISON COMPANY

DOCKET NO. 50-293

PILGRIM NUCLEAR POWER STATION

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 121
License No. DPR-35


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Boston Edison Company (the licensee) dated May 20, 1987 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 3.B of Facility Operating License No. DPR-35 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 121, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Richard H. Wessman, Director
Project Directorate I-3
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 8, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 121
FACILITY OPERATING LICENSE NO. DPR-35
DOCKET NO. 50-293

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove Pages

66b

77

Insert Pages

66b

77

Table 4.2.G

Minimum Test and Calibration Frequency for
ATWS RPT/ARI Instrumentation

Instrument Channel	Instrument Functional Test (2)	Calibration (2)	Instrument Check (2)
1. Reactor High Pressure	(1) (7)	(7)	Once/day
2. Reactor Low-Low Water Level	(1) (7)	(7)	Once/day

4.2 BASES (Cont'd)

The automatic pressure relief instrumentation can be considered to be a 1 out of 2 logic system and the discussion above applies also.

The instrumentation which is required for the recirculation pump trip and alternate rod insertion systems incorporate analog transmitters. The transmitter calibration frequency is once per refueling outage, which is consistent with both the equipment capabilities and the requirements for similar equipment used at Pilgrim. The Trip Unit Calibration and Instrument Functional Test is specified at monthly, which is the same frequency specified for other similar protective devices. An instrument check is specified at once per day; this is considered to be an appropriate frequency, commensurate with the design applications and the fact that the recirculation pump trip and alternate rod insertion systems are backups to existing protective instrumentation.