



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

BOSTON EDISON COMPANY

DOCKET NO. 50-293

PILGRIM NUCLEAR POWER STATION

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 120
License No. DPR-35

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Boston Edison Company (the licensee) dated June 30, 1988 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 3.B of Facility Operating License No. DPR-35 is hereby amended to read as follows:

BB09140416 BB0908
PDR ADOCK 05000293
P PNU

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 120, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Richard H. Wessman, Director
Project Directorate I-3
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 3, 1983

ATTACHMENT TO LICENSE AMENDMENT NO. 120
FACILITY OPERATING LICENSE NO. DPR-35
DOCKET NO. 50-293

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove Pages

49

50a

53a

197

Insert Pages

49

50a

53a

197

PNPS TABLE 3.2.B (Cont'd)
INSTRUMENTATION THAT INITIATES OR CONTROLS THE CORE AND CONTAINMENT COOLING SYSTEMS

| Minimum # of Operable Instrument Channels Per Trip System (1) | Trip Function | Trip Level Setting | Remarks |
|---|---|---|---|
| 1 | Core Spray Pump Start Timer | 0 < t < 1 sec. | Initiates sequential starting of CSCS pumps on any auto start. |
| 1 | LPCI Pump Start Timer | 4 < t < 6 sec. | |
| 1 | LPCI Pump Start Timer | 9 < t < 11 sec. | |
| 1 | Auto Blowdown Timer | ≥ 90, ≤ 120 sec. | In conjunction with Low Low Reactor Water Level, High Drywell Pressure and LPCI or Core Spray Pump running interlock, initiates Auto Blowdown. |
| 2 | ADS Drywell Pressure Bypass Timer | 11 ± 2 min. | Permits starting CS and LPCI pumps and actuating ADS SRV's if RPV water level is low and drywell pressure is not high. |
| 2 | RHR (LPCI) Pump Discharge Pressure Interlock | 150 ± 10 psig | Defers ADS actuation pending confirmation of Low Pressure core cooling system operation. (LPCI or Core Spray Pump running interlock.) |
| 2 | Core Spray Pump Discharge Pressure Interlock | 150 ± 10 psig | |
| 2 | Emergency Bus Voltage Relay | 20-25% of rated voltage resets at less than 50% | 1. Permits closure of the Diesel Generator to an unloaded emergency bus. 2. Permits starting of CSCS 4 kV motors. |

PNPS TABLE 3.2.B (Cont'd)
INSTRUMENTATION THAT INITIATES OR CONTROLS THE CORE AND CONTAINMENT COOLING SYSTEMS

| Minimum # of Operable Instrument Channels Per Trip System (1) | Trip Function | Trip Level Setting | Remarks |
|---|---|--|--|
| 2 | Startup Transformer Degraded Voltage | 3868V \pm 0.5% with 9.2 \pm 0.5 seconds time delay | <ol style="list-style-type: none"> 1. Trips Startup Transformer to Emergency Bus Breaker. 2. Locks out automatic closure of Startup Transformer to Emergency Bus. 3. Initiates starting of Diesel Generators in conjunction with loss of auxiliary transformer. 4. Prevents simultaneous starting of CPCS components. 5. Starts load shedding logic for Diesel Operation in conjunction with <ol style="list-style-type: none"> a) Low Low Reactor Water Level and Low Reactor Pressure or b) High drywell pressure or c) Core Standby Cooling System components in service in conjunction with Auxiliary Transformer breaker open. |

PNPS TABLE 3.2.B.1
INSTRUMENTATION THAT MONITORS EMERGENCY BUS VOLTAGE

| Minimum # of Operable Instrument Channels Per Trip System | Function | Setting | Remarks |
|---|---|--|---|
| 1 | Emergency 4160V Buses A5 & A6 Degraded Voltage Annunciation (i) | 3959V \pm 0.5% with 3.2 \pm 0.5 seconds time delay | Alerts Operator to possible degraded voltage conditions. Provides permissive to initiate load shedding in conjunction with LOCA signal. |

(1) In the event that the alarm system is determined inoperable, commence logging safety related bus voltage every 1/2 hour until such time as the alarm is restored to operable status.

3.9.B Operation with Inoperable Equipment

following conditions are satisfied:

- a. The startup transformer and both offsite 345 kV transmission lines are available and capable of automatically supplying auxiliary power to the emergency 4160 volt buses.
- b. A transmission line and associated shutdown transformer are available and capable of automatically supplying auxiliary power to the emergency 4160 volt buses.
5. From and after the date that one of the 125 or 250 volt battery systems is made or found to be inoperable for any reason, continued reactor operation is permissible during the succeeding three days within electrical safety considerations, provided repair work is initiated in the most expeditious manner to return the failed component to an operable state, and Specification 3.5.F is satisfied.
6. With the emergency bus voltage less than 3959V but above 3868V (excluding transients) during normal operation, transfer the safety related buses to the diesel generators. If grid voltage continues to degrade be in at least Hot Shutdown within the next 4 hours and in Cold Shutdown within the following 12 hours unless the grid conditions improve.