

ILLINOIS POWER

An Illinova Company

Illinois Power Company
Clinton Power Station
P.O. Box 678
Clinton, IL 61727
Tel 217 935-5623
Fax 217 935-4632

Walter G. MacFarland IV
Senior Vice President
and Chief Nuclear Officer

U-603090
2C.220

October 1, 1998

Docket No. 50-461

10CFR50.73

Document Control Desk
Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Clinton Power Station - Unit 1
Licensee Event Report No. 1998-032-00


Dear Madam or Sir:

Enclosed is Licensee Event Report (LER) No. 1998-032-00: Excessive Voltage Drop in the Control Circuit for the Division 3 Diesel Output Circuit Breaker Results in the Plant Being Outside Design Basis. This report is being submitted in accordance with the requirements of 10CFR50.73.

The enclosed report contains the following commitments:

- The reference to calculation 19-AJ-19 will be removed from calculation 19-D-27 at its next revision.
- A design change will be prepared to reduce the overall resistance of the control circuit to an acceptable level.

Sincerely yours,



Walter G. MacFarland, IV
Senior Vice President and
Chief Nuclear Officer

9810060349 981001
PDR ADOCK 05000441
S PDR

RAF/krk

Enclosure

cc: NRC Clinton Licensing Project Manager
NRC Resident Office, V-690
Acting Regional Administrator, Region III, USNRC
Illinois Department of Nuclear Safety
INPO Records Center

IE22/1

000078