Mr. J. E. Cross
President - Generation Group
Duquesne Light Company
Post Office Box 4
Shippingport, PA 15077

SUBJECT:

GENERIC LETTER 92-08 CLOS_OUT REPORT, THERMO-LAG RELATED AMPACITY DERATING ISSUES FOR BEAVER VALLEY POWER STATION, UNIT NO. 2 (TAC NO. MA1347)

Dear Mr. Cross:

By letter dated October 13, 1997, as supplemented May 27, 1998, Duquesne Light Company (DLC) submitted a response to the NRC staff's April 6, 1998, Request for Additional Information (RAI) related to Generic Letter (GL) 92-08, "Thermo-Lag 330-1 Fire Barriers," for Beaver Valley Power Station, Unit No. 2 (BVPS-2). The NRC staff, in conjunction with its contractor, Sandia National Laboratories (SNL), has completed its review of DLC's analytical approach for ampacity derating determinations. The results of the review are documented in the enclosed safety evaluation and in the SNL Technical Letter Report, "A Technical Evaluation of the Beaver Valley Fire Barrier Clad Cable Ampacity Assessments," dated January 23, 1998, (see attachment to enclosed safety evaluation).

On the basis of our review and DLC's commitment to take corrective actions to address the overloaded cables in conduits 2CL213ND and 2CL6070E, the NRC staff concludes that there are no outstanding ampacity derating issues identified in GL 92-08 for BVPS-2. This completes the NRC staff's action under TAC No. MA1347.

Please contact me at 301-415-1409 if you have any further questions regarding this issue.

Sincerely,

Donald S. Brinkman, Senior Project Manager Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket No. 50-412

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION:

Docket File

THarris (e-mail SE, TLH3) AKlugler

PUBLIC OGC PDI-2 Reading ACRS

JZwolinski PEselgroth, RGN I

RCapra MO'Brien JCalvo RJenkins

DBrinkman PGill

Nochkill	2	-	1	m	1	31748	
PGill	1	0			4	1	
THE PERSON NAMED IN COLUMN 2 IN THE PERSON NAMED IN THE PERSON NAMED IN THE PERSON NAMED IN THE PERSON NAMED IN	THE SHIPS WHEN DO NOT THE PARTY.	SECULOS/ADDASSA	ACOMMO	AMPRICADAM.	ASSESSED AND ADDRESS OF THE PARTY NAMED IN	NAME AND ADDRESS OF	MINER

	PDI-2/PM /) 16	PDHZADAR	PDI-2/D	
NAME	DBrinkman:mw	MO'Brien	RCapra Ra	
DATE	9 /29 /98	17/198	9 129198	

OFFICIAL RECORD COPY

DOCUMENT NAME: a:\BVMA1347.LTR

9810060356 981001 PDR ADOCK 05000412 PDR





UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

October 1, 1998

Mr. J. E. Cross
President - Generation Group
Duquesne Light Company
Post Office Box 4
Shippingport, PA 15077

SUBJECT:

GENERIC LETTER 92-08 CLOSEOUT REPORT, THERMO-LAG RELATED

AMPACITY DERATING ISSUES FOR BEAVER VALLEY POWER STATION,

UNIT NO. 2 (TAC NO. MA1347)

Dear Mr. Cross:

By letter dated October 13, 1997, as supplemented May 27, 1998, Duquesne Light Company (DLC) submitted a response to the NRC staff's April 6, 1998, Request for Additional Information (RAI) related to Generic Letter (GL) 92-08, "Thermo-Lag 330-1 Fire Barriers," for Beaver Valley Fower Station, Unit No. 2 (BVPS-2). The NRC staff, in conjunction with its contractor, Sandia National Laboratories (SNL), has completed its review of DLC's analytical approach for ampacity derating determinations. The results of the review are documented in the enclosed safety evaluation and in the SNL Technical Letter Report, "A Technical Evaluation of the Beaver Valley Fire Barrier Clad Cable Ampacity Assessments," dated January 23, 1998, (see attachment to enclosed safety evaluation).

On the basis of our review and DLC's commitment to take corrective actions to address the overloaded cables in conduits 2CL213ND and 2CL6070E, the NRC staff concludes that there are no outstanding ampacity derating issues identified in GL 92-08 for BVPS-2. This completes the NRC staff's action under TAC No. MA1347.

Please contact me at 301-415-1409 if you have any further questions regarding this issue.

Sincerely,

Donald S. Brinkman, Senior Project Manager

Project Directorate I-2

Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Donald & Beinformer

Docket No. 50-412

Enclosure: Safety Evaluation

cc w/encl: See next page

CC:

Jay E. Silberg, Esquire Shaw, Pittman, Potts & Trowbridge 2300 N Street, NW. Washington, DC 20037

Director-Safety and Licensing Department (BV-A) Duquesne Light Company Beaver Valley Power Station PO Box 4 Shippingport, PA 15077

Commissioner Roy M. Smith West Virginia Department of Labor Building 3, Room 319 Capitol Complex Charleston, WV 25305

Director, Utilities Department Public Utilities Commission 180 East Broad Street Columbus, OH 43266-0573

Director, Pennsylvania Emergency Management Agency Post Office Box 3321 Harrisburg, PA 17105-3321

Ohio EPA-DERR ATTN: Zack A. Clayton Post Office Box 1049 Columbus, OH 43266-0149

Dr. Judith Johnsrud National Energy Committee Sierra Club 433 Orlando Avenue State College, PA 16803

Duquesne Light Company
Beaver Valley Power Station
PO Box 4
Shippingport, PA 15077
ATTN: R. D. Brandt, Division Vice
President, Nuclear Operations
and Plant Manager (BV-SOSB-7)

Bureau of Radiation Protection Pennsylvania Department of Environmental Resources ATTN: Michael P. Murphy Post Office Box 2063 Harrisburg, PA 17120

Mayor of the Borough of Shippingport Post Office Box 3 Shippingport, PA 15077

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Bo 298
Shippingport, PA 15077

Duquesne Light Company
Beaver Valley Power Station
PO Box 4
Shippingport, PA 15077
ATTN: S. C. Jain, Senior Vice President
Nuclear Services (BV-A)

Mr. J. A. Hultz, Manager Projects & Support Services First Energy 76 South Main Street Akron, OH 44308