



ARKANSAS POWER & LIGHT COMPANY

Reeves E. Ritchie Nuclear Training Center
Arkansas Nuclear One
Rt. 3, Box 137G
Russellville, Arkansas 72801
April 21, 1988

ANO-88-2-00445

Mr. David Graves
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive
Suite 1000
Arlington, TX 76011

SUBJECT: Arkansas Nuclear One
Docket No. 50-368
License No. NPF-6
Comments on NRC SRO
Exam of April 18, 1988

Dear Mr. Graves:

I have attached the Training and Operations Department's comments on the SRO examination for your review and consideration. If you have any questions, please contact me.

Ed Force
Superintendent, Operations Training

EAF/PDC:djj

Attachment

cc: ANO-DCC

8805180355 880511
PDR ADOCK 05000368
V DCD

6.01a Change "5% power" to "10% power"
Reference O:2102.02 Rev. 25, 1/7/87
Step 13.18

6.02 Fifth answer should read "Service water supply valve to Containment
Spray Cooler (SD Cooling Hx) opens.

Common name for this cooler is Shutdown Cooling Heat Exchanger.