

U. S. NUCLEAR REGULATORY COMMISSIONTOLEDO EDISON COMPANY, ET AL.DOCKET NO. 50-346NOTICE OF ISSUANCE OF AMENDMENT TOFACILITY OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 119 to Facility Operating License No. NPF-3, issued to The Toledo Edison Company and The Cleveland Electric Illuminating Company (the licensee), which revised the Technical Specifications for operation of the Davis-Besse Nuclear Power Station, Unit No. 1 (the facility) located in Ottawa County, Ohio. The amendment was effective as of the date of its issuance.

The amendment changed the Main Steam Line Isolation valve closure time requirements in section 3/4.3.2 and 3/4.7.1 to make them consistent throughout the Technical Specifications.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Notice of Consideration of Issuance of Amendment and Opportunity for Hearing in connection with this action was published in the FEDERAL REGISTER


on March 23, 1988 (53 FR 9527). No request for hearing or petition for leave to intervene was filed following this notice.

For further details with respect to this action see (1) the application for amendment dated July 27, 1988, (2) Amendment No. 119 to License No. NPF-3, (3) the Commission's related Safety Evaluation dated September 1, 1988 and (4) the Environmental Assessment dated August 25, 1988 (53-FR 33562). All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C., and at the University of Toledo Library, Documents Department, 2801 Bancroft Avenue, Toledo, Ohio 43606.

A copy of items (2), (3) and (4) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Reactor Projects - III, IV, V and Special Projects.

Dated at Rockville, Maryland this 1st day of September 1988.

FOR THE NUCLEAR REGULATORY COMMISSION



Albert W. De Agazio, Sr. Project Manager
Project Directorate III-3
Division of Reactor Projects - III,
IV, V and Special Projects

3.0 STAFF POSITION

The staff has reviewed Toledo Edison Company's analyses of the Chapter 15 events and concurs with its assessment that the proposed MSIV closure times are bounded conservatively by the current safety analyses and are acceptable to the staff.

4.0 ENVIRONMENTAL CONSIDERATION

Pursuant to 10 CFR 51.21, 51.32, and 51.35, an environmental assessment and finding of no significant impact has been prepared and published in the Federal Register on August 31, 1988 (53 FR 33562). Accordingly, based upon the environmental assessment, the Commission has determined that the issuance of this amendment will not have a significant effect on the quality of the human environment.

5.0 CONCLUSION

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: Chang Li
George Schwenk
Albert De Agazio

Dated: September 1, 1988