

James A. FitzPatrick  
Nuclear Power Plant  
P.O. Box 41  
Lycoming, New York 13093  
315 342 3840



Radford J. Converse  
Resident Manager

February 20, 1986  
JAFP 86-0154

United States Nuclear Regulatory Commission  
Region 1  
631 Park Avenue  
King of Prussia, PA 19406

Attention: Dr. Thomas E. Murley  
Regional Administrator

SUBJECT: James A. FitzPatrick Nuclear Power Plant  
Docket No. 50-333  
1E Bulletin 84-02

- References:
1. NRC 1E Bulletin 84-02, "Failures of General Electric Type HFA Relays in use in Class 1E Safety Systems", dated March 12, 1984.
  2. NYPA letter, C. A. McNeill, Jr. to T. E. Murley, dated July 6, 1984 (JAFP-84-0666), concerning plans and schedules for replacing HFA relay coils.

Dear Dr. Murley:

Reference 1 discussed failures of General Electric Type HFA relays and required replacement of the affected relay coils by March 12, 1986.

Reference 2 identified 285 relays requiring modification or replacement. Completion of the replacement program was scheduled for January 31, 1986. However, because a scheduled outage was postponed, the replacement program was not completed by that date. Currently, 26 of the 285 relays remain to be replaced.

The next outage is scheduled to begin on March 14, 1986. The relays are scheduled to be replaced at that time.


8603060084 860220  
PDR ADOCK 05000333  
G PDR

1/0  
1E "

To: United States Nuclear Regulatory Commission February 20, 1986  
From: Radford J. Converse JAFP 86-0154  
Subject: IE Bulletin 84-02 Page 2 of 2

Should you or your staff have any questions regarding this matter,  
please contact Mr. Joseph Flaherty of my staff.

Very truly yours,



RADFORD J. CONVERSE  
Resident Manager

RJC:WF:fah

SUBSCRIBED AND SWORN TO BEFORE ME THIS 20<sup>th</sup> DAY OF  
February, 1986

Beverly R. Pruzemal  
NOTARY PUBLIC

BEVERLY R. PRUZEMAL, 84320499  
Notary Public - State of New York  
Appointed in Oswego County  
My Commission Expires March 30, 1986

DISTRIBUTION:

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

CC: J. Brons, NYPA, WPO  
R. Beedle, NYPA, WPO  
S. Zulla, NYPA, WPO  
R. Burns, NYPA, WPO  
J. Gray, NYPA, WPO  
A. Klausmann, NYPA, WPO  
T. Dougherty, NYPA, WPO  
L. Guaquil, NYPA, WPO  
G. Wilverding, NYPA, WPO  
W. Fernandez, NYPA, JAF  
R. Patch, NYPA, JAF  
J. Flaherty, NYPA, JAF  
J. Lyons, NYPA, JAF  
NRC Resident Inspector  
NRCB 84-02  
Document Control Center