

May 10, 1988

Docket Nos. 50-313
and 50-368

Mr. T. Gene Campbell
Vice President, Nuclear
Operations
Arkansas Power and Light Company
Post Office Box 551
Little Rock, Arkansas 72203

Dear Mr. Campbell:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING ITEMS 3.2.1
AND 3.2.2 OF GENERIC LETTER 83-28 - ARKANSAS NUCLEAR ONE,
UNITS 1 AND 2 (TAC NOS. 53733 AND 53734)

The staff has reviewed your letters dated November 5, 1983, May 27, 1985,
July 26, 1985, and February 16, 1988, regarding Generic Letter (GL) 83-28,
Items 3.2.1 and 3.2.2. For both Units 1 and 2, your responses were found to
be incomplete. Additional information identified in the enclosure is needed
to complete our review. Please provide your response within 30 days of the
receipt of this letter.

The reporting and/or recordkeeping requirements contained in this letter
affect fewer than ten respondents; therefore, OMB clearance is not required
under P.L. 96-511.

Please contact me if you have any questions concerning the request.

Sincerely,

/s/

C. Craig Harbuck, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
Request for Additional Information

cc w/enclosure:
See next page

DISTRIBUTION

Docket File	NRC PDR	Local PDR	PD4 Reading
L. Rubenstein	J. Calvo	P. Noonan	C. Harbuck
OGC-Rockville	E. Jordan	J. Partlow	ACRS (10)
PD4 Plant File			

PD4/LA *PN*
PNoonan
05/9/88

PD4/PM *CH*
CHarbuck:sr
05/9/88

PD4/D *MC*
JCalvo
05/10/88

8805190231 880510
PDR ADOCK 05000313
P PDR

May 10, 1988

Docket Nos. 50-313
and 50-368

Mr. T. Gene Campbell
Vice President, Nuclear
Operations -
Arkansas Power and Light Company
Post Office Box 551
Little Rock, Arkansas 72203

Dear Mr. Campbell:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING ITEMS 3.2.1
AND 3.2.2 OF GENERIC LETTER 83-28 - ARKANSAS NUCLEAR ONE,
UNITS 1 AND 2 (TAC NOS. 53733 AND 53734)

The staff has reviewed your letters dated November 5, 1983, May 27, 1985,
July 26, 1985, and February 16, 1988, regarding Generic Letter (GL) 83-28,
Items 3.2.1 and 3.2.2. For both Units 1 and 2, your responses were found to
be incomplete. Additional information identified in the enclosure is needed
to complete our review. Please provide your response within 30 days of the
receipt of this letter.

The reporting and/or recordkeeping requirements contained in this letter
affect fewer than ten respondents; therefore, OMB clearance is not required
under P.L. 96-511.

Please contact me if you have any questions concerning the request.

Sincerely,

/s/

C. Craig Harbuck, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
Request for Additional Information

cc w/enclosure:
See next page

DISTRIBUTION

Docket File	NRC PDR	Local PDR	PD4 Reading
L. Rubenstein	J. Calvo	P. Noonan	C. Harbuck
OGC-Rockville	E. Jordan	J. Partlow	ACRS (10)
PD4 Plant File			

PD4/LA *DJK*
PNoonan
05/19/88

PD4/PM *CH*
CHarbuck:sr
05/19/88

PD4/D *JJC*
JCalvo
05/18/88



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 10, 1988

Docket Nos. 50-313
and 50-368

Mr. T. Gene Campbell
Vice President, Nuclear
Operations
Arkansas Power and Light Company
Post Office Box 551
Little Rock, Arkansas 72203

Dear Mr. Campbell:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING ITEMS 3.2.1
AND 3.2.2 OF GENERIC LETTER 83-28 - ARKANSAS NUCLEAR ONE,
UNITS 1 AND 2 (TAC NOS. 53733 AND 53734)

The staff has reviewed your letters dated November 5, 1983, May 27, 1985,
July 26, 1985, and February 16, 1988, regarding Generic Letter (GL) 83-28,
items 3.2.1 and 3.2.2. For both Units 1 and 2, your responses were found to
be incomplete. Additional information identified in the enclosure is needed
to complete our review. Please provide your response within 30 days of the
receipt of this letter.

The reporting and/or recordkeeping requirements contained in this letter
affect fewer than ten respondents; therefore, OMB clearance is not required
under P.L. 96-511.

Please contact me if you have any questions concerning the request.

Sincerely,

A handwritten signature in cursive script that reads "C. Craig Harbuck".

C. Craig Harbuck, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
Request for Additional Information

cc w/enclosure:
See next page

Mr. T. Gene Campbell
Arkansas Power & Light Company

Arkansas Nuclear One
Unit Nos. 1 and 2

cc:

Mr. Dan R. Howard, Manager
Licensing
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
C-E Power Systems
7910 Woodmont Avenue
Suite 1310
Bethesda, Maryland 20814

Mr. James M. Levine, Executive Director
Site Nuclear Operations
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Mr. Frank Wilson, Director
Division of Environmental Health
Protection
Department of Health
Arkansas Department of Health
4815 West Markham Street
Little Rock, Arkansas 72201

Nicholas S. Reynolds, Esq.
Bishop, Liberman, Cook,
Purcell & Reynolds
1200 Seventeenth Street, N.W.
Suite 700
Washington, D.C. 20036

Honorable William Abernathy
County Judge of Pope County
Pope County Courthouse
Russelville, Arkansas 72801

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director for
Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
1 Nuclear Plant Road
Russellville, Arkansas 72801

Ms. Greta Dicus, Director
Division of Environmental Health
Protection
Arkansas Department of Health
4815 West Markam Street
Little Rock, Arkansas 72201

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220
1700 Rockville Pike, Suite 525
Rockville, Maryland 20852

ENCLOSURE

REQUEST FOR ADDITIONAL INFORMATION
REGARDING
RESPONSES TO GL 83-28, ITEMS 3.2.1 AND 3.2.2
ARKANSAS NUCLEAR ONE, UNITS 1 AND 2
DOCKET NOS. 50-313 AND 50-368

The staff has been directed to use the following guidelines in their review of Items 3.2.1 and 3.2.2.

1. The licensee has submitted a statement indicating that he has reviewed plant test and maintenance procedures and Technical Specifications to assure that postmaintenance operability testing of all safety-related components is required.
2. An unambiguous commitment should be obtained from each licensee that postmaintenance testing will verify component capability to perform all safety functions.

We request that you supply additional information on how the above guidelines are met.