



Georgia Institute of Technology

Neely Nuclear Research Center
900 Atlantic Drive
Atlanta, Georgia 30332-0425
(404) 894-3600 FAX: (404) 894-9325

October 1, 1998

U.S. Nuclear Regulatory Commission
Washington, D.C. 20555


Attention: Document Control Desk

Subject: Georgia Institute of Technology
License No. R-97 Docket No. 50-160
Quarterly Transmittal of All Safeguards
Events Log Entries

Pursuant to 10 CFR 73.71 (a) through (c), we report three entries in the Safeguards Event Log made during the months of July, August, and September 1998. The entries are described in an attached copy of the Event Log.

Should you have any question, please call me at (404) 894-3600.

Sincerely,



Nolan E. Hertel, Ph.D., P.E.
Director, Neely Nuclear Research Center

NEH/dpb

Cc: Mr. Craig Bassett
U.S. Nuclear Regulatory Commission
61 Forsyth Street, SW
Suite 23T85
Atlanta, GA 30303

070001

30021

9810070342 981001
PDR ADOCK 05000160
F PDR

	Log Entry Date/Time	Log Event Date/Time	EVENT	Response
59	9/21/98	Saturday 9/19/98	Intrusion Alarm at GTPS	Dr. Ice responded. Inspected facility, restricted areas and WREC perimeter. All OK
60	9/21/98 1500	9/21/98 0930	INTRUSION ALARM WAS TRIPPED	CONDITION THAT CAUSED THE INTRUSION ALARM TO TRIP HAD CLEARED ITSELF. SYSTEM RESETED & SUCCESSFULLY TESTED & LEFT IN RESET CONDITION. COULD FIND NO REASON FOR TRIP.
61	9/29/98 1500	9/24/98 11:30	Power outage Intrusion alarm was tripped	Alarm condition caused due to failure of system battery. System battery replaced on 9/24/98. System successfully tested and left in reset condition.
Blank OPP				

XED