

Ouver D. Kingsley, JR. Vice President Nuclear Operations

May 11, 1988

U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Attention: Document Control Desk

Gentlemen:

SUBJECT: Grand Gulf Nuclear Station

Unit 1

Docket No. 50-416 License No. NPF-29

Submittal of Fire Hazards Analysis

Revision 2 AECM-88/0082

By letter (AECM-85/0164) dated May 18, 1985 System Energy Resources, Incorporated (SERI) committed to provide the NRC with updates of the Fire Hazards Analysis (FHA) for Grand Gulf Nuclear Station (GGNS) on an annual basis. SERI is providing the attached Revision 2 affected pages of the FHA for NRC information consistent with that commitment.

The changes to the previously submitted FHA (AECM-87/0078 dated April 7, 1987) result from (1) a design change involving derating of fire walls in the Control Building performed under the provisions of 10CFR50.59 and (2) editorial changes and clarifications which do not affect the technical content of the FHA.

The derated fire walls do not separate safety related fire areas or safe shutdown components. The affected walls are not required to isolate safety related systems from unacceptable fire hazards. Derating of the fire walls will not affect control room habitability or the control room envelope.

The changes to the April 7, 1987 FHA have been evaluated and approved by a qualified fire protection engineer.

Yours truly,

ODK:bms Attachment

cc: (See Next Page)

8805200001 880511 PDR ADOCK 05000416 F DCD A006

cc: Mr. T. H. Cloninger (w/a)
Mr. R. B. McGehee (w/a)
Mr. N. S. Reynoids (w/a)
Mr. H. L. Thomas (w/o)
Mr. R. C. Butcher (w/a)

Dr. J. Nelson Grace, Regional Administrator (w/a) U. S. Nuclear Regulatory Commission Region II
101 Marietta St., N. W., Suite 2900
Atlanta, Georgia 30323

Mr. L. L. Kintner, Project Manager (w/a)
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop 14B20
Washington, D.C. 20555