

NUREG-0020
Vol. 12, No. 4
April 1988

LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT
DATA AS OF 03-31-88

UNITED STATES NUCLEAR REGULATORY COMMISSION



8805200063 880531
PDR NUREG
0020 R PDR

Available from

NRC/GPO Sales Program

Supintendent of Documents
Government Printing Office
Washington, D. C. 20402

A year's subscription consists of 12 issues for
this publication.

Single copies of this publication
are available from National Technical
Information Service, Springfield, VA 22161

Microfiche of single copies are
available from NRC/GPO Sales Program
Washington, D. C. 20555

NUREG-0020
Vol. 12, No. 4
April 1988

LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT

DATA AS OF 03-31-88

Manuscript Completed: May 1988
Date Published: May 1988

OFFICE OF ADMINISTRATION AND RESOURCES MANAGEMENT
U.S. NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555



STATEMENT OF PURPOSE

The U.S. Nuclear Regulatory Commission's monthly LICENSED OPERATING REACTORS Status Summary Report provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Information Resources Management, from the Headquarters Staff of NRC's Office of Inspection and Enforcement, from NRC's Regional Offices, and from utilities. Since all of the data concerning operation of the units is provided by the utility operators less than two weeks after the end of the month, necessary corrections to published information are shown on the ERRATA page.

This report is divided into three sections: the first contains monthly highlights and statistics for commercial operating units, and errata from previously reported data; the second is a compilation of detailed information on each unit, provided by NRC Regional Offices, IE Headquarters and the Utilities; and the third section is an appendix for miscellaneous information such as spent fuel storage capability, reactor years of experience and non-power reactors in the United States.

The percentage computations, Items 20 through 24 in Section 2, the vendor capacity factors on page 1-7, and actual vs. potential energy production on Page 1-2 are computed using actual data for the period of consideration. The percentages listed in power generation on Page 1-2 are computed as an arithmetic average. The factors for the life-span of each unit (the "Cumulative" column) are reported by the utility and are not entirely re-computed by NRC. Utility power production data is checked for consistency with previously submitted statistics.

It is hoped this status report proves informative and helpful to all agencies and individuals interested in analyzing trends in the nuclear industry which might have safety implications, or in maintaining an awareness of the U.S. energy situation as a whole.

T A B L E O F C O N T E N T S

| | PAGE |
|--|---------------------|
| GLOSSARY | ii |
| INDEX TO LICENSED UNITS | vii |
| | |
| <u>SECTION 1 - CURRENT DATA SUMMARIES</u> | |
| MONTHLY HIGHLIGHTS OF COMMERCIAL NUCLEAR POWER UNITS | 1-2 |
| Licensed Power Reactors | 1-2 |
| Power Generation | 1-2 |
| Actual vs. Potential Energy Production | 1-2 |
| Outage Data | 1-2 |
| Reasons for Shutdown | 1-3 |
| Derated Units | 1-3 |
| Shutdowns Greater Than 72 Hours Each | 1-3 |
| UNIT AVAILABILITY, CAPACITY, AND FORCED OUTAGE RATE PLOT | 1-4 |
| AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIAL OPERATING UNITS | 1-5 |
| AVERAGE CAPACITY FACTORS BY VENDOR | |
| Vendor Plot | 1-6 |
| Statistics | 1-7 |
| MEMORANDA - SPECIAL INFORMATION | 1-8 |
| ERRATA - CORRECTIONS TO PREVIOUSLY REPORTED DATA | 1-9 |
| | |
| <u>SECTION 2 - OPERATING POWER REACTORS</u> | |
| ARKANSAS 1 THROUGH ZION 2 | 2-002 through 2-483 |
| For each reactor: | |
| Operating Status | |
| Average Daily Power Level (MWe) Plot | |
| Unit Shutdowns/Reductions Summary | |
| Facility Data | |
| Inspection Status | |
| Licensee Reports | |
| | |
| <u>SECTION 3 - APPENDIX</u> | |
| STATUS OF SPENT FUEL STORAGE CAPABILITY | 3-2 |
| REACTOR-YEARS OF OPERATION | 3-6 |
| NON-POWER REACTORS IN THE U.S. | 3-7 |

G L O S S A R Y

| | |
|---|--|
| AVERAGE DAILY POWER LEVEL (MWe) | The net electrical energy generated during the day (measured from 0001 to 2400 hours inclusive) in megawatts hours, divided by 24 hours. |
| LICENSED THERMAL POWER (MWe) | The maximum thermal power of the reactor authorized by the NRC, expressed in megawatts. |
| DATE OF COMMERCIAL OPERATION | Date unit was declared by utility owner to be available for the regular production of electricity; usually related to satisfactory completion of qualification tests as specified in the purchase contract and to accounting policies and practices of utility. |
| DESIGN ELECTRICAL RATING (DER) (NET MWe) | The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design. |
| FORCED OUTAGE | An outage required to be initiated no later than the weekend following discovery of an offnormal condition. |
| FORCED OUTAGE HOURS | The clock hours during the report period that a unit is unavailable due to forced outages. |
| GROSS ELECTRICAL ENERGY GENERATED (MWH) | Electrical output of the unit during the report period as measured at the output terminals of the turbine generator, in megawatts hours. |
| GROSS HOURS | The clock hours from the beginning of a specified situation until its end. For outage durations, the clock hours during which the unit is not in power production. |
| GROSS THERMAL ENERGY GENERATED (MWH) | The thermal energy produced by the unit during the report period as measured or computed by the licensee in megawatt hours. |
| HOURS GENERATOR ON-LINE | Also, "Unit Service Hours." The total clock hours in the report period during which the unit operated with breakers closed to the station bus. These hours added to the total outage hours experienced by the unit during the report period, shall equal the hours in the report period. |
| HOURS IN REPORTING PERIOD | <p>For units in power ascension at the end of the period, the gross hours from the beginning of the period or the first electrical production, whichever comes last, to the end of the period.</p> <p>For units in commercial operation at the end of the period, the gross hours from the beginning of the period or of commercial operation, whichever comes last, to the end of the period or decommissioning, whichever comes first.</p> |

G L O S S A R Y (continued)

| | |
|---|--|
| HOURS REACTOR CRITICAL | The total clock hours in the report period during which the reactor sustained a controlled chain reaction. |
| MAXIMUM DEPENDABLE CAPACITY (GROSS) (MDC Gross) (Gross MWe) | Dependable main-unit gross capacity, winter or summer, whichever is smaller. The dependable capacity varies because the unit efficiency varies during the year due to cooling water temperature variations. It is the gross electrical output as measured at the output terminals of the turbine generator during the most restrictive seasonal conditions (usually summer). |
| MAXIMUM DEPENDABLE CAPACITY (NET) (MDC Net) (Net MWe) | Maximum Dependable Capacity (Gross) less the normal station service loads. |
| NAMEPLATE RATING (Gross MWe) | The nameplate power designation of the generator in megavolt amperes (MVA) times the nameplate power factor of the generator. NOTE: The nameplate rating of the generator may not be indicative of the maximum or dependable capacity, since some other item of equipment of a lesser rating (e.g., turbine) may limit unit output. |
| NET ELECTRICAL ENERGY GENERATED | Gross electrical output of the unit measured at the output terminals of the turbine generator during the reporting period, minus the normal station service electrical energy utilization. If this quantity is less than zero, a negative number should be recorded. |
| OUTAGE | A situation in which no electrical production takes place. |
| OUTAGE DATE | As reported on Appendix D of Reg. Guide 1.16, the date of the start of the outage. If continued from a previous month, report the same outage date but change "Method of Shutting Down Reactor" to "4 (continuations)" and add a note: "Continued from previous month." |
| OUTAGE DURATION | The Total clock hours of the outage measured from the beginning of the report period or the outage, whichever comes last, to the end of the report period or the outage, whichever comes first. |
| OUTAGE NUMBER | A number unique to the outage assigned by the licensee. The same number is reported each month in which the outage is in progress. One format is "76-05" for the fifth outage to occur in 1976. |
| PERIOD HOURS | See "Hours in Reporting Period." |
| POWER REDUCTION | A reduction in the Average Daily Power Level of more than 20% from the previous day. All power reductions are defined as outage of zero hours durations for the purpose of computing unit service and availability factors, and forced outage rate. |

G L O S S A R Y (continued)

| | |
|--|---|
| REACTOR AVAILABLE HOURS | The Total clock hours in the report period during which the reactor was critical or was capable of being made critical. (Reactor Reserve Shutdown Hours + Hours Reactor Critical.) |
| REACTOR AVAILABILITY FACTOR | $\frac{\text{Reactor Available Hours} \times 100}{\text{Period Hours}}$ |
| REACTOR RESERVE SHUTDOWN | The cessation of criticality in the reactor for administrative or other similar reasons when operation could have been continued. |
| REACTOR RESERVE SHUTDOWN HOURS | The total clock hours in the report period that the reactor is in reserve shutdown mode. NOTE: No credit is given for NRC imposed shutdowns. |
| REACTOR SERVICE FACTOR | $\frac{\text{Hours Reactor Critical} \times 100}{\text{Period Hours}}$ |
| REPORT PERIOD | Usually, the preceding calendar month. Can also be the preceding calendar year, (Year-to-Date), or the life-span of a unit (cumulative). |
| RESTRICTED POWER LEVEL | Maximum net electrical generation to which the unit is restricted during the report period due to the state of equipment, external conditions, administrative reasons, or a direction by NRC. |
| SCHEDULED OUTAGE | Planned removal of a unit from service for refueling, inspection, training, or maintenance. Those outages which do not fit the definition of "Forced Outage" perform are "Scheduled Outages." |
| STARTUP AND POWER ASCENSION TEST PHASE | Period following initial criticality during which the unit is tested at successively higher levels, culminating with operation at full power for a sustained period and completion of warranty runs. Following this phase, the utility generally considers the unit to be available for commercial operation. |
| UNIT | The set of equipment uniquely associated with the reactor, including turbine generators, and ancillary equipment, considered as a single electrical energy production facility. |
| UNIT AVAILABLE HOURS | The total clock hours in the report period during which the unit operated on-line or was capable of such operation. (Unit Reserve Shutdown Hours + Hours Generator On-Line.) |

G L O S S A R Y (continued)

| | |
|---|--|
| UNIT AVAILABILITY FACTOR | $\frac{\text{Unit Available Hours} \times 100}{\text{Period Hours}}$ |
| UNIT CAPACITY FACTORS | |
| - Using Licensed Thermal Power | $\frac{\text{Gross Thermal Energy Generated} \times 100}{\text{Period Hours} \times \text{Lic. Thermal Power}}$ |
| - Using Nameplate Rating | $\frac{\text{Gross Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{Nameplate Rating}}$ |
| - Using DER | $\frac{\text{Net Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{DER}}$ |
| - Using MDC Gross | $\frac{\text{Gross Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{MDC Gross}}$ |
| - Using MDC Net | $\frac{\text{Net Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{MDC Net}}$ |
| NOTE: if MDC GROSS and/or MDC NET have not been determined, the DER is substituted for this quantity for Unit Capacity Factor calculations. | |
| UNIT FORCED OUTAGE RATE | $\frac{\text{Forced Outage Hours} \times 100}{\text{Unit Service Hours} + \text{Forced Outage Hours}}$ |
| UNIT RESERVE SHUTDOWN | The removal of the unit from on-line operation for economic or other similar reasons when operation could have been continued. |
| UNIT RESERVE SHUTDOWN HOURS | The total clock hours in the report period during which the unit was in reserve shutdown mode. |
| UNIT SERVICE FACTOR | $\frac{\text{Unit Service Hours} \times 100}{\text{Period Hours}}$ |
| UNIT SERVICE HOURS | See "Hours Generator On-Line." |

NOTE:

At the end of each statement in the Enforcement Summary for any given facility may be found numbers in parentheses. These numbers are related to the inspection, e.g., 8111 (the 11th inspection of the plant in 1981); and the severity level, e.g., 4 (severity level IV). Violations are ranked by severity levels from I through V with level I being the most serious. The severity level is used in the determination of any resulting enforcement action. Gray Book lists severity level by Arabic numbers corresponding to the Roman numerals. Details on the various severity levels and enforcement actions can be found in Appendix C to 10 CFR Part 2 published in the Federal Register of March 9, 1982 pages 9987 through 9995, and as corrected April 14, 1982.

INDEX TO OPERATING POWER REACTORS

| | PAGE | | PAGE |
|------------------|-------|----------------------|-------|
| ARKANSAS 1 | 2-002 | MONTICELLO | 2-240 |
| ARKANSAS 2 | 2-006 | NINE MILE POINT 1 | 2-246 |
| BEAVER VALLEY 1 | 2-010 | NINE MILE POINT 2 | 2-250 |
| BEAVER VALLEY 2 | 2-014 | NORTH ANNA 1 | 2-254 |
| BIG ROCK POINT 1 | 2-018 | NORTH ANNA 2 | 2-260 |
| BRAIDWOOD 1 | 2-022 | OCONEE 1 | 2-264 |
| BROWNS FERRY 1 | 2-026 | OCONEE 2 | 2-268 |
| BROWNS FERRY 2 | 2-032 | OCONEE 3 | 2-272 |
| BROWNS FERRY 3 | 2-038 | OYSTER CREEK 1 | 2-276 |
| BRUNSWICK 1 | 2-044 | PALISADES | 2-280 |
| BRUNSWICK 2 | 2-050 | PALO VERDE 1 | 2-284 |
| BYRON 1 | 2-056 | PALO VERDE 2 | 2-290 |
| BYRON 2 | 2-060 | PALO VERDE 3 | 2-296 |
| CALLAWAY 1 | 2-064 | PEACH BOTTOM 2 | 2-302 |
| CALVERT CLIFFS 1 | 2-068 | PEACH BOTTOM 3 | 2-306 |
| CALVERT CLIFFS 2 | 2-072 | PERRY 1 | 2-310 |
| CATAWBA 1 | 2-076 | PILGRIM 1 | 2-314 |
| CATAWBA 2 | 2-082 | POINT BEACH 1 | 2-318 |
| CLINTON 1 | 2-088 | POINT BEACH 2 | 2-322 |
| COOK 1 | 2-092 | PRAIRIE ISLAND 1 | 2-326 |
| COOK 2 | 2-096 | PRAIRIE ISLAND 2 | 2-330 |
| COOPER STATION | 2-100 | QUAD CITIES 1 | 2-334 |
| CRYSTAL RIVER 3 | 2-104 | QUAD CITIES 2 | 2-338 |
| DAVIS-BESSE 1 | 2-108 | RANCHO SECO 1 | 2-342 |
| DIABLO CANYON 1 | 2-112 | RIVER BEND 1 | 2-348 |
| DIABLO CANYON 2 | 2-116 | ROBINSON 2 | 2-352 |
| DRESDEN 2 | 2-120 | SALEM 1 | 2-356 |
| DRESDEN 3 | 2-124 | SALEM 2 | 2-360 |
| DUANE ARNOLD | 2-128 | SAN ONOFRE 1 | 2-364 |
| FARLEY 1 | 2-132 | SAN ONOFRE 2 | 2-370 |
| FARLEY 2 | 2-138 | SAN ONOFRE 3 | 2-374 |
| FERMI 2 | 2-142 | SEQUOYAH 1 | 2-378 |
| FITZPATRICK | 2-146 | SEQUOYAH 2 | 2-386 |
| FORT CALHOUN 1 | 2-150 | SOUTH TEXAS 1 | 2-394 |
| FORT ST VRAIN | 2-154 | ST LUCIE 1 | 2-398 |
| GINNA | 2-158 | ST LUCIE 2 | 2-402 |
| GRAND GULF 1 | 2-162 | SUMMER 1 | 2-406 |
| HADDAM NECK | 2-168 | SURRY 1 | 2-410 |
| HARRIS 1 | 2-172 | SURRY 2 | 2-416 |
| HATCH 1 | 2-176 | SUSQUEHANNA 1 | 2-422 |
| HATCH 2 | 2-182 | SUSQUEHANNA 2 | 2-426 |
| HOPE CREEK 1 | 2-186 | THREE MILE ISLAND 1 | 2-430 |
| INDIAN POINT 2 | 2-190 | TROJAN | 2-434 |
| INDIAN POINT 3 | 2-194 | TURKEY POINT 3 | 2-438 |
| KEWAUNEE | 2-198 | TURKEY POINT 4 | 2-444 |
| LASALLE 1 | 2-202 | VERMONT YANKEE 1 | 2-450 |
| LASALLE 2 | 2-206 | VOSTLE 1 | 2-454 |
| LIMERICK 1 | 2-210 | WASHINGTON NUCLEAR 2 | 2-458 |
| MAINE YANKEE | 2-214 | WATERFORD 3 | 2-464 |
| MCGUIRE 1 | 2-218 | WOLF CREEK 1 | 2-468 |
| MCGUIRE 2 | 2-224 | YANKEE-ROWE 1 | 2-472 |
| MILLSTONE 1 | 2-228 | ZION 1 | 2-476 |
| MILLSTONE 2 | 2-232 | ZION 2 | 2-480 |
| MILLSTONE 3 | 2-236 | | |

SECTION 1

**CURRENT
DATA
SUMMARIES**

M O N T H L Y H I G H L I G H T S

```

*****
* LICENSED * (a) 2 IN POWER ASCENSION. . . . . 91,418 CAPACITY MWe (Net) --Based upon maximum dependable
* POWER * ----- 2,370 capacity; design elec. rating
* REACTORS * (b) 107 LICENSED TO OPERATE . . . . . 93,788 TOTAL used if MDC not determined
***** (c) 2 LICENSED FOR FUEL LOADING
AND LOW POWER TESTING
  
```

| | | | | | | |
|-----------------|---------|---------------------------|-----------------------|-----------------|----------|------|
| | MDC NET | | DER | | DATE | DER |
| (a) BRAIDWOOD 1 | 1120 | (b) Excludes these plants | 1. DRESDEN 1.....200 | (c) BRAIDWOOD 2 | 12/18/87 | 1120 |
| SOUTH TEXAS 1 | 1250 | licensed for operation | 2. HUMBOLDT BAY....65 | SHOREHAM | 07/03/85 | 820 |
| | | which are shut down | 3. TMI 2.....906 | | | |
| | | indefinitely or | 4. LACROSSE.....50 | | | |
| | | permanently | | | | |

| | | REPORT MONTH | PREVIOUS MONTH | YEAR-TO-DATE |
|----------------|--|--------------|----------------|--------------|
| ***** | 1. GROSS ELECTRICAL (MWHE) | 46,072,264 | 44,136,950 | 137,182,288 |
| * POWER * | 2. NET ELECTRICAL (MWHE) | 43,781,511 | 41,968,643 | 170,460,367 |
| * GENERATION * | 3. AVG. UNIT SERVICE FACTOR (%) | 69.4 | 71.1 | 71.2 |
| ***** | 4. AVG. UNIT AVAILABILITY FACTOR (%) | 69.4 | 71.1 | 71.2 |
| | 5. AVG. UNIT CAPACITY FACTOR (MDC) (%) | 65.5 | 67.2 | 67.4 |
| | 6. AVG. UNIT CAPACITY FACTOR (DER) (%) | 63.9 | 65.7 | 65.9 |
| | 7. FORCED OUTAGE RATE (%) | 10.3 | 13.8 | 12.3 |

| | | | % OF POTENTIAL PRODUCTION |
|---|--|-----------------|--------------------------------|
| ***** | 1. ENERGY ACTUALLY PRODUCED DURING THIS REPORT PERIOD. | 43,781,511 NET | 64.6 |
| * ACTUAL VS. * | 2. ENERGY NOT PRODUCED DUE TO SCHEDULED OUTAGES (NET). | 13,991,108 MWHe | 20.7 |
| * POTENTIAL * | 3. ENERGY NOT PRODUCED DUE TO FORCED OUTAGES (NET) | 7,581,049 MWHe | 11.2 |
| * ENERGY * | 4. ENERGY NOT PRODUCED FOR OTHER REASONS (NET) | 2,385,924 MWHe | 3.5 |
| * PRODUCTION * | | | |
| ***** | | | |
| POTENTIAL ENERGY PRODUCTION IN THIS PERIOD BY UNITS IN COMMERCIAL OPERATION | | 67,739,592 MWHe | 100.0% TOTAL |
| (Using Maximum Dependable Capacity Net) | | | |
| 5. ENERGY NOT PRODUCED DUE TO NRC-REQUIRED OUTAGES | | 773,784 MWHe | |
| 6. ENERGY NOT PRODUCED DUE TO NRC RESTRICTED POWER LEVELS. | | MWHe | 3 UNIT(S) WITH NRC RESTRICTION |

| | | NUMBER | HOURS | PERCENT OF CLOCK TIME | MWHE LOST PRODUCTION |
|------------|--|--------|----------|-----------------------|----------------------|
| ***** | 1. FORCED OUTAGES DURING REPORT PERIOD | 42 | 7,610.1 | 9.8 | 7,581,049 |
| * OUTAGE * | 2. SCHEDULED OUTAGES DURING REPORT PERIOD. | 43 | 16,186.3 | 20.8 | 13,991,108 |
| * DATA * | | | | | |
| ***** | | | | | |
| | TOTAL | 85 | 23,796.4 | 30.6 | 21,572,157 |

MWHE LOST PRODUCTION = Down time X maximum dependable capacity net

MONTHLY HIGHLIGHTS


| | | NUMBER | HOURS LOST |
|---------------|---|--------|------------|
| ***** | A - Equipment Failure | 29 | 2,417.9 |
| * REASONS * | B - Maintenance or Test | 20 | 3,348.0 |
| * FOR * | C - Refueling | 22 | 12,671.2 |
| * SHUTDOWNS * | D - Regulatory Restriction | 2 | 943.7 |
| ***** | E - Operator Training & License Examination | 1 | 41.0 |
| | F - Administrative | 5 | 3,720.0 |
| | G - Operational Error | 2 | 249.9 |
| | H - Other | 4 | 404.7 |
| | TOTAL | 85 | 23,796.4 |

| | MDC (MWe Net) | POWER LIMIT (MWe Net) | TYPE | |
|-------------|----------------|-----------------------|------|-----------------|
| * DERATED * | BYRON 1 | 1120 | 1097 | Self-imposed |
| * UNITS * | BYRON 2 | 1120 | 1055 | Self-imposed |
| ***** | COOK 1 | 1020 | 920 | Self-imposed |
| | COOK 2 | 1060 | 864 | Self-imposed |
| | FORT ST VRAIN | 330 | 271 | NRC Restriction |
| | PEACH BOTTOM 2 | 1051 | 0 | NRC Restriction |
| | PEACH BOTTOM 3 | 1035 | 0 | NRC Restriction |
| | ROBINSON 2 | 665 | 420 | Self-imposed |
| | SAN ONOFRE 1 | 436 | 390 | Self-imposed |

| | UNIT | REASON | UNIT | REASON | UNIT | REASON | UNIT | REASON |
|-----------------|-------------------|--------|------------------|--------|----------------|--------|---------------------|--------|
| * SHUTDOWNS * | ARKANSAS 2 | C | BROWNS FERRY 1 | F | BROWNS FERRY 2 | F | BROWNS FERRY 3 | F |
| * GREATER * | BRUNSWICK 2 | C | CALVERT CLIFFS 2 | B | CATAWBA 1 | H | CATAWBA 2 | A,H |
| * THAN 72 HRS * | CLINTON 1 | B | COOPER STATION | C | DAVIS-BESSE 1 | C | DIABLO CANYON 1 | C |
| * EACH * | DRESDEN 3 | C | FARLEY 1 | C | FERMI 2 | B | GINNA | A,C |
| ***** | HADDAM NECK | C | HARRIS 1 | A | HATCH 2 | C | HOPE CREEK 1 | C |
| | KEWAUNEE | C | LASALLE 1 | C | LASALLE 2 | A | NINE MILE POINT 1 | C |
| | NINE MILE POINT 2 | A,G | NORTH ANNA 1 | B | OCONEE 2 | C | PALO VERDE 1 | A |
| | PALO VERDE 2 | C | PEACH BOTTOM 2 | C | PEACH BOTTOM 3 | C | PILGRIM 1 | C |
| | PRAIRIE ISLAND 1 | B | RANCHO SECO 1 | D | ROBINSON 2 | D | SAN ONOFRE 1 | B |
| | SAN ONOFRE 2 | B | SEQUOYAH 1 | F | SEQUOYAH 2 | F | SURRY 2 | A |
| | SUSQUEHANNA 1 | B,G | SUSQUEHANNA 2 | C | TURKEY POINT 3 | A,A | WASHINGTON NUCLEAR* | A,A |
| | ZION 1 | C | | | | | | |

Unit Availability, Capacity, Forced Outage

Avg Unit Percentage as of March 1988



AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIALY OPERATING UNITS

This chart depicts the average daily power level for the units in commercial operation during the month.

The straight line on the graph labelled "SUM OF MDC" is plotted at the value shown by summing the separate maximum dependable capacities of the commercially operating units (in Net MWe). The plot shown below the line is calculated by summing the separate average daily power levels of the same units for each day of the month.


The scale on the left vertical axis runs in 1,000 MWe increments from 0 to 55,000 MWe (Net). The right vertical axis shows the percentage in 10% increments, up to 100% of the "SUM OF MDC".

It should be recognized that the 100% line would be obtainable only if all of the commercially operating units operated at 100% capacity, 24 hours per day, for the entire month. In other words, since any power generator must occasionally shut down to refuel and/or perform needed maintenance, and also since 100% capacity production is not always required by power demands, the 100% line is a theoretical goal and not a practical one.

THE AVERAGE POWER LEVEL CHART
IS NOT AVAILABLE THIS REPORT
PERIOD DUE TO SOFTWARE PROBLEMS.

Vendor Average Capacity Factors

3/31/88



Legend

- x General Electric
- o Westinghouse
- Combustion Engineering
- △ Babcock & Wilcox

NOTE: This display of average capacity factors provides a general performance comparison of plants supplied by the four nuclear steam supply system vendors. One must be careful when drawing conclusions regarding the reasons for the performance levels indicated, since plant performance may be affected by unspecified factors such as: (1) various plant designs and models are included for each vendor; (2) turbine/generators and (3) different architect/engineers are also involved.

Report Period MAR 1988

AVERAGE CAPACITY FACTORS BY VENDORS

| | | | |
|--------------------------------|------------------------|---------------------------|----------------------|
| ***** CFMDC | CFMDC | CFMDC | CFMDC |
| * GENERAL * 0.0 BROWNS FERRY 1 | 0.0 BROWNS FERRY 2 | 0.0 BROWNS FERRY 3 | 97.7 BRUNSHICK 1 |
| * ELECTRIC * 0.0 BRUNSWICK 2 | 51.3 CLINTON 1 | 10.7 COOPER STATION | 88.5 DRESDEN 2 |
| ***** 78.0 DRESDEN 3 | 95.9 DUANE ARNOLD | 0.0 FERMI 2 | 99.4 FITZPATRICK |
| 98.3 GRAND GULF 1 | 99.2 HATCH 1 | 19.9 HATCH 2 | 0.0 HOPE CREEK 1 |
| 35.1 LASALLE 1 | 58.4 LASALLE 2 | 97.1 LIMERICK 1 | 93.5 MILLSTONE 1 |
| 101.6 MONTICELLO | 0.0 NINE MILE POINT 1 | 36.8 NINE MILE POINT 2 | 102.5 OYSTER CREEK 1 |
| 0.0 PEACH BOTTOM 2 | 0.0 PEACH BOTTOM 3 | 92.6 PERRY 1 | 0.0 PILGRIM 1 |
| 98.0 QUAD CITIES 1 | 84.2 QUAD CITIES 2 | 94.9 RIVER BEND 1 | 53.1 SUSQUEHANNA 1 |
| 7.2 SUSQUEHANNA 2 | 100.6 VERMONT YANKEE 1 | 60.3 WASHINGTON NUCLEAR 2 | |

| | | | |
|-------------------------------|----------------------|--------------------|---------------------------|
| ***** CFMDC | CFMDC | CFMDC | CFMDC |
| * BABCOCK & * 80.2 ARKANSAS 1 | 84.5 CRYSTAL RIVER 3 | 17.5 DAVIS-BESSE 1 | 100.3 OCONEE 1 |
| * WILCOX * 0.0 OCONEE 2 | 100.6 OCONEE 3 | 0.0 RANCHO SECO 1 | 106.1 THREE MILE ISLAND 1 |
| ***** | | | |

| | | | |
|-----------------------------------|------------------------|----------------------|---------------------|
| ***** CFMDC | CFMDC | CFMDC | CFMDC |
| * COMBUSTION * 0.0 ARKANSAS 2 | 101.6 CALVERT CLIFFS 1 | 0.0 CALVERT CLIFFS 2 | 69.3 FORT CALHOUN 1 |
| * ENGINEERING * 98.6 MAINE YANKEE | 100.6 MILLSTONE 2 | 106.5 PALISADES | 58.4 PALO VERDE 1 |
| ***** 0.0 PALO VERDE 2 | 103.6 PALO VERDE 3 | 52.6 SAN ONOFRE 2 | 102.3 SAN ONOFRE 3 |
| 97.3 ST LUCIE 1 | 102.8 ST LUCIE 2 | 93.2 WATERFORD 3 | |

| | | | |
|---------------------------------------|----------------------|-----------------------|------------------------|
| ***** CFMDC | CFMDC | CFMDC | CFMDC |
| * WESTINGHOUSE * 85.4 BEAVER VALLEY 1 | 98.0 BEAVER VALLEY 2 | 94.3 BYRON 1 | 69.3 BYRON 2 |
| ***** 98.9 CALLAWAY 1 | 85.2 CATAWBA 1 | 30.4 CATAWBA 2 | 82.8 COOK 1 |
| 81.1 COOK 2 | 10.7 DIABLO CANYON 1 | 88.5 DIABLO CANYON 2 | 80.4 FARLEY 1 |
| 102.2 FARLEY 2 | 19.1 GINNA | 3.4 HADDAM NECK | 70.2 HARRIS 1 |
| 102.4 INDIAN POINT 2 | 98.9 INDIAN POINT 3 | 4.9 KEHAUNEE | 94.7 MCGUIRE 1 |
| 101.6 MCGUIRE 2 | 99.6 MILLSTONE 3 | 77.1 NORTH ANNA 1 | 100.3 NORTH ANNA 2 |
| 102.7 POINT BEACH 1 | 102.6 POINT BEACH 2 | 87.5 PRAIRIE ISLAND 1 | 103.2 PRAIRIE ISLAND 2 |
| 40.3 ROBINSON 2 | 94.8 SALEM 1 | 98.7 SALEM 2 | 0.0 SAN ONOFRE 1 |
| 0.0 SEQUOYAH 1 | 0.0 SEQUOYAH 2 | 100.6 SUMMER 1 | 84.4 SURRY 1 |
| 84.5 SURRY 2 | 100.9 TROJAN | 54.8 TURKEY POINT 3 | 98.8 TURKEY POINT 4 |
| 97.1 VOGTLE 1 | 102.3 WOLF CREEK 1 | 83.1 YANKEE-ROWE 1 | 0.0 ZION 1 |
| 90.5 ZION 2 | | | |

***** OTHER INFO *

Units excluded are:
 BIG ROCK POINT
 DRESDEN 1
 FORT ST VRAIN
 HUMBOLDT BAY
 LACROSSE
 THREE MILE ISLAND 2

Capacity factor in this page, denoted as CFMDC, is a function of the net maximum dependable capacity. See the corresponding definition in the glossary. The vendor averages are computed by the formula:

$$\frac{\text{Net Electrical Energy Produced by Vendor} \times 100\%}{\text{Potential Electrical Production by Vendor in this Month}}$$

| | GE BWRs | West PWRs | Comb PWRs | B&W PWRs | ALL PWRs |
|--------------------------------|------------|------------|-----------|-----------|------------|
| NET ELECTRICAL PRODUCTION..... | 11,252,285 | 21,962,215 | 7,388,624 | 2,975,139 | 32,325,978 |
| MDC NET..... | 30,858 | 39,508 | 13,949 | 6,704 | 60,161 |
| CFMDC..... | 49.6 | 74.7 | 71.2 | 59.6 | 72.2 |

MEMORANDA

THE FOLLOWING UNITS USE WEIGHTED AVERAGES TO CALCULATE CAPACITY FACTORS:

ITEM 22

BIG ROCK POINT 1
CALVERT CLIFFS 1
FARLEY 1
FITZPATRICK
FORT CALHOUN 1
INDIAN POINT 2*
KEWAUNEE
OYSTER CREEK 1
POINT BEACH 1 & 2
THREE MILE ISLAND 1
TURKEY POINT 3 & 4

ITEM 22 & 23

GINNA
HADDAM NECK (CONNECTICUT YANKEE)
MAINE YANKEE
MILLSTONE 2
OCONEE 1, 2, & 3
YANKEE-ROWE 1

*COMPUTED SINCE 7/1/74, THE DATE OF COMPLETION OF A 100 DAY - 100% POWER OPERATION TEST.

THE FOLLOWING UNITS USE THE DATE OF FIRST ELECTRICAL GENERATION INSTEAD OF COMMERCIAL OPERATION,
FOR THEIR CUMULATIVE DATA:

ITEMS 20 THROUGH 24

COOK 1 & 2
RIVER BEND
SAN ONOFRE 1

ITEM 24 ONLY

BIG ROCK POINT 1

E R R A T A
CORRECTIONS TO PREVIOUSLY REPORTED DATA

NOTE: THESE CHANGES ARE REFLECTED IN THE DATA CONTAINED IN THE CURRENT REPORT

REVISED MONTHLY HIGHLIGHTS

N O N E
N O N E
N O N E
N O N E

SECTION 2

**OPERATING
POWER
REACTORS**

1. Docket: 50-313 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: N. GOBELL (501) 964-3251

4. Licensed Thermal Power (Mwt): 2568

5. Nameplate Rating (Gross MWe): 1003 X 0.9 = 903

6. Design Electrical Rating (Net MWe): 850

7. Maximum Dependable Capacity (Gross MWe): 883

8. Maximum Dependable Capacity (Net MWe): 836

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>116,443.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,152.2</u> | <u>81,207.5</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>5,044.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,146.6</u> | <u>79,575.5</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>817.5</u> |
| 17. Gross Therm Ener (MWH) | <u>1,534,594</u> | <u>4,379,257</u> | <u>183,214,264</u> |
| 18. Gross Elec Ener (MWH) | <u>524,875</u> | <u>1,495,850</u> | <u>60,762,980</u> |
| 19. Net Elec Ener (MWH) | <u>498,569</u> | <u>1,418,599</u> | <u>57,807,976</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>98.3</u> | <u>68.3</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>98.3</u> | <u>69.0</u> |
| 22. Unit Cap Factor (MDC Net) | <u>80.2</u> | <u>77.7</u> | <u>59.4</u> |
| 23. Unit Cap Factor (DER Net) | <u>78.8</u> | <u>76.4</u> | <u>58.4</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>1.7</u> | <u>13.5</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>37.4</u> | <u>12,435.0</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING - SEPTEMBER 2, 1988, - 72 DAY DURATION

27. If Currently Shutdown Estimated Startup Date: N/A

* ARKANSAS 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ARKANSAS 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* ARKANSAS 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|------------------|---|
|-----|------|------|-------|--------|--------|------------|------------------|---|

NONE

* SUMMARY *

ARKANSAS I OPERATED ROUTINELY IN MARCH WITH NO OUTAGES OR
SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* ARKANSAS 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ARKANSAS
COUNTY.....POPE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...6 MI WNW OF
RUSSELLVILLE, AR
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 6, 1974
DATE ELEC ENER 1ST GENER...AUGUST 17, 1974
DATE COMMERCIAL OPERATE...DECEMBER 19, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...DARDANELLE RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ARKANSAS POWER & LIGHT
CORPORATE ADDRESS.....NINTH & LOUISIANA STREETS
LITTLE ROCK, ARKANSAS 72703
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....B. JOHNSON
LICENSING PROJ MANAGER.....G. DICK
DOCKET NUMBER.....50-313
LICENSE & DATE ISSUANCE...DPR-51, MAY 21, 1974
PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY
RUSSELLVILLE, ARKANSAS 72801

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED DEC 1, 87 - JAN 19, 88 (87-39) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, NRC BULLETIN FOLLOWUP, FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS, AND FOLLOWUP ON LICENSE EVENT REPORTS. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JAN 20 - FEB 21, 88 (88-01) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, FOLLOWUP ON A PREVIOUSLY IDENTIFIED ITEM, FOLLOWUP ON TMI ACTION ITEM II.K.3.5, AND FOLLOWUP ON GENERIC LETTERS. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

1. Docket: 50-368 O P E R A T I N G S T A T U S

2. Reporting Period: 05/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: D. F. HARRISON (501) 964-3743

4. Licensed Thermal Power (MWh): 2815

5. Nameplate Rating (Gross MWe): 945

6. Design Electrical Rating (Net MWe): 912

7. Maximum Dependable Capacity (Gross MWe): 897

8. Maximum Dependable Capacity (Net MWe): 858

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>70,272.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>1,027.6</u> | <u>50,795.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>1,430.1</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>1,027.5</u> | <u>49,420.9</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>75.0</u> |
| 17. Gross Therm Ener (MWh) | <u>0</u> | <u>2,816,266</u> | <u>127,673,823</u> |
| 18. Gross Elec Ener (MWh) | <u>0</u> | <u>939,120</u> | <u>41,938,531</u> |
| 19. Net Elec Ener (MWh) | <u>-1,918</u> | <u>893,875</u> | <u>39,913,372</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>47.0</u> | <u>70.3</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>47.0</u> | <u>70.4</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>47.7</u> | <u>66.2</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>44.9</u> | <u>62.3</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>19.4</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>8,336.0</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 05/02/88

* ARKANSAS 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ARKANSAS 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* ARKANSAS 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 88-01 | 02/12/88 | S | 744.0 | C | 4 | | ZZ | ZZZZZZ | UNIT SHUTDOWN FOR REFUELING AND MAINTENANCE. |

* SUMMARY *

ARKANSAS 2 REMAINED SHUTDOWN IN MARCH FOR REFUELING AND MAINTENANCE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* ARKANSAS 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ARKANSAS
COUNTY.....POPE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...6 MI WNW OF
RUSSELLVILLE, AR
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 5, 1978
DATE ELEC ENER 1ST GENER...DECEMBER 26, 1978
DATE COMMERCIAL OPERATE...MARCH 26, 1980
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...DARDANELLE RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ARKANSAS POWER & LIGHT
CORPORATE ADDRESS.....NINTH & LOUISIANA STREETS
LITTLE ROCK, ARKANSAS 72203
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC
REGULATORY INFORMATION
IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....W. JOHNSON
LICENSING PROJ MANAGER....C. HARBUCK
DOCKET NUMBER.....50-368
LICENSE & DATE ISSUANCE...NPF-6, SEPTEMBER 1, 1978
PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY
RUSSELLVILLE, ARKANSAS 72801

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED DEC 1, 1987 - JAN 19, 1988 (87-39) ROUTINE, UNANNOUNCED INSPECTION OF AREAS INCLUDING OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, AND SURVEILLANCE, NRC BULLETIN FOLLOWUP, FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS, AND FOLLOWUP ON LERS. WITHIN THE AREAS INSPECTED, ONE DEVIATION (FAILURE TO PROVIDE) SUPPLEMENTS TO LERS WAS IDENTIFIED.

INSPECTION CONDUCTED JAN 20 - FEB 21, 1988 (88-01) ROUTINE, UNANNOUNCED INSPECTION OF OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, FOLLOWUP ON TMI ACTION ITEM II.K.3.5, AND FOLLOWUP ON GENERIC LETTERS. WITHIN THE AREAS INSPECTED, ONE APPARENT VIOLATION WAS IDENTIFIED (EXCESSIVE COMBUSTIBLES IN DIESEL GENERATOR ROOM).

ENFORCEMENT SUMMARY

CONTRARY TO TECH. SPEC. 6.8.1 THE LICENSEE FAILED TO PROPERLY CONTROL COMBUSTIBLES IN THE NORTH EMERGENCY DIESEL GENERATOR ROOM. (8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

1. Docket: 50-334 O P E R A T I N G S T A T U S
2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: P.A. SMITH (412) 393-7621
4. Licensed Thermal Power (MWt): 2652
5. Nameplate Rating (Gross MWe): 1026 X 0.9 = 923
6. Design Electrical Rating (Net MWe): 835
7. Maximum Dependable Capacity (Gross MWe): 860
8. Maximum Dependable Capacity (Net MWe): 810
9. If Changes Occur Above Since Last Report, Give Reasons:
NONE
10. Power Level To Which Restricted, If Any (Net MWe): _____
11. Reasons for Restrictions, If Any: _____
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>104,472.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>744.0</u> | <u>59,932.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>4,482.7</u> |
| 15. Hrs Generator On-Line | <u>710.0</u> | <u>710.0</u> | <u>58,364.3</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>2.2</u> |
| 17. Gross Therm Ener (MWH) | <u>1,677,626</u> | <u>1,677,626</u> | <u>138,594,936</u> |
| 18. Gross Elec Ener (MWH) | <u>547,359</u> | <u>547,359</u> | <u>44,413,119</u> |
| 19. Net Elec Ener (MWH) | <u>514,577</u> | <u>503,657</u> | <u>41,439,260</u> |
| 20. Unit Service Factor | <u>95.4</u> | <u>32.5</u> | <u>58.2</u> |
| 21. Unit Avail Factor | <u>95.4</u> | <u>32.5</u> | <u>58.2</u> |
| 22. Unit Cap Factor (MDC Net) | <u>85.4</u> | <u>28.5</u> | <u>52.2</u> |
| 23. Unit Cap Factor (DER Net) | <u>82.8</u> | <u>27.6</u> | <u>50.6</u> |
| 24. Unit Forced Outage Rate | <u>1.1</u> | <u>1.1</u> | <u>19.5</u> |
| 25. Forced Outage Hours | <u>8.1</u> | <u>8.1</u> | <u>19,049.5</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A *

XX
 X BEAVER VALLEY 1 X
 XXX
 AVERAGE DAILY POWER LEVEL (MWe) PLOT

BEAVER VALLEY 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * BEAVER VALLEY 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 3 | 12/11/87 | S | 25.9 | C | 4 | | ZZ | ZZZZZZ | THE UNIT WAS SHUTDOWN FOR THE UNIT'S SIXTH REFUELING OUTAGE. |
| 4 | 03/02/88 | F | 3.1 | B | 1 | | CH | VALVEX | THE UNIT WAS REMOVED FROM SERVICE TO STABILIZE CONTROL OF THE STEAM GENERATOR FEEDWATER SYSTEM. |
| 5 | 03/02/88 | F | 5.0 | B | 1 | | HA | TURBIN | TURBINE WAS TAKEN OFF LINE FOR TURBINE OVERSPEED TRIP TESTING. |
| 6 | 03/02/88 | S | 0.0 | B | 5 | | ZZ | ZZZZZZ | STARTUP AND PHYSICS TESTING FOLLOWING COMPLETION OF SIXTH REFUELING. |
| 7 | 03/29/88 | F | 0.0 | B | 5 | | HC | HTEXCH | THE UNIT'S OUTPUT WAS REDUCED TO 80% TO PERMIT CLEANING THE CONDENSER TUBES IN THE 'A' WATERBOX OF THE UNIT'S MAIN CONDENSER. |
| 8 | 03/30/88 | F | 0.0 | B | 5 | | HC | HTEXCH | THE UNIT'S OUTPUT WAS REDUCED TO 80% TO PERMIT CLEANING THE CONDENSER TUBES IN THE 'D' WATERBOX OF THE UNIT'S MAIN CONDENSER. |
| 9 | 03/31/88 | F | 0.0 | B | 5 | | HC | HTEXCH | THE UNIT'S OUTPUT WAS REDUCED TO 80% TO PERMIT CLEANING THE CONDENSER TUBES IN THE 'B' WATERBOX OF THE UNIT'S MAIN CONDENSER. |

 * SUMMARY *

 BEAVER VALLEY I COMPLETED SCHEDULED REFUELING OUTAGE ON MARCH 2, 1988, AND SUBSEQUENTLY INCURRED 2 OUTAGES AND 4 POWER REDUCTIONS DURING THE REMAINDER OF THE MONTH.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* BEAVER VALLEY 1 *

F A C I L I T Y D A T A

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....BEAVER
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...SHIPPINGPORT, PENNSYLVANIA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 10, 1976
DATE ELEC ENER 1ST GENER...JUNE 14, 1976
DATE COMMERCIAL OPERATE...OCTOBER 1, 1976
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...OHIO RIVER
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUQUESNE LIGHT
CORPORATE ADDRESS.....ONE OXFORD CENTRE, 301 GRANT STREET
PITTSBURGH, PENNSYLVANIA 15279
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....J. BEALL
LICENSING PROJ MANAGER....P. TAM
DOCKET NUMBER.....50-334
LICENSE & DATE ISSUANCE...DPR-66, JULY 2, 1976
PUBLIC DOCUMENT ROOM.....B.F. JONES MEMORIAL LIBRARY
633 FRANKLIN AVENUE
ALIQUIPPA, PA 15001

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

* BEAVER VALLEY 1 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------------------|------------------|-------------------|---------|
| ----- | | | |
| NO INPUT PROVIDED. | | | |
| ===== | | | |

1. Docket: 50-412 O P E R A T I N G S T A T U S
2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: P. A. SMITH (412) 643-1825
4. Licensed Thermal Power (MWT): 2652
5. Nameplate Rating (Gross MWe): 923
6. Design Electrical Rating (Net MWe): 836
7. Maximum Dependable Capacity (Gross MWe): 885
8. Maximum Dependable Capacity (Net MWe): 833
9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____
11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>3,255.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>1,784.5</u> | <u>2,750.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>1,771.7</u> | <u>2,721.5</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,961,547</u> | <u>4,557,370</u> | <u>6,843,007</u> |
| 18. Gross Elec Ener (MWH) | <u>639,900</u> | <u>1,483,300</u> | <u>2,265,500</u> |
| 19. Net Elec Ener (MWH) | <u>607,197</u> | <u>1,399,393</u> | <u>2,137,497</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>81.1</u> | <u>58.2</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>81.1</u> | <u>58.2</u> |
| 22. Unit Cap Factor (MDC Net) | <u>98.0</u> | <u>76.9</u> | <u>52.2</u> |
| 23. Unit Cap Factor (DER Net) | <u>97.6</u> | <u>76.6</u> | <u>50.6</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>3.6</u> | <u>19.5</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>65.3</u> | <u>186.5</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: P.A.

XX
 X BEAVER VALLEY 2 X
 XXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BEAVER VALLEY 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
* BEAVER VALLEY 2 *
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

XXXXXXXXXXXX BEAVER VALLEY 2 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES
* SUMMARY * OR SIGNIFICANT POWER REDUCTIONS.
XXXXXXXXXXXX

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* BEAVER VALLEY 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....BEAVER
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...SHIPPINGPORT, PENNSYLVANIA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 4, 1987
DATE ELEC ENER 1ST GENER...AUGUST 17, 1987
DATE COMMERCIAL OPERATE...NOVEMBER 17, 1987
CONDENSER COOLING METHOD...HNDCT
CONDENSER COOLING WATER...OHIO RIVER
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUQUESNE LIGHT
CORPORATE ADDRESS.....435 SIXTH AVENUE
PITTSBURGH, PENNSYLVANIA 15219
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....J. BEALL
LICENSING PROJ MANAGER.....P. TAM
DOCKET NUMBER.....50-412
LICENSE & DATE ISSUANCE...NPF-73, AUGUST 14, 1987
PUBLIC DOCUMENT ROOM.....B F. JONES MEMORIAL LIBRARY
633 FRANKLIN AVENUE
ALIQIPPA, PA 15001

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

1. Docket: 50-155 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. R. JOHNSTON (616) 547-6537

4. Licensed Thermal Power (Mwt): 240

5. Nameplate Rating (Gross MWe): 70.6 X 0.85 = 60

6. Design Electrical Rating (Net MWe): 72

7. Maximum Dependable Capacity (Gross MWe): 73

8. Maximum Dependable Capacity (Net MWe): 69

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|----------------|----------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>219,235.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>1,997.0</u> | <u>157,830.7</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>1,953.8</u> | <u>155,088.7</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>138,834</u> | <u>368,946</u> | <u>29,302,469</u> |
| 18. Gross Elec Ener (MWH) | <u>45,562</u> | <u>120,121</u> | <u>9,291,955</u> |
| 19. Net Elec Ener (MWH) | <u>43,064</u> | <u>113,525</u> | <u>8,786,767</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>89.5</u> | <u>70.7</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>89.5</u> | <u>70.7</u> |
| 22. Unit Cap Factor (MDC Net) | <u>83.9</u> | <u>75.3</u> | <u>59.5*</u> |
| 23. Unit Cap Factor (DER Net) | <u>80.4</u> | <u>72.2</u> | <u>55.7</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>7.7</u> | <u>13.5</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>163.3</u> | <u>12,270.0</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING - APRIL 8, 1988 - 60 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

* BIG ROCK POINT 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
BIG ROCK POINT 1



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * BIG ROCK POINT 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|------------------|---|
| 88-07 | 03/22/88 | F | 0.0 | A | 5 | | | POWER WAS REDUCED TO ALLOW REPAIRS TO THE HP EXTRACTION LINE STEAM LEAK. TEMPORARY REPAIRS WERE MADE AT THIS TIME WITH PERMANENT REPAIRS BEING MADE DURING THE UPCOMING REFUELING OUTAGE. THE UNIT WAS RETURNED TO ITS ORIGINAL POWER LEVEL AFTER THE TEMPORARY REPAIRS WERE COMPLETED. |
| 88-08 | 03/26/88 | F | 0.0 | A | 5 | | | POWER WAS REDUCED TO ALLOW REPAIRS TO THE HP EXTRACTION LINE AFTER INVESTIGATION INDICATED THAT PIN HOLE STEAM LEAK RESULTING FROM POROSITY, EXISTED IN THE WELD REPAIRS MADE DURING EVENT #88-07 ABOVE. THE UNIT WAS RETURNED TO NORMAL POWER LEVELS AFTER REPAIRS WERE MADE. |

 * SUMMARY *

 BIG ROCK POINT INCURRED 2 POWER REDUCTIONS IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | H-Other | 4-Continued | Data Entry Sheet |
| | D-Regulatory Restriction | 5-Reduced Load | Licensee Event Report |
| | E-Operator Training | 9-Other | (LER) File (NUREG-0161) |
| | & License Examination | | |

* BIG ROCK POINT 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN
COUNTY.....CHARLEVOIX
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...4 MI NE OF
CHARLEVOIX, MICH
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 27, 1962
DATE ELEC ENER 1ST GENER...DECEMBER 8, 1962
DATE COMMERCIAL OPERATE...MARCH 29, 1963
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CONSUMERS POWER
CORPORATE ADDRESS.....212 WEST MICHIGAN AVENUE
JACKSON, MICHIGAN 49201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....S. GUTHRIE
LICENSING PROJ MANAGER.....W. SCOTT
DOCKET NUMBER.....50-155
LICENSE & DATE ISSUANCE...DPR-6, AUGUST 30, 1962
PUBLIC DOCUMENT ROOM.....NORTH CENTRAL MICHIGAN COLLEGE
1515 HOWARD STREET
PETOSKEY, MICHIGAN 49770

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON DECEMBER 14, 1987 THROUGH FEBRUARY 16, 1988 (88002): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY THE SENIOR RESIDENT INSPECTOR OF OPERATIONAL SAFETY, MAINTENANCE OPERATION, SURVEILLANCE OPERATION, REGIONAL REQUESTS, REACTOR TRIPS, IE BULLETINS, LICENSEE EVENT REPORT FOLLOW-UP, AND TRAINING. OF THE EIGHT AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. NO SIGNIFICANT SAFETY ITEMS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

* BIG ROCK POINT 1 *

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING ROUTINELY.

LAST IE SITE INSPECTION DATE: 02/16/88

INSPECTION REPORT NO: 88002

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---|
| 88-03 | 020788 | 030888 | REACTOR SHUTDOWN - HIGH PRIMARY SYSTEM UNIDENTIFIED LEAK RATE |

=====

1. Docket: 50-456 O P E R A T I N G S T A T U S
 2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
 3. Utility Contact: B. M. PEACOCK (815) 458-2801 EXT. 2480
 4. licensed Thermal Power (MWh): 3411
 5. Nameplate Rating (Gross MWe): _____
 6. Design Electrical Rating (Net MWe): 1120
 7. Maximum Dependable Capacity (Gross MWe): 1175
 8. Maximum Dependable Capacity (Net MWe): 1120
 9. If Changes Occur Above Since Last Report, Give Reasons: _____

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------------|----------------|------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>6,337.0</u> |
| 13. Hours Reactor Critical | <u>71.4</u> | <u>85.9</u> | <u>3,145.6</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>58.1</u> | <u>72.6</u> | <u>2,683.3</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>49,033</u> | <u>96,316</u> | <u>5,111,988</u> |
| 18. Gross Elec Ener (MWH) | <u>13,498</u> | <u>30,554</u> | <u>1,635,158</u> |
| 19. Net Elec Ener (MWH) | <u>0</u> | <u>16,111</u> | <u>1,472,762</u> |
| 20. Unit Service Factor | | | |
| 21. Unit Avail Factor | | NOT IN | |
| 22. Unit Cap Factor (MDC Net) | | COMMERCIAL | |
| 23. Unit Cap Factor (LER Net) | | OPERATION | |
| 24. Unit Forced Outage Rate | | | |
| 25. Forced Outage Hours | <u>205.0</u> | <u>205.0</u> | <u>1,077.2</u> |

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): _____


NONE

27. If Currently Shutdown Estimated Startup Date: 04/15/88

 * BRAIDWOOD 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BRAIDWOOD 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * BRAIDHOOD 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|------------------|--|
| 01 | 01/01/88 | S | 480.9 | H | 4 | | | CONTINUANCE OF 6 WEEK SURVEILLANCE OUTAGE. |
| 02 | 01/23/88 | F | 205.0 | H | 1 | | | UNIT SHUT DOWN DUE TO ENVIRONMENTAL QUALIFICATION CONCERNS WITH LIMITORQUE VALVE OPERATOR GREASE. GREASE IS BEING CHANGED AS REQUIRED. |

 * SUMMARY *

 BRAIDHOOD 1 COMPLETED 6 WEEK SCHEDULED SURVEILLANCE OUTAGE. SUBSEQUENTLY INCURRED 1 POWER OUTAGE AS DISCUSSED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* BRAIDWOOD 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....WILL
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...24 MI SSW OF
JOLIET, ILL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 29, 1987
DATE ELEC ENER 1ST GENER...JULY 12, 1987
DATE COMMERCIAL OPERATE...*****
CONDENSER COOLING METHOD...CC ART
CONDENSER COOLING WATER...KANKAKEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....L. MCGREGOR
LICENSING PROJ MANAGER.....S. SANDS
DOCKET NUMBER.....50-456
LICENSE & DATE ISSUANCE...NPF-72, JULY 2, 1987
PUBLIC DOCUMENT ROOM.....HEAD LIBRARIAN
GOVERNMENT DOCUMENTS COLLECTION
WILMINGTON PUBLIC LIBRARY
201 SOUTH KANKAKEE STREET
WILMINGTON, ILLINOIS, 60481

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION DURING THE PERIOD JANUARY 13 THROUGH FEBRUARY 16, 1988 (88004; 88005). ROUTINE, UNANNOUNCED INSPECTION OF THE OPERATIONAL RADIATION PROTECTION PROGRAM (INCLUDING: LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS (IP 92701); ORGANIZATION AND MANAGEMENT CONTROLS (IP 83722); AUDITS AND APPRAISALS (IP 83722) TRAINING AND QUALIFICATIONS (IP 83723); EXTERNAL EXPOSURE CONTROL AND PERSONAL DOSIMETRY (IP 83724); INTERNAL EXPOSURE CONTROL AND ASSESSMENT (IP 83725); CONTROL OF RADIOACTIVE MATERIALS AND CONTAMINATION (IP 83726); ALARA ACTIVITIES (IP 83728); FACILITIES AND EQUIPMENT (IP 83727); UNIT 1 STARTUP SURVEY DATA (IP 83521) AND STATUS OF CERTAIN TMI ACTION PLAN ITEM (IP 25401). THE LICENSEE'S RADIATION PROTECTION PROGRAM CONTINUES TO BE EFFECTIVE IN PROTECTING THE HEALTH AND SAFETY OF OCCUPATIONAL WORKERS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON FEBRUARY 16-25, 1988 (88006; 88008). ROUTINE, ANNOUNCED INSPECTION OF THE LICENSEE'S IMPLEMENTATION OF GENERIC LETTER 83-28 IN THE AREAS OF EQUIPMENT CLASSIFICATION, VENDOR INTERFACE, POST MAINTENANCE TESTING, AND REACTOR TRIP SYSTEM RELIABILITY. CLOSED TI 2515/64R1 AND TI 2515/91. (25564) (25591) NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

* BRAIDWOOD 1 *

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

BRAIDWOOD 1 OPERATING IN THE STARTUP TEST PROGRAM UP TO 100% RATED POWER

LAST IE SITE INSPECTION DATE: 03/28/88

INSPECTION REPORT NO: 88012

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|--|
| 88-04 | 031188 | 040488 | MANUAL REACTOR TRIP DUE TO DIGITAL ROD POSITION INDICATION SYSTEM COMPONENT FAILURE |
| 88-06 | 031388 | 040688 | PARTIAL LOSS OF AUX BUILDING NON ACCESSIBLE FILTER PLENUM POSITION INDICATION DUE TO AN ADMINISTRATIVE AND MANAGEMENT DEFICIENCY |
| 88-07 | 021587 | 031388 | RESIDUAL HEAT REMOVAL PUMPS DECLARED INOPERABLE DUE TO IMPROPER SURVEILLANCE EXECUTION |

=====

1. Docket: 50-259 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. D. CRAWFORD (205) 729-2507

4. Licensed Thermal Power (MWh): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------------|----------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>119,810.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>.0</u> | <u>59,520.9</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>6,996.8</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>.0</u> | <u>58,276.4</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>.0</u> | <u>.0</u> | <u>167,963,338</u> |
| 18. Gross Elec Ener (MWH) | <u>.0</u> | <u>.0</u> | <u>55,398,130</u> |
| 19. Net Elec Ener (MWH) | <u>-1,978</u> | <u>-4,809</u> | <u>53,663,108</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>.0</u> | <u>48.6</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>.0</u> | <u>48.6</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>.0</u> | <u>42.1</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>.0</u> | <u>42.1</u> |
| 24. Unit Forced Outage Rate | <u>100.0</u> | <u>100.0</u> | <u>42.4</u> |
| 25. Forced Outage Hours | <u>744.0</u> | <u>2,184.0</u> | <u>42,882.1</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* BROWNS FERRY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

XX
X BROWNS FERRY 1 X
XX

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|------------------|--|
| 315 | 06/01/85 | F | 744.0 | F | 4 | | | ADMINISTRATIVE HOLD TO RESOLVE VARIOUS TVA AND NRC CONCERNS. |

* SUMMARY *

BROWNS FERRY 1 REMAINED ON ADMINISTRATIVE HOLD IN MARCH
IN ORDER TO RESOLVE VARIOUS TVA AND NRC CONCERNS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

ENFORCEMENT SUMMARY

FAILURE TO MAINTAIN AND FOLLOW CONTROL AND ACCOUNTABILITY FOR NON FUEL SNM. FAILURE TO UPDATE INTERNAL RECORDS IN A TIMELY MANNER.

(8702 4)

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION II, CRITERION V, CRITERION XVII, QA TOPICAL REPORT TABLE 17E-1, NUCLEAR QUALITY ASSURANCE MANUAL (NQAM), PART 1, SECTION 2.17, AND NUCLEAR ENGINEERING PROCEDURE 1.2, REV. 1, AS OF OCTOBER 1987, ONE TRAINING AND DOCUMENTATION FAILED TO MEET THE FOLLOWING REQUIREMENTS OF NEP-1.2: (1) THE ASSISTANT CHIEF MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 30 OF 40 REQUIRED TRAINING SUBJECTS. A LEAD MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 35 OF 40 REQUIRED TRAINING SUBJECTS. (2) WATTS BAR SITE-SPECIFIED TRAINING REQUIREMENTS WERE LESS THAN THE TRAINING PROGRAM SPECIFIED BY NEP-1.2. A TYPICAL EXAMPLE CONCERNS A WATTS BAR ASSISTANT PROJECT ENGINEER (APE), WHOSE SITE-SPECIFIED TRAINING REQUIREMENTS DID NOT INCLUDE SEVEN AREAS REQUIRED BY NEP-1.2. (3) THE LICENSEE WAS UNABLE TO CONFIRM THAT REQUIREMENTS OF THE TRAINING MATRIX HAD BEEN ACCOMPLISHED FOR FIVE MECHANICAL ENGINEERING BRANCH (MEB) PERSONNEL AND TWO WATTS BAR APES. SINCE AN ADDITIONAL OPPORTUNITY TO CONFIRM THE ABOVE TRAINING WAS AFFORDED SUBSEQUENT TO THE EXIT INTERVIEW AND THE TRAINING WAS NOT CONFIRMED, THE NRC CONCLUDES THAT THE TRAINING WAS NOT CONDUCTED.

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION XVIII, CRITERION XVI, AND NQAM, PART 1, SECTION 2.18, REV. 0, 10 AUDITS FROM 1985 TO JANUARY 1987 IDENTIFIED TRAINING DEFICIENCIES WHICH, AT THE TIME OF THE INSPECTION, HAD NOT BEEN CORRECTED.

(8703 4)

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION V, AND NEP 1.3, REV. 0, CORRECTIONS WERE MADE TO NUMEROUS DOCUMENTS IN A MANNER NOT IN CONFORMANCE WITH THE ONE LINE, INITIAL, AND DATE METHOD.

(8703 5)

CONTRARY TO TECHNICAL SPECIFICATION (TS) 4.7.B.2.A, THE TEST PERFORMED ON SGTS TRAIN B NOVEMBER 25, 1987, TO SATISFY THIS REQUIREMENT FOLLOWING A FIRE IN THE UNIT 2 DRYWELL DID NOT COMPLY WITH ANSI N510-1975 IN THE FOLLOWING EXAMPLES: (1) THE FREON GAS GENERATOR OUTPUT WAS NOT HELD TO PLUS OR MINUS 20% OF THE PRE-SET VALUE AS SPECIFIED IN STEP 12.4.3 OF ANSI N510-1975. (2) THE UPSTREAM CONCENTRATION OF FREON TRACER GAS WAS NOT LIMITED TO 20 PPM AS SPECIFIED IN STEP 12.4.3 OF ANSI N510-1975.

(8704 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

ENVIRONMENTAL QUALIFICATION WORK.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

TVA APPOINTED MR. JOHN WALKER TO PLANT MANAGER POSITION.

PLANT STATUS:

SHUTDOWN FOR REPAIRS ON 03/19.

Report Period MAR 1988 INSPECTION STATUS - (CONTINUED)

OTHER ITEMS

LAST IE SITE INSPECTION DATE: FEBRUARY 1-29, 1988 +
 INSPECTION REPORT NO: 50-259/88-04 +

REPORTS FROM LICENSEE

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|--|
| 88-005 | 01/22/88 | 02/19/88 | DIESEL GENERATOR AND EMERGENCY EQUIPMENT COOLING WATER PUMP ACTUATIONS DUE TO PERSONNEL ERROR |
| 88-006 | 02/20/88 | 03/18/88 | UNPLANNED ES; ACTUATIONS DUE TO PERSONNEL ERROR CAUSED BY PROCEDURAL INADEQUACIES AND HUMAN FACTORS CONCERNS |
| 88-007 | 01/27/88 | 02/26/88 | RHR SERVICE WATER PUMP FLOW NOT DEMONSTRATED IN ACCORDANCE WITH TECH SPECS DUE TO CALIBRATION ERROR |
| 88-008 | 01/20/88 | 02/19/88 | STANDBY GAS TREATMENT RELATIVE HUMIDITY HEATERS HAVE NOT BEEN TESTED IN ACCORDANCE WITH TS DUE TO INADEQUATE PROCEDURES |
| 88-009 | 02/02/88 | 03/03/88 | UNPLANNED STANDBY GAS TREATMENT TRAIN ACTUATIONS DUE TO INADVERTENT RELAY OPERATIONS |
| 88-010 | 01/22/88 | 03/04/88 | INADEQUATE PROCEDURES CAUSE TWO CASES OF MISSED SAMPLES THAT WERE REQUIRED TO COMPENSATE FOR INOP EFFLUENT RADIATION MONITOR |
| 88-011 | 03/04/88 | 04/01/88 | ENGINEERED SAFETY FEATURE ACTUATION DUE TO PERSONNEL ERROR DURING RETURNING SYSTEM TO SERVICE |
| 88-012 | 03/03/88 | 04/01/88 | BATTERY FAILURE CONCURRENT WITH LOP/LOCA PREVENTS AUTOMATIC START OF RESIDUAL HEAT REMOVAL PUMP |

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-260 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. D. CRAWFORD (205) 729-2507

4. Licensed Thermal Power (MWT): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------------|----------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>114,721.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>.0</u> | <u>55,859.6</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>14,200.4</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>.0</u> | <u>54,338.5</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>0</u> | <u>0</u> | <u>153,245,167</u> |
| 18. Gross Elec Ener (MWH) | <u>0</u> | <u>0</u> | <u>50,771,798</u> |
| 19. Net Elec Ener (MWH) | <u>-1,783</u> | <u>-5,742</u> | <u>49,178,091</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>.0</u> | <u>47.4</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>.0</u> | <u>47.4</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>.0</u> | <u>40.3</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>.0</u> | <u>40.3</u> |
| 24. Unit Forced Outage Rate | <u>100.0</u> | <u>100.0</u> | <u>41.7</u> |
| 25. Forced Outage Hours | <u>744.0</u> | <u>2,184.0</u> | <u>38,937.4</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* BROWNS FERRY 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* BROWNS FERRY 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|------------------|---|
|-----|------|------|-------|--------|--------|------------|------------------|---|

| | | | | | | | | |
|-----|----------|---|-------|---|---|--|--|--|
| 305 | 09/15/84 | F | 744.0 | F | 4 | | | ADMINISTRATIVE HOLD TO RESOLVE VARIOUS TVA AND NRC CONCERNS. |
|-----|----------|---|-------|---|---|--|--|--|

* SUMMARY *

BROWNS FERRY 2 REMAINED ON ADMINISTRATIVE HOLD IN MARCH IN ORDER TO RESOLVE VARIOUS TVA AND NRC CONCERNS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* BROWNS FERRY 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA

COUNTY.....LIMESTONE

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI NW OF
DECATUR, ALA

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...JULY 20, 1974

DATE ELEC ENER 1ST GENER...AUGUST 28, 1974

DATE COMMERCIAL OPERATE...MARCH 1, 1975

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER...TENNESSEE RIVER

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY

CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II
CHATTANOOGA, TENNESSEE 37401

CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....J. PAULK

LICENSING PROJ MANAGER.....J. GEARS
DOCKET NUMBER.....50-260

LICENSE & DATE ISSUANCE...DPR-52, AUGUST 2, 1974

PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY
SOUTH AND FORREST
ATHENS, ALABAMA 35611

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION OCTOBER 5-18 (87-38): THIS ROUTINE INSPECTION WAS CONDUCTED IN THE AREAS OF ALLEGATIONS AND LICENSEE ACTION ON INSPECTOR IDENTIFIED ITEMS. THREE VIOLATIONS WERE IDENTIFIED INVOLVING DIVISION OF NUCLEAR ENGINEERING (DNE) TRAINING, INEFFECTIVE FOLLOWUP ON AUDIT FINDINGS AND IMPROPER CORRECTIONS TO QUALITY ASSURANCE (QA) RECORDS.

INSPECTION JANUARY 1-31 (88-02): THIS ROUTINE INSPECTION WAS IN THE AREAS OF: OPEN INSPECTION ITEM FOLLOWUP; OPERATIONAL SAFETY; MAINTENANCE OBSERVATION, RESTART TEST PROGRAM; MAINTENANCE IMPROVEMENT; MANAGEMENT MEETINGS, COVERING NUCLEAR SAFETY REVIEW BOARD, PIECE PARTS, AND JOINT TEST GROUP ACTIVITIES; SURVEILLANCE INSTRUCTION (SI) UPGRADE PROGRAM REVIEW (TEAM INSPECTION); AND ENGINEERING CHANGES AND MODIFICATIONS. ONE VIOLATION OF 10 CFR 50, APPENDIX B, CRITERION V WAS IDENTIFIED IN THE ENGINEERING CHANGES AND MODIFICATIONS AREA.

INSPECTION FEBRUARY 1-29 (88-04): THIS ROUTINE INSPECTION WAS IN THE AREAS OF OPERATIONAL SAFETY, MAINTENANCE OBSERVATION, SURVEILLANCE TESTING OBSERVATION, REPORTABLE OCCURRENCES, PREVIOUS ENFORCEMENT ACTION, RESTART TEST PROGRAM, EMPLOYEE CONCERNS, DESIGN CONTROLS AND QUALITY SURVEILLANCE REPORT REVIEWS. TWO VIOLATIONS WERE IDENTIFIED: TWO EXAMPLES OF INADEQUATE PROCEDURES OR FAILURE TO FOLLOW PROCEDURES FOR QA RECORDS PREPARATION AND WORKPLAN CONTROL, FAILURE TO CORRECTLY TRANSLATE THE DESIGN BASIS INTO SPECIFICATIONS AND DRAWINGS.

ENFORCEMENT SUMMARY

FAILURE TO MAINTAIN AND FOLLOW CONTROL AND ACCOUNTABILITY FOR NON FUEL SNM. FAILURE TO UPDATE INTERNAL RECORDS IN A TIMELY MANNER.

(8702 4)

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION II, CRITERION V, CRITERION XVII, QA TOPICAL REPORT TABLE 17E-1, NUCLEAR QUALITY ASSURANCE MANUAL (NQAM), PART 1, SECTION 2.17, AND NUCLEAR ENGINEERING PROCEDURE 1.2, REV. 1, AS OF OCTOBER 1987, DNE TRAINING AND DOCUMENTATION FAILED TO MEET THE FOLLOWING REQUIREMENTS OF NEP-1.2: (1) THE ASSISTANT CHIEF MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 30 OF 40 REQUIRED TRAINING SUBJECTS. A LEAD MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 35 OF 40 REQUIRED TRAINING SUBJECTS. (2) WATTS BAR SITE-SPECIFIED TRAINING REQUIREMENTS WERE LESS THAN THE TRAINING PROGRAM SPECIFIED BY NEP-1.2. A TYPICAL EXAMPLE CONCERNS A WATTS BAR ASSISTANT PROJECT ENGINEER (APE), WHOSE SITE-SPECIFIED TRAINING REQUIREMENTS DID NOT INCLUDE SEVEN AREAS REQUIRED BY NEP-1.2. (3) THE LICENSEE WAS UNABLE TO CONFIRM THAT REQUIREMENTS OF THE TRAINING MATRIX HAD BEEN ACCOMPLISHED FOR FIVE MECHANICAL ENGINEERING BRANCH (MEB) PERSONNEL AND TWO WATTS BAR APES. SINCE AN ADDITIONAL OPPORTUNITY TO CONFIRM THE ABOVE TRAINING WAS AFFORDED SUBSEQUENT TO THE EXIT INTERVIEW AND THE TRAINING WAS NOT CONFIRMED, THE NRC CONCLUDES THAT THE TRAINING WAS NOT CONDUCTED.

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION XVIII, CRITERION XVI, AND NQAM, PART 1, SECTION 2.18, REV. 0, 10 AUDITS FROM 1985 TO JANUARY 1987 IDENTIFIED TRAINING DEFICIENCIES WHICH, AT THE TIME OF THE INSPECTION, HAD NOT BEEN CORRECTED.

(8703 4)

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION V, AND NEP 1.3, REV. 0, CORRECTIONS WERE MADE TO NUMEROUS DOCUMENTS IN A MANNER NOT IN CONFORMANCE WITH THE ONE LINE, INITIAL, AND DATE METHOD.

(8703 5)

CONTRARY TO TECHNICAL SPECIFICATION (TS) 4.7.B.2.A, THE TEST PERFORMED ON SGTS TRAIN B NOVEMBER 25, 1987, TO SATISFY THIS REQUIREMENT FOLLOWING A FIRE IN THE UNIT 2 DRYWELL DID NOT COMPLY WITH ANSI N510-1975 IN THE FOLLOWING EXAMPLES: (1) THE FREON GAS GENERATOR OUTPUT WAS NOT HELD TO PLUS OR MINUS 20% OF THE PRE-SET VALUE AS SPECIFIED IN STEP 12.4.3 OF ANSI N510-1975. (2) THE UPSTREAM CONCENTRATION OF FREON TRACER GAS WAS NOT LIMITED TO 20 PPM AS SPECIFIED IN STEP 12.4.3 OF ANSI N510-1975.

(8704 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

TVA APPOINTED MR. JOHN WALKER TO PLANT MANAGER POSITION.

PLANT STATUS:

SHUTDOWN ON SEPTEMBER 15, 1984 FOR REFUELING OUTAGE.

Report Period MAR 1988

INSPECTION STATUS - (CONTINUED)

XX
X BROHNS FERRY 2 X
XX

OTHER ITEMS

LAST IE SITE INSPECTION DATE: FEBRUARY 1-29, 1988 +
INSPECTION REPORT NO: 50-260/88-04 +

REPORTS FROM LICENSEE

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|---------|
| ----- | | | |

NONE.

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-296 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. D. CRAWFORD (205) 729-2507

4. Licensed Thermal Power (Mwt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------------|----------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>97,176.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>.0</u> | <u>45,306.8</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>5,149.4</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>.0</u> | <u>44,195.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>.0</u> | <u>.0</u> | <u>131,846,076</u> |
| 18. Gross Elec Ener (MWH) | <u>.0</u> | <u>.0</u> | <u>43,473,760</u> |
| 19. Net Elec Ener (MWH) | <u>-1,539</u> | <u>-8,767</u> | <u>42,033,301</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>.0</u> | <u>45.5</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>.0</u> | <u>45.5</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>.0</u> | <u>40.6</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>.0</u> | <u>40.6</u> |
| 24. Unit Forced Outage Rate | <u>100.0</u> | <u>100.0</u> | <u>42.7</u> |
| 25. Forced Outage Hours | <u>744.0</u> | <u>2,184.0</u> | <u>32,921.4</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* BROWNS FERRY 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 3



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* BROWNS FERRY 3 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|------------------|--|
| 157 | 03/03/85 | F | 744.0 | F | | | | ADMINISTRATIVE HOLD TO RESOLVE VARIOUS TVA AND NRC CONCERNS. |

* SUMMARY *

BROWNS FERRY 3 REMAINED ON ADMINISTRATIVE HOLD IN MARCH
IN ORDER TO RESOLVE VARIOUS TVA AND NRC CONCERNS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* BROWNS FERRY 3 *

FACILITY DATA

Report Period MAR 1983

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA
COUNTY.....LIMESTONE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI NW OF
DECATUR, ALA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...AUGUST 8, 1976
DATE ELEC ENER 1ST GENER...SEPTEMBER 12, 1976
DATE COMMERCIAL OPERATE...MARCH 1, 1977
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...TENNESSEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II
CHATTANOOGA, TENNESSEE 37401
CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. PAULK
LICENSING PROJ MANAGER.....J. GEARS
DOCKET NUMBER.....50-296
LICENSE & DATE ISSUANCE...DPR-68, AUGUST 18, 1976
PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY
SOUTH AND FORREST
ATHENS, ALABAMA 35611

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION OCTOBER 5-18 (87-38): THIS ROUTINE INSPECTION WAS CONDUCTED IN THE AREAS OF ALLEGATIONS AND LICENSEE ACTION ON INSPECTOR IDENTIFIED ITEMS. THREE VIOLATIONS WERE IDENTIFIED INVOLVING DIVISION OF NUCLEAR ENGINEERING (DNE) TRAINING, INEFFECTIVE FOLLOWUP ON AUDIT FINDINGS AND IMPROPER CORRECTIONS TO QUALITY ASSURANCE (QA) RECORDS.

INSPECTION JANUARY 1-31 (88-02): THIS ROUTINE INSPECTION WAS IN THE AREAS OF: OPEN INSPECTION ITEM FOLLOWUP; OPERATIONAL SAFETY; MAINTENANCE OBSERVATION, RESTART TEST PROGRAM; MAINTENANCE IMPROVEMENT; MANAGEMENT MEETINGS, COVERING NUCLEAR SAFETY REVIEW BOARD, PIECE PARTS, AND JOINT TEST GROUP ACTIVITIES; SURVEILLANCE INSTRUCTION (SI) UPGRADE PROGRAM REVIEW (TEAM INSPECTION); AND ENGINEERING CHANGES AND MODIFICATIONS. ONE VIOLATION OF 10 CFR 50, APPENDIX B, CRITERION V WAS IDENTIFIED IN THE ENGINEERING CHANGES AND MODIFICATIONS AREA.

INSPECTION FEBRUARY 1-29 (88-04): THIS ROUTINE INSPECTION WAS IN THE AREAS OF OPERATIONAL SAFETY, MAINTENANCE OBSERVATION, SURVEILLANCE TESTING OBSERVATION, REPORTABLE OCCURRENCES, PREVIOUS ENFORCEMENT ACTION, RESTART TEST PROGRAM, EMPLOYEE CONCERNS, DESIGN CONTROLS AND QUALITY SURVEILLANCE REPORT REVIEWS. TWO VIOLATIONS WERE IDENTIFIED: TWO EXAMPLES OF INADEQUATE PROCEDURES OR FAILURE TO FOLLOW PROCEDURES FOR QA RECORDS PREPARATION AND WORKPLAN CONTROL, FAILURE TO CORRECTLY TRANSLATE THE DESIGN BASIS INTO SPECIFICATIONS AND DRAWINGS.

ENFORCEMENT SUMMARY

FAILURE TO MAINTAIN AND FOLLOW CONTROL AND ACCOUNTABILITY FOR NON FUEL SNM. FAILURE TO UPDATE INTERNAL RECORDS IN A TIMELY MANNER.

(8702 4)

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION II, CRITERION V, CRITERION XVII, QA TOPICAL REPORT TABLE 17E-1, NUCLEAR QUALITY ASSURANCE MANUAL (NQAM), PART 1, SECTION 2.17, AND NUCLEAR ENGINEERING PROCEDURE 1.2, REV. 1, AS OF OCTOBER 1987, DNE TRAINING AND DOCUMENTATION FAILED TO MEET THE FOLLOWING REQUIREMENTS OF NEP-1.2: (1) THE ASSISTANT CHIEF MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 30 OF 40 REQUIRED TRAINING SUBJECTS. A LEAD MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 35 OF 40 REQUIRED TRAINING SUBJECTS. (2) WATTS BAR SITE-SPECIFIED TRAINING REQUIREMENTS WERE LESS THAN THE TRAINING PROGRAM SPECIFIED BY NEP-1.2. A TYPICAL EXAMPLE CONCERNS A WATTS BAR ASSISTANT PROJECT ENGINEER (APE), WHOSE SITE-SPECIFIED TRAINING REQUIREMENTS DID NOT INCLUDE SEVEN AREAS REQUIRED BY NEP-1.2. (3) THE LICENSEE WAS UNABLE TO CONFIRM THAT REQUIREMENTS OF THE TRAINING MATRIX HAD BEEN ACCOMPLISHED FOR FIVE MECHANICAL ENGINEERING BRANCH (MEB) PERSONNEL AND TWO WATTS BAR APES. SINCE AN ADDITIONAL OPPORTUNITY TO CONFIRM THE ABOVE TRAINING WAS AFFORDED SUBSEQUENT TO THE EXIT INTERVIEW AND THE TRAINING WAS NOT CONFIRMED, THE NRC CONCLUDES THAT THE TRAINING WAS NOT CONDUCTED.

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION XVIII, CRITERION XVI, AND NQAM, PART 1, SECTION 2.18, REV. 0, 10 AUDITS FROM 1985 TO JANUARY 1987 IDENTIFIED TRAINING DEFICIENCIES WHICH, AT THE TIME OF THE INSPECTION, HAD NOT BEEN CORRECTED.

(8703 4)

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION V, AND NEP 1.3, REV. 0, CORRECTIONS WERE MADE TO NUMEROUS DOCUMENTS IN A MANNER NOT IN CONFORMANCE WITH THE ONE LINE, INITIAL, AND DATE METHOD.

(8703 5)

CONTRARY TO TECHNICAL SPECIFICATION (TS) 4.7.B.2.A, THE TEST PERFORMED ON SGT'S TRAIN B NOVEMBER 25, 1987, TO SATISFY THIS REQUIREMENT FOLLOWING A FIRE IN THE UNIT 2 DRYWELL DID NOT COMPLY WITH ANSI N510-1975 IN THE FOLLOWING EXAMPLES: (1) THE FREON GAS GENERATOR OUTPUT WAS NOT HELD TO PLUS OR MINUS 20% OF THE PRE-SET VALUE AS SPECIFIED IN STEP 12.4.3 OF ANSI N510-1975. (2) THE UPSTREAM CONCENTRATION OF FREON TRACER GAS WAS NOT LIMITED TO 20 PPM AS SPECIFIED IN STEP 12.4.3 OF ANSI N510-1975.

(8704 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

LICENSEE EVALUATING CAUSE OF REACTOR VESSEL WATER LEVEL INDICATION PROBLEMS.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

TVA APPOINTED MR. JOHN WALKER TO PLANT MANAGER POSITION.

PLANT STATUS:

SHUTDOWN ON MARCH 9, 1985.

* BRONNS FERRY 3 *

Report Period MAR 1988 I N S P E C T I O N S T A T U S - (CONTINUED)

OTHER ITEMS

LAST IE SITE INSPECTION DATE: FEBRUARY 1-29, 1988 +
INSPECTION REPORT NO: 50-296/88-04 +

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

NONE.

THIS PAGE INTENTIONALLY LEFT BLANK


1. Docket: 50-325 O P E R A T I N G S T A T U S
2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: FRANCES HARRISON (919) 457-2756
4. Licensed Thermal Power (Mwt): 2436
5. Nameplate Rating (Gross MWe): 963 X 0.9 = 867
6. Design Electrical Rating (Net MWe): 821
7. Maximum Dependable Capacity (Gross MWe): 815
8. Maximum Dependable Capacity (Net MWe): 790
9. If Changes Occur Above Since Last Report, Give Reasons:
NONE
10. Power Level To Which Restricted, If Any (Net MWe): _____
11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|---|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>96,769.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>1,530.8</u> | <u>62,468.5</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>0</u> | <u>0</u> | <u>1,647.1</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>1,461.6</u> | <u>59,322.3</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,787,981</u> | <u>3,438,753</u> | <u>125,418,289</u> |
| 18. Gross Elec Ener (MWH) | <u>590,030</u> | <u>1,131,395</u> | <u>41,240,942</u> |
| 19. Net Elec Ener (MWH) | <u>574,312</u> | <u>1,093,871</u> | <u>39,673,003</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>66.9</u> | <u>61.3</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>66.9</u> | <u>61.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>97.7</u> | <u>63.4</u> | <u>51.9</u> |
| 23. Unit Cap Factor (DER Net) | <u>94.0</u> | <u>61.0</u> | <u>49.9</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>15.3</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>10,619.7</u> |
| 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>NONE</u> | | | |

27. If Currently Shutdown Estimated Startup Date: 1/A

* BRUNSWICK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
BRUNSWICK 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * BRUNSWICK 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 88015 | 03/25/88 | S | 0.0 | A | 5 | | | | REDUCED POWER TO REMOVE FEEDWATER HEATERS 4A AND 5A FROM SERVICE TO INVESTIGATE INSTRUMENT LEAK. PERFORM ROD IMPROVEMENT. |
| 88016 | 03/26/88 | S | 0.0 | A | 5 | | | | OPERATE AT REDUCED LOAD DUE TO FEEDWATER HEATERS 4A AND 5A BEING OUT OF SERVICE. |
| 88017 | 03/27/88 | S | 0.0 | B | 5 | | | | SET NEW ROD PATTERN--PREVIOUS PATTERN TOO COLD. |
| 88018 | 03/29/88 | S | 0.0 | A | 5 | | | | REDUCE POWER TO RETURN FEEDWATER HEATER 4A AND 5A TO SERVICE. |

 * SUMMARY *

 BRUNSWICK 1 INCURRED 4 POWER REDUCTIONS IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* BRUNSWICK 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA
COUNTY.....BRUNSWICK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...3 MI N OF
SOUTHPORT, NC
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...OCTOBER 8, 1976
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1976
DATE COMMERCIAL OPERATE...MARCH 18, 1977
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CAPE FEAR RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CAROLINA POWER & LIGHT
CORPORATE ADDRESS.....P. O. BOX 1551
RALEIGH, NORTH CAROLINA 27602
CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BROWN & ROOT
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. RULAND
LICENSING PROJ MANAGER.....E. SYLVESTER
DOCKET NUMBER.....50-325
LICENSE & DATE ISSUANCE...DPR-71, NOVEMBER 12, 1976
PUBLIC DOCUMENT ROOM.....RANDALL LIBRARY
UNIV OF N.C. AT WILMINGTON
601 S. COLLEGE ROAD
WILMINGTON, N. C. 28403

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JANUARY 1-31 (88-01): THIS ROUTINE SAFETY INSPECTION BY THE RESIDENT INSPECTOR INVOLVED THE AREAS OF FOLLOWUP ON PREVIOUS ENFORCEMENT MATTERS, MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, PREPARATION FOR REFUELING, FOLLOWUP ON INSPECTOR IDENTIFIED AND UNRESOLVED ITEMS, ONSITE FOLLOWUP OF EVENTS, INADVERTENT HEATUP OF UNIT 1, AND PLANT MODIFICATIONS. IN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED - FAILURE TO COMPLETE TECHNICAL SPECIFICATION SURVEILLANCE WITHIN THE REQUIRED TIME. A PERSONNEL ERROR WHICH ALLOWED AN INADVERTENT HEATUP OF THE REACTOR COOLANT SYSTEM AND A QUESTION CONCERNING THE SEISMIC CLASS OF THE RADIATION MONITORING SYSTEM REMAINED UNRESOLVED AT THE CONCLUSION OF THE INSPECTION.

INSPECTION JANUARY 11-31 - FEBRUARY 5 (88-02): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF INSERVICE INSPECTION (ISI) OF WELDS, PIPING AND COMPONENTS FOR INTEGRANULAR STRESS CORROSION CRACKING (IGSCC), WELD OVERLAY REPAIR WELDING, REVIEW OF MECHANICAL STRESS IMPROVEMENT PROCESS (MSIP) ACTIVITIES, AND INDEPENDENT INSPECTION ACTIVITIES. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

INSPECTION FEBRUARY 1-29 (88-05): THIS ROUTINE SAFETY INSPECTION BY THE RESIDENT INSPECTOR INVOLVED THE AREAS OF FOLLOWUP ON PREVIOUS ENFORCEMENT MATTERS, MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ONSITE LICENSEE EVENT REPORTS (LER) REVIEW, Q-LIST REVIEW CONCERNS, DIESEL GENERATOR AIR SYSTEM SEISMIC QUALIFICATION, SILICON BRONZE BUS BAR BOLTS, HYDROGEN LEAK/UNUSUAL EVENT, ESF SYSTEM WALKDOWN, INERTING LINE FAILURE, AND PLANT MODIFICATIONS. IN THE AREAS INSPECTED, NO PROGRAMMATIC WEAKNESSES, VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. TWO UNRESOLVED ITEMS WERE IDENTIFIED: SERVICE WATER SYSTEM OPERATING MODE CONCERNS, AND CONTAINMENT ATMOSPHERE DILUTION SYSTEM DISCREPANCIES.

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-324 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: FRANCES HARRISON (919) 457-2756

4. Licensed Thermal Power (Mwt): 2436

5. Nameplate Rating (Gross MWe): 963 X 0.9 = 867

6. Design Electrical Rating (Net MWe): 821

7. Maximum Dependable Capacity (Gross MWe): 815

8. Maximum Dependable Capacity (Net MWe): 790

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------------|----------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>108,793.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>24.3</u> | <u>67,097.3</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>24.3</u> | <u>63,270.8</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>0</u> | <u>37,715</u> | <u>126,625,194</u> |
| 18. Gross Elec Ener (MWH) | <u>0</u> | <u>11,910</u> | <u>41,753,442</u> |
| 19. Net Elec Ener (MWH) | <u>-4,898</u> | <u>-1,482</u> | <u>40,041,347</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>1.1</u> | <u>58.2</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>1.1</u> | <u>58.2</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>.0</u> | <u>46.6</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>.0</u> | <u>44.8</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.4</u> | <u>14.9</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.1</u> | <u>11,459.9</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 04/15/88

* BRUNSWICK 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BRUNSWICK 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* BRUNSWICK 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 88003 | 01/02/88 | S | 744.0 | C | 4 | | RC | FUELXX | REFUELING/MAINTENANCE OUTAGE. |

* SUMMARY *

BRUNSWICK 2 REMAINED SHUTDOWN IN MARCH FOR SCHEDULED
REFUELING OUTAGE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|--------------|-------------------------|
| F-Forced | A-Equip Failure | F-Admin | 1-Manual |
| S-Sched | B-Maint or Test | G-Oper Error | 2-Manual Scram |
| | C-Refueling | H-Other | 3-Auto Scram |
| | D-Regulatory Restriction | | 4-Continued |
| | E-Operator Training | | 5-Reduced Load |
| | & License Examination | | 9-Other |
| | | | Exhibit F & H |
| | | | Instructions for |
| | | | Preparation of |
| | | | Data Entry Sheet |
| | | | Licensee Event Report |
| | | | (LER) File (LUREG-0161) |

FACILITY DESCRIPTION

LOCATION
 STATE.....NORTH CAROLINA
 COUNTY.....BRUNSWICK
 DIST AND DIRECTION FROM
 NEAREST POPULATION CTR...3 MI N OF
 SOUTHPORT, NC
 TYPE OF REACTOR.....BWR
 DATE INITIAL CRITICALITY...MARCH 20, 1975
 DATE ELEC ENER 1ST GENER...APRIL 29, 1975
 DATE COMMERCIAL OPERATE...NOVEMBER 3, 1975
 CONDENSER COOLING METHOD...ONCE THRU
 CONDENSER COOLING WATER...CAPE FEAR RIVER
 ELECTRIC RELIABILITY
 COUNCIL.....SOUTHEASTERN ELECTRIC
 RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
 LICENSEE.....CAROLINA POWER & LIGHT
 CORPORATE ADDRESS.....411 FAYETTEVILLE STREET
 RALEIGH, NORTH CAROLINA 27602
 CONTRACTOR
 ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
 NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
 CONSTRUCTOR.....BROWN & ROOT
 TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
 IE RESIDENT INSPECTOR.....W. RULAND
 LICENSING PROJ MANAGER.....E. SYLVESTER
 DOCKET NUMBER.....50-324
 LICENSE & DATE ISSUANCE...DPR-62, DECEMBER 27, 1974
 PUBLIC DOCUMENT ROOM.....RANDALL LIBRARY
 UNIV OF N.C. AT WILMINGTON
 601 S. COLLEGE ROAD
 WILMINGTON, N. C. 28403

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

* INSPECTION JANUARY 1-31 (88-01): THIS ROUTINE SAFETY INSPECTION BY THE RESIDENT INSPECTOR INVOLVED THE AREAS OF FOLLOWUP ON PREVIOUS ENFORCEMENT MATTERS, MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, PREPARATION FOR REFUELING, FOLLOWUP ON INSPECTOR IDENTIFIED AND UNRESOLVED ITEMS, ONSITE FOLLOWUP OF EVENTS, INADVERTENT HEATUP OF UNIT 1, AND PLANT MODIFICATIONS. IN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED - FAILURE TO COMPLETE TECHNICAL SPECIFICATION SURVEILLANCE WITHIN THE REQUIRED TIME. A PERSONNEL ERROR WHICH ALLOWED AN INADVERTENT HEATUP OF THE REACTOR COOLANT SYSTEM AND A QUESTION CONCERNING THE SEISMIC CLASS OF THE RADIATION MONITORING SYSTEM REMAINED UNRESOLVED AT THE CONCLUSION OF THE INSPECTION.

INSPECTION JANUARY 11-31 - FEBRUARY 5 (88-02): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF INSERVICE INSPECTION (ISI) OF WELDS, PIPING AND COMPONENTS FOR INTEGRANULAR STRESS CORROSION CRACKING (IGSCC), WELD OVERLAY REPAIR WELDING, REVIEW OF MECHANICAL STRESS IMPROVEMENT PROCESS (MSIP) ACTIVITIES, AND INDEPENDENT INSPECTION ACTIVITIES. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

INSPECTION FEBRUARY 1-29 (88-05): THIS ROUTINE SAFETY INSPECTION BY THE RESIDENT INSPECTOR INVOLVED THE AREAS OF FOLLOWUP ON PREVIOUS ENFORCEMENT MATTERS, MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ONSITE LICENSEE EVENT REPORTS (LER) REVIEW, Q-LIST REVIEW CONCERNS, DIESEL GENERATOR AIR SYSTEM SEISMIC QUALIFICATION, SILICON BRONZE BUS BAR BOLTS, HYDROGEN LEAK/UNUSUAL EVENT, ESF SYSTEM WALKDOWN, INERTING LINE FAILURE, AND PLANT MODIFICATIONS. IN THE AREAS INSPECTED, NO PROGRAMMATIC WEAKNESSES, VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. TWO UNRESOLVED ITEMS WERE IDENTIFIED: SERVICE WATER SYSTEM OPERATING MODE CONCERNS, AND CONTAINMENT ATMOSPHERE DILUTION SYSTEM DISCREPANCIES.

INSPECTION SUMMARY

INSPECTION JANUARY 25-29 (88-06): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREA OF INSEERVICE TESTING OF PUMPS AND VALVES. ONE VIOLATION WAS IDENTIFIED INVOLVING DEFICIENCIES IN VALVE TESTING PROCEDURES AND FAILURES TO FOLLOW THE PROCEDURES.

INSPECTION FEBRUARY 8 (88-08): THIS ROUTINE, UNANNOUNCED PHYSICAL SECURITY INSPECTION INCLUDED A REVIEW AND INSPECTION OF: SECURITY PLAN AND IMPLEMENTING PROCEDURES; MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM; SECURITY ORGANIZATION; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AREA; PHYSICAL BARRIERS - VITAL AREAS; COMPENSATORY MEASURES; ACCESS CONTROL - PERSONNEL; ACCESS CONTROL - PACKAGES; ACCESS CONTROL - VEHICLES; COMMUNICATIONS; AND SAFEGUARDS CONTINGENCY PLAN IMPLEMENTATION REVIEW. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS IN THE 12 AREAS INSPECTED.

INSPECTION FEBRUARY 8-12 (88-09): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF AUDITS AND APPRAISALS, OUTAGE PLANNING AND PREPARATION; TRAINING AND QUALIFICATION OF NEW PERSONNEL; EXTERNAL EXPOSURE CONTROL; INTERNAL EXPOSURE CONTROL; CONTROL OF RADIOACTIVE MATERIAL, CONTAMINATION, SURVEYS AND MONITORING; MAINTAINING EXPOSURES AS LOW AS REASONABLY ACHIEVABLE (ALARA); AND INFORMATION NOTICES FOLLOWUP. TWO VIOLATIONS WERE IDENTIFIED - FAILURE TO MAINTAIN ACCESS TO A HIGH RADIATION AREA LOCKED; AND FAILURE TO FOLLOW PROCEDURES OR TO HAVE ADEQUATE PROCEDURES.

INSPECTION FEBRUARY 22-25 (88-12): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF FIRE PROTECTION/PREVENTION, REVIEW OF THE STATUS OF APPENDIX R FIRE PROTECTION MODIFICATIONS, AND PREVIOUSLY IDENTIFIED INSPECTION ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TS 4.0.5.A.2 AND 6.8.1, ASME SECTION XI, REQUIREMENTS FOR STROKE TIMING POWER OPERATED VALVES WERE NOT PROPERLY IMPLEMENTED. CONTRARY TO TS 6.12.2, ON NOVEMBER 12, 1987, AN AUXILIARY EQUIPMENT OPERATOR (AEO) WHILE PERFORMING DAILY ROUNDS OF PLANT SYSTEMS UNLOCKED THE ENTRANCE TO THE UNIT 2, 80 FOOT EAST FUEL POOL HEAT EXCHANGER ROOM, A HIGH RADIATION AREA, AND LEFT THE AREA UNATTENDED. CONTRARY TO TS 6.11.1, TS 6.8.1, RG 1.33, APPENDIX A, SECTION I.3, PLANT PROCEDURE ENP-46, RADIATION CONTROL AND PROTECTION PROCEDURE, VOLUME VIII, SECTION 6.6.2 AND SECTION 6.6.3, THE LICENSEE FAILED TO ESTABLISH ADEQUATE RADIATION PROTECTION PROCEDURES CONCERNING HANDLING OF IRRADIATED DRY TUBES AND USING PERSONNEL MONITORING DEVICES, AND TO ADHERE TO A RADIATION CONTROL PROCEDURE.
(8800 4)

CONTRARY TS 3.8.1.1.B, REQUIREMENTS WERE NOT MET IN THAT, WITH TWO DIESEL GENERATORS INOPERABLE ON JANUARY 5, 1988, AT 3:52 P.M., THE REMAINING OPERABLE DIESEL GENERATORS WERE NOT OPERATED AT LEAST AT 1750 KW FOR 15 MINUTES WITHIN 2 HOURS. DIESEL GENERATOR NO. 4 COMPLETED ITS 15 MINUTE RUN AT 6:00 P.M., ON JANUARY 5, 1988.
(8800 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

OTHER ITEMS

NONE.

PLANT STATUS:

+ REFUELING OUTAGE RESTART IN LATE APRIL, 1988.

LAST IE SITE INSPECTION DATE: FEBURARY 22-25, 1988 +

INSPECTION REPORT NO: 50-324/88-12 +

R E P O R T S F R O M L I C E N S E E

```

=====

```

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---|
| 88-003 | 02/07/88 | 03/07/88 | AUTO-ISOLATION OF RX WATER CLEANUP SYSTEM INLET OUTBOARD ISOLATION VALVE WITH REACTOR DEFUELED |
| 88-004 | 02/24/88 | 03/24/88 | UNPLANNED AUTO STARTING OF SGT SYSTEM TRAINS AND AUTO ISOLATION OF REACTOR BLDG VENTILATION DURING SURV TESTING |
| 88-005 | 02/04/88 | 03/04/88 | SAFETY RELIEF VALVES SETPOINTS EXCEEDED DURING TESTING AT WYLE LABORATORIES |

```

=====

```

THIS PAGE INTENTIONALLY LEFT BLANK

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* BYRON 1 *

No. Date Type Hours Reason Method LER # Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

BYRON 1 OPERATED ROUTINELY IN MARCH WITH NO POWER OUTAGES OR
SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* BYRON 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....OGLE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI SW OF
ROCKFORD, ILL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...FEBRUARY 2, 1985
DATE ELEC ENER 1ST GENER...MARCH 1, 1985
DATE COMMERCIAL OPERATE...SEPTEMBER 16, 1985
CONDENSER COOLING METHOD...CC HNDCT
CONDENSER COOLING WATER...ROCK RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. HINDS
LICENSING PROJ MANAGER.....L. OLSHAN
DOCKET NUMBER.....50-454
LICENSE & DATE ISSUANCE...NPF-37, FEBRUARY 14, 1985
PUBLIC DOCUMENT ROOM.....LIBRARIAN
BUSINESS SCIENCE & TECHNOLOGY DEPT.
ROCKFORD PUBLIC LIBRARY
215 NORTH WYMAN STREET
ROCKFORD, ILLINOIS 61101

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JANUARY 11 THROUGH FEBRUARY 17, 1988 (88003). SPECIAL, ANNOUNCED SAFETY INSPECTION OF THE ENVIRONMENTAL QUALIFICATION (EQ) OF ELECTRIC EQUIPMENT WITHIN THE SCOPE OF 10 CFR 50.49. THE INSPECTION INCLUDED LICENSEE ACTION ON PREVIOUSLY IDENTIFIED FINDINGS; SER/TER COMMITMENTS; EQ PROGRAM COMPLIANCE TO 10 CFR 50.49; ADEQUACY OF EQ DOCUMENTATION; AND A PLANT PHYSICAL INSPECTION OF EQ EQUIPMENT (MODULES NO. 30703, NO. 25576, AND NO. 92701). 10 CFR 50.49, PARAGRAPHS (F) AND (G), REQUIRES EQUIPMENT IMPORTANT TO SAFETY TO BE QUALIFIED BY TESTING AND ANALYSIS PRIOR TO THE EQ DEADLINE OF NOVEMBER 30, 1985. ONE VIOLATION WAS SITED.

INSPECTION BETWEEN JANUARY 28 AND FEBRUARY 18, 1988 (88004; 88005). INCLUDED A REVIEW OF PROTECTED AREA BARRIER; PROTECTED AREA DETECTION AIDS; ASSESSMENT AIDS; LIGHTING; RECORD AND REPORTS; AND ALARM STATIONS. THE LICENSEE'S PROGRESS IN RESOLVING REGULATORY EFFECTIVENESS REVIEW INSPECTION FINDINGS WAS REVIEWED. THE LICENSEE'S INVESTIGATION OF AN EVENT INVOLVING INADEQUATE FIREWATCH TOURS AND POTENTIALLY FALSIFIED RECORDS WAS ALSO REVIEWED. AN OPEN ITEM PERTAINING TO SPECIAL NUCLEAR MATERIAL (SNM) DOCUMENTATION WAS REVIEWED IN THE NRC REGION III OFFICE. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREA EXAMINED EXCEPT AS NOTED BELOW:

DETECTION AIDS - PROTECTED AREA: SEVERAL ZONES OF AN INTRUSION DETECTION SYSTEM DID NOT DETECT PENETRATION ATTEMPTS AS REQUIRED BY THE SECURITY PLAN (SECTION 8 OF THE REPORT DETAILS). AN OPEN ITEM PERTAINING TO SNM DOCUMENTATION WAS CLOSED. AN UNRESOLVED ITEM WAS IDENTIFIED PERTAINING TO INADEQUATE CORPORATE GUIDANCE FOR REPORTING SECURITY EVENTS. AN OPEN ITEM PERTAINING TO THE

1. Docket: 50-455 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + In-line Hrs: 744.0

3. Utility Contact: D. J. SPITZER (815)234-5441 X2023

4. Licensed Thermal Power (Mwt): 3411

5. Nameplate Rating (Gross MWe): 1175

6. Design Electrical Rating (Net MWe): 1120

7. Maximum Dependable Capacity (Gross MWe): 1120

8. Maximum Dependable Capacity (Net MWe): 1120

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): 1055

11. Reasons for Restrictions, If Any:

STEAM GENERATOR SPLIT FLOW

| | MONth | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>5,377.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,169.6</u> | <u>4,496.8</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>626.1</u> | <u>1,971.2</u> | <u>4,251.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,875,876</u> | <u>5,445,146</u> | <u>11,917,309</u> |
| 18. Gross Elec Ener (MWH) | <u>613,398</u> | <u>1,796,428</u> | <u>3,900,739</u> |
| 19. Net Elec Ener (MWH) | <u>577,226</u> | <u>1,687,212</u> | <u>3,658,113</u> |
| 20. Unit Service Factor | <u>84.2</u> | <u>90.3</u> | <u>79.1</u> |
| 21. Unit Avail Factor | <u>84.2</u> | <u>90.3</u> | <u>79.1</u> |
| 22. Unit Cap Factor (MDC Net) | <u>69.3</u> | <u>69.0</u> | <u>60.7</u> |
| 23. Unit Cap Factor (DER Net) | <u>69.3</u> | <u>69.0</u> | <u>60.7</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>1.3</u> | <u>6.9</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>25.2</u> | <u>313.2</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * BYRON 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BYRON 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * BYRON 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 5 | 02/27/88 | S | 52.8 | A | 4 | | EH | | TOOK UNIT 2 TURBINE OFF LINE TO REPAIR EH SYSTEM LOW PRESSURE. |
| 6 | 03/26/88 | S | 65.1 | A | 1 | | EH | | TOOK UNIT 2 TURBINE OFF LINE TO REPAIR CHECK VALVE LEAKING ON #2 GV DUMP HEADER. |

 * SUMMARY *

 BYRON 2 ENTERED MONTH SHUTDOWN. SUBSEQUENTLY, RETURNED TO POWER. INCURRED 1 OUTAGE FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* BYRON 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....OGLE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI SW OF
ROCKFORD, ILL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JANUARY 9, 1987
DATE ELEC ENER 1ST GENER...FEBRUARY 6, 1987
DATE COMMERCIAL OPERATE...AUGUST 21, 1987
CONDENSER COOLING METHOD...CCHNDCT
CONDENSER COOLING WATER...ROCK RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. HINDS
LICENSING PROJ MANAGER....L. OLSHAN
DOCKET NUMBER.....50-455
LICENSE & DATE ISSUANCE...NPF-66, JANUARY 30, 1987
PUBLIC DOCUMENT ROOM.....LIBRARIAN
BUSINESS SCIENCE & TECHNOLOGY DEPT.
ROCKFORD PUBLIC LIBRARY
215 NORTH WYMAN STREET
ROCKFORD, ILLINOIS 61101

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JANUARY 11 THROUGH FEBRUARY 17, 1988 (88003). SPECIAL, ANNOUNCED SAFETY INSPECTION OF THE ENVIRONMENTAL QUALIFICATION (EQ) OF ELECTRIC EQUIPMENT WITHIN THE SCOPE OF 10 CFR 50.49. THE INSPECTION INCLUDED LICENSEE ACTION ON PREVIOUSLY IDENTIFIED FINDINGS; SERVICE COMMITMENTS; EQ PROGRAM COMPLIANCE TO 10 CFR 50.49; ADEQUACY OF EQ DOCUMENTATION; AND A PLANT PHYSICAL INSPECTION OF EQ EQUIPMENT (MODULES NO. 30703, NO. 25576, AND NO. 92701). 10 CFR 50.49, PARAGRAPHS (F) AND (G), REQUIRES EQUIPMENT IMPORTANT TO SAFETY TO BE QUALIFIED BY TESTING AND ANALYSIS PRIOR TO THE EQ DEADLINE OF NOVEMBER 30, 1985. ONE VIOLATION WAS SITED.

INSPECTION BETWEEN JANUARY 28 AND FEBRUARY 18, 1988 (88004; 88005). INCLUDED A REVIEW OF PROTECTED AREA BARRIER; PROTECTED AREA DETECTION AIDS; ASSESSMENT AIDS; LIGHTING; RECORD AND REPORTS; AND ALARM STATIONS. THE LICENSEE'S PROGRESS IN RESOLVING REGULATORY EFFECTIVENESS REVIEW INSPECTION FINDINGS WAS REVIEWED. THE LICENSEE'S INVESTIGATION OF AN EVENT INVOLVING INADEQUATE FIREWATCH TOURS AND POTENTIALLY FALSIFIED RECORDS WAS ALSO REVIEWED. AN OPEN ITEM PERTAINING TO SPECIAL NUCLEAR MATERIAL (SNM) DOCUMENTATION WAS REVIEWED IN THE NRC REGION III OFFICE. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREA EXAMINED EXCEPT AS NOTED BELOW:

DETECTION AIDS - PROTECTED AREA: SEVERAL ZONES OF AN INTRUSION DETECTION SYSTEM DID NOT DETECT PENETRATION ATTEMPTS AS REQUIRED BY THE SECURITY PLAN (SECTION 8 OF THE REPORT DETAILS). AN OPEN ITEM PERTAINING TO SNM DOCUMENTATION WAS CLOSED. AN UNRESOLVED ITEM WAS IDENTIFIED PERTAINING TO INADEQUATE CORPORATE GUIDANCE FOR REPORTING SECURITY EVENTS. AN OPEN ITEM PERTAINING TO THE

1. Docket: 50-483 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: MARY DALY (314) 676-8460

4. Licensed Thermal Power (Mwt): 3565

5. Nameplate Rating (Gross MWe): 1373 X .9 = 1236

6. Design Electrical Rating (Net MWe): 1171

7. Maximum Dependable Capacity (Gross MWe): 1174

8. Maximum Dependable Capacity (Net MWe): 1120

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>28,766.5</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,077.7</u> | <u>24,075.5</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,047.6</u> | <u>23,503.4</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,534,237</u> | <u>6,879,631</u> | <u>75,169,411</u> |
| 18. Gross Elec Ener (MWH) | <u>864,568</u> | <u>2,347,368</u> | <u>25,389,088</u> |
| 19. Net Elec Ener (MWH) | <u>824,482</u> | <u>2,236,720</u> | <u>24,126,396</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>93.8</u> | <u>81.7</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>93.8</u> | <u>81.7</u> |
| 22. Unit Cap Factor (MDC Net) | <u>98.9</u> | <u>91.4</u> | <u>74.9</u> |
| 23. Unit Cap Factor (DER Net) | <u>94.6</u> | <u>87.5</u> | <u>71.6</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>6.2</u> | <u>4.2</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>136.4</u> | <u>1,039.9</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 X CALLAWAY 1 X

 AVERAGE DAILY POWER LEVEL (MWe) PLOT

CALLAWAY 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* CALLAWAY 1 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

CALLAWAY 1 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES OR
SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* CALLAWAY 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....MISSOURI
COUNTY.....CALLAWAY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI SE OF
FULTON, MO
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 2, 1984
DATE ELEC ENER 1ST GENER...OCTOBER 24, 1984
DATE COMMERCIAL OPERATE...DECEMBER 19, 1984
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...MISSOURI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....UNION ELECTRIC
CORPORATE ADDRESS.....P.O. BOX 149
ST LOUIS, MISSOURI 63166
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NWC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DANIEL INTERNATIONAL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....B. LITTLE
LICENSING PROJ MANAGER....T. ALEXION
DOCKET NUMBER.....50-483
LICENSE & DATE ISSUANCE...NPF-30, OCTOBER 18, 1984
PUBLIC DOCUMENT ROOM.....WASHINGTON UNIVERSITY
JOHN M. OLIN LIBRARY
SKINKER & LINDELL BLVD.
ST. LOUIS, MO. 63130

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON FEBRUARY 18 - MARCH 3, 1988 (88005). INCLUDED A REVIEW OF MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM; RECORDS AND REPORTS; PROTECTED AREA BARRIERS AND ALARMS; LIGHTING; ASSESSMENT AIDS; ALARM STATIONS; PROTECTION OF SAFEGUARDS INFORMATION; AND FOLLOWUP ON PREVIOUS INSPECTION FINDINGS. PROPOSED MODIFICATIONS TO A PORTION OF THE PROTECTED AREA BOUNDARY WERE ALSO REVIEWED. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THE INSPECTION. SENIOR MANAGEMENT SUPPORT IS NEEDED TO CORRECT TWO ADVERSE TRENDS NOTED DURING THE INSPECTION. THESE TRENDS PERTAINED TO VITAL AREA DOOR CLOSURE PROBLEMS AND VEHICLE KEY CONTROL WITHIN THE PROTECTED AREA. CORRECTIVE ACTIONS FOR FIVE FINDINGS IDENTIFIED IN INSPECTION REPORT NO. 50-483/87027(DRSS) WERE REVIEWED, AND THE INSPECTION FINDINGS WERE CLOSED. A CONCERN PERTAINING TO STRENGTHENING ALARM STATION OPERATIONS WAS NOTED. SUBMITTAL OF A FORMAL PROPOSAL PERTAINING TO THE SITE PROTECTED AREA BOUNDARY MODIFICATION WAS RECOMMENDED. (DETAILS - UNCLASSIFIED SAFEGUARDS INFORMATION)

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

1. Docket: 50-317 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: C. BEHNKE (301) 260-4871

4. Licensed Thermal Power (MWT): 2700

5. Nameplate Rating (Gross MWe): 1020 X 0.9 = 918

6. Design Electrical Rating (Net MWe): 845

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 825

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>113,077.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>88,571.2</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>2,299.2</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,158.4</u> | <u>89,611.3</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,933,567</u> | <u>5,628,600</u> | <u>217,703,318</u> |
| 18. Gross Elec Ener (MWH) | <u>649,141</u> | <u>1,892,567</u> | <u>72,108,168</u> |
| 19. Net Elec Ener (MWH) | <u>623,869</u> | <u>1,815,837</u> | <u>68,831,354</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>98.8</u> | <u>76.6</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>98.8</u> | <u>76.6</u> |
| 22. Unit Cap Factor (MDC Net) | <u>101.6</u> | <u>100.8</u> | <u>73.8*</u> |
| 23. Unit Cap Factor (DER Net) | <u>99.2</u> | <u>98.4</u> | <u>72.0</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>1.2</u> | <u>9.1</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>25.6</u> | <u>8,607.8</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
APRIL 8, 1988, - REFUELING - 48 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

* CALVERT CLIFFS 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
CALVERT CLIFFS 1



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* CALVERT CLIFFS 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|------------------|---|
|-----|------|------|-------|--------|--------|------------|------------------|---|

NONE

* SUMMARY *

CALVERT CLIFFS 1 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES OR SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* CALVERT CLIFFS 1 *

F A C I L I T Y D A T A

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....MARYLAND
COUNTY.....CALVERT
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI S OF
ANNAPOLIS, MD
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 7, 1974
DATE ELEC ENER 1ST GENER...DECEMBER 30, 1974
DATE COMMERCIAL OPERATE...MAY 8, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CHESAPEAKE BAY
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
ARE' COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....BALTIMORE GAS & ELEC
CORPORATE ADDRESS.....P.O. BOX 1475
BALTIMORE, MARYLAND 21203
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. FOLEY
LICENSING PROJ MANAGER.....S. MCNEIL
DOCKET NUMBER.....50-317
LICENSE & DATE ISSUANCE...DPR-53, JULY 31, 1974
PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY
FOURTH STREET
PRINCE FREDERICK, MARYLAND 20678

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

NO INPUT PROVIDED.

=====

1. Docket: 50-318 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: C. BEHNKE (301) 260-4871

4. Licensed Thermal Power (Mht): 2700

5. Nameplate Rating (Gross MWe): 1012 X 0.9 = 911

6. Design Electrical Rating (Net MWe): 845

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 825

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|--------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>96,432.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>1,357.7</u> | <u>79,200.7</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>1,296.8</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>1,352.9</u> | <u>78,033.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>.0</u> | <u>3,556,246</u> | <u>196,896,909</u> |
| 18. Gross Elec Ener (MWH) | <u>.0</u> | <u>1,210,673</u> | <u>65,098,809</u> |
| 19. Net Elec Ener (MWH) | <u>.0</u> | <u>1,161,178</u> | <u>62,150,075</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>61.9</u> | <u>80.9</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>61.9</u> | <u>80.9</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>64.4</u> | <u>78.1</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>62.9</u> | <u>76.3</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>1.2</u> | <u>5.5</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>15.8</u> | <u>4,588.3</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 04/01/88

* CALVERT CLIFFS 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CALVERT CLIFFS 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* CALVERT CLIFFS 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|------------------|--|
| 88-05 | 02/27/88 | S | 744.0 | B | 4 | | | CONTINUED SHUTDOWN FOR PRE-SUMMER GENERAL MAINTENANCE MINI-OUTAGE. |

* SUMMARY *

CALVERT CLIFFS 2 REMAINED SHUTDOWN IN MARCH FOR PRE-SUMMER GENERAL MAINTENANCE MINI-OUTAGE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* CALVERT CLIFFS 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....MARYLAND
COUNTY.....CALVERT
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI S OF
ANNAPOLIS, MD
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 30, 1976
DATE ELEC ENER 1ST GENER...DECEMBER 7, 1976
DATE COMMERCIAL OPERATE...APRIL 1, 1977
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CHESAPEAKE BAY
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....BALTIMORE GAS & ELEC
CORPORATE ADDRESS.....P.O. BOX 1475
BALTIMORE, MARYLAND 21203
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. FOLEY
LICENSING PROJ MANAGER.....S. MCNEIL
DOCKET NUMBER.....50-318
LICENSE & DATE ISSUANCE...DPR-69, NOVEMBER 30, 1976
PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY
FOURTH STREET
PRINCE FREDERICK, MARYLAND 20678

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period MAR 1988

I N S P E C T I O M S T A T U S - (CONTINUED)

* CALVERT CLIFFS 2 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------------------|------------------|-------------------|---------|
| NO INPUT PROVIDED. | | | |

=====

1. Docket: 50-413 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MHT): 3411

5. Nameplate Rating (Gross MWe): 1305

6. Design Electrical Rating (Net MWe): 1145

7. Maximum Dependable Capacity (Gross MWe): 1145

8. Maximum Dependable Capacity (Net MWe): 1129

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level to Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>29,169.0</u> |
| 13. Hours Reactor Critical | <u>667.1</u> | <u>1,897.8</u> | <u>17,011.8</u> |
| 14. Rx Reserve Shutdown Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>658.7</u> | <u>1,854.6</u> | <u>16,453.9</u> |
| 16. Unit Reserve Shutdown Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,127,096</u> | <u>5,879,324</u> | <u>51,934,188</u> |
| 18. Gross Elec Ener (MWH) | <u>758,660</u> | <u>2,402,270</u> | <u>18,176,192</u> |
| 19. Net Elec Ener (MWH) | <u>715,879</u> | <u>1,960,060</u> | <u>16,960,905</u> |
| 20. Unit Service Factor | <u>88.5</u> | <u>84.9</u> | <u>68.1</u> |
| 21. Unit Avail Factor | <u>88.5</u> | <u>84.9</u> | <u>68.1</u> |
| 22. Unit Cap Factor (MDC Net) | <u>85.2</u> | <u>79.5</u> | <u>62.2</u> |
| 23. Unit Cap Factor (DER Net) | <u>84.0</u> | <u>78.4</u> | <u>61.3</u> |
| 24. Unit Forced Outage Rate | <u>11.5</u> | <u>15.1</u> | <u>17.9</u> |
| 25. Forced Outage Hours | <u>85.3</u> | <u>328.9</u> | <u>3,588.0</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* CATAWBA 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CATAWBA 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * CATAWBA 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 22-P | 03/01/88 | F | 0.0 | A | 5 | | CB | XXXXXX | POWER REDUCTION DUE TO REACTOR COOLANT FLOW OUT OF SPEC. |
| 23-P | 03/09/88 | F | 0.0 | H | 5 | | CG | XXXXXX | POWER DECREASE DUE TO ACCIDENTAL BORON INJECTION. |
| 24-P | 03/10/88 | F | 0.0 | H | 5 | | WB | XXXXXX | POWER REDUCTION DUE TO LOSS OF ASSURED BACKUP COOLING WATER DUE TO ASIATIC CLAMS. |
| 7 | 03/10/88 | F | 85.5 | H | 1 | | WB | XXXXXX | UNIT SHUTDOWN DUE TO LOSS OF ASSURED BACKUP COOLING WATER DUE TO ASIATIC CLAMS. |
| 25-P | 03/14/88 | S | 0.0 | B | 5 | | IE | INSTRU | POWER INCREASE ON HOLD FOR NUCLEAR INSTRUMENTATION CALIBRATION. |
| 30-P | 03/27/88 | S | 0.0 | F | 5 | | ZZ | ZZZZZ | POWER REDUCTION PER DISPATCHER REQUEST. |

 * SUMMARY *

 CATAWBA 1 INCURRED 1 POWER OUTAGE AND SEVERAL POWER REDUCTIONS IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |
| | F-Admin | | |
| | G-Oper Error | | |
| | H-Other | | |

* CATAHBA 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....YORK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...6 MI NNW OF
ROCK HILL, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JANUARY 7, 1985
DATE ELEC ENER 1ST GENER...JANUARY 22, 1985
DATE COMMERCIAL OPERATE...JUNE 29, 1985
CONDENSER COOLING METHOD...MDCT
CONDENSER COOLING WATER...LAKE WYLIE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE POWER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....P. SKINNER
LICENSING PROJ MANAGER.....K. JABBOUR
DOCKET NUMBER.....50-413
LICENSE & DATE ISSUANCE...NPF-35, JANUARY 17, 1985
PUBLIC DOCUMENT ROOM.....YORK COUNTY LIBRARY
138 E. BLACK STREET
ROCK HILL, SOUTH CAROLINA 29730

INSPECTION STATUS

INSPECTION SUMMARY

* INSPECTION FEBRUARY 17-21 (88-03): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED THE OBSERVATION OF THE ANNUAL EMERGENCY RESPONSE EXERCISE. THIS FULL PARTICIPATION EXERCISE (WITH THE EXCEPTION OF MECKLENSBURG COUNTY AND THE STATE OF NORTH CAROLINA) WAS INITIATED AT 6:00 P.M. ON FEBRUARY 19, AS AN UNANNOUNCED EXERCISE. FOLLOWING THE STAFFING AND ACTIVATION OF LICENSEE, STATE, AND COUNTY EMERGENCY FACILITIES, THE EXERCISE WAS SUSPENDED UNTIL 9:00 A.M. ON THE NEXT DAY. THE EXERCISE THEN RESUMED AND WAS TERMINATED AT 2:40 P.M. FIVE EXERCISE WEAKNESS WERE IDENTIFIED INVOLVING THE FAILURE TO FULLY MEET EXERCISE OBJECTIVES IN THE AREAS OF EMERGENCY MANAGEMENT, ACCIDENT ASSESSMENT, PROTECTIVE ACTION RECOMMENDATIONS, AND THE MEDICAL DRILL. THEREFORE, THE LICENSEE COMMITTED TO AN EARLY DEMONSTRATION OF CORRECTIVE ACTIONS BY CONDUCTING A SITE ONLY MEDICAL DRILL; A PARTIAL CMC STAFF TABLE TOP EXERCISE USING THE FEBRUARY 20, 1988, SCENARIO AS THE TRAINING MEDIA; AND THE FULL MANNING AND PARTICIPATION OF THE CMC STAFF IN THE FORTHCOMING MCGUIRE EMERGENCY EXERCISE. ALTHOUGH CORRECTIVE ACTIONS ARE REQUIRED, THE EXERCISE WAS CONSIDERED SUCCESSFUL IN THAT THE LICENSEE DEVELOPED A PLAUSIBLE AND CHALLENGING SCENARIO THAT IDENTIFIED TRAINING WEAKNESSES. THE LICENSEE'S TIMELY AND AGGRESSIVE RESPONSE TO SECURING CORRECTIVE ACTIONS IS INDICATIVE OF MANAGEMENT SUPPORT TO AN EFFECTIVE PREPAREDNESS PROGRAM.

4 JANUARY 26 - FEBRUARY 25 (88-08): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE INSPECTING IN THE AREAS OF PLANT OPERATIONS; SURVEILLANCE OBSERVATION; MAINTENANCE OBSERVATION; REVIEW OF LICENSEE NONROUTINE EVENT REPORTS; PREVIOUSLY IDENTIFIED ITEMS; REFUELING ACTIVITIES AND MEETING WITH LOCAL OFFICIALS. OF THE SEVEN (7) AREAS INSPECTED, CURRENT VIOLATIONS WERE IDENTIFIED IN TWO AREAS. (FAILURE TO FOLLOW PROCEDURES RESULTING IN TWO INADVERTENT SAFETY RISKS AND INADEQUATE CORRECTIVE ACTION INVOLVING MOUNTING HARDWARE MODIFICATION FOR ROTORK ACTUATORS.

INSPECTION SUMMARY

INSPECTION FEBRUARY 2-4 (88-09): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF STEAM GENERATOR TUBE PROBLEMS (UNIT 2). ONE VIOLATION WAS IDENTIFIED - FAILURE TO ESTABLISH ADEQUATE MEASURES TO CONTROL ET TESTING OF STEAM GENERATOR TUBES.

INSPECTION FEBRUARY 8-12 (88-10): THIS ROUTINE, UNANNOUNCED PHYSICAL SECURITY INSPECTION EXAMINED THE AREAS OF: TESTING AND MAINTENANCE; LOCKS, KEYS, AND COMBINATIONS; PHYSICAL BARRIERS PROTECTED AREA; LIGHTING; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL AND PACKAGES; AND PERSONNEL TRAINING AND QUALIFICATION - GENERAL REQUIREMENTS. NO VIOLATIONS OF REGULATORY REQUIREMENTS WERE IDENTIFIED.

INSPECTION FEBRUARY 16-18 (88-11): THIS ROUTINE, UNANNOUNCED ENTAILED THE REVIEW OF PROCEDURES, RECORDS, AND OPERATIONS FOR THE CONTROL, AND ACCOUNTABILITY OF SPECIAL NUCLEAR MATERIAL. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

INSPECTION FEBRUARY 26 - MARCH 25 (88-13): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE INSPECTING IN THE AREAS OF REVIEW OF PLANT OPERATIONS; SURVEILLANCE OBSERVATION; MAINTENANCE OBSERVATION; REVIEW OF LICENSEE NONROUTINE EVENT REPORTS; FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS AND STARTUP ACTIVITIES (UNIT 2). OF THE SIX (6) AREAS INSPECTED, ONE APPARENT VIOLATION WAS IDENTIFIED IN ONE AREA. (FAILURE TO FOLLOW TECHNICAL SPECIFICATION ADMINISTRATIVE REQUIREMENTS FOR APPROVAL OF MODIFICATIONS.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NONE.

LAST IE SITE INSPECTION DATE: FEBRUARY 26 - MARCH 25, 1988 +

INSPECTION REPORT NO: 50-413/88-13 +

Report Period MAR 1988

REPORTS FROM LICENSEE

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
* CATAWBA 1 *
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|--|
| 88-005 | 01/20/88 | 02/19/88 | COLD LEG ACCUM DISCHARGE ISOLATION VALVE MOTOR OPER FOUND TO CONTAIN NON-ENVIR QUALIFIED TERMINAL BLOCKS; MANUFACTURE DEFICIENCY |
| 88-006 | 01/22/88 | 02/19/88 | UNPLANNED NUCLEAR SERVICE WATER SWAP TO THE STANDBY NUCLEAR SERVICE WATER POND DUE TO A MANAGEMENT DEFICIENCY |
| 88-007 | 01/23/88 | 02/22/88 | SAFETY INJECTION ACTUATED DURING UNIT HEAT-UP DUE TO A PERSONNEL ERROR |
| 88-008 | 01/25/88 | 02/24/88 | ONE TRAIN OF CONTROL ROOM AREA VENTILATION SYSTEM INOPERABLE DUE TO A PERSONNEL ERROR |
| 88-009 | 02/06/88 | 03/07/88 | FAILURE TO MAINTAIN ENVIRONMENTAL QUALIFICATIONS OF LIMITORQUE VALVE ACTUATORS DUE TO CONSTRUCTION AND MANAGEMENT DEFICIENCY |
| 88-010 | 02/11/88 | 03/11/88 | UNMONITORED RELEASE OF LIQUID RADWASTE DUE TO PERSONNEL ERROR |
| 88-011 | 01/26/88 | 03/11/88 | NUTS RECEIVED AND ISSUED AS ASME CATEGORY II WITHOUT PROPER DOCUMENTATION; MANUFACTURING DEFICIENCY AND A PERSONNEL ERROR |
| 88-013 | 02/29/88 | 03/31/88 | TECH SPEC VIOLATION BECAUSE BOTH TRAINS OF THE CONTAINMENT SPRAY SYSTEM BEING INOPERABLE DUE TO A MANAGEMENT DEFICIENCY |

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-414 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MHT): 3411

5. Nameplate Rating (Gross MWe): 1305

6. Design Electrical Rating (Net MWe): 1145

7. Maximum Dependable Capacity (Gross MWe): 1145

8. Maximum Dependable Capacity (Net MWe): 1129

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|----------------|----------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>14,185.0</u> |
| 13. Hours Reactor Critical | <u>377.7</u> | <u>377.7</u> | <u>8,983.4</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>315.0</u> | <u>315.0</u> | <u>8,659.8</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>840,085</u> | <u>840,085</u> | <u>26,567,578</u> |
| 18. Gross Elec Ener (MWH) | <u>291,287</u> | <u>291,287</u> | <u>9,368,315</u> |
| 19. Net Elec Ener (MWH) | <u>255,292</u> | <u>235,672</u> | <u>8,702,369</u> |
| 20. Unit Service Factor | <u>42.3</u> | <u>14.4</u> | <u>61.0</u> |
| 21. Unit Avail Factor | <u>42.3</u> | <u>14.4</u> | <u>61.0</u> |
| 22. Unit Cap Factor (MDC Net) | <u>36.4</u> | <u>9.6</u> | <u>54.3</u> |
| 23. Unit Cap Factor (DER Net) | <u>30.0</u> | <u>9.4</u> | <u>53.6</u> |
| 24. Unit Forced Outage Rate | <u>57.6</u> | <u>59.5</u> | <u>30.8</u> |
| 25. Forced Outage Hours | <u>427.5</u> | <u>463.5</u> | <u>3,857.5</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * CATAWBA 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CATAWBA 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * CATAWBA 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 4 | 02/28/88 | F | 197.2 | A | 4 | | HH | PUMPXX | OUTAGE OVERRUN DUE TO TURBINE DRIVEN AUXILIARY FEEDWATER PUMP PROBLEMS. |
| 5 | 03/09/88 | S | 1.5 | B | 2 | | HA | TURBIN | TURBINE OVERSPEED TRIP TEST. |
| 6 | 03/09/88 | F | 18.0 | A | 3 | | HH | VALVEX | TURBINE/REACTOR TRIP WHEN S/G '2B' FEEDWATER BYPASS CONTROL VALVE FAILED OPEN. |
| 7 | 03/10/88 | F | 212.3 | H | 9 | | WB | XXXXXX | START-UP DELAY DUE TO LOSS OF ASSURED BACKUP COOLING WATER DUE TO ASIATIC CLAMS. |
| 1-P | 03/19/88 | S | 0.0 | B | 5 | | IE | XXXXXX | POWER INCREASE ON HOLD FOR FLUX MAPPING. |
| 2-P | 03/20/88 | F | 0.0 | H | 5 | | IF | XXXXXX | POWER INCREASE DELAY DUE TO LOW REACTOR COOLANT SYSTEM AVERAGE TEMPERATURE. |
| 3-P | 03/20/88 | S | 0.0 | B | 5 | | IE | INSTRU | POWER INCREASE ON HOLD DUE TO NUCLEAR INSTRUMENTATION CALIBRATION. |
| 17-P | 03/31/88 | F | 0.0 | B | 5 | | HH | VALVEX | POWER DECREASE FOR REPAIR OF S/G '2C' FEEDWATER CONTROL VALVE. |

 * SUMMARY *

 CATAWBA 2 INCURRED 4 POWER OUTAGES AND NUMEROUS POWER REDUCTIONS IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|---|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | G-Oper Error | 3-Auto Scram | Preparation of |
| | C-Refueling | 4-Continued | Data Entry Sheet |
| | H-Other | 5-Reduced Load | Licensee Event Report |
| | D-Regulatory Restriction | 9-Other | (LER) File (NUREG-6161) |
| | E-Operator Training & license Examination | | |

* CATAHBA 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....YORK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...6 MI NNW OF
ROCK HILL, SC
TYPE OF REACTOR.....PHR
DATE INITIAL CRITICALITY...MAY 8, 1986
DATE ELEC ENER 1ST GENER...MAY 18, 1986
DATE COMMERCIAL OPERATE...AUGUST 19, 1986
CONDENSER COOLING METHOD...HNDCT
CONDENSER COOLING WATER...LAKE WYLIE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....POWER BLDG., BOX 2178
CHARLOTTE, NORTH CAROLINA 28201
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE POWER
NUC STEAM SYS SUPPLIER...HESTINGHOUSE
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....P. SKINNER
LICENSING PROJ MANAGER.....K. JABBOUR
DOCKET NUMBER.....50-414
LICENSE & DATE ISSUANCE...NPF-52, MAY 15, 1986
PUBLIC DOCUMENT ROOM.....YORK COUNTY LIBRARY
138 E. BLACK STREET
ROCK HILL, SOUTH CAROLINA 29730

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

* INSPECTION FEBRUARY 17-21 (88-03): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED THE OBSERVATION OF THE ANNUAL EMERGENCY RESPONSE EXERCISE. THIS FULL PARTICIPATION EXERCISE (WITH THE EXCEPTION OF MECKLENBURG COUNTY AND THE STATE OF NORTH CAROLINA) WAS INITIATED AT 6:00 P.M. ON FEBRUARY 19, AS AN UNANNOUNCED EXERCISE. FOLLOWING THE STAFFING AND ACTIVATION OF LICENSEE, STATE, AND COUNTY EMERGENCY FACILITIES, THE EXERCISE WAS SUSPENDED UNTIL 9:00 A.M. ON THE NEXT DAY. THE EXERCISE THEN RESUMED AND WAS TERMINATED AT 2:40 P.M. FIVE EXERCISE WEAKNESS WERE IDENTIFIED INVOLVING THE FAILURE TO FULLY MEET EXERCISE OBJECTIVES IN THE AREAS OF EMERGENCY MANAGEMENT, ACCIDENT ASSESSMENT, PROTECTIVE ACTION RECOMMENDATIONS, AND THE MEDICAL DRILL. THEREFORE, THE LICENSEE COMMITTED TO AN EARLY DEMONSTRATION OF CORRECTIVE ACTIONS BY CONDUCTING A SITE ONLY MEDICAL DRILL; A PARTIAL CMC STAFF TABLE TOP EXERCISE USING THE FEBRUARY 20, 1988, SCENARIO AS THE TRAINING MEDIA; AND THE FULL MANNING AND PARTICIPATION OF THE CMC STAFF IN THE FORTHCOMING MCGUIRE EMERGENCY EXERCISE. ALTHOUGH CORRECTIVE ACTIONS ARE REQUIRED, THE EXERCISE WAS CONSIDERED SUCCESSFUL IN THAT THE LICENSEE DEVELOPED A PLAUSIBLE AND CHALLENGING SCENARIO THAT IDENTIFIED TRAINING WEAKNESSES. THE LICENSEE'S TIMELY AND AGGRESSIVE RESPONSE TO SECURING CORRECTIVE ACTIONS IS INDICATIVE OF MANAGEMENT SUPPORT TO AN EFFECTIVE EMERGENCY PREPAREDNESS PROGRAM.

INSPECTION JANUARY 26 - FEBRUARY 25 (88-08): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE INSPECTING IN THE AREAS OF REVIEW OF PLANT OPERATIONS; SURVEILLANCE OBSERVATION; MAINTENANCE OBSERVATION; REVIEW OF LICENSEE NONROUTINE EVENT REPORTS; FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS; REFUELING ACTIVITIES AND MEETING WITH LOCAL OFFICIALS. OF THE SEVEN (7) AREAS INSPECTED, TWO APPARENT VIOLATIONS WERE IDENTIFIED IN TWO AREAS. (FAILURE TO FOLLOW PROCEDURES RESULTING IN TWO INADVERTENT SAFETY INJECTIONS); AND INADEQUATE CORRECTIVE ACTION INVOLVING MOUNTING HARDWARE MODIFICATION FOR ROTORK ACTUATORS.

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-461 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: F.A. SPANGENBERG (217)935-8881 X3400

4. Licensed Thermal Power (Mwt): 2894

5. Nameplate Rating (Gross MWe): _____

6. Design Electrical Rating (Net MWe): 933

7. Maximum Dependable Capacity (Gross MWe): 933

8. Maximum Dependable Capacity (Net MWe): 930

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>3,082.3</u> |
| 13. Hours Reactor Critical | <u>435.3</u> | <u>1,875.3</u> | <u>2,773.6</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>430.5</u> | <u>1,870.5</u> | <u>2,768.8</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,130,339</u> | <u>5,085,874</u> | <u>7,231,374</u> |
| 18. Gross Elec Ener (MWH) | <u>375,529</u> | <u>1,703,040</u> | <u>2,419,690</u> |
| 19. Net Elec Ener (MWH) | <u>354,986</u> | <u>1,628,016</u> | <u>2,312,119</u> |
| 20. Unit Service Factor | <u>57.9</u> | <u>85.6</u> | <u>89.8</u> |
| 21. Unit Avail Factor | <u>57.9</u> | <u>85.6</u> | <u>89.8</u> |
| 22. Unit Cap Factor (MDC Net) | <u>51.3</u> | <u>80.2</u> | <u>80.7</u> |
| 23. Unit Cap Factor (DER Net) | <u>51.1</u> | <u>79.9</u> | <u>80.4</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>.0</u> |

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 04/26/88

 * CLINTON 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CLINTON 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * CLINTON 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 6 | 03/05/88 | F | 0.0 | A | 5 | | | | POWER REDUCED TO APPROXIMATELY 60% OF RATED POWER TO ALLOW REPAIR OF A LEAKING VALVE IN THE REACTOR WATER CLEANUP SYSTEM. |
| 7 | 03/09/88 | F | 0.0 | A | 5 | | | | POWER REDUCED TO APPROXIMATELY 60% OF RATED POWER TO ALLOW REPAIR OF A LEAKING VALVE IN THE REACTOR WATER CLEANUP SYSTEM. |
| 8 | 03/19/88 | S | 313.5 | B | 1 | | | | PLANT SHUTDOWN TO PERFORM SURVEILLANCE TESTING AND SCHEDULED MAINTENANCE. |

 * SUMMARY *

 CLINTON 1 INCURRED 2 POWER REDUCTIONS AND 1 POWER OUTAGE IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* CLINTON 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....DE WITT
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...6 MI E OF
CLINTON, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...FEBRUARY 27, 1987
DATE ELEC ENER 1ST GENER...APRIL 24, 1987
DATE COMMERCIAL OPERATE...NOVEMBER 24, 1987
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...SALT CREEK
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ILLINOIS POWER
CORPORATE ADDRESS.....500 SOUTH 27TH STREET
DECATUR, ILLINOIS 62525
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BALDWIN ASSOCIATES
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....P. HILAND
LICENSING PROJ MANAGER.....J. STEVENS
DOCKET NUMBER.....50-461
LICENSE & DATE ISSUANCE...NPF-62, APRIL 17, 1987
PUBLIC DOCUMENT ROOM.....VESPASIAN WARNER PUBLIC LIBRARY
120 WEST JOHNSON ST.
CLINTON, IL. 61727

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

OTHER ITEMS

NONE

PLANT STATUS:

THE LICENSEE HAS COMPLETED THE POWER ASCENSION TEST PROGRAM. THE LICENSEE IS CURRENTLY OPERATING AT 100% POWER.

LAST IE SITE INSPECTION DATE: 02/26/88

INSPECTION REPORT NO: 88005

R E P O R T S F R O M L I C E N S E E

```

=====

```

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---|
| 88-05 | 021688 | 031888 | LICENSED OPERATOR FAILURE TO RECOGNIZE INOPERABLE DRYWELL ATMOSPHERE PARTICULATE RADIOACTIVITY MONITORING SYSTEM RESULTS IN MISSED PARTICULATE GRAB SAMPLES |
| 88-06 | 022988 | 032588 | INADEQUATE ACCESS AND VISIBILITY DURING RADIATION DETECTOR ASSEMBLY RESULT IN DAMAGED DETECTOR SIGNAL CABLE AND STANDBY GAS TREATMENT SYSTEM AUTO-START |
| 88-08 | 032088 | 040888 | VALVE SEATING SURFACE WEAR BASED ON SERVICE SEEN DURING POWER ASCENSION PROGRAM AND INITIAL PLANT OPERATION RESULTS IN UNNACE PTABLE MAIN STEAM ISOLATION VALVE LEAKAGE RATES |

```

=====

```

1. Docket: 50-315 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: HIRSCH (616) 465-5901

4. Licensed Thermal Power (Mwt): 3250

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1030

7. Maximum Dependable Capacity (Gross MWe): 1056

8. Maximum Dependable Capacity (Net MWe): 1020

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): 920

11. Reasons for Restrictions, If Any:
ADMINISTRATIVE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>116,136.0</u> |
| 13. Hours Reactor Critical | <u>711.5</u> | <u>2,131.3</u> | <u>83,968.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>463.0</u> |
| 15. Hrs Generator On-Line | <u>705.5</u> | <u>2,119.0</u> | <u>82,356.4</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>321.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,007,159</u> | <u>6,081,745</u> | <u>239,073,115</u> |
| 18. Gross Elec Ener (MWH) | <u>653,610</u> | <u>1,982,760</u> | <u>78,127,430</u> |
| 19. Net Elec Ener (MWH) | <u>628,050</u> | <u>1,905,734</u> | <u>75,136,732</u> |
| 20. Unit Service Factor | <u>94.8</u> | <u>97.0</u> | <u>72.1</u> |
| 21. Unit Avail Factor | <u>94.8</u> | <u>97.0</u> | <u>72.1</u> |
| 22. Unit Cap Factor (MDC Net) | <u>82.8</u> | <u>85.5</u> | <u>64.5</u> |
| 23. Unit Cap Factor (DER Net) | <u>82.0</u> | <u>84.7</u> | <u>62.4</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>1.2</u> | <u>8.2</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>26.5</u> | <u>6,644.7</u> |


26. Shutdowns Sched Over Next 4 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* COOK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

COOK 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * COOK 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 268 | 03/25/88 | S | 38.5 | B | 1 | | | | UNIT 1 WAS SHUTDOWN TO MODE 3 TO PERFORM ICE CONDENSER SURVEILLANCES. THE UNIT WAS RETURNED TO SERVICE ON 3-27-88, WITH 90% POWER (ADMINISTRATIVE LIMIT) RESTORED ON 3-29-88. |

 * SUMMARY *

 COOK 1 INCURRED 1 POWER OUTAGE IN MARCH FOR REASONS STATED ABOVE. CONTINUES TO OPERATE AT AN ADMINISTRATIVE IMPOSED REDUCTION OF 90% POWER.

| Type | Reason | Method | System & Component |
|----------|--------------------------|--------------|-------------------------|
| F-Forced | A-Equip Failure | F-Admin | 1-Manual |
| S-Sched | B-Maint or Test | G-Oper Error | 2-Manual Scram |
| | C-Refueling | H-Other | 3-Auto Scram |
| | D-Regulatory Restriction | | 4-Continued |
| | E-Operator Training | | 5-Reduced Load |
| | & License Examination | | 9-Other |
| | | | Exhibit F & H |
| | | | Instructions for |
| | | | Preparation of |
| | | | Data Entry Sheet |
| | | | Licensee Event Report |
| | | | (LER) File (NUREG-0161) |

* COOK 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN
COUNTY.....BERRIEN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI S OF
BENTON HARBOR, MI
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JANUARY 18, 1975
DATE ELEC ENER 1ST GENER...FEBRUARY 10, 1975
DATE COMMERCIAL OPERATE...AUGUST 27, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....INDIANA MICHIGAN POWER CO.
CORPORATE ADDRESS.....1 RIVERSIDE PLAZA
COLUMBUS, OHIO 43216
CONTRACTOR
ARCHITECT/ENGINEER.....AMERICAN ELEC. POWER SERVICE CORP.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....AMERICAN ELEC. POWER SERVICE CORP.
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....B. JORGENSEN
LICENSING PROJ MANAGER.....J. STANG
DOCKET NUMBER.....50-315
LICENSE & DATE ISSUANCE...DPR-58, OCTOBER 25, 1974
PUBLIC DOCUMENT ROOM.....MAUDE PRESTON PALENSKE MEMORIAL LIBRARY
500 MARKET STREET
ST. JOSEPH, MICHIGAN 49085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JANUARY 25-29, 1988 (88006; 88007). ROUTINE, UNANNOUNCED INSPECTION OF THE FOLLOWING AREAS OF THE DONALD C. COOK NUCLEAR POWER PLANT EMERGENCY PREPAREDNESS PROGRAM: ACTION ON PREVIOUSLY-IDENTIFIED ITEMS; EMERGENCY PLAN ACTIVATIONS; LER REVIEW; OPERATIONAL STATUS OF THE EMERGENCY PREPAREDNESS PROGRAM; DOSE ASSESSMENT; NOTIFICATIONS AND COMMUNICATIONS; SHIFT STAFFING AND AUGMENTATION; EMERGENCY PREPAREDNESS TRAINING; LICENSEE AUDITS; AND MAINTAINING EMERGENCY PREPAREDNESS. THE INSPECTION INVOLVED TWO NRC INSPECTORS. ONE VIOLATION WAS IDENTIFIED RELATED TO 10 CFR 50, APPENDIX E (E) (9.D.), REQUIREMENTS FOR COMMUNICATION TESTING.

INSPECTION ON FEBRUARY 10-18, 1988 (88010; 88011). ROUTINE, ANNOUNCED INSPECTION OF: (1) THE CHEMISTRY PROGRAM, INCLUDING PROCEDURES, ORGANIZATION, AND TRAINING; (2) PRIMARY AND SECONDARY SYSTEMS WATER QUALITY CONTROL PROGRAM; (3) QUALITY ASSURANCE/QUALITY CONTROL PROGRAM IN THE LABORATORY; AND (4) NONRADIOLOGICAL CONFIRMATORY MEASUREMENTS. NO VIOLATION OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

FAILURE TO ADEQUATELY IMPLEMENT A COMPENSATORY MEASURE.

(8800 4)

1. Docket: 50-316 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: HIRSCH (616) 465-5901

4. Licensed Thermal Power (MWh): 3411

5. Nameplate Rating (Gross MWe): 1333 X 0.85 = 1133

6. Design Electrical Rating (Net MWe): 1100

7. Maximum Dependable Capacity (Gross MWe): 1100

8. Maximum Dependable Capacity (Net MWe): 1060

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): 864

11. Reasons for Restrictions, If Any: ADMINISTRATIVE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>89,832.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>63,056.4</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,184.0</u> | <u>61,679.2</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>2.2</u> |
| 17. Gross Therm Ener (MWH) | <u>2,038,466</u> | <u>5,978,340</u> | <u>190,557,578</u> |
| 18. Gross Elec Ener (MWH) | <u>666,170</u> | <u>1,955,650</u> | <u>61,432,090</u> |
| 19. Net Elec Ener (MWH) | <u>639,969</u> | <u>1,878,687</u> | <u>59,142,168</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>70.6</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>70.6</u> |
| 22. Unit Cap Factor (MDC Net) | <u>81.1</u> | <u>81.2</u> | <u>63.8</u> |
| 23. Unit Cap Factor (DER Net) | <u>78.2</u> | <u>78.2</u> | <u>62.3</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>14.6</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>10,497.2</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
S.G. REPLACEMENT APRIL 23, 1988 - DURATION OF 225 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

* COOK 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

COOK 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* COOK 2 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

COOK 2 OPERATED AT A NOMINAL 80% ADMINISTRATIVELY IMPOSED
POWER LEVEL DURING MARCH. INCURRED NO OUTAGES OR REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* COOK 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN
COUNTY.....BERRIEN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI S OF
BENTON HARBOR, MI
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 10, 1978
DATE ELEC ENER 1ST GENER...MARCH 22, 1978
DATE COMMERCIAL OPERATE...JULY 1, 1978
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....INDIANA MICHIGAN POWER CO.
CORPORATE ADDRESS.....1 RIVERSIDE PLAZA
COLUMBUS, OHIO 43216
CONTRACTOR
ARCHITECT/ENGINEER.....AMERICAN ELEC. POWER SERVICE CORP.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....J. A. JONES CONSTRUCTION
TURBINE SUPPLIER.....BROWN BOVERI

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....B. JORGENSEN
LICENSING PROJ MANAGER.....J. STANG
DOCKET NUMBER.....50-316
LICENSE & DATE ISSUANCE...DPR-74, DECEMBER 23, 1977
PUBLIC DOCUMENT ROOM.....MAUDE PRESTON PALENSKE MEMORIAL LIBRARY
500 MARKET STREET
ST. JOSEPH, MICHIGAN 49085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JANUARY 25-29, 1988 (88006; 88007). ROUTINE, UNANNOUNCED INSPECTION OF THE FOLLOWING AREAS OF THE DONALD C. COOK NUCLEAR POWER PLANT EMERGENCY PREPAREDNESS PROGRAM: ACTION ON PREVIOUSLY-IDENTIFIED ITEMS; EMERGENCY PLAN ACTIVATIONS; LER REVIEW; OPERATIONAL STATUS OF THE EMERGENCY PREPAREDNESS PROGRAM; DOSE ASSESSMENT; NOTIFICATIONS AND COMMUNICATIONS; SHIFT STAFFING AND AUGMENTATION; EMERGENCY PREPAREDNESS TRAINING; LICENSEE AUDITS; AND MAINTAINING EMERGENCY PREPAREDNESS. THE INSPECTION INVOLVED TWO NRC INSPECTORS. ONE VIOLATION WAS IDENTIFIED RELATED TO 10 CFR 50, APPENDIX E (E) (9.D.), REQUIREMENTS FOR COMMUNICATION TESTING.

INSPECTION ON FEBRUARY 10-18, 1988 (88010; 88011). ROUTINE, ANNOUNCED INSPECTION OF: (1) THE CHEMISTRY PROGRAM, INCLUDING PROCEDURES, ORGANIZATION, AND TRAINING; (2) PRIMARY AND SECONDARY SYSTEMS WATER QUALITY CONTROL PROGRAM; (3) QUALITY ASSURANCE/QUALITY CONTROL PROGRAM IN THE LABORATORY; AND (4) NONRADIOLOGICAL CONFIRMATORY MEASUREMENTS. NO VIOLATION OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

FAILURE TO ADEQUATELY IMPLEMENT A COMPENSATORY MEASURE.

(8800 4)

1. Docket: 50-298 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. T. SCHEUERMAN (402) 825-3811

4. Licensed Thermal Power (Mwt): 2581

5. Nameplate Rating (Gross MWe): 983 X 0.85 = 836

6. Design Electrical Rating (Net MWe): 778

7. Maximum Dependable Capacity (Gross MWe): 787

8. Maximum Dependable Capacity (Net MWe): 764

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|----------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>120,553.0</u> |
| 13. Hours Reactor Critical | <u>100.5</u> | <u>1,297.0</u> | <u>91,304.4</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>100.5</u> | <u>1,281.2</u> | <u>89,825.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>189,168</u> | <u>2,629,440</u> | <u>177,260,147</u> |
| 18. Gross Elec Ener (MWH) | <u>62,995</u> | <u>872,027</u> | <u>56,931,108</u> |
| 19. Net Elec Ener (MWH) | <u>60,597</u> | <u>840,096</u> | <u>54,868,720</u> |
| 20. Unit Service Factor | <u>13.5</u> | <u>58.7</u> | <u>74.5</u> |
| 21. Unit Avail Factor | <u>13.5</u> | <u>58.7</u> | <u>74.5</u> |
| 22. Unit Cap Factor (MDC Net) | <u>10.7</u> | <u>50.3</u> | <u>59.6</u> |
| 23. Unit Cap Factor (DER Net) | <u>10.5</u> | <u>49.4</u> | <u>58.5</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>16.8</u> | <u>4.9</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>259.3</u> | <u>3,953.6</u> |


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 04/29/88

* COOPER STATION *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

COOPER STATION



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* COOPER STATION *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 88-02 | 03/05/88 | S | 643.5 | C | 2 | | | | REACTOR SHUTDOWN FOR 1988 (EOC11) REFUELING AND MAINTENANCE OUTAGE. |

* SUMMARY *

COOPER SHUTDOWN ON MARCH 5 FOR SCHEDULED REFUELING OUTAGE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* COOPER STATION *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE..... NEBRASKA
COUNTY..... NEMAHA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR... 23 MI S OF
NEBRASKA CITY, NEB
TYPE OF REACTOR..... BWR
DATE INITIAL CRITICALITY... FEBRUARY 21, 1974
DATE ELEC ENER 1ST GENER... MAY 10, 1974
DATE COMMERCIAL OPERATE... JULY 1, 1974
CONDENSER COOLING METHOD... ONCE THRU
CONDENSER COOLING WATER... MISSOURI RIVER
ELECTRIC RELIABILITY
COUNCIL..... MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE..... NEBRASKA PUBLIC POWER DISTRICT
CORPORATE ADDRESS..... P.O. BOX 499
COLUMBUS, NEBRASKA 68601
CONTRACTOR
ARCHITECT/ENGINEER..... BURNS & ROE
NUC STEAM SYS SUPPLIER... GENERAL ELECTRIC
CONSTRUCTOR..... BURNS & ROE
TURBINE SUPPLIER..... WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE..... IV
IE RESIDENT INSPECTOR..... D. DUBOIS
LICENSING PROJ MANAGER.... W. LONG
DOCKET NUMBER..... 50-298
LICENSE & DATE ISSUANCE... DPR-46, JANUARY 18, 1974
PUBLIC DOCUMENT ROOM..... AUBURN PUBLIC LIBRARY
1118 15TH STREET
AUBURN, NEBRASKA 68305

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED FEB 1, THROUGH FEB 29, 1988 (88-06) ROUTINE, UNANNOUNCED INSPECTION OF LICENSE ACTIONS ON PREVIOUS INSPECTION FINDINGS, OPERATIONAL SAFETY VERIFICATION, LICENSE EVENT REPORT FOLLOWUP, IE BULLETIN 84-02 FOLLOWUP, MONTHLY SURVEILLANCE AND WITHIN THE AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED (FAILURE TO VERIFY JET PUMP OPERABILITY, FAILURE TO FOLLOW FIRE PROTECTION PROCEDURES, AND FAILURE TO PERFORM ADEQUATE REVIEW. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRABAND MATERIALS WERE FOUND INSIDE THE PROTECTED AREA IN VIOLATION OF REGULATIONS.
(8703 3)

10 CFR 50.54(Q) REQUIRES THAT A LICENSEE SHALL FOLLOW AND MAINTAIN IN EFFECT EMERGENCY PLANS WHICH MEET THE STANDARDS IN 50.47(B) AND THE REQUIREMENTS IN APP.E. SEC. 8.1.1 OF THE EMERGENCY PLAN STATES THAT FORMAL CLASSROOM TRAINING IS PROVIDED TO EACH CNS EMPLOYEE ON AN ANNUAL BASIS. INITIAL TRAINING WILL BE CONDUCTED AND REFRESHER TRAINING WILL BE CONDUCTED ON AN ANNUAL BASIS. CONTRARY TO THE ABOVE, A REVIEW OF RANDOMLY SELECTED EMERGENCY RESPONSE PERSONNEL TRAINING RECORDS INDICATED THAT NINE INDIVIDUALS HAD NOT RECEIVED APPROPRIATE REQUIRED EMERGENCY RESPONSE TRAINING. IN THAT 8 STATION OPERATORS HAD NOT RECEIVED REQUIRED ANNUAL FORMAL CLASSROOM RETRAINING DURING CALENDAR YEAR 1987 AND ONE STATION OPERATOR HAD NOT RECEIVED THE REQUIRED INITIAL TRAINING OR RETRAINING. 10 CFR 50.54(T) REQUIRES THAT PART OF THE REVIEW INVOLVING EVALUATION FOR ADEQUACY OF LICENSEE INTERFACE WITH STATE

1. Docket: 50-302 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: D. GRAHAM (904) 795-3802

4. Licensed Thermal Power (Mwt): 2544

5. Nameplate Rating (Gross MWe): 989 X 0.9 = 890

6. Design Electrical Rating (Net MWe): 825

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 821

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>96,888.0</u> |
| 13. Hours Reactor Critical | <u>697.9</u> | <u>1,913.0</u> | <u>61,239.8</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>1,275.5</u> |
| 15. Hrs Generator On-Line | <u>670.4</u> | <u>1,847.6</u> | <u>59,863.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,575.214</u> | <u>4,359,349</u> | <u>134,106,537</u> |
| 18. Gross Elec Ener (MWH) | <u>542,742</u> | <u>1,501,760</u> | <u>45,875,875</u> |
| 19. Net Elec Ener (MWH) | <u>516,080</u> | <u>1,427,620</u> | <u>43,561,202</u> |
| 20. Unit Service Factor | <u>90.1</u> | <u>84.6</u> | <u>61.8</u> |
| 21. Unit Avail Factor | <u>90.1</u> | <u>84.6</u> | <u>61.8</u> |
| 22. Unit Cap Factor (MDC Net) | <u>84.5</u> | <u>79.6</u> | <u>54.8</u> |
| 23. Unit Cap Factor (DER Net) | <u>84.1</u> | <u>79.2</u> | <u>54.5</u> |
| 24. Unit Forced Outage Rate | <u>7.9</u> | <u>4.8</u> | <u>22.8</u> |
| 25. Forced Outage Hours | <u>57.7</u> | <u>93.9</u> | <u>17,728.9</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

X CRYSTAL RIVER 3 X

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CRYSTAL RIVER 3



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * CRYSTAL RIVER 3 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 88-4 | 02/28/88 | F | 57.7 | A | 4 | 88-006 | CH | VALVOP | CONTINUED OUTAGE RESULTING FROM A REACTOR TRIP ON HIGH RCS PRESSURE. A BROKEN STEM NUT CAUSED THE MAIN FEEDWATER BLOCK VALVE (FWV-29) TO CLOSE. |
| 88-5 | 03/03/88 | S | 0.0 | A | 5 | | CH | VALVOP | OPERATED AT REDUCED LOAD OF APPROXIMATELY 60% DUE TO WORK BEING PERFORMED ON FWV-29. |
| 88-6 | 03/07/88 | S | 15.9 | B | 1 | | CH | VALVOP | THE PLANT WAS TAKEN OFF-LINE TO COMPLETE TESTING OF THE FEEDWATER BLOCK VALVE REPAIRS. |

 * SUMMARY *

 CRYSTAL RIVER 3 ENTERED MONTH SHUTDOWN. SUBSEQUENTLY RETURNED TO POWER. INCURRED 1 POWER REDUCTION AND 1 OUTAGE FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|--------------|-------------------------|
| F-Forced | A-Equip Failure | F-Admin | 1-Manual |
| S-Sched | B-Maint or Test | G-Oper Error | 2-Manual Scram |
| | C-Refueling | H-Other | 3-Auto Scram |
| | D-Regulatory Restriction | | 4-Continued |
| | E-Operator Training | | 5-Reduced Load |
| | & License Examination | | 9-Other |
| | | | Exhibit F & H |
| | | | Instructions for |
| | | | Preparation of |
| | | | Data Entry Sheet |
| | | | Licensee Event Report |
| | | | (LER) File (NUREG-0161) |

* CRYSTAL RIVER 3 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA
COUNTY.....CITRUS
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...7 MI NW OF
CRYSTAL RIVER, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JANUARY 14, 1977
DATE ELEC ENER 1ST GENER...JANUARY 30, 1977
DATE COMMERCIAL OPERATE...MARCH 13, 1977
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...GULF OF MEXICO
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER CORPORATION
CORPORATE ADDRESS.....3201 34TH STREET, SOUTH
ST PETERSBURG, FLORIDA 33733
CONTRACTOR
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....J. A. JONES CONSTRUCTION
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....T. STETKA
LICENSING PROJ MANAGER....H. SILVER
DOCKET NUMBER.....50-302
LICENSE & DATE ISSUANCE...DPR-72, JANUARY 28, 1977
PUBLIC DOCUMENT ROOM.....CRYSTAL RIVER PUBLIC LIBRARY
668 N.W. FIRST
CRYSTAL RIVER, FLORIDA 32629

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 16 - FEBRUARY 11 (88-01): THIS ROUTINE INSPECTION WAS CONDUCTED BY TWO RESIDENT INSPECTORS IN THE AREAS OF PLANT OPERATIONS, SECURITY, RADIOLOGICAL CONTROLS, LICENSEE EVENT REPORTS AND NONCONFORMING OPERATIONS REPORTS, FACILITY MODIFICATIONS, REVIEW OF SPECIAL REPORTS, PLANT STARTUP FROM REFUELING, COLD WEATHER PREPARATIONS, AND LICENSEE ACTION ON PREVIOUS INSPECTION ITEMS. NUMEROUS FACILITY TOURS WERE CONDUCTED AND FACILITY OPERATIONS OBSERVED. SOME OF THESE TOURS AND OBSERVATIONS WERE CONDUCTED ON BACKSHIFTS. TWO VIOLATIONS WERE IDENTIFIED. FAILURE TO IMPLEMENT PLANT PROCEDURES, AND FAILURE TO HAVE SEISMIC MONITORING INSTRUMENTATION WITH THE REQUIRED MEASUREMENT RANGE.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.8.1.A, PROCEDURES CP-115 AND OP-703 WERE NOT ADHERED TO IN THAT REQUIRED CLEARANCE CERTIFICATIONS AND PROPER PROCEDURE STEPS TO DEENERGIZE A 4160V ES BUS WERE NOT FOLLOWED.
(8704 4)

CONTRARY TO TS 6.8.1, PLANT PROCEDURES OP-703, PT-110, AND AI 2205 WERE NOT PROPERLY IMPLEMENTED. CONTRARY TO TS 3.3.3.3, TABLE 3.7-7, THE TRIAXIAL PEAK ACCELOGRAPHS DID NOT HAVE THE REQUIRED PLUS OR MINUS 2.06 MEASUREMENT RANGE.
(8806 6)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: DECEMBER 16 - FEBRUARY 11, 1988 +

INSPECTION REPORT NO: 50-302/88-01 +

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|--|
| 88-001 | 01/07/88 | 02/08/88 | IMPROPER POSITIONING OF TURBINE BYPASS VALVES AND SLUGGISH RESPONSE RESULTS IN A LOW LEVEL IN "B" SG AND SUB EF ACT |
| 88-002 | 01/07/88 | 02/08/88 | TECHNICIAN ERROR CAUSES TRIP OF OPERATING FEEDWATER PUMP RESULTS IN EMERGENCY FEEDWATER ACT AND OVERSPEED DURING EMERG FEEDWATER |
| 88-003 | 01/28/88 | 02/29/88 | PERSONNEL ERROR DURING DEVELOPMENT & REVIEW OF SURVEY PROCEDURE LEADS TO INADEQUATE SURVEY FREQUENCY FOR FOUR CONT. ISOLATION VALVES |
| 88-004 | 01/28/88 | 03/14/88 | PROCEDURAL INADEQUACY CAUSES MISSED TECH SPEC SURVEILLANCE AND DELAY IN DECLARING DETECTOR SYSTEM INOPERABLE |
| 88-005 | 02/23/88 | 03/24/88 | PERSONNEL ERROR RESULTS IN FAILURE TO ENTER ACTION STATEMENT FOR CONTAINMENT ISOLATION VALVE STROKE TIME |
| 88-006 | 02/28/88 | 03/29/88 | BROKEN STEM NUT IN "B" FEEDWATER MAIN BLOCK VALVE RESULTS IN A FEEDWATER TRANSIENT AND A SUBSEQUENT REACTOR TRIP |

=====

1. Docket: 50-346 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: MORTEZA KHARZRAI (419) 249-5000 X7290

4. Licensed Thermal Power (Mwt): 2772

5. Nameplate Rating (Gross MWe): 1069 X 0.9 = 962

6. Design Electrical Rating (Net MWe): 906

7. Maximum Dependable Capacity (Gross MWe): 904

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


| | MONTH | YEAR | CUMULATIVE |
|---|----------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>84,769.0</u> |
| 13. Hours Reactor Critical | <u>221.3</u> | <u>1,661.3</u> | <u>45,143.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>5,050.1</u> |
| 15. Hrs Generator On-Line | <u>220.5</u> | <u>1,580.0</u> | <u>43,380.8</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>1,732.7</u> |
| 17. Gross Therm Ener (MWH) | <u>381,871</u> | <u>3,306,442</u> | <u>101,268,640</u> |
| 18. Gross Elec Ener (MWH) | <u>123,340</u> | <u>1,072,485</u> | <u>33,448,288</u> |
| 19. Net Elec Ener (MWH) | <u>111,824</u> | <u>998,787</u> | <u>31,299,434</u> |
| 20. Unit Service Factor | <u>29.6</u> | <u>72.3</u> | <u>51.1</u> |
| 21. Unit Avail Factor | <u>29.6</u> | <u>72.3</u> | <u>53.2</u> |
| 22. Unit Cap Factor (MDC Net) | <u>17.5</u> | <u>53.2</u> | <u>42.9</u> |
| 23. Unit Cap Factor (DER Net) | <u>16.6</u> | <u>50.5</u> | <u>40.7</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>32.5</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>21,470.0</u> |
| 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>NONE</u> | | | |

27. If Currently Shutdown Estimated Startup Date: 09/12/88

* DAVIS-BESSE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DAVIS-BESSE 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* DAVIS-BESSE 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 2 | 03/10/88 | S | 523.5 | C | 1 | | | | THE REFUELING OUTAGE WAS INITIATED TO PERFORM SCHEDULED MAINTENANCE AND REFUELING WORK. |

***** DAVIS-BESSE 1 SHUTDOWN IN MARCH FOR SCHEDULED REFUELING AND MAINTENANCE. * SUMMARY * *****

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* DAVIS-BESSE 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....OHIO
COUNTY.....OTTAWA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...21 MI E OF
TOLEDO, OH
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 12, 1977
DATE ELEC ENER 1ST GENER...AUGUST 28, 1977
DATE COMMERCIAL OPERATE...JULY 31, 1978
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...LAKE ERIE
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TOLEDO EDISON
CORPORATE ADDRESS.....300 MADISON AVENUE
TOLEDO, OHIO 43652
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....P. BYRON
LICENSING PROJ MANAGER.....A. DEGAZIO
DOCKET NUMBER.....50-346
LICENSE & DATE ISSUANCE...NPF-3, APRIL 22, 1977
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF TOLEDO LIBRARY
GOVERNMENT DOCUMENTS COLLECTION
2801 WEST BANCROFT AVENUE
TOLEDO, OHIO 43606

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON FEBRUARY 2-4, 9-11, 23-25, AND MARCH 7-8, 1988 (88005). ROUTINE, UNANNOUNCED SAFETY INSPECTION OF INSERVICE INSPECTION (ISI) ACTIVITIES INCLUDING REVIEW OF PROGRAM (73051), PROCEDURES (73052), OBSERVATION OF WORK ACTIVITIES (737543), AND DATE REVIEW (73755). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 3.7.9.3.A REQUIRES THAT WITH ONE OR MORE FIRE HOSE STATIONS IN TABLE 3.7-4 INOPERABLE, AN ADDITIONAL EQUIVALENT FIRE HOSE SHALL BE ROUTED TO THE UNPROTECTED AREA FROM AN OPERABLE HOSE STATION WITHIN ONE HOUR. FIRE HOSE STATION HCS-30 IS LISTED IN TABLE 3.7-4. CONTRARY TO THE ABOVE, ON OCTOBER 26, 1987, THE LICENSEE REPLACED A 75 FOOT HOSE SECTION WITH A 50 FT. HOSE SECTION ON FIRE HOSE STATION HCS-30. THE SHORTER HOSE RENDERED FIRE HOSE STATION HCS-30 INOPERABLE BECAUSE IT WAS UNABLE TO REACH ALL OF THE EQUIPMENT IMPORTANT TO SAFETY IN ROOM 515. THE SHIFT SUPERVISOR WAS NOTIFIED OF THIS CONDITION AT 9:57 A.M. ON OCTOBER 26, 1987. THE SHIFT SUPERVISOR DIRECTED THAT AN ADDITIONAL LENGTH OF HOSE BE ADDED TO FIRE HOSE STATION HCS-30, WHICH MADE IT OPERABLE. FIRE HOSE STATION HCS-30 WAS INOPERABLE FOR APPROXIMATELY FOUR DAYS.
(8703 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

TWO MAIN STEAM SAFETY VALVES (MSSV) WERE REPLACED WITH BLANK FLANGES. ONE FAILED AFTER THE PLANT TRIP ON SEPTEMBER 6, 1987, THE SECOND WAS REMOVED DUE TO INDICATIONS OF WEAR WHICH MAY BE A PRECURSOR TO FAILURE. A THIRD MSSV WAS GAGGED SHUT ON OCTOBER 9, 1987, AFTER ADDITIONAL ENGINEERING EVALUATIONS AND INSPECTIONS REVEALED SIGNS OF ANOTHER POSSIBLE FAILURE PRECURSOR.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

SALP MEETING WITH THE LICENSEE AT THE SITE ON MARCH 30, 1988

PLANT STATUS:

SHUT DOWN FOR A 6 MONTH MAINTENANCE/MODIFICATION/REFUELING OUTAGE. RESTART ABOUT MID- SEPTEMBER, 1988.

LAST IE SITE INSPECTION DATE: 03/11/88

INSPECTION REPORT NO: 88008

R E P O R T S F R O M L I C E N S E E

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|---|
| 88-06 | 022288 | 032388 | SOFTWARE ERROR IN KAMAN RADIATION MONITORS |
| 88-07 | 030488 | 033188 | AIR OPERATED VALVE ACCUMULATOR LEAKAGE AND SUBSEQUENT DECAY HEAT REMOVAL SYSTEM INOPERABILITY |

1. Docket: 50-275 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: P. BEDASAM (805) 595-4097

4. Licensed Thermal Power (MWT): 3338

5. Nameplate Rating (Gross MWe): 1137

6. Design Electrical Rating (Net MWe): 1086

7. Maximum Dependable Capacity (Gross MWe): 1124

8. Maximum Dependable Capacity (Net MWe): 1073

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|----------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>25,438.3</u> |
| 13. Hours Reactor Critical | <u>143.3</u> | <u>1,531.6</u> | <u>21,270.3</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>143.2</u> | <u>1,523.3</u> | <u>20,831.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>274,544</u> | <u>4,020,604</u> | <u>62,985,067</u> |
| 18. Gross Elec Ener (MWH) | <u>97,100</u> | <u>1,355,000</u> | <u>21,205,832</u> |
| 19. Net Elec Ener (MWH) | <u>85,502</u> | <u>1,273,686</u> | <u>20,085,388</u> |
| 20. Unit Service Factor | <u>19.2</u> | <u>69.7</u> | <u>81.9</u> |
| 21. Unit Avail Factor | <u>19.2</u> | <u>69.7</u> | <u>81.9</u> |
| 22. Unit Cap Factor (MDC Net) | <u>10.7</u> | <u>54.4</u> | <u>73.6</u> |
| 23. Unit Cap Factor (DER Net) | <u>10.6</u> | <u>53.7</u> | <u>72.7</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>3.8</u> | <u>3.9</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>59.9</u> | <u>840.6</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 05/15/88

 * DIABLO CANYON 1 *

 AVERAGE DAILY POWER LEVEL (MWe) PLOT

DIABLO CANYON 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* DIABLO CANYON 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 1 | 03/05/88 | S | 600.8 | C | 1 | | | | SCHEDULED REFUELING OUTAGE. |

* SUMMARY *

DIABLO CANYON 1 SHUTDOWN IN MARCH TO COMMENCE SCHEDULED REFUELING OUTAGE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|--------------|-------------------------|
| F-Forced | A-Equip Failure | F-Admin | 1-Manual |
| S-Sched | B-Maint or Test | G-Oper Error | 2-Manual Scram |
| | C-Refueling | H-Other | 3-Auto Scram |
| | D-Regulatory Restriction | | 4-Continued |
| | E-Operator Training | | 5-Reduced Load |
| | & License Examination | | 9-Other |
| | | | Exhibit F & H |
| | | | Instructions for |
| | | | Preparation of |
| | | | Data Entry Sheet |
| | | | Licensee Event Report |
| | | | (LER) File (NUREG-0161) |

* DIABLO CANYON 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SAN LUIS OBISPO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI WSW OF
SAN LUIS OBISPO
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 29, 1984
DATE ELEC ENER 1ST GENER...NOVEMBER 11, 1984
DATE COMMERCIAL OPERATE...MAY 7, 1985
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...PACIFIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PACIFIC GAS & ELECTRIC
CORPORATE ADDRESS.....77 BEALE STREET
SAN FRANCISCO, CALIFORNIA 94106

CONTRACTOR
ARCHITECT/ENGINEER.....PACIFIC GAS & ELECTRIC
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....PACIFIC GAS & ELECTRIC
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....J. BURDOIN
LICENSING PROJ MANAGER.....H. ROOD
DOCKET NUMBER.....50-275
LICENSE & DATE ISSUANCE...DPR-80, NOVEMBER 2, 1984
PUBLIC DOCUMENT ROOM.....ROBERT F. KENNEDY LIBRARY
CALIFORNIA POLYTECHNIC STATE UNIVERSITY
SAN LUIS OBISPO, CA. 93407

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON FEBRUARY 29 - MARCH 4, 1988 (REPORT NO. 50-275/88-02) REPORT BEING PREPARED, TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JANUARY 31 - MARCH 5, 1988 (REPORT NO. 50-275/88-03) AREAS INSPECTED: THE INSPECTION INCLUDED ROUTINE INSPECTIONS OF PLANT OPERATIONS, MAINTENANCE AND SURVEILLANCE ACTIVITIES, FOLLOW-UP OF ON-SITE EVENTS, OPEN ITEMS, AND LICENSEE EVENT REPORTS, AS WELL AS SELECTED INDEPENDENT INSPECTION ACTIVITIES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: ONE VIOLATION AND NO DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON FEBRUARY 8-22, 1988 (REPORT NO. 50-275/88-04) AREAS INSPECTED: THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED THE AREAS OF INSERVICE TESTING OF PUMPS AND VALVES. THE INSPECTION INVOLVED REVIEW OF THE PROGRAM, PROCEDURES, RECORDS, AND INTERVIEWS WITH LICENSEE PERSONNEL. DURING THIS INSPECTION, TWO INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: IN THE AREAS INSECTED, ONE VIOLATION WAS IDENTIFIED FOR NOT ESTABLISHING THE REQUIRED REFERENCE FLOW RATE DURING A PUMP TEST.

+ INSPECTION ON MARCH 14-18, 1988 (REPORT NO. 50-275/88-05) REPORT BEING PREPARED, TO BE REPORTED NEXT MONTH.

+ INSPECTION ON MARCH 21-25, 1988 (REPORT NO. 50-275/88-06) REPORT BEING PREPARED, TO BE REPORTED NEXT MONTH.

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

* DIABLO CANYON 1 *

INSPECTION SUMMARY

+ INSPECTION ON MARCH 6 - APRIL 9, 1988 (REPORT NO. 50-275/88-07) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE PLANT IS IN COMMERCIAL OPERATION, AT APPROXIMATELY 78% POWER AND IS IN COAS DOWN FOR SECOND REFUELING OUTAGE.

LAST IE SITE INSPECTION DATE: 03/06 - 04/09/88+

INSPECTION REPORT NO: 50-275/88-07+

R E P O R T S F R O M L I C E N S E E

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|----------|---------------|----------------|---|
| 87-05-S0 | 11-07-87 | 12-07-87 | 10 CFR 73.71 (C) REPORT RE: PROBLEMS WITH SECURITY UPS SYSTEM (SAFEGUARDS EVENT) |
| 87-06-S0 | 12-30-87 | 01-29-88 | 10 CFR 73.71 (C) REPORT RE: UNIDENTIFIED CAPOULE PILL FOUND ON SITE (SAFEGUARDS EVENT) |
| 88-01-S0 | 01-08-88 | 01-25-88 | 10 CFR 73.71 (C) REPORT RE: SECURITY FORCE MEMBER CAUSING ADVERSE MEDIA INTEREST (SAFEGUARDS EVENT) |
| 88-05-L0 | 02-03-88 | 03-04-88 | CONTAINMENT ISOLATION DUE TO ELECTRONIC NOISE & LATE ISSUANCE OF 10 CFR 50.72 REPORT |

1. Docket: 50-323 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: P. BEDESEM (805) 595-4097

4. Licensed Thermal Power (MWh): 3411

5. Nameplate Rating (Gross MWe): 1164

6. Design Electrical Rating (Net MWe): 1119

7. Maximum Dependable Capacity (Gross MWe): 1137

8. Maximum Dependable Capacity (Net MWe): 1087

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>17,997.0</u> |
| 13. Hours Reactor Critical | <u>677.2</u> | <u>2,117.2</u> | <u>15,033.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>676.6</u> | <u>2,116.6</u> | <u>14,601.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWh) | <u>2,257,456</u> | <u>7,070,569</u> | <u>46,332,556</u> |
| 18. Gross Elec Ener (MWh) | <u>755,500</u> | <u>2,361,300</u> | <u>15,348,999</u> |
| 19. Net Elec Ener (MWh) | <u>716,095</u> | <u>2,245,628</u> | <u>14,509,020</u> |
| 20. Unit Service Factor | <u>90.9</u> | <u>96.9</u> | <u>81.1</u> |
| 21. Unit Avail Factor | <u>90.9</u> | <u>96.9</u> | <u>81.1</u> |
| 22. Unit Cap Factor (MDC Net) | <u>88.5</u> | <u>94.6</u> | <u>74.2</u> |
| 23. Unit Cap Factor (DER Net) | <u>86.0</u> | <u>91.9</u> | <u>72.0</u> |
| 24. Unit Forced Outage Rate | <u>9.1</u> | <u>3.1</u> | <u>9.7</u> |
| 25. Forced Outage Hours | <u>67.4</u> | <u>67.4</u> | <u>1,572.8</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 X DIABLO CANYON 2

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DIABLO CANYON 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * DIABLO CANYON 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 1 | 03/03/88 | F | 67.4 | A | 3 | 88-002-00 | IN | RLY | REACTOR TRIP DUE TO AN UNDETECTED FAILED RELAY DURING SEISMIC TRIP CHANNEL CALIBRATION. DURING CALIBRATION A REDUNDANT CHANNEL WAS PLACED IN THE TRIP CONDITION THEREBY SATISFYING THE 2 OUT OF 3 REQUIRED LOGIC WITH ONE RELAY FAILED AND ONE IN TEST. THE FAILED RELAY WAS REPLACED AND A DESIGN CHANGE REQUESTED TO ADD ALL RELAY OUTPUTS TO THE ANNUNCIATOR. |

 * SUMMARY *

 DIABLO CANYON 2 INCURRED 1 OUTAGE IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* DIABLO CANYON 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SAN LUIS OBISPO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI WSW OF
SAN LUIS OBISPO
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 19, 1985
DATE ELEC ENER 1ST GENER...OCTOBER 20, 1985
DATE COMMERCIAL OPERATE...MARCH 13, 1986
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...PACIFIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PACIFIC GAS & ELECTRIC
CORPORATE ADDRESS.....77 BEALE STREET
SAN FRANCISCO, CALIFORNIA 94106
CONTRACTOR
ARCHITECT/ENGINEER.....PACIFIC GAS & ELECTRIC
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....PACIFIC GAS & ELECTRIC
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....J. BURDOIN
LICENSING PROJ MANAGER.....H. ROOD
DOCKET NUMBER.....50-323
LICENSE & DATE ISSUANCE...DPR-82, AUGUST 26, 1985
PUBLIC DOCUMENT ROOM.....ROBERT F. KENNEDY LIBRARY
CALIFORNIA POLYTECHNIC STATE UNIVERSITY
SAN LUIS OBISPO, CA. 93407

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON FEBRUARY 29 - MARCH 4, 1988 (REPORT NO. 50-323/88-02) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON FEBRUARY 8-22, 1988 (REPORT NO. 50-323/88-03) AREAS INSPECTED: THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED THE AREAS OF INSERVICE TESTING OF PUMPS AND VALVES. THE INSPECTION INCLUDED REVIEW OF THE PROGRAM, PROCEDURES, RECORDS AND INTERVIEWS WITH LICENSEE PERSONNEL. DURING THIS INSPECTION, TWO INSPECTION PROCEDURES WERE UTILIZED.
RESULTS: IN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED FOR RETURNING A VALVE TO ITS ORIGINAL STROKE TIME TEST FREQUENCY, WITH NO CORRECTIVE ACTION PERFORMED.
- + INSPECTION ON JANUARY 31 - MARCH 5, 1988 (REPORT NO. 50-323/88-04) AREAS INSPECTED: THE INSPECTION INCLUDED ROUTINE INSPECTIONS OF PLANT OPERATIONS, MAINTENANCE AND SURVEILLANCE ACTIVITIES, FOLLOW-UP OF ON-SITE EVENTS, OPEN ITEMS, AND LICENSEE EVENT REPORTS, AS WELL AS SELECTED INDEPENDENT INSPECTION ACTIVITIES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.
RESULTS: ONE VIOLATION AND NO DEVIATIONS WERE IDENTIFIED.
- + INSPECTION ON MARCH 14-18, 1988 (REPORT NO. 50-323/88-05) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON MARCH 28 - APRIL 1, 1988 (REPORT NO. 50-323/88-06) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

INSPECTION SUMMARY

+ INSPECTION ON MARCH 6 - APRIL 9, 1988 (REPORT NO. 50-323/88-07) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE PLANT IS IN COMMERCIAL OPERATION, AT APPROXIMATELY 100% POWER.

LAST IE SITE INSPECTION DATE: 03/06 - 04/09/88+

INSPECTION REPORT NO: 50-323/88-07+

R E P O R T S F R O M L I C E N S E E

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

NONE

1. Docket: 50-237 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: D.C. MAXWELL (815) 942-2920 X 489

4. Licensed Thermal Power (MWh): 2527

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 794

7. Maximum Dependable Capacity (Gross MWe): 812

8. Maximum Dependable Capacity (Net MWe): 772

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>156,768.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>118,756.3</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,184.0</u> | <u>113,277.8</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWh) | <u>1,676,477</u> | <u>4,979,460</u> | <u>232,998,283</u> |
| 18. Gross Elec Ener (MWh) | <u>533,397</u> | <u>1,595,183</u> | <u>74,535,153</u> |
| 19. Net Elec Ener (MWh) | <u>508,386</u> | <u>1,523,041</u> | <u>70,459,219</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>72.3</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>72.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>88.5</u> | <u>90.3</u> | <u>58.2</u> |
| 23. Unit Cap Factor (DER Net) | <u>86.1</u> | <u>87.8</u> | <u>56.6</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>11.5</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>7,157.0</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


BATTERY DISCHARGE TEST, MAY, 1988. DURATION 1 WEEK

27. If Currently Shutdown Estimated Startup Date: N/A

 X DRESDEN 2 X

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DRESDEN 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* DRESDEN 2 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

DRESDEN II OPERATED ROUTINELY IN MARCH WITH NO OUTAGES OR
SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* DRESDEN 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....GRUNDY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9 MI E OF
MORRIS, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JANUARY 7, 1970
DATE ELEC ENER 1ST GENER...APRIL 13, 1970
DATE COMMERCIAL OPERATE...JUNE 9, 1970
CONDENSER COOLING METHOD...COOLING LAKE
CONDENSER COOLING WATER...KANKAKEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 747
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....S. DUPONT
LICENSING PROJ MANAGER.....M. GROTENHUIS
DGCKET NUMBER.....50-237
LICENSE & DATE ISSUANCE...DPR-19, DECEMBER 22, 1969
PUBLIC DOCUMENT ROOM.....MORRIS PUBLIC LIBRARY
604 LIBERTY STREET
MORRIS, ILLINOIS 60450

INSPECTION STATUS

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION (TS) 3.7.A.5.A, "LIMITING CONDITION FOR OPERATION (LCO)," REQUIRES THAT THE PRIMARY CONTAINMENT ATMOSPHERE BE REDUCED TO LESS THAN FOUR PERCENT OXYGEN WITH NITROGEN GAS DURING REACTOR POWER OPERATION WITH REACTOR COOLANT PRESSURE ABOVE 90 PSIG, EXCEPT AS SPECIFIED IN TS 3.7.A.5.B. WHICH PROVIDES THAT DEINERTING MAY COMMENCE 24 HOURS PRIOR TO A SHUTDOWN. DRESDEN OPERATING PROCEDURE 1600-9, REVISION 4, "NITROGEN MAKE-UP TO PRIMARY CONTAINMENT," STATES THAT "THE CONTAINMENT ATMOSPHERE SHALL BE REDUCED TO LESS THAN FOUR % OXYGEN WITH NITROGEN GAS . . . AND UP TO 24 HOURS BEFORE TAKING THE REACTOR OUT OF THE RUN MODE." CONTRARY TO THE ABOVE, AT 1220 HOURS ON NOVEMBER 28, 1986, DURING POWER OPERATION AND WITH REACTOR COOLANT PRESSURE ABOVE 90 PSIG, THE LICENSEE COMMENCED DEINERTING PROCEDURES. ALTHOUGH THE OXYGEN CONCENTRATION WAS GREATER THAN FOUR PERCENT, THE REACTOR CONTINUED OPERATING UNTIL IT WAS MANUALLY SCRAMMED AT 1703 HOURS ON 11/29/86 A DEINERTING PERIOD OF 28 HOURS & 43 MINUTES. (B) TECHNICAL SPEC. LIMITING CONDITION FOR OPERATION 3.7.A.7.A. REQ. THAT DIFFERENTIAL PRESSURE BETWEEN THE DRYWELL & SUPPRESSION CHAMBER BE MAINTAINED AT = TO OR < THAN 1.00 PSID EXCEPT AS SPECIFIED IN TS 3.7.A.7.A(1), WHICH PROVIDES THAT THE DIFFERENTIAL MAY BE RELAXED 24 HOURS PRIOR TO A REACTOR SHUTDOWN, AND TS 3.7.A.7.A(2) IS NOT APPLICABLE HERE. CONTRARY TO THE ABOVE, AT 1220 HOURS ON NOVEMBER 28, 1986, A TWO INCH EQUALIZING LINE BETWEEN THE DRYWELL AND THE TORUS WAS OPENED, THEREBY REDUCING THE DIFFERENTIAL PRESSURE TO LESS THAN 1.00 PSID. THE REACTOR CONTINUED TO OPERATE IN THIS CONFIGURATION UNTIL 1703 HOURS ON NOVEMBER 29, 1986, A PERIOD OF 28 HOURS AND 43 MINUTES, WHEN THE REACTOR WAS MANUALLY SCRAMMED.
(8700 3)

1. Docket: 50-249 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: D.C. MAXWELL (815) 942-2920 X 489

4. Licensed Thermal Power (MHT): 2527

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 794

7. Maximum Dependable Capacity (Gross MWe): 812

8. Maximum Dependable Capacity (Net MWe): 773

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>146,353.0</u> |
| 13. Hours Reactor Critical | <u>626.4</u> | <u>2,066.4</u> | <u>105,474.8</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>626.0</u> | <u>2,066.0</u> | <u>100,913.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,455,641</u> | <u>4,792,721</u> | <u>206,168,243</u> |
| 18. Gross Elec Ener (MWH) | <u>469,867</u> | <u>1,557,623</u> | <u>66,588,865</u> |
| 19. Net Elec Ener (MWH) | <u>448,461</u> | <u>1,490,722</u> | <u>63,068,542</u> |
| 20. Unit Service Factor | <u>84.1</u> | <u>94.6</u> | <u>69.0</u> |
| 21. Unit Avail Factor | <u>84.1</u> | <u>94.6</u> | <u>69.0</u> |
| 22. Unit Cap Factor (MDC Net) | <u>78.0</u> | <u>88.3</u> | <u>55.7</u> |
| 23. Unit Cap Factor (DER Net) | <u>75.9</u> | <u>86.0</u> | <u>54.3</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>12.6</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>9,463.9</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 06/25/88

* D R E S D E N 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DRESDEN 3



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* DRESDEN 3 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 1 | 03/27/88 | S | 118.0 | C | 1 | | | | UNIT OFF-LINE MANUALLY TO ITS 10TH REFUELING OUTAGE. |

***** DRESDEN III ENDED MONTH SHUTDOWN FOR SCHEDULED REFUELING OUTAGE.
* SUMMARY *

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* DRESDEN 3 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....GRUNDY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9 MI E OF
MORRIS, ILL
TYPE OF REACTOR.....BWR
DATE INITIATED CRITICALITY...JANUARY 31, 1971
DATE ELEC ENER 1ST GENER...JULY 22, 1971
DATE COMMERCIAL OPERATE...NOVEMBER 16, 1971
CONDENSER COOLING METHOD...COOLING LAKE
CONDENSER COOLING WATER...KANKAKEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....L. MCGREGOR
LICENSING PROJ MANAGER.....M. GROTENHUIS
DOCKET NUMBER.....50-249
LICENSE & DATE ISSUANCE...DPR-25, MARCH 2, 1971
PUBLIC DOCUMENT ROOM.....MORRIS PUBLIC LIBRARY
604 LIBERTY STREET
MORRIS, ILLINOIS 60450

INSPECTION STATUS

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

10 CFR 50, APPENDIX B, CRITERION XVI, AS IMPLEMENTED BY CECO TOPICAL REPORT CE-1-A, "QUALITY ASSURANCE PROGRAM FOR NUCLEAR GENERATING STATIONS", AND CECO CORPORATE QUALITY ASSURANCE MANUAL, NUCLEAR GENERATING STATIONS, "QUALITY REQUIREMENT SECTION 16.0", REQUIRE THAT CORRECTIVE ACTIONS IDENTIFIED FROM NONCONFORMANCES, INCIDENTS AND DEVIATIONS ARE VERIFIED FOR SATISFACTORY COMPLETION TO PRECLUDE REPETITION. CONTRARY TO THE ABOVE, THE CORRECTIVE ACTIONS TAKEN TO RESOLVE AN AUGUST 18, 1987, VIOLATION OF TECHNICAL SPECIFICATION TABLE 3.1.1, WHICH REQUIRES A MINIMUM OF TWO OPERABLE APRM DOWNSCALE/IRM HIGH HIGH OR INOPERABLE TRIP FUNCTIONS PER REACTOR PROTECTION SYSTEM CHANNEL WERE NOT EFFECTIVE IN PREVENTING A SECOND IDENTICAL VIOLATION OF THIS TECHNICAL SPECIFICATION REQUIREMENT WHICH OCCURRED FOUR MONTHS LATER ON DECEMBER 18, 1987.
(8703 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

1. Docket: 50-331 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: L. MILLER (319) 851-7204

4. Licensed Thermal Power (MWh): 1658

5. Nameplate Rating (Gross MWe): 663 X 0.9 = 597

6. Design Electrical Rating (Net MWe): 538

7. Maximum Dependable Capacity (Gross MWe): 545

8. Maximum Dependable Capacity (Net MWe): 515

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>115,392.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>82,497.8</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>172.8</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,184.0</u> | <u>80,439.4</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,204,568</u> | <u>3,549,047</u> | <u>103,586,328</u> |
| 18. Gross Elec Ener (MWH) | <u>410,175</u> | <u>1,216,071</u> | <u>34,775,899</u> |
| 19. Net Elec Ener (MWh) | <u>367,264</u> | <u>1,132,232</u> | <u>32,575,560</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>69.7</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>69.7</u> |
| 22. Unit Cap Factor (MDC Net) | <u>95.9</u> | <u>100.7</u> | <u>54.8</u> |
| 23. Unit Cap Factor (DER Net) | <u>91.8</u> | <u>96.4</u> | <u>52.5</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>14.8</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>13,917.7</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
* DUANE ARNOLD *
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DUANE ARNOLD



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* DUANE ARNOLD *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 1 | 03/19/88 | S | 0.0 | B | 5 | | | | DECREASED POWER TO PERFORM AN INSPECTION OF THE STEAM TUNNEL AND A CRD EXERCISE. |

* SUMMARY *

DUANE ARNOLD INCURRED 1 POWER REDUCTION IN MARCH TO PERFORM MAINTENANCE INSPECTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* DUANE ARNOLD *

F A C I L I T Y D A T A

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....IOWA
COUNTY.....LINN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...8 MI NW OF
CEDAR RAPIDS, IA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 23, 1974
DATE ELEC ENER 1ST GENER...MAY 19, 1974
DATE COMMERCIAL OPERATE...FEBRUARY 1, 1975
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...CEDAR RAPIDS RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....IOWA ELECTRIC LIGHT & POWER
CORPORATE ADDRESS.....I E TOWERS, P.O. BOX 351
CEDAR RAPIDS, IOWA 52406
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....M. PARKER
LICENSING PROJ MANAGER.....J. HALL
DOCKET NUMBER.....50-331
LICENSE & DATE ISSUANCE...DPR-49, FEBRUARY 22, 1974
PUBLIC DOCUMENT ROOM.....CEDAR RAPIDS PUBLIC LIBRARY
500 FIRST STREET, S.E.
CEDAR RAPIDS, IOWA 52401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

1. Docket: 50-545 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. D. WOODARD (205) 899-5156

4. Licensed Thermal Power (MWT): 2652

5. Nameplate Rating (Gross MWe): 860

6. Design Electrical Rating (Net MWe): 829

7. Maximum Dependable Capacity (Gross MWe): 853

8. Maximum Dependable Capacity (Net MWe): 813

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>90,576.0</u> |
| 13. Hours Reactor Critical | <u>600.8</u> | <u>2,040.8</u> | <u>67,257.5</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>3,650.7</u> |
| 15. Hrs Generator On-Line | <u>600.1</u> | <u>2,040.1</u> | <u>65,865.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,581,648</u> | <u>5,400,491</u> | <u>167,823,808</u> |
| 18. Gross Elec Ener (MWH) | <u>514,706</u> | <u>1,763,232</u> | <u>53,829,568</u> |
| 19. Net Elec Ener (MWH) | <u>486,388</u> | <u>1,673,430</u> | <u>50,842,626</u> |
| 20. Unit Service Factor | <u>80.7</u> | <u>93.4</u> | <u>72.7</u> |
| 21. Unit Avail Factor | <u>80.7</u> | <u>93.4</u> | <u>72.7</u> |
| 22. Unit Cap Factor (MDC Net) | <u>80.4</u> | <u>94.2</u> | <u>69.7*</u> |
| 23. Unit Cap Factor (DER Net) | <u>78.9</u> | <u>92.4</u> | <u>67.7</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>9.4</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>6,823.1</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 05/09/88

 * FARLEY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 FARLEY 1



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* FARLEY 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|------------------|---|
| 001 | 03/26/88 | S | 143.9 | C | 1 | | | UNIT WAS TAKEN OFF LINE FOR THE CYCLE 8-9 REFUELING OUTAGE. |

***** FARLEY 1 BEGAN SCHEDULED REFUELING OUTAGE IN MARCH.
* SUMMARY *

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

 * FARLEY 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
 STATE.....ALABAMA
 COUNTY.....HOUSTON
 DIST AND DIRECTION FROM
 NEAREST POPULATION CTR...18 MI SE OF
 DOTHAN, ALA
 TYPE OF REACTOR.....PWR
 DATE INITIAL CRITICALITY...AUGUST 9, 1977
 DATE ELEC ENER 1ST GENER...AUGUST 18, 1977
 DATE COMMERCIAL OPERATE...DECEMBER 1, 1977
 CONDENSER COOLING METHOD...COOLING TOWER
 CONDENSER COOLING WATER...CHATAHOOCHEE RIVER
 ELECTRIC RELIABILITY
 COUNCIL.....SOUTHEASTERN ELECTRIC
 RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
 LICENSEE.....ALABAMA POWER CO.
 CORPORATE ADDRESS.....600 NORTH 18TH STREET
 BIRMINGHAM, ALABAMA 35203
 CONTRACTOR
 ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED
 NUC STEAM SYS SUPPLIER...WESTINGHOUSE
 CONSTRUCTOR.....DANIEL INTERNATIONAL
 TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
 IE RESIDENT INSPECTORW. BRADFORD
 LICENSING PROJ MANAGER.....E. REEVES
 DOCKET NUMBER.....50-348
 LICENSE & DATE ISSUANCE. ...NPF-2, JUNE 25, 1977
 PUBLIC DOCUMENT ROOM.....HOUSTON/LOVE MEMORIAL LIBRARY
 212 W. BURDESHAW STREET
 DOTHAN, ALABAMA 36302

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

* INSPECTION DECEMBER 16-18 (87-57): THIS SPECIAL, ANNOUNCED INSPECTION WAS CONDUCTED TO FOLLOWUP ON ALLEGATIONS REGARDING THE RADIATION PROTECTION PROGRAM. ONE LICENSEE IDENTIFIED VIOLATION FOR FAILURE OF A LICENSEE EMPLOYEE TO SIGN IN ON A RADIATION WORK PERMIT (RWP).

INSPECTION FEBRUARY 29 - MARCH 4 (88-06): THIS ROUTINE, UNANNOUNCED INSPECTION WAS TO ASSESS THE OPERATIONAL READINESS OF THE SITE EMERGENCY PREPAREDNESS PROGRAM SINCE THE MARCH 1985 INSPECTION MEET NRC REQUIREMENTS, COMMITMENTS, AND THE AFFECT OF CHANGES ON THE OVERALL STATE OF EMERGENCY PREPAREDNESS. ONE VIOLATION WAS IDENTIFIED - FAILURE TO PROVIDE PERSONNEL DESIGNATED AS OPERATIONS SHIFT AIDE ANNUAL COMMUNICATION TRAINING.

INSPECTION FEBRUARY 11 - MARCH 10 (88-07): THIS ROUTINE, ON-SITE INSPECTION INVOLVED A REVIEW OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY SYSTEM INSPECTION, RADIOLOGICAL PROTECTION PROGRAM AND PHYSICAL SECURITY PROGRAM. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.8.1, FOUR SAFETY-RELATED BREAKERS WERE NOT IN THE POSITION SPECIFIED BY PROCEDURE AND ANOTHER PROCEDURE DID NOT ADEQUATELY SPECIFY FLOW PATH VERIFICATION. CONTRARY TO TS 5.7.11.2, ON JANUARY 19 AND 20, UNIT 1 FIRE SUPPRESSION SYSTEM WAS

Report Period MAR 1988

REPORTS FROM LICENSEE

* FARLEY 1 *

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|--|
| 88-004 | 02/19/88 | 03/17/88 | PERSONNEL ERROR RESULTS IN REQUIRED FIRE WATCH PATROL NOT BEING ESTABLISHED WITHIN THE REQUIRED TIME |
| 88-005 | 02/26/88 | 03/21/88 | FIRE DOOR 453 INOPERABLE FOR MORE THAN SEVEN DAYS |
| 88-006 | 03/01/88 | 03/31/88 | POTENTIAL INOPERABILITY OF THE A TRAIN CHARGING PUMP DUE TO GAS ACCUMULATION |
| 88-007 | 03/06/88 | 04/04/88 | TECH SPEC 3.0.3 ENTERED WHILE SWITCHING THE ALIGNMENT OF THE BATTERY CHARGER FROM ONE TRAIN TO THE OTHER |

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-364 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. D. WOODARD (205) 899-5156

4. Licensed Thermal Power (MWT): 2652

5. Nameplate Rating (Gross MWe): 860

6. Design Electrical Rating (Net MWe): 829

7. Maximum Dependable Capacity (Gross MWe): 864

8. Maximum Dependable Capacity (Net MWe): 823

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>58,489.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>50,072.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>138.4</u> |
| 15. Hrs Generator On-line | <u>744.0</u> | <u>2,184.0</u> | <u>49,432.5</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,973,062</u> | <u>5,751,493</u> | <u>126,703,613</u> |
| 18. Gross Elec Ener (MWH) | <u>656,162</u> | <u>1,917,152</u> | <u>41,120,246</u> |
| 19. Net Elec Ener (MWH) | <u>625,996</u> | <u>1,827,862</u> | <u>38,979,600</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>84.5</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>84.5</u> |
| 22. Unit Cap Factor (MDC Net) | <u>102.2</u> | <u>101.7</u> | <u>81.0</u> |
| 23. Unit Cap Factor (DER Net) | <u>101.5</u> | <u>101.0</u> | <u>80.4</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>5.2</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>2,690.4</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* FARLEY 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FARLEY 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* FARLEY 2 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

FARLEY 2 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES
OR SIGNIFICANT POWER REDUCTIONS.

| <u>Type</u> | <u>Reason</u> | <u>Method</u> | <u>System & Component</u> |
|-------------|--|----------------|-------------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | F-Maint or Test | 2-Manual Scram | Instructions for |
| | G-Oper Error | 3-Auto Scram | Preparation of |
| | C-Refueling | 4-Continued | Data Entry Sheet |
| | H-Other | 5-Reduced Load | Licensee Event Report |
| | D-Regulatory Restriction | 9-Other | (LER) File (NUREG-0161) |
| | E-Operator Training & license Examination | | |

* FARLEY 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA

COUNTY.....HOUSTON

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...28 MI SE OF
DOTHAN, ALA

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...MAY 5, 1981

DATE ELEC ENER 1ST GENER...MAY 25, 1981

DATE COMMERCIAL OPERATE...JULY 30, 1981

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER...CHATAHOOCHEE RIVER

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ALABAMA POWER CO.

CORPORATE ADDRESS.....600 NORTH 18TH STREET
BIRMINGHAM, ALABAMA 35203

CONTRACTOR
ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....W. BRADFORD

LICENSING PROJ MANAGER.....E. REEVES
DOCKET NUMBER.....50-364

LICENSE & DATE ISSUANCE...NPF-8, MARCH 31, 1981

PUBLIC DOCUMENT ROOM.....HOUSTON/LOVE MEMORIAL LIBRARY
212 W. BURDESHAW STREET
DOTHAN, ALABAMA 36302

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 16-18 (87-37): THIS SPECIAL, ANNOUNCED INSPECTION WAS CONDUCTED TO FOLLOWUP ON ALLEGATIONS REGARDING THE RADIATION PROTECTION PROGRAM. ONE LICENSEE IDENTIFIED VIOLATION FOR FAILURE OF A LICENSEE EMPLOYEE TO SIGN IN ON A RADIATION WORK PERMIT (RWP).

INSPECTION FEBRUARY 29 - MARCH 4 (88-06): THIS ROUTINE, UNANNOUNCED INSPECTION WAS TO ASSESS THE OPERATIONAL READINESS OF THE SITE EMERGENCY PREPAREDNESS PROGRAM SINCE THE MARCH 1985 INSPECTION MEET NRC REQUIREMENTS, COMMITMENTS, AND THE AFFECT OF CHANGES ON THE OVERALL STATE OF EMERGENCY PREPAREDNESS. ONE VIOLATION WAS IDENTIFIED - FAILURE TO PROVIDE PERSONNEL DESIGNATED AS OPERATIONS SHIFT AIDE ANNUAL COMMUNICATION TRAINING.

INSPECTION FEBRUARY 11 - MARCH 10 (88-07): THIS ROUTINE, ON-SITE INSPECTION INVOLVED A REVIEW OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY SYSTEM INSPECTION, RADIOLOGICAL PROTECTION PROGRAM AND PHYSICAL SECURITY PROGRAM. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TECHNICAL SPECIFICATION 6.8.1, FNP-0-AP-6, PROCEDURE ADHERENCE, AND FNP-0-AP-16, CONDUCT OF OPERATIONS, FNP-0-AP-52, EQUIPMENT STATUS CONTROL AND MAINTENANCE AUTHORIZATION AND FNP-0-AP-5, SURVEILLANCE PROGRAM ADMINISTRATIVE CONTROL. ON NOVEMBER

1. Docket: 50-341 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: P. M. ANTHONY (313) 586-1617

4. Licensed Thermal Power (MWh): 3292

5. Nameplate Rating (Gross MWe): 1215

6. Design Electrical Rating (Net MWe): 1093

7. Maximum Dependable Capacity (Gross MWe): 1093

8. Maximum Dependable Capacity (Net MWe): 1093

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|--------------|------------------|------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>1,646.0</u> | <u>1,646.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>830.7</u> | <u>830.7</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>830.3</u> | <u>830.3</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>0</u> | <u>2,066,876</u> | <u>2,066,876</u> |
| 18. Gross Elec Ener (MWH) | <u>0</u> | <u>670,845</u> | <u>670,845</u> |
| 19. Net Elec Ener (MWH) | <u>0</u> | <u>639,601</u> | <u>639,601</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>50.4</u> | <u>50.4</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>50.4</u> | <u>50.4</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>35.6</u> | <u>35.6</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>35.6</u> | <u>35.6</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>7.9</u> | <u>7.9</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>71.7</u> | <u>71.7</u> |

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Start-up Date: 04/15/88

 * FERM1 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FERMI 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* FERM I 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|------------------|--|
| 88-01 | 02/27/88 | S | 744.0 | B | 4 | | | CURRENTLY FERMI 2 IS IN AN LLRT OUTAGE. WORK IS CONTINUING ON SCHEDULE AND WILL BE COMPLETED APRIL 15, 1988. |

* SUMMARY *

FERMI 2 REMAINED SHUTDOWN IN MARCH, IN AN LLRT OUTAGE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced load | licensee Event Report |
| | & license Examination | 9-Other | (LER) File (NUREG-0161) |

* FERM I 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN
COUNTY.....MONROE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...LAGUNA BEACH, MICH
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JUNE 21, 1985
DATE ELEC ENER 1ST GENER...SEPTEMBER 21, 1986
DATE COMMERCIAL OPERATE...JANUARY 23, 1988
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ERIE
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DETROIT EDISON
CORPORATE ADDRESS.....2000 SECOND AVENUE
DETROIT, MICHIGAN 48226
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....DANIEL INTERNATIONAL
TURBINE SUPPLIER.....NONE

REGULATORY INFORMATION

IE REGION RESPONSIBLE...III
IE RESIDENT INSPECTOR.....W. ROGERS
LICENSING PROJ MANAGER.....T. QUAY
DOCKET NUMBER.....50-341
LICENSE & DATE ISSUANCE...MPF-43, JULY 15, 1985
PUBLIC DOCUMENT ROOM.....MONROE COUNTY LIBRARY SYSTEM
3700 SOUTH CUSTER ROAD
MONROE, MI. 48161

INSPECTION SUMMARY

I N S P E C T I O N S T A T U S

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

1. Docket: 50-333 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. COOK (315) 349-6569

4. Licensed Thermal Power (Mwt): 2436

5. Nameplate Rating (Gross MWe): 981 X 0.9 = 883

6. Design Electrical Rating (Net MWe): 816

7. Maximum Dependable Capacity (Gross MWe): 805

8. Maximum Dependable Capacity (Net MWe): 778

9. If Changes Occur Above Since Last Report, Give Reasons:
ITEM 7 & 8 RECALCULATED USING PREVIOUS YEARS DATA.

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>111,145.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>1,802.3</u> | <u>81,455.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>1,762.9</u> | <u>79,116.3</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,738,848</u> | <u>4,170,240</u> | <u>171,396,556</u> |
| 18. Gross Elec Ener (MWH) | <u>596,590</u> | <u>1,429,020</u> | <u>58,036,420</u> |
| 19. Net Elec Ener (MWH) | <u>575,080</u> | <u>1,377,000</u> | <u>56,155,470</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>80.7</u> | <u>71.2</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>80.7</u> | <u>71.2</u> |
| 22. Unit Cap Factor (MDC Net) | <u>99.4</u> | <u>80.0</u> | <u>65.0*</u> |
| 23. Unit Cap Factor (DER Net) | <u>94.7</u> | <u>77.3</u> | <u>61.9</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>11.4</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>10,337.5</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUEL - AUGUST 6, 1988 - DURATION 75 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

 * FITZPATRICK *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 FITZPATRICK



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * FITZPATRICK *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 2 | 03/16/88 | F | 0.0 | A | 5 | | JK | SC | REDUCED POWER TO REPAIR "B" REACTOR FEED PUMP SPEED CONTROL. CLEANED CLOGGED HYDRAULIC LINE, TESTED, AND RETURNED TO FULL POWER OPERATION. |

 * SUMMARY *

 FITZPATRICK INCURREDD 1 POWER REDUCTION IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0'61) |

* FITZPATRICK *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....OSWEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...8 MI NE OF
OSWEGO, NY
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...NOVEMBER 17, 1974
DATE ELEC ENER 1ST GENER...FEBRUARY 1, 1975
DATE COMMERCIAL OPERATE...JULY 28, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ONTARIO
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NEW YORK POWER AUTHORITY
CORPORATE ADDRESS.....10 COLUMBUS CIRCLE
NEW YORK, NEW YORK 10019
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....A. LUPTAK
LICENSING PROJ MANAGER....H. ABELSON
DOCKET NUMBER.....50-333
LICENSE & DATE ISSUANCE...DPR-59, OCTOBER 17, 1974
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO
PENFIELD LIBRARY - GOVERNMENT DOCUMENTS COL
OSWEGO, NY 13126
(315) 341-2323

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

1. Docket: 50-285 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: T. P. MATTHEWS (402) 536-4733

4. Licensed Thermal Power (MWT): 1500

5. Nameplate Rating (Gross MWe): 591 X 0.85 = 502

6. Design Electrical Rating (Net MWe): 478

7. Maximum Dependable Capacity (Gross MWe): 502

8. Maximum Dependable Capacity (Net MWe): 478

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|----------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>127,249.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>99,743.8</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>1,309.5</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,184.0</u> | <u>98,052.9</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>782,732</u> | <u>2,720,012</u> | <u>127,249,629</u> |
| 18. Gross Elec Ener (MWH) | <u>262,560</u> | <u>924,842</u> | <u>42,209,618</u> |
| 19. Net Elec Ener (MWH) | <u>246,382</u> | <u>876,573</u> | <u>40,020,641</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>77.1</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>77.1</u> |
| 22. Unit Cap Factor (MDC Net) | <u>69.3</u> | <u>84.0</u> | <u>67.9*</u> |
| 23. Unit Cap Factor (DER Net) | <u>69.3</u> | <u>84.0</u> | <u>65.8</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>3.0</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>1,857.6</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING - SEPTEMBER 2, 1988 - DURATION 76 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

* FORT CALHOUN 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FORT CALHOUN 1



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * FORT CALHOUN 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 88-01 | 02/12/88 | S | 0.0 | H | 5 | | BK | FAN | ON FEBRUARY 12, 1988, A POWER REDUCTION COMMENCED TO REPAIR A NUCLEAR DETECTOR WELL COOLING FAN IN CONTAINMENT. POWER WAS HELD AT 35% WHILE REPAIRS WERE MADE AND POWER WAS THEN RETURNED TO 70% ON FEBRUARY 15, 1988. POWER WILL REMAIN AT 70% FOR APPROXIMATELY SEVEN WEEKS TO EXTEND THE FUEL BURNUP WINDOW TO THE DESIRED SHUTDOWN DATE IN SEPTEMBER 1988. |

 * SUMMARY *

 FORT CALHOUN OPERATED AT APPROXIMATELY 70% POWER DURING MARCH AS DISCUSSED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

INSPECTION SUMMARY

IDENTIFIED.

INSPECTION CONDUCTED FEB 22-26, 1988 (88-09) ROUTINE, UNANNOUNCED INSPECTION OF PENETRATION FIRE BARRIERS. WITHIN THE AREA INSPECTED, ONE POTENTIAL VIOLATION WAS IDENTIFIED (NONFUNCTIONAL PENETRATION FIRE BARRIERS PROTECTING SAFETY-RELATED AREAS).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

AN ENFORCEMENT CONFERENCE WAS HELD IN REGION IV ON MARCH 15, 1988 TO DISCUSS MISSING ELECTRICAL CONDINT FIRE BARRIERS.

AN ENFORCEMENT CONFERENCE WAS HELD IN REGION IV ON MARCH 21, 1988 TO DISCUSS HEALTH PHYSICS RELATED ISSUES.

PLANT STATUS:

HOLDING AT 70% POWER FOR FUEL CONSERVATION

LAST SITE INSPECTION DATE: FEB. 29, 1988

INSPECTION REPORT NO: 50-285/88-07

R E P O R T S F R O M L I C E N S E E

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|---------|
| NONE | | | |

1. Docket: 50-267 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: FRANK NOVACHEK (303) 785-2224

4. Licensed Thermal Power (MWt): 812

5. Nameplate Rating (Gross MWe): 403 X 0.85 = 343

6. Design Electrical Rating (Net MWe): 330

7. Maximum Dependable Capacity (Gross MWe): 342

8. Maximum Dependable Capacity (Net MWe): 330

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): 271

11. Reasons for Restrictions, If Any:
REANALYSIS OF SAFE SHUTDOWN COOLING.

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|----------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>76,729.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,149.1</u> | <u>35,550.8</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>739.1</u> | <u>2,102.3</u> | <u>23,683.3</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>455,972</u> | <u>1,059,218</u> | <u>11,880,631</u> |
| 18. Gross Elec Ener (MWH) | <u>169,126</u> | <u>401,160</u> | <u>3,943,674</u> |
| 19. Net Elec Ener (MWH) | <u>160,184</u> | <u>378,278</u> | <u>3,507,253</u> |
| 20. Unit Service Factor | <u>99.3</u> | <u>96.3</u> | <u>30.9</u> |
| 21. Unit Avail Factor | <u>99.3</u> | <u>96.3</u> | <u>30.9</u> |
| 22. Unit Cap Factor (MDC Net) | <u>65.2</u> | <u>52.5</u> | <u>13.9</u> |
| 23. Unit Cap Factor (DER Net) | <u>65.2</u> | <u>52.5</u> | <u>13.9</u> |
| 24. Unit Forced Outage Rate | <u>.7</u> | <u>3.7</u> | <u>62.1</u> |
| 25. Forced Outage Hours | <u>4.9</u> | <u>81.7</u> | <u>38,758.3</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
HELIUM CIRC REPAIRS-JULY 5, 1988-DURATION 91 DAYS

27. If Currently Shutdown Estimated Startup Date: N/A

* FORT ST VRAIN *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FORT ST VRAIN



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* FORT ST VRAIN *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 88-06 | 03/29/88 | F | 4.9 | A | 9 | | XX | XXXXXX | TURBINE TRIP ON LOW MAIN STEAM TEMPERATURE FOLLOWING TRIP OF 'C' HELIUM CIRCULATOR. |

* SUMMARY *

FORT ST. VRAIN OPERATED AT A RESTRICTED POWER LEVEL DURING MARCH AND INCURRED ONE FORCED OUTAGE AS DISCUSSED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* FORT ST VRAIN *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....COLORADO
COUNTY.....WELD
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...35 MI N OF
DENVER, COL
TYPE OF REACTOR.....HTGR
DATE INITIAL CRITICALITY...JANUARY 31, 1974
DATE ELEC ENER 1ST GENER...DECEMBER 11, 1976
DATE COMMERCIAL OPERATE...JULY 1, 1979
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...S. PLATTE RIVER
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PUBLIC SERVICE OF COLORADO
CORPORATE ADDRESS.....P.O. BOX 840
DENVER, COLORADO 80201
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ATOMIC CORP.
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....R. FARRELL
LICENSING PROJ MANAGER.....K. HEITNER
DOCKET NUMBER.....50-267
LICENSE & DATE ISSUANCE...DPR-34, DECEMBER 21, 1973
PUBLIC DOCUMENT ROOM.....GREELEY PUBLIC LIBRARY
CITY COMPLEX BUILDING
GREELEY, COLORADO 80631

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED FEB 1-29, 1988 (88-03) ROUTINE, UNANNOUNCED INSPECTION OF FOLLOWUP OF LICENSEE ACTION ON PREVIOUSLY IDENTIFIED INSPECTION FINDINGS, OPERATIONAL SAFETY VERIFICATION, FOLLOWUP OF UNUSUAL EVENT, ENGINEERED SAFETY FEATURES WALKDOWN, MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, RADIOLOGICAL PROTECTION, AND PHYSICAL SECURITY OBSERVATION. WITHIN THE EIGHT AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED (THE FAILURE TO IMPLEMENT AND FOLLOW PROCEDURES FOR MAINTENANCE AND OPERATIONS ACTIVITIES).

ENFORCEMENT SUMMARY

FAILURE TO MAKE MANAGEMENT NOTIFICATIONS REQUIRED BY SEC.2.1 AND ATTACHMENT 2 OF FT.ST.VRAIN MEDICAL EMERGENCY PROCEDURE, ISSUE 20.
(8702 5)

LACK OF PROCEDURAL CONTROLS - INADEQUATE PROCEDURES, 2 EXAMPLES; FAILURE TO FOLLOW PROCEDURES -
(8703 4)

OTHER ITEMS

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

A MANAGEMENT MEETING WAS HELD IN REGION IV WITH PSCO PERSONNEL ON MAR 3, 1988, TO DISCUSS THE INTERCHANGING OF HELIUM INTO THE CORE SUPPORT FLOOR, AND THE HELIUM CIRCULATOR QA PROGRAM.

PLANT STATUS:

POWER OPERATION

LAST IE SITE INSPECTION DATE: FEB 29, 1988

INSPECTION REPORT NO: 50-267/88-03

R E P O R T S F R O M L I C E N S E E

```

=====
NUMBER      DATE OF      DATE OF      SUBJECT
            EVENT        REPORT
-----
87-030      12/13/87    01/12/87    TECH. SPEC. SURVEILLANCE NOT PERFORMED WITHIN REQUIRED INTERVAL
87-031      12/25/87    01/25/88    HOT REHEAT TEMPERATURE SCRAM DUE TO OPERATOR INATTENTION
=====

```


1. Docket: 50-244 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: ANDREW MC NAMARA (315) 524-4446

4. Licensed Thermal Power (Mwt): 1520

5. Nameplate Rating (Gross MWe): 608 X 0.85 = 517

6. Design Electrical Rating (Net MWe): 470

7. Maximum Dependable Capacity (Gross MWe): 490

8. Maximum Dependable Capacity (Net MWe): 470

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|----------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>160,824.0</u> |
| 13. Hours Reactor Critical | <u>307.3</u> | <u>1,166.2</u> | <u>125,184.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>1,687.7</u> |
| 15. Hrs Generator On-Line | <u>243.2</u> | <u>1,101.5</u> | <u>122,749.2</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>8.5</u> |
| 17. Gross Therm Ener (MWH) | <u>223,258</u> | <u>1,378,978</u> | <u>172,306,311</u> |
| 18. Gross Elec Ener (MWH) | <u>71,848</u> | <u>462,555</u> | <u>56,590,141</u> |
| 19. Net Elec Ener (MWH) | <u>66,631</u> | <u>436,370</u> | <u>53,647,655</u> |
| 20. Unit Service Factor | <u>32.7</u> | <u>50.4</u> | <u>76.3</u> |
| 21. Unit Avail Factor | <u>32.7</u> | <u>50.4</u> | <u>76.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>19.1</u> | <u>42.5</u> | <u>72.4*</u> |
| 23. Unit Cap Factor (DER Net) | <u>19.1</u> | <u>42.5</u> | <u>72.4*</u> |
| 24. Unit Forced Outage Rate | <u>48.6</u> | <u>17.2</u> | <u>6.4</u> |
| 25. Forced Outage Hours | <u>229.5</u> | <u>229.5</u> | <u>4,553.9</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* GINNA *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

GINNA



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * GINNA *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 88-1 | 03/12/88 | S | 270.8 | C | 4 | | | | ANNUAL REFUELING AND MAINTENANCE. |
| 88-2 | 03/13/88 | S | 0.5 | B | 1 | | HA | TURBIN | TURBINE OVERSPEED TRIP TEST. NOTE: REACTOR REMAINS CRITICAL. |
| 88-3 | 03/14/88 | F | 229.5 | A | 1 | 88-004 | CA | HTEXCH | "B" STEAM GENERATOR TUBE LEAK. |
| 88-4 | 03/26/88 | F | 0.0 | A | 5 | | CH | PUMPXX | IMPELLER DAMAGE TO "A" MAIN FEEDWATER PUMP, OUT OF SERVICE. |

 * SUMMARY *

 GINNA COMPLETED REFUELING DURING MARCH AND SUBSEQUENTLY INCURRED 2 OUTAGES AND 1 POWER REDUCTION WHILE ESCALATING TO POWER.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & N |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* GINNA *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....WAYNE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...15 MI NE OF
ROCHESTER, NY
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 8, 1969
DATE ELEC ENER 1ST GENER...DECEMBER 2, 1969
DATE COMMERCIAL OPERATE...JULY 1, 1970
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ONTARIO
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ROCHESTER GAS & ELECTRIC
CORPORATE ADDRESS.....89 EAST AVENUE
ROCHESTER, NEW YORK 14604
CONTRACTOR
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....C. MARSCHALL
LICENSING PROJ MANAGER.....C. STAHL
DOCKET NUMBER.....50-244
LICENSE & DATE ISSUANCE...DPR-18, DECEMBER 10, 1984
PUBLIC DOCUMENT ROOM.....ROCHESTER PUBLIC LIBRARY
BUSINESS AND SOCIAL SCIENCE DIVISION
115 SOUTH AVENUE
ROCHESTER, NEW YORK 14610

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

1. Docket: 50-416 OPERATING STATUS
 2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
 3. Utility Contact: S. H. HOBBS (601) 969-2458
 4. Licensed Thermal Power (MWt): 3833
 5. Nameplate Rating (Gross MWe): 1373
 6. Design Electrical Rating (Net MWe): 1250
 7. Maximum Dependable Capacity (Gross MWe): 1190
 8. Maximum Dependable Capacity (Net MWe): 1142
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):
 11. Reasons for Restrictions, If Any:

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|-----------|-----------|------------|
| 12. Report Period Hrs | 744.0 | 2,184.0 | 24,121.0 |
| 13. Hours Reactor Critical | 727.3 | 1,969.9 | 17,681.2 |
| 14. Rx Reserve Shtdwn Hrs | .0 | .0 | .0 |
| 15. Hrs Generator On-Line | 714.8 | 1,839.5 | 16,962.5 |
| 16. Unit Reserve Shtdwn Hrs | .0 | .0 | .0 |
| 17. Gross Therm Ener (MWH) | 2,635,918 | 6,618,385 | 55,814,057 |
| 18. Gross Elec Ener (MWH) | 869,520 | 2,199,130 | 17,390,540 |
| 19. Net Elec Ener (MWH) | 835,623 | 2,112,074 | 16,591,268 |
| 20. Unit Service Factor | 96.1 | 84.2 | 70.3 |
| 21. Unit Avail Factor | 96.1 | 84.2 | 70.3 |
| 22. Unit Cap Factor (MDC Net) | 98.3 | 84.7 | 60.2 |
| 23. Unit Cap Factor (DER Net) | 89.9 | 77.4 | 55.0 |
| 24. Unit Forced Outage Rate | 3.9 | 10.7 | 7.3 |
| 25. Forced Outage Hours | 29.2 | 221.2 | 1,329.4 |

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * GRAND GULF 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

GRAND GULF 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * GRAND GULF 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|------------------|--|
| 88-3 | 03/12/88 | S | 0.0 | H | 5 | | | CONTROL ROD SEQUENCE EXCHANGE. |
| 88-4 | 03/15/88 | F | 29.2 | A | 3 | 88-010 | JC | THE REACTOR SCRAMMED ON LOW WATER LEVEL DURING THE MONTHLY CHANNEL FUNCTIONAL SURVEILLANCE FOR THE HIGH/LOW REACTOR WATER LEVEL INSTRUMENTATION. A LOOSE CONNECTION IN A REACTOR PROTECTION SYSTEM (RPS) TERMINAL BOX DEENERGIZED 29 GROUP 3 SCRAM PILOT SOLENOIDS. WHEN A PLANNED HALF SCRAM SIGNAL, REQUIRED BY THE SURVEILLANCE PROCEDURE, WAS INITIATED, 29 OF THE GROUP 3 CONTROL RODS RECEIVED A FULL SCRAM SIGNAL AND FULLY INSERTED. THE RESULTING SUDDEN VOID COLLAPSE CAUSED A FULL SCRAM ON LOW WATER LEVEL. THE CONNECTIONS IN THE TERMINAL BOX WERE CLEANED AND RETIGHTENED AND SIMILAR CONNECTIONS WERE INSPECTED. |

 * SUMMARY *

 GRAND GULF 1 INCURRED 1 OUTAGE AND 1 POWER REDUCTION IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* GRAND GULF 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....MISSISSIPPI
COUNTY.....CLAIBORNE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI S OF
VICKSBURG, MISS
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...AUGUST 18, 1982
DATE ELEC ENER 1ST GENER...OCTOBER 20, 1984
DATE COMMERCIAL OPERATE...JULY 1, 1985
CONDENSER COOLING METHOD...CCHNDCT
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY
LICENSEE.....MISSISSIPPI POWER & LIGHT COMPANY
CORPORATE ADDRESS.....P.O. BOX 1640
JACKSON, MISSISSIPPI 39205
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....ALLIS-CHALMERS

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....R. BUTCHER
LICENSING PROJ MANAGER.....L. KINTNER
DOCKET NUMBER.....50-416
LICENSE & DATE ISSUANCE...NPF-29, NOVEMBER 1, 1984
PUBLIC DOCUMENT ROOM.....HINDS JUNIOR COLLEGE
MC LENDON LIBRARY
RAYMOND, MISSISSIPPI 39154

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

* INSPECTION DECEMBER 14-18 (87-32): THIS SPECIAL, ANNOUNCED INSPECTION WAS IN THE AREA OF ENVIRONMENTAL QUALIFICATION (EQ) OF ELECTRICAL EQUIPMENT AND INCLUDED A REVIEW OF SYSTEM ENERGY RESOURCES, INC'S (SERI) IMPLEMENTATION OF REQUIREMENTS OF 10 CFR 50.49 FOR GRAND GULF NUCLEAR STATION (GGNS) AND AN INSPECTION OF ELECTRICAL EQUIPMENT WITHIN THE SCOPE OF 10 CFR 50.49. ENVIRONMENTAL QUALIFICATION (EQ) FOR ELECTRICAL EQUIPMENT WAS INITIALLY REQUIRED TO MEET NUREG 0588 CATEGORY II REQUIREMENTS. THE ELECTRICAL EQUIPMENT REQUIRING ENVIRONMENTAL QUALIFICATION AT GGNS IS QUALIFIED TO THE REQUIREMENTS OF NUREG 0588 CATEGORY I OR CATEGORY II. THE NRC INSPECTORS EXAMINED SYSTEM ENERGY RESOURCES, INC. (SERI) PROGRAM FOR ESTABLISHING THE QUALIFICATION OF EQUIPMENT WITHIN THE SCOPE OF 10 CFR 50.49. THE PROGRAM WAS EVALUATED BY AN EXAMINATION OF SERI'S QUALIFICATION DOCUMENTATION FILES, REVIEW OF PROCEDURES FOR CONTROLLING THE EQ EFFORT, AND VERIFICATION OF ADEQUACY AND ACCURACY OF THE PROGRAM FOR MAINTAINING THE QUALIFIED STATUS OF THE APPLICABLE EQUIPMENT AT GRAND GULF. BASED ON THE INSPECTION FINDINGS, WHICH ARE DISCUSSED IN THE REPORT, THE INSPECTION TEAM DETERMINED THAT SERI HAS IMPLEMENTED A PROGRAM TO MEET THE REQUIREMENTS OF 10 CFR 50.49 FOR GRAND GULF ALTHOUGH SOME DEFICIENCIES WERE IDENTIFIED. FOUR VIOLATIONS WERE IDENTIFIED: COMMERCIAL GRADE COMPONENTS INSTALLED IN EQ EQUIPMENT; LIMITOQUE MOV, T-DRAINS AND GREASE RELIEF VALVES; RAYCHEM HEAT SHRINK TUBING IN UNQUALIFIED CONFIGURATIONS; AND QUALIFICATION PACKAGE FOR LUBRICANTS.

INSPECTION JANUARY 16 - FEBRUARY 19 (88-01): THIS ROUTINE INSPECTION WAS CONDUCTED BY THE RESIDENT INSPECTORS AT THE SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, ESF SYSTEM WALKDOWN, REPORTABLE OCCURRENCES, OPERATING REACTOR EVENTS, INSPECTOR FOLLOWUP AND UNRESOLVED ITEMS AND A MANAGEMENT MEETING. ONE VIOLATION WAS IDENTIFIED: FAILURE TO FOLLOW PROCEDURE FOR PROPERLY STORING NITROGEN CHARGING BOTTLES INSIDE CONTAINMENT.

INSPECTION SUMMARY

INSPECTION JANUARY 25-29 (88-02): THIS ROUTINE, UNANNOUNCED PHYSICAL SECURITY INSPECTION INCLUDED A REVIEW OF THE LICENSEE'S RESPONSE AND ACTIONS RELATIVE TO A BARRIER OPENING WHICH EXCEEDED THE 96 SQUARE INCH CRITERIA. IN ADDITION, A REVIEW AND EVALUATION OF PERTINENT SECURITY DOCUMENTATION WAS CONDUCTED IN AN ATTEMPT TO SUBSTANTIATE SEVERAL ALLEGATIONS RELATING TO IMPROPRIETIES IN SECURITY FORCE OPERATIONS. IN THIS REGARDING, THE FOLLOWING FUNCTIONAL AREAS OF PHYSICAL SECURITY ACIIVITIES WERE REVIEWED: MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM; SECURITY ORGANIZATION; RECORDS AND REPORTS; PHYSICAL BARRIERS - PROTECTED AREAS; PHYSICAL BARRIERS - VITAL AREAS; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL; ACCESS CONTROL - VEHICLES; DETECTION AIDS; ALARM STATION AND PERSONNEL TRAINING AND QUALIFICATION GENERAL REQUIREMENTS. NO VIOLATIONS OF REGULATORY REQUIREMENTS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

IN STARTUP FOLLOWING REFUELING AND REPAIR OF NO. 10 MAIN GENERATOR BEARING.

LAST IE SITE INSPECTION DATE: JANUARY 25-29, 1988 +

INSPECTION REPORT NO: 50-416/88-02 +

Report Period MAR 1988

R E P O R T S F R O M L I C E N S E E

* GRAND GULF 1 *

```
=====
```

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---|
| 88-003 | 01/09/88 | 02/08/88 | EMERGENCY CORE COOLING SYSTEMS DELTA PRESSURE INSTRUMENTATION NO CALIBRATED IN ACCORDANCE WITH TECHNICAL SPECIFICATIONS |
| 88-006 | 01/20/88 | 02/19/88 | CONDENSER MANWAY LEAKAGE ON HOTWELL LOW LEVEL SWITCHES TRIPS ALL CONDENSER BOOSTER PUMPS; RX SCRAM ON LOW WATER LEVEL |
| 88-007 | 02/04/88 | 03/04/88 | FAILURE TO TAKE THE REQUIRED ACTION IN TECH SPECS FOR INOPERABLE RADIATION MONITOR ON STANDBY SERVICE WATER SYSTEM |
| 88-008 | 02/08/88 | 03/09/88 | MSIV-LCS DILUTION AIR INLET FOUND SEALED WITH TAPE |
| 88-009 | 02/27/88 | 03/29/88 | HYDROGEN IGNITION IN OFFGAS SYSEM WHILE SWAPPING STEAM JET AIR EJECTORS |

```
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-215 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. STANFORD (203) 267-2556 X452

4. Licensed Thermal Power (Mkt): 1825

5. Nameplate Rating (Gross MWe): 667 X 0.9 = 600

6. Design Electrical Rating (Net MWe): 582

7. Maximum Dependable Capacity (Gross MWe): 596

8. Maximum Dependable Capacity (Net MWe): 569

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------------|----------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>177,504.0</u> |
| 13. Hours Reactor Critical | <u>257.7</u> | <u>257.7</u> | <u>146,446.9</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>1,221.2</u> |
| 15. Hrs Generator On-Line | <u>129.0</u> | <u>129.0</u> | <u>140,329.1</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>398.0</u> |
| 17. Gross Therm Ener (MWH) | <u>82,124</u> | <u>82,124</u> | <u>242,852,128</u> |
| 18. Gross Elec Ener (MWH) | <u>25,330</u> | <u>25,330</u> | <u>79,805,708</u> |
| 19. Net Elec Ener (MWH) | <u>14,371</u> | <u>9,151</u> | <u>75,569,765</u> |
| 20. Unit Service Factor | <u>17.3</u> | <u>5.9</u> | <u>79.1</u> |
| 21. Unit Avail Factor | <u>17.3</u> | <u>5.9</u> | <u>79.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>3.4</u> | <u>.7</u> | <u>77.8*</u> |
| 23. Unit Cap Factor (DER Net) | <u>3.3</u> | <u>.7</u> | <u>73.2*</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>6.0</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>2,432.8</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REPLACE RCP NO.3 SEAL, 4/18/88, 6 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

* HADDAM NECK *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

HADDAM NECK



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * HADDAM NECK *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 87-03 | 07/18/87 | S | 614.1 | C | 4 | | RC | FUELXX | CONTINUATION OF REFUELING OUTAGE. |
| 88-01 | 03/27/88 | S | 0.9 | B | 1 | | | ZZZZZ | TURBINE OVERSPEED TRIP TEST. |

 * SUMMARY *

 HADDAM NECK ENTERED MONTH SHUTDOWN FOR REFUELING. RETURNED TO POWER, SUBSEQUENTLY INCURRED 1 POWER OUTAGE FOR TURBINE OVERSPEED TRIP TEST.

| Type | Reason | Method | System & Component |
|----------|--------------------------|--------------|-------------------------|
| F-Forced | A-Equip Failure | F-Admin | 1-Manual |
| S-Sched | B-Maint or Test | G-Oper Error | 2-Manual Scram |
| | C-Refueling | H-Other | 3-Auto Scram |
| | D-Regulatory Restriction | | 4-Continued |
| | E-Operator Training | | 5-Reduced Load |
| | & License Examination | | 9-Other |
| | | | Exhibit F & H |
| | | | Instructions for |
| | | | Preparation of |
| | | | Data Entry Sheet |
| | | | Licensee Event Report |
| | | | (LER) File (NUREG-0161) |

* HADDAM NECK *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....CONNECTICUT
COUNTY.....MIDDLESEX
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...13 MI E OF
MERIDEN, CONN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 24, 1967
DATE ELEC ENER 1ST GENER...AUGUST 7, 1967
DATE COMMERCIAL OPERATE...JANUARY 1, 1968
CONDENSER COOLING METHDD...ONCE THRU
CONDENSER COOLING WATER...CONNECTICUT RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CONNECTICUT YANKEE ATOMIC POWER
CORPORATE ADDRESS.....P.O. BOX 270
HARTFORD, CONNECTICUT 06101
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. SCHEDLOSKY
LICENSING PROJ MANAGER.....A. WANG
DOCKET NUMBER.....50-213
LICENSE & DATE ISSUANCE...DPR-61, DECEMBER 27, 1974
PUBLIC DOCUMENT ROOM.....RUSSELL LIBRARY
123 BROAD STREET
MIDDLETOWN, CONNECTITCUT 06457

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X HADDAM LECK X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------------------|------------------|-------------------|---------|
| ----- | | | |
| NO INPUT PROVIDED. | | | |

=====

1. Docket: 50-400 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: MARK W. HALE (919) 362-2944

4. Licensed Thermal Power (Mht): 2775

5. Nameplate Rating (Gross MWe): 950

6. Design Electrical Rating (Net MWe): 900

7. Maximum Dependable Capacity (Gross MWe): 920

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

Reasons for Restrictions, If Any:

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>8,041.0</u> |
| 13. Hours Reactor Critical | <u>554.2</u> | <u>1,994.2</u> | <u>6,449.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>542.4</u> | <u>1,982.4</u> | <u>6,306.0</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,446,278</u> | <u>5,463,104</u> | <u>16,573,245</u> |
| 18. Gross Elec Ener (MWH) | <u>485,132</u> | <u>1,835,783</u> | <u>5,501,001</u> |
| 19. Net Elec Ener (MWH) | <u>449,380</u> | <u>1,716,269</u> | <u>5,095,098</u> |
| 20. Unit Service Factor | <u>72.9</u> | <u>90.8</u> | <u>78.4</u> |
| 21. Unit Avail Factor | <u>72.9</u> | <u>90.3</u> | <u>78.4</u> |
| 22. Unit Cap Factor (MDC Net) | <u>70.2</u> | <u>91.4</u> | <u>73.7</u> |
| 23. Unit Cap Factor (DER Net) | <u>67.1</u> | <u>87.3</u> | <u>70.4</u> |
| 24. Unit Forced Outage Rate | <u>27.1</u> | <u>9.2</u> | <u>10.1</u> |
| 25. Forced Outage Hours | <u>201.6</u> | <u>201.6</u> | <u>704.9</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING-JULY 16, 1988-7 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

 * HARRIS 1 *

 AVERAGE DAILY POWER LEVEL (MWe) PLOT

HARRIS 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * HARRIS 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|--------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 88-006 | 03/09/88 | F | 21.4 | A | 3 | 88-07 | HH | ELECON | AUTOMATIC REACTOR SCRAM FROM 100% POWER DUE TO LOW STEAM GENERATOR LEVEL/STEAM FLOW FEED FLOW MISMATCH. THIS WAS CAUSED BY A LOOSE FUSE IN THE FEEDWATER ISOLATION CIRCUIT FOR THE "B" MAIN FEEDWATER REGULATING VALVE. THIS CAUSED THE REGULATING VALVE TO FAIL CLOSED. THE INVESTIGATION REVEALED A LOOSE RENEWABLE FUSE ON THE SOLENOID CAUSED LOSS OF CONTINUITY. THE FUSE WAS REPLACED WITH A RENEWABLE TYPE AND THE UNIT WAS RETURNED TO SERVICE. |
| 88-007 | 03/19/88 | F | 0.0 | A | 5 | | HJ | PIPEXX | LOAD REDUCTION TO 90% DUE TO THE TRIP OF A HEATER WATER PUMP. THE TRIP WAS DUE TO A FAILURE IN THE EXTRACTION STEAM SYSTEM DISCUSSED IN THE NEXT ENTRY. |
| 88-008 | 03/20/88 | F | 180.2 | A | 1 | | HJ | PIPEXX | WHILE INVESTIGATING ENTRY 88-007, SECONDARY CHEMISTRY PARAMETERS INDICATED A CONDENSER TUBE LEAK. THE UNIT WAS REMOVED FROM SERVICE TO INVESTIGATE. THE INVESTIGATION REVEALED DAMAGED EXTRACTION STEAM EXPANSION JOINTS ON THE LOW PRESSURE TURBINE. THE JOINTS WERE REPLACED WITH SPARES AND A STUDY IS UNDERWAY TO EVALUATE REPLACEMENT OF ALL EXTRACTION STEAM EXPANSION JOINTS WITH JOINTS OF A DIFFERENT TYPE OF MATERIAL IN A FUTURE OUTAGE. THE DAMAGED CONDENSER TUBES WERE PLUGGED AND THE UNIT WAS RETURNED TO FULL POWER. |

***** HARRIS 1 INCURRED 1 POWER REDUCTION AND 2 OUTAGES IN MARCH
 * SUMMARY *
 ***** FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|---|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | F-Admin | 2-Manual Scram | Instructions for |
| | B-Maint or Test | 3-Auto Scram | Preparation of |
| | G-Oper Error | 4-Continued | Data Entry Sheet |
| | C-Refueling | 5-Reduced Load | Licensee Event Report |
| | H-Other | 9-Other | (LER) File (NUREG-0161) |
| | D-Regulatory Restriction | | |
| | E-Operator Training & License Examination | | |

* HARRIS 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA
COUNTY.....WAKE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI SW OF
RALEIGH, NC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JANUARY 3, 1987
DATE ELEC ENER 1ST GENER...JANUARY 19, 1987
DATE COMMERCIAL OPERATE...MAY 2, 1987
CONDENSER COOLING METHOD...NDCT
CONDENSER COOLING WATER...MAKEUP RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CAROLINA POWER & LIGHT
CORPORATE ADDRESS.....336 FAYETTEVILLE STREET
RALEIGH, NORTH CAROLINA 27602
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DANIEL INTERNATIONAL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....S. MAXWELL
LICENSING PROJ MANAGER.....B. BUCKLEY
DOCKET NUMBER.....50-400
LICENSE & DATE ISSUANCE...NPF-63, JANUARY 12, 1987
PUBLIC DOCUMENT ROOM.....RICHARD B. HARRISON LIBRARY
1313 NLY BERM AVE.
RALEIGH, N. C., 27610

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JANUARY 22 - FEBRUARY 20 (88-03): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED INSPECTION IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, OPERATIONAL SAFETY VERIFICATION AND MONTHLY MAINTENANCE OBSERVATION. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

INSPECTION FEBRUARY 29 - MARCH 4 (88-05): THIS ROUTINE, UNANNOUNCED PHYSICAL SECURITY INSPECTION EXAMINED TH AREAS OF: SECURITY PLAN AND IMPLEMENTING PROCEDURES; MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM; SECURITY ORGANIZATION; RECORDS AND REPORTS; LOCKS, KEYS, AND COMBINATIONS; LIGHTING; ACCESS CONTROL - PERSONNEL AND VEHICLES; ALARM STATIONS; COMMUNICATIONS; ANND PERSONNEL TRAINING AND QUALIFICATION - GENERAL REQUIREMENTS. A VIOLATION WAS IDENTIFIED IN THE AREA OF ACCESS CONTROL - PERSONNEL AND VEHICLES.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* HATCH 1 *

| No. | Date | Type | Hours | Reason | Method | LEX Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|------------------|---|
|-----|------|------|-------|--------|--------|------------|------------------|---|

NONE

 * SUMMARY *

 HATCH 1 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES OR
 SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Sched | Instructions for |
| | C-Refueling | 3-Auto Sched | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* HATCH 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....GEORGIA

COUNTY.....APPLING

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI N OF
BAXLEY, GA

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...SEPTEMBER 12, 1974

DATE ELEC ENER 1ST GENER...NOVEMBER 11, 1974

DATE COMMERCIAL OPERATE...DECEMBER 31, 1975

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER...ALTAMAHA RIVER

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GEORGIA POWER

CORPORATE ADDRESS.....333 PIEDMONT AVENUE
ATLANTA, GEORGIA 30308

CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....GEORGIA POWER CO.

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....P. HOLMES RAY

LICENSING PROJ MANAGER.....L. CROCKER
DOCKET NUMBER.....50-321

LICENSE & DATE ISSUANCE...DPR-57, OCTOBER 13, 1974

PUBLIC DOCUMENT ROOM.....APPLING COUNTY PUBLIC LIBRARY
301 CITY HALL DRIVE
BAXLEY, GEORGIA 31513

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 7-10 (87-32): THIS SPECIAL, ANNOUNCED INSPECTION WAS AN EMERGENCY RESPONSE FACILITY APPRAISAL. AREAS EXAMINED DURING THE APPRAISAL INCLUDED A REVIEW OF SELECTED PROCEDURES AND REPRESENTATIVE RECORDS, THE ERFS AND RELATED EQUIPMENT, AND INTERVIEWS WITH LICENSEE PERSONNEL. SELECT ACTIVITIES WERE OBSERVED DURING THE 1987 ANNUAL EXERCISE TO ASCERTAIN THE ADEQUACY OF THE ERFS AND RELATED EQUIPMENT. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 25-29 (88-02): THIS ROUTINE, UNANNOUNCED PHYSICAL SECURITY INSPECTION INCLUDED A REVIEW AND EXAMINATION OF: MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM; SECURITY ORGANIZATION; SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; LOCKS, KEYS AND COMBINATIONS; SECURITY SYSTEM POWER SUPPLY; LIGHTING; ACCESS CONTROL - PERSONNEL; ACCESS CONTROL - PACKAGES; ACCESS CONTROL - VEHICLES; SAFEGUARDS CONTINGENCY PLAN IMPLEMENTATION REVIEW, AND PHYSICAL PROTECTION SAFEGUARDS INFORMATION. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS WITHIN THE TWELVE AREAS INSPECTED.

INSPECTION FEBRUARY 1-5 (88-03): THIS ROUTINE, ANNOUNCED INSPECTION WAS IN THE AREAS OF THE PREVIOUS OPEN ITEMS, SEISMIC ANALYSIS FOR AS-BUILT SAFETY-RELATED PIPING SYSTEMS (IEB 79-14), AND MARK I CONTAINMENT LONG TERM PROGRAM MODIFICATION (USI A-7). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 23 - FEBRUARY 19 (88-05): THIS ROUTINE INSPECTION WAS CONDUCTED AT THE SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATION, PLANT MODIFICATION, SURVEILLANCE OBSERVATION, RADIOLOGICAL PROTECTION, PHYSICAL SECURITY, REPORTABLE OCCURRENCES, AND REACTOR OPERATING EVENTS. TWO VIOLATIONS WERE IDENTIFIED.

Report Period MAR 1988

REPORTS FROM LICENSEE

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X HATCH 1 X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|---|
| 88-001 | 02/09/88 | 03/02/88 | PERSONNEL ERRORS CAUSE PROCEDURE ERRORS LEADING TO VIOLATIONS OF TECHNICAL SPECIFICATIONS |
| 88-003 | 02/26/88 | 03/28/88 | SPURIOUS GROUND FAULT TRIPS MAIN TURBINE AND GENERATOR RESULTING IN REACTOR SCRAM |

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-366 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. H. RICHARDSON (912) 367-7781 X2878

4. Licensed Thermal Power (Mwt): 2436

5. Nameplate Rating (Gross MWe): 850

6. Design Electrical Rating (Net MWe): 784

7. Maximum Dependable Capacity (Gross MWe): 801

8. Maximum Dependable Capacity (Net MWe): 768

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|----------------|----------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>75,145.0</u> |
| 13. Hours Reactor Critical | <u>319.7</u> | <u>615.6</u> | <u>53,307.6</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>218.4</u> | <u>509.0</u> | <u>51,082.8</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>406,290</u> | <u>919,306</u> | <u>109,657,629</u> |
| 18. Gross Elec Ener (MWH) | <u>124,320</u> | <u>295,150</u> | <u>36,050,250</u> |
| 19. Net Elec Ener (MWH) | <u>113,747</u> | <u>272,437</u> | <u>34,316,949</u> |
| 20. Unit Service Factor | <u>29.4</u> | <u>23.3</u> | <u>68.0</u> |
| 21. Unit Avail Factor | <u>29.4</u> | <u>23.3</u> | <u>68.0</u> |
| 22. Unit Cap Factor (MDC Net) | <u>19.9</u> | <u>16.2</u> | <u>59.5</u> |
| 23. Unit Cap Factor (DER Net) | <u>19.5</u> | <u>15.9</u> | <u>58.2</u> |
| 24. Unit Forced Outage Rate | <u>13.8</u> | <u>6.5</u> | <u>8.3</u> |
| 25. Forced Outage Hours | <u>35.1</u> | <u>35.1</u> | <u>4,618.9</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* HATCH 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

HATCH 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * HATCH 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|--------|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 88-002 | 01/13/88 | S | 483.7 | C | 4 | | RC | FUELXX | REFUELING OUTAGE CONTINUES. |
| 88-003 | 03/21/88 | S | 6.8 | B | 1 | | HA | TURBIN | REMOVED GENERATOR FROM GRID FOR TURBINE OVERSPEED TEST. |
| 88-004 | 03/21/88 | F | 35.1 | H | 2 | 2-88-008 | CH | INSTRU | DUR TO IMPROPER CONTROL SETTINGS ON THE REACTOR FEED PUMP CONTROLLER OSCILLATIONS WERE EXPERIENCED IN THE FEEDWATER SYSTEM WHICH CAUSED A REACTOR FEED PUMP TRIP ON LOW SUCTION PRESSURE. A MANUAL SCRAM WAS SUBSEQUENTLY INSERTED. THE PROPER CONTROL SETTINGS WERE IDENTIFIED AND THE FEED PUMP CONTROLLER RECALIBRATED. |

 * SUMMARY *

 HATCH 2 COMPLY CD REFUELING OUTAGE IN MARCH. SUBSEQUENTLY RETURNED TO POWER AND INCURRED 2 OUTAGES FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LFR) File (NUREG-0161) |

* HATCH 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....GEORGIA
COUNTY.....APPLING
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI N OF
BAXLEY, GA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JULY 4, 1978
DATE ELEC ENER 1ST GENER...SEPTEMBER 22, 1978
DATE COMMERCIAL OPERATE...SEPTEMBER 5, 1979
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...ALTAMAHA RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GEORGIA POWER
CORPORATE ADDRESS.....333 PIEDMONT AVENUE
ATLANTA, GEORGIA 30308
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....GEORGIA POWER CO.
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....P. HOLMES RAY
LICENSING PROJ MANAGER.....L. CROCKER
DOCKET NUMBER.....50-366
LICENSE & DATE ISSUANCE...NPF-5, JUNE 13, 1978
PUBLIC DOCUMENT ROOM.....APPLING COUNTY PUBLIC LIBRARY
301 CITY HALL DRIVE
BAXLEY, GEORGIA 31513

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 7-10 (87-32): THIS SPECIAL, ANNOUNCED INSPECTION WAS AN EMERGENCY RESPONSE FACILITY APPRAISAL. AREAS EXAMINED DURING THE APPRAISAL INCLUDED A REVIEW OF SELECTED PROCEDURES AND REPRESENTATIVE RECORDS, THE ERFS AND RELATED EQUIPMENT, AND INTERVIEWS WITH LICENSEE PERSONNEL. SELECT ACTIVITIES WERE OBSERVED DURING THE 1987 ANNUAL EXERCISE TO ASCERTAIN THE ADEQUACY OF THE ERFS AND RELATED EQUIPMENT. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 25-29 (88-02): THIS ROUTINE, UNANNOUNCED PHYSICAL SECURITY INSPECTION INCLUDED A REVIEW AND EXAMINATION OF: MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM; SECURITY ORGANIZATION; SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; LOCKS, KEYS AND COMBINATIONS; SECURITY SYSTEM POWER SUPPLY; LIGHTING; ACCESS CONTROL - PERSONNEL, ACCESS CONTROL - PACKAGES; ACCESS CONTROL - VEHICLES; SAFEGUARDS CONTINGENCY PLAN IMPLEMENTATION REVIEW, AND PHYSICAL PROTECTION SAFEGUARDS INFORMATION. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS WITHIN THE TWELVE AREAS INSPECTED.

INSPECTION FEBRUARY 1-5 (88-63): THIS ROUTINE, ANNOUNCED INSPECTION WAS IN THE AREAS OF THE PREVIOUS OPEN ITEMS, SEISMIC ANALYSIS FOR AS-BUILT SAFETY-RELATED PIPING SYSTEMS (IEB 79-14), AND MARK I CONTAINMENT LONG TERM PROGRAM MODIFICATION (USI A-7). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 23 - FEBRUARY 19 (88-05): THIS ROUTINE INSPECTION WAS CONDUCTED AT THE SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATION, PLANT MODIFICATION, SURVEILLANCE OBSERVATION, RADIOLOGICAL PROTECTION, PHYSICAL SECURITY, REPORTABLE OCCURRENCES, AND REACTOR OPERATING EVENTS. TWO VIOLATIONS WERE IDENTIFIED.

1. Docket: 50-354 OPERATING STATUS
 2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
 3. Utility Contact: BRYAN W. GORMAN (609) 339-3400
 4. Licensed Thermal Power (Mwt): 3293
 5. Nameplate Rating (Gross MWe): 1118
 6. Design Electrical Rating (Net MWe): 1067
 7. Maximum Dependable Capacity (Gross MWe): 1118
 8. Maximum Dependable Capacity (Net MWe): 1067
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____
 11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|--------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>11,232.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>1,045.0</u> | <u>8,903.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>1,037.9</u> | <u>8,783.0</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MNH) | <u>0</u> | <u>3,378,284</u> | <u>27,186,851</u> |
| 18. Gross Elec Ener (MWH) | <u>0</u> | <u>1,133,984</u> | <u>9,045,681</u> |
| 19. Net Ele Ener (MWH) | <u>0</u> | <u>1,085,075</u> | <u>8,650,113</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>47.5</u> | <u>78.2</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>47.5</u> | <u>78.2</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>46.6</u> | <u>54.5*</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>46.6</u> | <u>72.2</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>8.0</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>760.6</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 04/15/88

 * HOPE CREEK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

HOPE CREEK 1



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* HOPE CREEK 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 2 | 02/13/88 | S | 744.0 | C | 4 | | | | CONTINUATION OF REFUELING OUTAGE. |

* SUMMARY *

HOPE CREEK REMAINED SHUTDOWN IN MARCH FOR SCHEDULED
REFUELING OUTAGE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* HOPE CREEK 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NEW JERSEY
COUNTY.....SALEM
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...18 MI SE OF
WILMINGTON, DEL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JUNE 28, 1986
DATE ELEC ENFR 1ST GENER...AUGUST 1, 1986
DATE COMMERCIAL OPERATE...DECEMBER 20, 1986
CONDENSER COOLING METHOD...NDCT
CONDENSER COOLING WATER...DELAWARE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS
CORPORATE ADDRESS.....80 PARK PLACE
NEWARK, NEW JERSEY 07101
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....
LICENSING PROJ MANAGER.....G. RIVENBARK
DOCKET NUMBER.....50-354
LICENSE & DATE ISSUANCE...NPF-57, JULY 25, 1986
PUBLIC DOCUMENT ROOM.....PENNSVILLE PUBLIC LIBRARY
190 SOUTH BROADWAY
PENNSVILLE, N. J. 08070

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

1. Docket: 50-247 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: K. KRIEGER (914) 526-5155

4. Licensed Thermal Power (Mwt): 2758

5. Nameplate Rating (Gross MWe): 1126 X 0.9 = 1013

6. Design Electrical Rating (Net MWe): 873

7. Maximum Dependable Capacity (Gross MWe): 900

8. Maximum Dependable Capacity (Net MWe): 864

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>120,553.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>1,673.3</u> | <u>62,292.4</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>2,867.6</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>1,539.9</u> | <u>79,936.2</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,054,955</u> | <u>3,957,636</u> | <u>208,800,506</u> |
| 18. Gross Elec Ener (MWH) | <u>680,578</u> | <u>1,296,742</u> | <u>64,910,298</u> |
| 19. Net Elec Ener (MWH) | <u>658,241</u> | <u>1,236,066</u> | <u>61,371,854</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>70.5</u> | <u>66.3</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>70.5</u> | <u>66.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>102.4</u> | <u>65.5</u> | <u>59.9*</u> |
| 23. Unit Cap Factor (DER Net) | <u>101.3</u> | <u>64.8</u> | <u>58.3</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>1.6</u> | <u>8.6</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>25.3</u> | <u>7,283.3</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* INDIAN POINT 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
INDIAN POINT 2



MARCH 1988

* Item calculated with a Weighted Average

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|--------|-----------|---|
|-----|------|------|-------|--------|--------|------------|--------|-----------|---|

NONE

 * SUMMARY *

 INDIAN POINT 2 OPERATED ROUTINELY IN MARCH WITH NO
 OUTAGES OR SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|--------------|--------------------------------------|
| F-Forced | A-Equip Failure | F-Admin | 1-Manual Exhibit F & P |
| S-Sched | B-Maint or Test | G-Oper Error | 2-Manual Scram Instructions for |
| | C-Refueling | H-Other | 3-Auto Scram Preparation of |
| | D-Regulatory Restriction | | 4-Continued Data Entry Sheet |
| | E-Operator Training | | 5-Reduced Load Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* INDIAN POINT 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....WESTCHESTER
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI N OF
NEW YORK CITY, NY
TYPE OF REACTOR.....PHR
DATE INITIAL CRITICALITY...MAY 22, 1973
DATE ELEC ENER 1ST GENER...JUNE 26, 1973
DATE COMMERCIAL OPERATE...AUGUST 1, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...HUDSON RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CONSOLIDATED EDISON
CORPORATE ADDRESS.....4 IRVING PLACE
NEW YORK, NEW YORK 10003
CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....L. ROSSBACH
LICENSING PROJ MANAGER....M. SLOSSON
DOCKET NUMBER.....50-247
LICENSE & DATE ISSUANCE...DPR-26, SEPTEMBER 28, 1973
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY
100 MARTINE AVENUE
WHITE PLAINS, NEW YORK 10601

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------------------|------------------|-------------------|---------|
| NO INPUT PROVIDED. | | | |

=====

1. Docket: 50-286 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: L. KELLY (914) 739-8200

4. Licensed Thermal Power (Mht): 3025

5. Nameplate Rating (Gross MWe): 1126 X 0.9 = 1013

6. Design Electrical Rating (Net MWe): 965

7. Maximum Dependable Capacity (Gross MWe): 1000

8. Maximum Dependable Capacity (Net MWe): 965

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>101,569.0</u> |
| 13. Hours Reactor Critical | <u>734.2</u> | <u>2,158.0</u> | <u>61,503.3</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>734.2</u> | <u>2,152.5</u> | <u>59,618.4</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,219,298</u> | <u>6,479,631</u> | <u>158,491,774</u> |
| 18. Gross Elec Ener (MWH) | <u>734,820</u> | <u>2,142,820</u> | <u>50,520,876</u> |
| 19. Net Elec Ener (MWH) | <u>710,160</u> | <u>2,070,489</u> | <u>48,461,047</u> |
| 20. Unit Service Factor | <u>98.7</u> | <u>98.6</u> | <u>58.7</u> |
| 21. Unit Avail Factor | <u>98.7</u> | <u>98.6</u> | <u>58.7</u> |
| 22. Unit Cap Factor (MDC Net) | <u>98.9</u> | <u>98.2</u> | <u>49.4</u> |
| 23. Unit Cap Factor (DER Net) | <u>98.9</u> | <u>98.2</u> | <u>49.4</u> |
| 24. Unit Forced Outage Rate | <u>1.3</u> | <u>1.4</u> | <u>18.1</u> |
| 25. Forced Outage Hours | <u>9.8</u> | <u>31.5</u> | <u>13,120.9</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
MAINTENANCE-MAY, 1988-DURATION 2 WEEKS.

27. If Currently Shutdown Estimated Startup Date: 04/02/88

* INDIAN POINT 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

INDIAN POINT 3



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * INDIAN POINT 3 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 02 | 03/31/88 | F | 9.8 | A | 3 | 88-092-00 | HH | PUMPXX | UNIT TRIP ON HIGH LEVEL IN NO. 31 STEAM GENERATOR DUE TO THE STEAM GENERATOR LEVEL TRANSIENTS WHICH FOLLOWED AN INADVERTENT AUTOMATIC TRIP OF NO. 32 MAIN BOILER FEED PUMP. |

 * SUMMARY *

 INDIAN POINT 3 INCURRED 1 OUTAGE IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|---|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | F-Admin | 3-Auto Scram | Preparation of |
| | G-Oper Error | 4-Continued | Data Entry Sheet |
| | C-Refueling | 5-Reduced Load | Licensee Event Report |
| | D-Regulatory Restriction | 9-Other | (LER) File (NUREG-0161) |
| | H-Other | | |
| | E-Operator Training & License Examination | | |

* INDIAN POINT 3 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....WESTCHESTER
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI N OF
NEW YORK CITY, NY
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 6, 1976
DATE ELEC ENER 1ST GENER...APRIL 27, 1976
DATE COMMERCIAL OPERATE...AUGUST 30, 1976
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...HUDSON RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NEW YORK POWER AUTHORITY
CORPORATE ADDRESS.....10 COLUMBUS CIRCLE
NEW YORK, NEW YORK 10019
CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....P. KOLTAY
LICENSING PROJ MANAGER.....J. NEIGHBORS
DOCKET NUMBER.....50-286
LICENSE & DATE ISSUANCE...DPR-64, APRIL 5, 1976
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY
100 MARTINE AVENUE
WHITE PLAINS, NEW YORK 10601

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

FAILURE TO FOLLOW QA PROCEDURE 1601 SECTION 6-2 REQUIREMENTS TO PROVIDE TIMELY ESCALATED ACTION FOR LATE RESPONSES TO QA FINDING AND NONCONFORMANCE AND CORRECTIVE ACTION REQUESTS (NOBS).
(8702 4)

FAILURE TO FOLLOW ANSI N45.2-9-1974 SECTION 5-3 REQUIREMENTS FOR WRITTEN PROCEDURES WHICH: (1) DESCRIBE THE RECORD STORAGE AREAS, (2) DESCRIBE THE RECORD FILING SYSTEM USED, (3) DESCRIBE THE METHOD USED TO VERIFY THAT THE RECORDS RECEIVED IN AGREEMENT WITH THE TRANSMITTAL DOCUMENT OR A PREESTABLISHED CHECK LIST. ALSO LICENSEE HAD NOT ESTABLISHED A PROGRAM FOR VERIFYING THAT RECEIVED RECORDS WERE IN AGREEMENT WITH THE TRANSMITTAL DOCUMENT OR A PREESTABLISHED CHECK LIST. 10 CFR 20.203(E) REQUIRES IN PART, THAT EACH AREA OR ROOM IN WHICH LICENSED MATERIAL IS USED OR STORED AND WHICH CONTAINS ANY RADIOACTIVE MATERIAL IN AN AMOUNT EXCEEDING 10 TIMES THE QUANTITY OF SUCH MATERIAL IN APPENDIX C OF THIS PART, SHALL BE CONSPICUOUSLY POSTED WITH A SIGN OR SIGNS BEARING THE RADIATION CAUTION SYMBOL AND THE WORDS "CAUTION RADIOACTIVE MATERIALS". CONTRARY TO THE ABOVE, AS OF DECEMBER 4, 1987, THE TOOL STORAGE AREA, AN AREA LOCATED ON THE 36' ELEVATION OF THE PAB, WHICH CONTAINED LICENSED RADIOACTIVE MATERIAL IN EXCESS OF 10 TIMES THE AMOUNT SPECIFIED IN APPENDIX C OF 10 CFR, WAS NOT POSTED WITH A SIGN BEARING THE WORDS "CAUTION RADIOACTIVE MATERIALS."

INSPECTION STATUS - (CONTINUED)

Report Period MAR 1988

ENFORCEMENT SUMMARY

(8702 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

.....

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

NO INPUT PROVIDED.

.....

1. Docket: 50-305 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: G. RUITER (414) 388-2560 X225

4. Licensed Thermal Power (MWT): 1650

5. Nameplate Rating (Gross MWe): 622 X 0.9 = 560

6. Design Electrical Rating (Net MWe): 535

7. Maximum Dependable Capacity (Gross MWe): 529

8. Maximum Dependable Capacity (Net MWe): 503

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, if Any (Net MWe): _____

11. Reasons for Restrictions, if Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>120,913.6</u> |
| 13. Hours Reactor Critical | <u>37.8</u> | <u>1,477.8</u> | <u>102,940.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>2,330.5</u> |
| 15. Hrs Generator On-Line | <u>37.8</u> | <u>1,477.8</u> | <u>101,359.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>10.0</u> |
| 17. Gross Therm Ener (MWH) | <u>57,885</u> | <u>2,410,176</u> | <u>159,830,050</u> |
| 18. Gross Elec Ener (MWH) | <u>19,200</u> | <u>800,500</u> | <u>52,787,600</u> |
| 19. Net Elec Ener (MWH) | <u>18,278</u> | <u>764,484</u> | <u>50,268,994</u> |
| 20. Unit Service Factor | <u>5.1</u> | <u>67.7</u> | <u>83.8</u> |
| 21. Unit Avail Factor | <u>5.1</u> | <u>67.7</u> | <u>83.8</u> |
| 22. Unit Cap Factor (MDC Net) | <u>4.9</u> | <u>69.6</u> | <u>80.7*</u> |
| 23. Unit Cap Factor (DER Net) | <u>4.6</u> | <u>65.4</u> | <u>77.7</u> |
| 24. Unit Forced Outage Rate | <u>2.3</u> | <u>.1</u> | <u>2.8</u> |
| 25. Forced Outage Hours | <u>.9</u> | <u>.9</u> | <u>2,839.7</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 04/15/88

X KEWAUNEE X

AVERAGE DAILY POWER LEVEL (MWe) PLOT

KEWAUNEE



MARCH 1988

* Item calculated with a Weighted Average

| No. | Date | Type | Hours | Reason | Method | IER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|------------------|--|
| 1 | 03/02/88 | F | 0.9 | A | 7 | 88-001 | EB ELECON | AN ELECTRICAL FAULT ON THE BUS FROM THE MAIN AUXILIARY TRANSFORMER (MAT) *Y* WINDING TO BUSES 1 AND 2 INITIATED A MAIN GENERATOR LOCKOUT TRIP AND A TURBINE TRIP/PEACOR TRIP. GIVEN THE PROXIMITY TO THE SCHEDULED REFUELING OUTAGE START DATE (3/4/88), THE DECISION WAS MADE TO BEGIN THE REFUELING OUTAGE RATHER THAN RESTART THE UNIT. |

2 03/02/88 5 705.3 C 9 ZZ ZZZZZZ COMMENCED CYCLE XIII-XIV REFUELING OUTAGE.

***** KENAUHEE INCURRED 1 FORCED OUTAGE DURING MARCH. SUBSEQUENTLY, MADE DECISION TO REMAIN SHUTDOWN FOR REFUELING RATHER THAN RESTART.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhib F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced load | License Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* Kewaunee *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....WISCONSIN
COUNTY.....KEWAUNEE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...27 MI E OF
GREEN BAY, WI.
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 7, 1974
DATE ELEC ENER 1ST GENER...APRIL 8, 1974
DATE COMMERCIAL OPERATE...JUNE 16, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WISCONSIN PUBLIC SERVICE
CORPORATE ADDRESS.....P.O. BOX 19002
GREEN BAY, WISCONSIN 54307
CONTRACTOR
ARCHITECT/ENGINEER.....PIONEER SERVICES & ENGINEERING
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....PIONEER SERVICES & ENGINEERING
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....R. NELSON
LICENSING PROJ MANAGER.....J. GIITTER
DOCKET NUMBER.....50-305
LICENSE & DATE ISSUANCE...DPR-43, DECEMBER 21, 1973
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF WISCONSIN
LIBRARY LEARNING CENTER
2420 NICOLET DRIVE
GREEN BAY, WISCONSIN 54301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

1. Docket: 50-573 OPERATING STATUS
 2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
 3. Utility Contact: G. J. KIRCHNER (815) 357-6761 X 705
 4. Licensed Thermal Power (Mwt): 3323
 5. Nameplate Rating (Gross MWe): 1078
 6. Design Electrical Rating (Net MWe): 1078
 7. Maximum Dependable Capacity (Gross MWe): 1078
 8. Maximum Dependable Capacity (Net MWe): 1036
 9. If Changes Occur Above Since Last Report, Give Reasons:
 NONE

10. Power Level To Which Restricted, If Any (Net MWe):
 11. Reasons for Restrictions, If Any:
 NONE


| | MONTH | YEAR | CUMULATIVE |
|--|---------|-----------|------------|
| 12. Report Period Hrs | 744.0 | 2,184.0 | 37,248.0 |
| 13. Hours Reactor Critical | 289.8 | 1,729.8 | 21,773.0 |
| 14. Rx Reserve Shtdwn Hrs | .0 | .0 | 1,640.9 |
| 15. Hrs Generator On-Line | 289.8 | 1,729.8 | 21,158.4 |
| 16. Unit Reserve Shtdwn Hrs | .0 | .0 | 1.0 |
| 17. Gross Therm Ener (MWH) | 848,976 | 5,252,088 | 63,222,404 |
| 18. Gross Elec Ener (MWH) | 286,164 | 1,777,631 | 18,744,890 |
| 19. Net Elec Ener (MWH) | 270,406 | 1,711,746 | 17,821,534 |
| 20. Unit Service Factor | 39.0 | 79.2 | 56.8 |
| 21. Unit Avail Factor | 39.0 | 79.2 | 56.8 |
| 22. Unit Cap Factor (MDC Net) | 35.1 | 75.7 | 46.2 |
| 23. Unit Cap Factor (DER Net) | 33.7 | 72.7 | 44.4 |
| 24. Unit Forced Outage Rate | .0 | .0 | 13.4 |
| 25. Forced Outage Hours | .0 | .0 | 3,264.6 |
| 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE | | | |

27. If Currently Shutdown Estimated Startup Date: 06/26/88

 * LASALLE 1 *

 AVERAGE DAILY POWER LEVEL (MWe) PLOT

LASALLE 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* LASALLE I

| No. | Date | Type | Hours | Reason | Method | IER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|------------------|---|
| 4 | 03/13/88 | S | 454.2 | C | 1 | | | SECOND REFUEL OUTAGE. |

* SUMMARY *

LA SALLE I COMMENCED REFUELING OUTAGE IN MARCH.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* LASALLE 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LA SALLE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI SE OF
OTTAWA, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JUNE 21, 1982
DATE ELEC ENER 1ST GENER...SEPTEMBER 4, 1982
DATE COMMERCIAL OPERATE...JANUARY 1, 1984
CONDENSER COOLING METHOD...POND
CONDENSER COOLING WATER...RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....M. JORDAN
LICENSING PROJ MANAGER....P. SHEMANSKI
DOCKET NUMBER.....50-373
LICENSE & DATE ISSUANCE...NPF-11, AUGUST 13, 1982
PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE
RURAL ROUTE NO. 1
OGLESBY, ILLINOIS 61348

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JANUARY 7 THROUGH FEBRUARY 9, 1988 (88003). ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY RESIDENT INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; SURVEILLANCE; MAINTENANCE; TRAINING; LICENSEE EVENT REPORTS; REGIONAL REQUESTS/FOLLOWUP ON GENERIC LETTERS; SECURITY; AND ALLEGATIONS. OF THE NINE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. THE LICENSEE HAS BEEN SUCCESSFUL IN REDUCING PERSONNEL ERRORS AND INCREASING THE AWARENESS OF PLANT PERSONNEL. BOTH UNITS HAVE BEEN OPERATING AT OR NEAR 100% POWER. THE LICENSEE STILL NEEDS TO MAINTAIN EFFORTS TO MINIMIZE ERRORS. THERE WAS ONE PERSONNEL ERROR DURING THIS REPORTING PERIOD WHICH CAUSED A FEEDWATER TRANSIENT WHICH COULD HAVE TRIPPED THE UNIT (I.E., A NEAR-MISS). THE OVERALL PERFORMANCE OF THE LICENSEE CONTINUES TO IMPROVE.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

OTHER ITEMS

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT SHUTDOWN FOR REFUELING OUTAGE ON 3/15/88 (EXPECTED TO LAST END OF JUNE)

LAST IE SITE INSPECTION DATE: 03/18/88

INSPECTION REPORT NO: 88006

R E P O R T S F R O M L I C E N S E E

```
=====
```

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|--|
| 88-01 | 022288 | 032188 | FAILURE OF REACTOR CORE ISOLATION COOLING HIGH REACTOR WATER LEVEL SWITCH DUE TO SETPOINT DRIFT CAUSED BY STRIPED SETPOINT LOCKING MECHANISM SCREW |

```
=====
```


1. Docket: 50-374 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: G. J. KIRCHNER (815) 357-6761 X 704

4. Licensed Thermal Power (Mwt): 3323

5. Nameplate Rating (Gross MWe): 1078

6. Design Electrical Rating (Net MWe): 1078

7. Maximum Dependable Capacity (Gross MWe): 1078

8. Maximum Dependable Capacity (Net MWe): 1036

9. If Charges Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

Reasons for Restrictions, If Any:

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>30,240.0</u> |
| 13. Hours Reactor Critical | <u>542.5</u> | <u>1,982.5</u> | <u>18,767.2</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>1,716.7</u> |
| 15. Hrs Generator On-Line | <u>525.9</u> | <u>1,965.9</u> | <u>18,437.9</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,419,096</u> | <u>5,840,640</u> | <u>53,635,695</u> |
| 18. Gross Elec Ener (MWH) | <u>470,842</u> | <u>1,953,935</u> | <u>17,762,146</u> |
| 19. Net Elec Ener (MWH) | <u>450,050</u> | <u>1,883,362</u> | <u>16,965,885</u> |
| 20. Unit Service Factor | <u>70.7</u> | <u>90.0</u> | <u>61.0</u> |
| 21. Unit Avail Factor | <u>70.7</u> | <u>90.0</u> | <u>61.0</u> |
| 22. Unit Cap Factor (MDC Net) | <u>58.4</u> | <u>83.2</u> | <u>54.2</u> |
| 23. Unit Cap Factor (DER Net) | <u>56.1</u> | <u>80.0</u> | <u>52.0</u> |
| 24. Unit Forced Outage Rate | <u>29.3</u> | <u>10.0</u> | <u>19.0</u> |
| 25. Forced Outage Hours | <u>218.1</u> | <u>218.1</u> | <u>4,317.9</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * LASALLE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 LASALLE 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * LASALLE 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 5 | 03/07/88 | S | 0.0 | B | 5 | | | | HEATER BAY WORK AND SURVEILLANCES. |
| 6 | 03/09/88 | F | 218.1 | A | 3 | | | | REACTOR SCRAMMED ON APRM HI-HI AND LOSS OF BOTH RR PUMPS. |
| 7 | 03/30/88 | S | 0.0 | B | 5 | | | | ROD PATTERN ADJUSTMENT. |

 * SUMMARY *

 LA SALLE 2 INCURRED 2 POWER REDUCTIONS AND 1 FORCED OUTAGE
 IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* LASALLE 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LA SALLE
DIS. AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI SE OF
OTTAWA, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 10, 1984
DATE ELEC ENER 1ST GENER...APRIL 20, 1984
DATE COMMERCIAL OPERATE...OCTOBER 19, 1984
CONDENSER COOLING METHOD...POND
CONDENSER COOLING WATER...RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....TII
IE RESIDENT INSPECTOR.....M. JORDAN
LICENSING PROJ MANAGER.....P. SHEMANSKI
DOCKET NUMBER.....50-374
LICENSE & DATE ISSUANCE...NPF-18, MARCH 23, 1984
PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE
RURAL ROUTE NO. 1
OGLESBY, ILLINOIS 61348

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JANUARY 7 THROUGH FEBRUARY 9, 1988 (88003). ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY RESIDENT INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; SURVEILLANCE; MAINTENANCE; TRAINING; LICENSEE EVENT REPORTS; REGIONAL REQUESTS/FOLLOWUP ON GENERIC LETTERS; SECURITY; AND ALLEGATIONS. OF THE NINE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. THE LICENSEE HAS BEEN SUCCESSFUL IN REDUCING PERSONNEL ERRORS AND INCREASING THE AWARENESS OF PLANT PERSONNEL. BOTH UNITS HAVE BEEN OPERATING AT OR NEAR 100% POWER. THE LICENSEE STILL NEEDS TO MAINTAIN EFFORTS TO MINIMIZE ERRORS. THERE WAS ONE PERSONNEL ERROR DURING THIS REPORTING PERIOD WHICH CAUSED A FEEDWATER TRANSIENT WHICH COULD HAVE TRIPPED THE UNIT (I.E., A NEAR-MISS). THE OVERALL PERFORMANCE OF THE LICENSEE CONTINUES TO IMPROVE.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

OTHER ITEMS

ON MARCH 9, 1988 THE UNIT RECEIVED A DUAL RECIRC PUMP TRIP WHICH RESULTED IN CORE POWER OSCILLATIONS. AN AIT WAS DISPATCHED TO FOLLOWUP ON THIS EVENT. THE DETAILS WILL BE CONTINUED IN INSPECTION REPORT 373/88008; 374/88008

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT OPERATING AT FULL POWER.

LAST IE SITE INSPECTION DATE: 03/18/88

INSPECTION REPORT NO: 88006

R E P O R T S F R O M L I C E N S E E

```

=====

```

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---|
| 88-01 | 030288 | 033188 | 2B DIESEL GENERATOR COOLING WATER PUMP FAILURE TO AUTO START |
| 88-02 | 030388 | 040188 | GROUP 10 ISOLATION DUE TO TEST SWITCH FAILURE FOUND DURING SURVEILLANCE TESTING |
| 88-03 | 030988 | 040788 | REACTOR SCRAM ON HIGH AVERAGE POWER RANGE MONITOR FLUX LEVEL DUE TO PERSONNEL VALVING ERROR |

```

=====

```

1. Docket: 50-352 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: R. W. GROPP (215) 841-5058

4. Licensed Thermal Power (Mwt): 3293

5. Nameplate Rating (Gross MWe): 1138

6. Design Electrical Rating (Net MWe): 1055

7. Maximum Dependable Capacity (Gross MWe): 1092

8. Maximum Dependable Capacity (Net MWe): 1055

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>18,960.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>15,028.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,184.0</u> | <u>14,746.7</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,434,138</u> | <u>7,051,748</u> | <u>45,948,129</u> |
| 18. Gross Elec Ener (MWH) | <u>789,500</u> | <u>2,282,550</u> | <u>14,981,960</u> |
| 19. Net Elec Ener (MWH) | <u>762,209</u> | <u>2,202,179</u> | <u>14,370,016</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>77.8</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>77.8</u> |
| 22. Unit Cap Factor (MDC Net) | <u>97.1</u> | <u>95.6</u> | <u>71.8</u> |
| 23. Unit Cap Factor (DER Net) | <u>97.1</u> | <u>95.6</u> | <u>71.8</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>3.2</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>491.9</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


MAINTENANCE-APRIL 8, 1988 - 14 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

* LIMERICK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LIMERICK 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* LIMERICK 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|--------|-----------|---|
|-----|------|------|-------|--------|--------|------------|--------|-----------|---|

NONE

* SUMMARY *

LIMERICK 1 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES OR
SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* LIMERICK 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....MONTGOMERY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...21 MI NW OF
PHILADELPHIA, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...DECEMBER 22, 1984
DATE ELEC EMER 1ST GENER...APRIL 13, 1985
DATE COMMERCIAL OPERATE...FEBRUARY 1, 1986
CONDENSER COOLING METHOD...CC HNDCT
CONDENSER COOLING WATER...SCHUYLKILL RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PHILADELPHIA ELECTRIC
CORPORATE ADDRESS.....2301 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19105
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....G. KELLY
LICENSING PROJ MANAGER.....D. CLARK
DOCKET NUMBER.....50-352
LICENSE & DATE ISSUANCE...NPF-39, AUGUST 8, 1985
PUBLIC DOCUMENT ROOM.....POTTSTOWN PUBLIC LIBRARY
500 HIGH STREET
POTTSTOWN, PENNSYLVANIA 19464

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

1. Docket: 50-309 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. M. TAYLOR (207) 882-6321

4. Licensed Thermal Power (MWh): 2630

5. Nameplate Rating (Gross MWe): 864

6. Design Electrical Rating (Net MWe): 825

7. Maximum Dependable Capacity (Gross MWe): 850

8. Maximum Dependable Capacity (Net MWe): 810

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>134,940.6</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,167.9</u> | <u>108,020.5</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,154.8</u> | <u>104,813.7</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,055,449</u> | <u>5,628,331</u> | <u>239,988,665</u> |
| 18. Gross Elec Ener (MWH) | <u>614,070</u> | <u>1,769,690</u> | <u>78,658,420</u> |
| 19. Net Elec Ener (MWH) | <u>594,059</u> | <u>1,711,539</u> | <u>75,186,488</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>98.7</u> | <u>77.7</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>98.7</u> | <u>77.7</u> |
| 22. Unit Cap Factor (MDC Net) | <u>98.6</u> | <u>96.7</u> | <u>70.4*</u> |
| 23. Unit Cap Factor (DER Net) | <u>96.8</u> | <u>95.0</u> | <u>68.6*</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>1.3</u> | <u>7.6</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>29.2</u> | <u>7,739.8</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* MAINE YANKEE *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
MAINE YANKEE



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* MAINE YANKEE *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|--------|-----------|---|
|-----|------|------|-------|--------|--------|------------|--------|-----------|---|

NONE

 * SUMMARY *

 MAINE YANKEE OPERATED ROUTINELY IN MARCH WITH NO OUTAGES
 OR SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* MAINE YANKEE *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....MAINE
COUNTY.....LINCOLN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI N OF
BATH, ME
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 23, 1972
DATE ELEC ENER 1ST GENER...NOVEMBER 8, 1972
DATE COMMERCIAL OPERATE...DECEMBER 28, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...BACK RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....MAINE YANKEE ATOMIC POWER
CORPORATE ADDRESS.....83 EDISON DRIVE
AUGUSTA, MAINE 04366
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....C. HOLDEN
LICENSING PROJ MANAGER....P. SEARS
DOCKET NUMBER.....50-309
LICENSE & DATE ISSUANCE...DPR-36, JUNE 29, 1973
PUBLIC DOCUMENT ROOM.....WISCASSET PUBLIC LIBRARY
HIGH STREET
WISCASSET, MAINE 04578

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

* MAINE YANKEE *

OTHER ITEMS:

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

NO INPUT PROVIDED.


=====

 * MCGUIRE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MCGUIRE 1

1. Docket: 50-369 OPERATING STATUS
2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: J. A. REAVIS (704) 373-7567
4. Licensed Thermal Power (MWT): 3411
5. Nameplate Rating (Gross MWe): 1305
6. Design Electrical Rating (Net MWe): 1180
7. Maximum Dependable Capacity (Gross MWe): 1225
8. Maximum Dependable Capacity (Net MWe): 1129
9. If Changes Occur Above Since Last Report, Give Reasons:
NONE
10. Power Level To Which Restricted, If Any (Net MWe): _____
11. Reasons for Restrictions, If Any: _____
NONE
- | | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>55,512.0</u> |
| 13. Hours Reactor Critical | <u>720.5</u> | <u>2,145.9</u> | <u>39,010.3</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>717.2</u> | <u>2,140.0</u> | <u>38,483.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,380,942</u> | <u>7,075,619</u> | <u>112,144,036</u> |
| 18. Gross Elec Ener (MWH) | <u>824,580</u> | <u>2,455,667</u> | <u>38,851,244</u> |
| 19. Net Elec Ener (MWH) | <u>795,041</u> | <u>2,367,743</u> | <u>37,033,241</u> |
| 20. Unit Service Factor | <u>96.4</u> | <u>98.0</u> | <u>69.3</u> |
| 21. Unit Avail Factor | <u>96.4</u> | <u>98.0</u> | <u>69.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>94.7</u> | <u>96.0</u> | <u>59.1</u> |
| 23. Unit Cap Factor (DER Net) | <u>90.6</u> | <u>91.9</u> | <u>56.5</u> |
| 24. Unit Forced Outage Rate | <u>3.6</u> | <u>2.0</u> | <u>13.6</u> |
| 25. Forced Outage Hours | <u>26.8</u> | <u>44.0</u> | <u>6,066.7</u> |
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE
27. If Currently Shutdown Estimated Startup Date: N/A



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * MCGUIRE 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|------------------|--|
| 2 | 03/23/88 | F | 26.8 | A | 3 | | IA ELECON | LOOSE WIRE IN REACTOR PROTECTION (SSPS) CABINET INITIATED SAFETY INJECTION SIGNAL. |
| 14-P | 03/24/88 | F | 0.0 | B | 5 | | HG XXXXXX | POWER HOLD FOR SECONDARY CHEMISTRY. |
| 15-P | 03/24/88 | F | 0.0 | B | 5 | | ED PIPEXX | BUSLINE RELAY WORK. |
| 16-P | 03/27/88 | S | 0.0 | F | 5 | | ZZ ZZZZZZ | POWER DECREASE PER DISPATCHER REQUEST. |
| 17-P | 03/28/88 | F | 0.0 | A | 5 | | HA INSTRU | CHANGE OUT GENERATOR VOLTAGE REGULATOR CONTROL. |

 * SUMMARY *

 MCGUIRE 1 INCURRED 1 OUTAGE AND 4 POWER REDUCTIONS IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-----------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | LER File (NUREG-0161) |

* MCGUIRE 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA
COUNTY.....MECKLENBURG
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI N OF
CHARLOTTE, NC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 8, 1981
DATE ELEC ENER 1ST GENER...SEPTEMBER 12, 1981
DATE COMMERCIAL OPERATE...DECEMBER 1, 1981
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE NORMAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE POWER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. ORDERS
LICENSING PROJ MANAGER....D. HOOD
DOCKET NUMBER.....50-369
LICENSE & DATE ISSUANCE...NPF-9, JULY 8, 1981
PUBLIC DOCUMENT ROOM.....MS. DAWN HUBBS
ATKINS LIBRARY
UNIVERSITY OF NORTH CAROLINA - CHARLOTTE
UNCC STATION,
CHARLOTTE, NC 28223

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

* INSPECTION JANUARY 21 - FEBRUARY 26 (88-04): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED THE AREAS OF OPERATIONS SAFETY VERIFICATION, SURVEILLANCE TESTING, MAINTENANCE ACTIVITIES, AND FOLLOW-UP ON PREVIOUS INSPECTION FINDINGS. IN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED WITH TWO EXAMPLES INVOLVING A FAILURE TO FOLLOW PROCEDURES AND AN INADEQUATE PROCEDURE ASSOCIATED WITH PERFORMING EQUALIZING CHARGES ON VITAL BATTERIES AND OPERATING THE CHEMICAL AND VOLUME CONTROL SYSTEM.

INSPECTION FEBRUARY 27 - MARCH 18 (88-07): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED THE AREAS OF OPERATIONS SAFETY VERIFICATION, SURVEILLANCE TESTING, MAINTENANCE ACTIVITIES, AND FOLLOW-UP ON PREVIOUS INSPECTION FINDINGS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, TECHNICAL SPECIFICATION (TS) 6.8.1, ON DECEMBER 28, 1987 AN ERROR ON A PLANT ELECTRICAL DRAWING LED TO AN ACTUATION OF THE REACTOR PROTECT ION SYSTEM, CAUSING A REACTOR TRIP. WHILE PERFORMING MONTHLY SURVEILLANCE TEST, PT/1/A/4601/02, PROTECTIVE SYSTEM CHANNEL 2 FUNCTIONAL TEST, A DRAWING ERROR ON SCHEMATIC DIAGRAM MCM 1399.05-0568 001 CAUSED LICENSEE PERSONNEL CONDUCTING THE TEST ON CHANNEL 2 OF NARROW RANGE STEAM GENERATOR LEVEL INSTRUMENTATION

ENFORCEMENT SUMMARY

TO MAKE AN ADJUSTMENT IN CHANNEL 4 WHICH TOGETHER WITH THE EXISTING SIGNAL IN CHANNEL 2 CAUSED THE REACTOR TRIP. ALSO, ON DECEMBER 28, 1987 LICENSEE PERSONNEL FAILED TO FOLLOW A PROCEDURE STEP CAUSING AN ACTUATION OF THE REACTOR PROTECTION SYSTEM. WHILE PERFORMING PERIODIC TEST PT/D/A/4600/14C, NUCLEAR INSTRUMENTATION SYSTEM SOURCE RANGE FUNCTIONAL TEST, LICENSEE PERSONNEL ELECTED TO MANIPULATE A TEST SWITCH IN THE SOLID STATE PROTECTION SYSTEM WITHOUT MEETING THE CONDITIONS FOR DOING SO AS SPECIFIED IN THE PROCEDURE. THIS RESULTED IN A REACTOR TRIP.
(8704 4)

CONTRARY TO TS 6.8.1.A, MCGUIRE NUCLEAR STATION PROCEDURE IP/O/A/3061/08, WATER ADDITION AND EQUALIZING CHARGE FOR VITAL BATTERIES, STEP 10.4.3., AND MCGUIRE NUCLEAR STATION PROCEDURE OP/1/A/6200/01 ENCLOSURE 4.7: (1) PROCEDURE IP/O/A/3061/08 WAS NOT PROPERLY IMPLEMENTED IN THAT AN OUTPUT VOLTAGE OF APPROXIMATELY 148 VDC RATHER THAN THE REQUIRED 141.0 VDC WAS BEING USED ON FEBRUARY 10, 1988, WHEN CONDUCTING AN EQUALIZING CHARGE ON VITAL BATTERY EVCB. INSTRUMENT AND ELECTRICAL (IAE) TECHNICIANS AND ENGINEERS WERE AWARE OF THE PROCEDURAL REQUIREMENT TO ESTABLISH 141.0 VDC BUT CHOSE TO ESTABLISH A HIGHER VOLTAGE WITHOUT MAKING THE REQUIRED CHANGE TO THE PROCEDURE. (2) THE PROCEDURE FOR REMOVING THE CATION BED DEMINERALIZER FROM SERVICE, OP/1/A/6200/01 CHEMICAL AND VOLUME CONTROL SYSTEM, WAS NOT PROPERLY MAINTAINED IN THAT STEPS WERE CHANGED DURING A REVISION LEADING TO OVERPRESSURIZATION OF THE SYSTEM. THIS OVERPRESSURIZATION ON FEBRUARY 3, 1988, LED TO THE RUPTURE OF THE DIAPHRAM ON VALVE INV-474 AND A CONTAMINATED SPILL.
(8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: FEBRUARY 27 - MARCH 18, 1988 +

INSPECTION REPORT NO: 50-369/88-07 +

Report Period MAR 1988

R E P O R T S F R O M L I C E N S E E

* MCGUIRE 1 *

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
| ----- | | | |
| NONE. | | | |

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-370 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS EXT (704) 373-7567

4. Licensed Thermal Power (Mwt): 3411

5. Nameplate Rating (Gross MWe): 1450 X .9 = 1305

6. Design Electrical Rating (Net MWe): 1180

7. Maximum Dependable Capacity (Gross MWe): 1225

8. Maximum Dependable Capacity (Net MWe): 1129

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>35,808.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,166.7</u> | <u>26,612.2</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,161.2</u> | <u>25,988.7</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,528,325</u> | <u>7,276,432</u> | <u>85,522,036</u> |
| 18. Gross Elec Ener (MWH) | <u>884,445</u> | <u>2,543,874</u> | <u>29,619,102</u> |
| 19. Net Elec Ener (MWH) | <u>853,682</u> | <u>2,453,111</u> | <u>28,389,113</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>99.0</u> | <u>72.6</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>99.0</u> | <u>72.6</u> |
| 22. Unit Cap Factor (MDC Net) | <u>101.6</u> | <u>99.5</u> | <u>70.2</u> |
| 23. Unit Cap Factor (DER Net) | <u>97.2</u> | <u>95.2</u> | <u>67.2</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>1.0</u> | <u>11.6</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>22.8</u> | <u>3,417.3</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING - MAY 27, 1988 - 10 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

 * MCGUIRE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MCGUIRE 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

XX
* MCGUIRE 2 *
XX

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 7-P | 03/11/88 | F | 0.0 | A | 5 | | ZZ | CKTBKR | RUNBACK DUE TO ALARMS ASSOCIATED WITH SWITCHYARD CONTROL SYSTEM. |

* SUMMARY *

MCGUIRE 2 INCURRED 1 POWER REDUCTION IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|---|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | G-Oper Error | 3-Auto Scram | Preparation of |
| | C-Refueling | 4-Continued | Data Entry Sheet |
| | H-Other | 5-Reduced Load | Licensee Evnt Report |
| | D-Regulatory Restriction | 9-Other | (LER) File (NUREG-0161) |
| | E-Operator Training & License Examination | | |

* MCGUIRE 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA
COUNTY.....MECKLENBURG
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI N OF
CHARLOTTE, NC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 8, 1983
DATE ELEC ENER 1ST GENER...MAY 23, 1983
DATE COMMERCIAL OPERATE...MARCH 1, 1984
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE NORMAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....POWER BLDG., BOX 2178
CHARLOTTE, NORTH CAROLINA 28201
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE POWER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. ORDERS
LICENSING PROJ MANAGFR.....D. HOOD
DOCKET NUMBER50-370
LICENSE & DATE ISSUANCE...NPF-17, MAY 27, 1983
PUBLIC DOCUMENT ROOM.....MS. DAWN HUBBS
ATKINS LIBRARY
UNIVERSITY OF NORTH CAROLINA - CHARLOTTE
UNCC STATION,
CHARLOTTE, NC 28223

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JANUARY 21 - FEBRUARY 26 (83-04): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED THE AREAS OF OPERATIONS SAFETY VERIFICATION, SURVEILLANCE TESTING, MAINTENANCE ACTIVITIES, AND FOLLOW-UP ON PREVIOUS INSPECTION FINDINGS. IN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED WITH TWO EXAMPLES INVOLVING A FAILURE TO FOLLOW PROCEDURES AND AN INADEQUATE PROCEDURE ASSOCIATED WITH PERFORMING EQUALIZING CHARGES ON VITAL BATTERIES AND OPERATING THE CHEMICAL AND VOLUME CONTROL SYSTEM.

INSPECTION FEBRUARY 27 - MARCH 18 (88-07): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED THE AREAS OF OPERATIONS SAFETY VERIFICATION, SURVEILLANCE TESTING, MAINTENANCE ACTIVITIES, AND FOLLOW-UP ON PREVIOUS INSPECTION FINDINGS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

1. Docket: 50-245 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On line Hrs: 744.0

3. Utility Contact: G. NEWBIRGH (203) 947-1791 X4400

4. Licensed Thermal Power (MWT): 2011

5. Nameplate Rating (Gross MWe): 735 X 0.9 = 662

6. Design Electrical Rating (Net MWe): 660

7. Maximum Dependable Capacity (Gross MWe): 684

8. Maximum Dependable Capacity (Net MWe): 654

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|-----------|-----------|-------------|
| 12. Report Period Hrs | 744.0 | 2,184.0 | 151,992.0 |
| 13. Hours Reactor Critical | 714.8 | 2,154.8 | 118,481.1 |
| 14. Rx Reserve Shtdwn Hrs | .0 | .0 | 3,283.3 |
| 15. Hrs Generator On-Line | 705.6 | 2,145.6 | 115,338.1 |
| 16. Unit Reserve Shtdwn Hrs | .0 | .0 | 277.4 |
| 17. Gross Therm Ener (MWH) | 1,390,142 | 4,269,473 | 214,475,568 |
| 18. Gross Elec Ener (MWH) | 476,100 | 1,464,400 | 72,240,946 |
| 19. Net Elec Ener (MWH) | 455,176 | 1,401,126 | 68,918,587 |
| 20. Unit Service Factor | 94.8 | 98.2 | 75.9 |
| 21. Unit Avail Factor | 94.8 | 98.2 | 76.5 |
| 22. Unit Cap Factor (MDC Net) | 93.5 | 98.1 | 69.3 |
| 23. Unit Cap Factor (DER Net) | 92.7 | 97.2 | 68.7 |
| 24. Unit Forced Outage Rate | 5.2 | 1.8 | 11.1 |
| 25. Forced Outage Hours | 38.4 | 38.4 | 6,344.9 |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE

27. If Currently Shutdown Estimated Startup Date: N/A

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
 * MILLSTONE 1 *
 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MILLSTONE 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

XX
* MILLSTONE 1 *
XX

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 88-01 | 03/12/88 | F | 38.4 | A | 3 | 88-003 | SJ | PS | THE "A" FEEDWATER PUMP LOW SUCTION PRESSURE SWITCH HAS REPLACED, RECALIBRATED AND TESTED SATISFACTORILY. |

XXXXXXXXXXXX MILLSTONE 1 INCURRED 1 OUTAGE IN MARCH FOR REASONS
* SUMMARY *
XXXXXXXXXXXX STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-161) |
| | F-Admin | | |
| | G-Oper Error | | |
| | H-Other | | |

* MILLSTONE 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....CONNECTICUT
COUNTY.....NEW LONDON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S: OF
NEW LONDON, CONN
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...OCTOBER 26, 1970
DATE ELEC ENER 1ST GENER...NOVEMBER 29, 1970
DATE COMMERCIAL OPERATE...MARCH 1, 1971
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LONG ISLAND SOUND
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHEAST NUCLEAR ENERGY
CORPORATE ADDRESS.....P.O. BOX 270
HARTFORD, CONNECTICUT 06101
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....W. RAYMOND
LICENSING PROJ MANAGER....M. BOYLE
DOCKET NUMBER.....50-245
LICENSE & DATE ISSUANCE...DPR-21, OCTOBER 26, 1970
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY
49 ROPE FERRY ROAD
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

10 CFR 50.22(b)(2)(III) REQUIRES THAT THE NRC BE NOTIFIED WITHIN FOUR HOURS OF ANY EVENT OR CONDITION THAT ALONE COULD HAVE PREVENTED THE FULFILLMENT OF THE SAFETY FUNCTION OF SYSTEMS NEEDED TO SAFELY SHUT DOWN THE REACTOR OR MITIGATE THE CONSEQUENCES OF AN ACCIDENT. CONTRARY TO THE ABOVE, THE LICENSEE FAILED TO NOTIFY THE NRC THAT 8 OUT OF 12 CHECK VALVES IN THE MILLSTONE 1 NITROGEN SUPPLY SYSTEM TO THE AUTOMATIC PRESSURE RELIEF (APR) SYSTEM VALVES FAILED TO PASS THE REQUIRED LEAK TEST CONDUCTED ON NOVEMBER 2, 1985.
(8703 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS

OTHER ITEMS

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------------------|------------------|-------------------|---------|
| NO INPUT PROVIDED. | | | |

=====

1. Docket: 50-336 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: G. NERON (203) 447-1791 X4417

4. Licensed Thermal Power (MWh): 2700

5. Nameplate Rating (Gross MWe): 1011 X 0.9 = 910

6. Design Electrical Rating (Net MWe): 870

7. Maximum Dependable Capacity (Gross MWe): 889

8. Maximum Dependable Capacity (Net MWe): 857

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>107,520.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>1,036.5</u> | <u>77,300.5</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>2,166.9</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>958.8</u> | <u>74,210.5</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>468.2</u> |
| 17. Gross Therm Ener (MWH) | <u>2,006,818</u> | <u>2,446,448</u> | <u>189,766,439</u> |
| 18. Gross Elec Ener (MWH) | <u>664,300</u> | <u>804,800</u> | <u>61,667,373</u> |
| 19. Net Elec Ener (MWH) | <u>641,262</u> | <u>766,881</u> | <u>59,143,138</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>43.9</u> | <u>69.0</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>43.9</u> | <u>69.5</u> |
| 22. Unit Cap Factor (MDC Net) | <u>100.6</u> | <u>41.0</u> | <u>64.9*</u> |
| 23. Unit Cap Factor (DER Net) | <u>99.1</u> | <u>40.4</u> | <u>63.9*</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>15.0</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>11,785.4</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Dat, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* MILLSTONE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
MILLSTONE 2



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* MILLSTONE 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|------------------|---|
|-----|------|------|-------|--------|--------|------------|------------------|---|

NONE

* SUMMARY *

MILLSTONE 2 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES
OR SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0151) |

* MILLSTONE 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....CONNECTICUT
COUNTY.....NEW LONDON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI SW OF
NEW LONDON, CONN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 17, 1975
DATE ELEC EMER 1ST GENER...NOVEMBER 9, 1975
DATE COMMERCIAL OPERATE...DECEMBER 26, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LONG ISLAND SOUND
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHEAST NUCLEAR ENERGY
CORPORATE ADDRESS.....P.O. BOX 270
HARTFORD, CONNECTICUT 06101
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....W. RAYMOND
LICENSING PROJ MANAGER.....D. JAFFE
DOCKET NUMBER.....50-336
LICENSE & DATE ISSUANCE...DPR-65, SEPTEMBER 30, 1975
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY
49 ROPE FERRY ROAD
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

MILLSTONE UNIT 2 TS 6.2.2A REQUIRES THAT ADMINISTRATIVE PROCEDURES BE DEVELOPED AND IMPLEMENTED TO LIMIT WORKING HOURS OF UNIT STAFF WHO PERFORM SAFETY-RELATED FUNCTIONS. PLANT PROCEDURE ACP 1.19/NDO 1.09, "OVERTIME CONTROLS FOR PERSONNEL WORKING AT THE OPERATING NUCLEAR STATION," REV 1, DEVELOPED PURSUANT TO THE ABOVE THE THREE MILE ISLAND ACTION PLAN, REQUIRES THAT AN INDIVIDUAL NOT BE PERMITTED TO WORK MORE THAN 24 HOURS IN ANY 48 HOUR PERIOD OR MORE THAN 72 HOURS IN ANY WORK WEEK, UNLESS SUCH OVERTIME USE IS AUTHENTICATED AND CONTROLLED BY STATION MANAGEMENT. CONTRARY TO THE ABOVE, DURING ONE WEEK WORK INTERVALS IN THE PERIOD FROM JANUARY 26, 1987 TO FEBRUARY 15, 1987 SIX INDIVIDUALS WORKED MORE THAN 72 HOURS IN A WORK WEEK WITHOUT THE REQUIRED MANAGEMENT APPROVAL, AND ONE INDIVIDUAL WORKED MORE THAN 72 HOURS IN A WEEK AND MORE THAN 24 HOURS IN A 48 HOUR PERIOD WITHOUT THE REQUIRED MANAGEMENT APPROVAL.

(8702 5)

OTHER ITEMS

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

NO INPUT PROVIDED.

=====

1. Docket: 50-425 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: A. ELMS (203) 444-5388

4. Licensed Thermal Power (Mwt): 3411

5. Nameplate Rating (Gross MWe): 1253

6. Design Electrical Rating (Net MWe): 1154

7. Maximum Dependable Capacity (Gross MWe): 1197

8. Maximum Dependable Capacity (Net MWe): 1142

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>17,016.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>1,358.7</u> | <u>13,122.2</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>226.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>1,192.5</u> | <u>12,783.0</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,425,760</u> | <u>3,775,431</u> | <u>46,044,862</u> |
| 18. Gross Elec Ener (MWH) | <u>882,105</u> | <u>1,344,397</u> | <u>14,553,667</u> |
| 19. Net Elec Ener (MWH) | <u>846,260</u> | <u>1,269,011</u> | <u>13,873,088</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>54.6</u> | <u>75.1</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>54.6</u> | <u>75.1</u> |
| 22. Unit Cap Factor (MDC Net) | <u>99.6</u> | <u>50.9</u> | <u>71.4</u> |
| 23. Unit Cap Factor (DER Net) | <u>98.6</u> | <u>50.4</u> | <u>70.6</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>3.0</u> | <u>8.0</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>37.1</u> | <u>1,111.6</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* MILLSTONE 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MILLSTONE 3



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* MILLSTONE 3 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|------------------|---|
|-----|------|------|-------|--------|--------|------------|------------------|---|

NONE

* SUMMARY *

MILLSTONE 3 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES OR
SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* MILLSTONE 3 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....CONNECTICUT
COUNTY.....NEW LONDON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...3.2 MI WSW OF
NEW LONDON CT.
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JANUARY 23, 1986
DATE ELEC ENER 1ST GENER...FEBRUARY 12, 1986
DATE COMMERCIAL OPERATE...APRIL 23, 1986
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...ATLANTIC BAY
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHEAST NUCLEAR ENERGY
CORPORATE ADDRESS.....P.O. BOX 270
HARTFORD, CONNECTICUT 06101
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....W. RAYMOND
LICENSING PROJ MANAGER....R. FERGUSON
DOCKET NUMBER.....50-423
LICENSE & DATE ISSUANCE...NPF-49, JANUARY 31, 1986
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY
49 ROPE FERRY ROAD
WATERFORD, CONNECTICUT 06385

INSPECTION STATUS

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

1. Docket: 50-263 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: A. L. Myrabo (612) 295-5151

4. Licensed Thermal Power (MWh): 1670

5. Nameplate Rating (Gross MWe): 632 X 0.9 = 569

6. Design Electrical Rating (Net MWe): 545

7. Maximum Dependable Capacity (Gross MWe): 564

8. Maximum Dependable Capacity (Net MWe): 536

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>146,857.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>114,421.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>940.7</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,184.0</u> | <u>112,197.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,241,530</u> | <u>3,629,173</u> | <u>179,307,247</u> |
| 18. Gross Elec Ener (MWH) | <u>420,799</u> | <u>1,231,187</u> | <u>58,111,243</u> |
| 19. Net Elec Ener (MWH) | <u>405,222</u> | <u>1,185,460</u> | <u>55,556,578</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>76.4</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>76.4</u> |
| 22. Unit Cap Factor (MDC Net) | <u>101.6</u> | <u>101.3</u> | <u>70.6</u> |
| 23. Unit Cap Factor (DER Net) | <u>99.9</u> | <u>99.6</u> | <u>69.4</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>4.4</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>1,498.3</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* MONTICELLO *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MONTICELLO



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

XXX
X MONTICELLO X
XXX

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

***** MONTICELLO OPERATED ROUTINELY IN MARCH WITH NO OUTAGES OR
* SUMMARY * SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | G-Oper Error | 3-Auto Scram | Preparation of |
| | C-Refueling | 4-Continued | Data Entry Sheet |
| | H-Other | 5-Reduced Load | Licensee Event Report |
| | D-Regulatory Restriction | 9-Other | (LER) File (NUREG-0161) |
| | E-Operator Training & License Examination | | |

* MONTICELLO *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....MINNESOTA
COUNTY.....WRIGHT
DIST AND DIRECTION FROM
NEAREST POPULATION CTR.... MI NW OF
MINNEAPOLIS, MN
TYPE OF REACTOR.....B1
DATE INITIAL CRITICALITY...DECEMBER 10, 1970
DATE ELECTRIC 1ST GENER...MARCH 5, 1971
DATE COMMERCIAL OPERATE...JUNE 30, 1973
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHERN STATES POWER
CORPORATE ADDRESS.....414 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....P. HARTMAN
LICENSING PROJ MANAGER.....J. STEFANO
DOCKET NUMBER.....50-263
LICENSE & DATE ISSUANCE...DPR-22, JANUARY 9, 1981
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY
MINNEAPOLIS PUBLIC LIBRARY
300 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

INSPECTION SUMMARY

INSPECTION STATUS

INSPECTION ON JANUARY 13 - FEBRUARY 23, 1988 (88003). A ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY VERIFICATION; MAINTENANCE SURVEILLANCE; HIGH PRESSURE COOLANT INJECTION SYSTEM; REACTOR COOLANT INJECTION COOLING SYSTEM; RESIDUAL HEAT REMOVAL SERVICE WATER SYSTEM; RADIATION SURVEYS; AND LICENSEE EVENT REPORTS. OF THE NINE AREAS INSPECTED, NO VIOLATIONS AND NO SAFETY CONCERNS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

10 CFR 50.49, PARAGRAPHS (F) AND (G) REQUIRE EQUIPMENT IMPORTANT TO SAFETY TO BE QUALIFIED BY TESTING AND ANALYSIS PRIOR TO THE EQ DEADLINE OF NOVEMBER 30, 1985. CONTRARY TO THE ABOVE, THE FOLLOWING EQUIPMENT WAS NOT QUALIFIED BY TEST AND/OR ANALYSIS FOR THEIR INSTALLED CONDITIONS. IN ADDITION, APPROPRIATE MAINTENANCE ACTIVITIES WERE NOT SPECIFIED IN THE LICENSEE'S QUALIFICATION FILES AS NECESSARY TO MAINTAIN THE ENVIRONMENTAL QUALIFICATION (EQ) OF THE EQUIPMENT, AND THE LICENSEE COULD NOT PROVIDE EVIDENCE OF HAVING PERFORMED THESE ACTIVITIES. EQ REPORT 0910-111-FR-14 FOR LIMITORQUE OPERATORS STATES THAT THE AGING OF LUBRICANTS IS NOT A CONCERN IF REGULAR INSPECTION AND REPLACEMENT OF LUBRICANTS IS PERFORMED. LIMITORQUE PROCEDURE LC8 INDICATES THAT THE LUBRICANT IN THE LIMITORQUE MAIN GEAR CASE AND THE LIMIT SWITCH COMPARTMENT SHOULD BE INSPECTED AND CHANGED, IF NECESSARY, AT 18 MONTH INTERVALS AND 36 MONTH INTERVALS RESPECTIVELY. THIS PROCEDURE ALLOWS FOR EXTENDING THESE INTERVALS IF PREVIOUS INSPECTIONS HAVE NOT IDENTIFIED ANY DEGRADATION OF THE LUBRICANT. THE INSPECTORS OBSERVED THAT THE LUBRICANT IN LIMITORQUE MOTOR OPERATORS 2012

ENFORCEMENT SUMMARY

AND 2373 HAD NOT BEEN INSPECTED SINCE 1984. AND THAT THE LICENSEE COULD NOT PROVIDE EVIDENCE THAT PRIOR INSPECTIONS HAD BEEN PERFORMED TO IDENTIFY ANY DEGRADATION OF THE LUBRICANT. (50-263/87013-01(A)(DRS)) (B) EQ REPORT 0910-111-FR-33, PAGE 21 OF 42, PARAGRAPH 4.2.3, FOR RELIANCE MOTORS, REQUIRES LUBRICANTS TO BE EXAMINED ON A PERIODIC BASIS TO IDENTIFY ANY DEGRADATION AND REQUIRES PERIODIC MAINTENANCE PROCEDURES TO INCLUDE ACTIVITIES FOR SURVEILLANCE AND REPLACEMENT OF LUBRICANTS. THE INSPECTORS OBSERVED THAT THIS REQUIREMENT WAS NOT IDENTIFIED IN THE LICENSEE'S EQ MAINTENANCE OR PREVENTATIVE MAINTENANCE PROGRAMS, AND THAT THERE WAS NO EVIDENCE THAT THE LICENSEE HAD PERFORMED SUCH SURVEILLANCE INSPECTIONS. (50-263/87013-01(B)(DRS)) (C) DURING EXAMINATION OF RHR PUMP MOTOR P-202B THE INSPECTORS OBSERVED THAT THE INSTALLED MOTOR LEAD JUNCTION BOX CONTAINED WATER AND SLUDGE, AND THAT THE CABLE AND CABLE SPLICES IN THE BOX WERE WET DUE TO CONDENSATION IN THE CONDUIT AND DRAINAGE INTO THE MOTOR LEAD JUNCTION BOX. THIS CONDITION WAS CONTRARY TO THE TESTED CONDITIONS AND INSTALLATION REQUIREMENTS. (50-263/87013-01(C)(DRS)). (D) MOBILUX EPD IS USED TO LUBRICATE THE MAIN GEAR CASE LIMITORQUE OPERATORS(50-263/87013-01(D)) (8701 4)

TECHNICAL SPECIFICATION 6.5, PLANT OPERATING PROCEDURES, STATES THAT DETAILED WRITTEN PROCEDURES, INCLUDING THE APPLICABLE CHECK-OFF LISTS AND INSTRUCTIONS, SHALL BE PREPARED AND FOLLOWED. CONTRARY TO THE ABOVE, DURING THE PERIOD OF DECEMBER 1, 1987 TO JANUARY 12, 1988 SEVERAL EXAMPLES OF FAILURE TO FOLLOW APPROVED PLANT PROCEDURES WERE IDENTIFIED. EACH EXAMPLE IS DISCUSSED BELOW: (A) DURING THE PERFORMANCE OF TEST PROCEDURE #0417-2, REVISION 0, "B" CGCS RECOMBINER REACTION CHAMBER OPERABILITY TEST AN OPERATOR FAILED TO PERFORM A SOAK OF THE CGCS RECOMBINATION REACTION CHAMBER IN ACCORDANCE WITH THE PROCEDURE. (B) DURING THE PERFORMANCE OF TEST PROCEDURE #0189-1, REVISION 12, EMERGENCY DIESEL GENERATOR AUTOMATIC FAST START INITIATION OPERATORS FAILED TO FOLLOW APPROVED METHODS OF INDEPENDENT VERIFICATION SPECIFIED IN 4 ACD (ADMINISTRATIVE CONTROL DOCUMENT)-04.07, REVISION 12, SECTION 6.16. (C) DURING THE PERFORMANCE OF TEST PROCEDURE #0036-1/0039-1, REVISION 10, ECCS EMERGENCY BUS UNDERVOLTAGE TEST-1/ECCS LOSS OF NORMAL AUXILIARY POWER TEST-1 OPERATORS FAILED TO FOLLOW APPROVED METHODS OF INDEPENDENT VERIFICATION SPECIFIED IN 4 ACD-04.07, REVISION 12, SECTION 6.16. (D) DURING PERFORMANCE OF TEST PROCEDURE NO.1025A, A RADIATION PROTECTION SPECIALIST FAILED TO FOLLOW AN APPROVED PROCEDURE BY TESTING A DIFFERENT RADIATION MONITOR THAN REQUIRED BY THE TEST PROCEDURE. THIS RESULTED IN ENGINEERED SAFETY FEATURE (ESF) ACTUATIONS. (E) DURING PERFORMANCE OF TEST PROCEDURE NO. 0067, A LICENSED OPERATOR FAILED TO FOLLOW AN APPROVED PROCEDURE STEP OF INSTALLING A JUMPER ON A SPECIFIED TERMINAL. THIS RESULTED IN AN ESF ACTUATION. (F) DURING PERFORMANCE OF THE MODIFICATION PREOPERATIONAL TEST PROCEDURE FOR RESIDUAL HEAT REMOVAL VALVE MO-2407, A LICENSED OPERATOR FAILED TO INSTALL A JUMPER ON THE PROPER TERMINAL AS REQUIRED. THE ERROR RESULTED FROM INSTALLATION BY WIRE IDENTIFICATION RATHER THAN TERMINAL VERIFICATION. THIS RESULTED IN ESF ACTUATIONS. (8702 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING ROUTINELY

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-220 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: THOMAS W. ROMAN (315) 349-2422

4. Licensed Thermal Power (Mwt): 1850

5. Nameplate Rating (Gross MWe): 755 X 0.85 = 642

6. Design Electrical Rating (Net MWe): 620

7. Maximum Dependable Capacity (Gross MWe): 630

8. Maximum Dependable Capacity (Net MWe): 610

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|--------------|----------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>161,424.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>.0</u> | <u>115,235.2</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>1,204.2</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>.0</u> | <u>112,102.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>20.2</u> |
| 17. Gross Therm Ener (MWH) | <u>.0</u> | <u>0</u> | <u>188,473,049</u> |
| 18. Gross Elec Ener (MWH) | <u>.0</u> | <u>0</u> | <u>62,473,071</u> |
| 19. Net Elec Ener (MWH) | <u>.0</u> | <u>0</u> | <u>60,524,379</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>.0</u> | <u>69.4</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>.0</u> | <u>69.5</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>.0</u> | <u>61.5</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>.0</u> | <u>60.5</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>100.0</u> | <u>14.9</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>516.0</u> | <u>15,047.9</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 05/07/88

* NINE MILE POINT 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
NINE MILE POINT 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * NINE MILE POINT 1 *

| No. | Date | Typ. | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 02 | 01/22/88 | S | 744.0 | C | 4 | | | | THE DECISION WAS MADE TO START THE REFUEL OUTAGE SINCE THE PLANT WAS ALREADY SHUTDOWN DUE TO PROBLEMS WITH THE F.W. SYSTEM. |

 * SUMMARY *

 NINE MILE POINT 1 REMAINED SHUTDOWN IN MARCH FOR SCHEDULED REFUELING OUTAGE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* NINE MILE POINT 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....OSWEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...8 MI NE OF
OSWEGO, NY
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 5, 1969
DATE ELEC ENER 1ST GENER...NOVEMBER 9, 1969
DATE COMMERCIAL OPERATE...DECEMBER 1, 1969
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ONTARIO
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NIAGARA MOHAWK POWER CORP.
CORPORATE ADDRESS.....300 ERIE BOULEVARD WEST
SYRACUSE, NEW YORK 13202
CONTRACTOR
ARCHITECT/ENGINEER.....NIAGARA MOHAWK POWER CORP.
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....S. HUDSON
LICENSING PROJ MANAGER.....R. BENEDICT
DOCKET NUMBER.....50-220
LICENSE & DATE ISSUANCE...DPR-63, DECEMBER 26, 1974
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO
PENFIELD LIBRARY - DOCUMENTS
OSWEGO, NY 13126
(315) 341-2323

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

* NINE MILE POINT 1 *

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

NO INPUT PROVIDED.

=====

1. Docket: 50-410 OPERATING STATUS
 2. Reporting Period: 03/01/88 Outage + On-line Hrs: 489.0
 3. Utility Contact: E. TOMLINSON (315) 349-2761
 4. Licensed Thermal Power (MWT): 3323
 5. Nameplate Rating (Gross MWe): 1214
 6. Design Electrical Rating (Net MWe): 1080
 7. Maximum Dependable Capacity (Gross MWe): 1080
 8. Maximum Dependable Capacity (Net MWe): 1080
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|----------------|----------------|----------------|
| 12. Report Period Hrs | <u>489.0</u> | <u>489.0</u> | <u>489.0</u> |
| 13. Hours Reactor Critical | <u>304.4</u> | <u>304.4</u> | <u>304.4</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>272.0</u> | <u>272.0</u> | <u>272.0</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>893,359</u> | <u>893,359</u> | <u>893,359</u> |
| 18. Gross Elec Ener (MWH) | <u>215,640</u> | <u>215,640</u> | <u>215,640</u> |
| 19. Net Elec Ener (MWH) | <u>194,090</u> | <u>194,090</u> | <u>194,090</u> |
| 20. Unit Service Factor | <u>55.6</u> | <u>55.6</u> | <u>55.6</u> |
| 21. Unit Avail Factor | <u>55.6</u> | <u>55.6</u> | <u>55.6</u> |
| 22. Unit Cap Fzctor (MDC Net) | <u>36.8</u> | <u>36.8</u> | <u>36.8</u> |
| 23. Unit Cap Factor (DER Net) | <u>36.8</u> | <u>36.8</u> | <u>36.8</u> |
| 24. Unit Forced Outage Rate | <u>44.4</u> | <u>44.4</u> | <u>44.4</u> |
| 25. Forced Outage Hours | <u>217.0</u> | <u>217.0</u> | <u>217.0</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

5/2/88-21 DAYS, MAINT/SURV 9/15/88-48 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

 * NINE MILE POINT 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 NINE MILE POINT 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * NINE MILE POINT 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 88-1 | 03/13/88 | F | 116.1 | A | 3 | 88-14 | AD | PT/LT | A FAILED STEAM DOME PRESSURE TRANSMITTER CAUSED REACTOR RECIRC. PUMPS TO DOWN SHIFT DUE TO DELTA TEMP. LOGIC. THIS LEAD TO A SEQUENCE OF EVENTS THAT DROPPED REACTOR WATER LEVEL TO LVL 3 INITIATING A SCRAM. |
| 88-2 | 03/21/88 | F | 100.9 | G | 3 | 88-17 | SJ | | I&C TECHNICIAN VALVED OUT A FEEDWATER FLOW TRANSMITTER FOR CALIBRATION, WHICH SENT A FALSE SIGNAL TO THE FEEDWATER CONTROL SYSTEM. THIS SIGNAL FAILURE RESULTED IN THE FEEDWATER SYSTEM INCREASING FLOW TO LVL 8 WHICH RESULTED IN A MAIN TURBINE TRIP AND REACTOR SCRAM ON TCV FAST CLOSURE. |

 * SUMMARY *

 NINE MILE POINT 2 ENTERED COMMERCIAL OPERATION ON MARCH 11, 1988,
 AND SUBSEQUENTLY, INCURRED TWO FORCED OUTAGES.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* NINE MILE POINT 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....OSWEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...8 MI NE OF
OSWEGO, NY
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MAY 23, 1987
DATE ELEC ENER 1ST GENER...AUGUST 8, 1987
DATE COMMERCIAL OPERATE...MARCH 11, 1988
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...LAKE ONTARIO
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NIAGARA MOHAWK POWER CORP.
CORPORATE ADDRESS.....300 ERIE BOULEVARD WEST
SYRACUSE, NEW YORK 13202
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....W. COOK
LICENSING PROJ MANAGER.....M. HAUGHEY
DOCKET NUMBER.....50-410
LICENSE & DATE ISSUANCE...NPF-69, JULY 2, 1987
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO
PENFIELD LIBRARY - DOCUMENTS
OSWEGO, NY 13126
(315) 341-2323

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

* NINE MILE POINT 2 *

PLANT STATUS:

INFO. NOT SUPPLIED BY REGION

LAST IE SITE INSPECTION DATE: INFO. NOT SUPPLIED REGION

INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION

R E P O R T S F R O M L I C E N S E E

NUMBER DATE OF DATE OF SUBJECT
 EVENT REPORT

INFO. NOT SUPPLIED BY REGION

1. Docket: 50-338 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: B. GARNER (703) 894-5151 X2527

4. Licensed Thermal Power (Mwt): 2893

5. Nameplate Rating (Gross MWe): 947

6. Design Electrical Rating (Net MWe): 907

7. Maximum Dependable Capacity (Gross MWe): 963

8. Maximum Dependable Capacity (Net MWe): 915

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Lev To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>86,089.0</u> |
| 13. Hours Reactor Critical | <u>678.0</u> | <u>1,458.8</u> | <u>58,890.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>66.0</u> | <u>148.6</u> | <u>5,796.6</u> |
| 15. Hrs Generator On-Line | <u>630.2</u> | <u>1,298.5</u> | <u>57,067.0</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,670,521</u> | <u>3,501,361</u> | <u>149,678,135</u> |
| 18. Gross Elec Ener (MWH) | <u>553,740</u> | <u>1,156,593</u> | <u>49,060,481</u> |
| 19. Net Elec Ener (MWH) | <u>524,729</u> | <u>1,096,198</u> | <u>46,390,792</u> |
| 20. Unit Service Factor | <u>84.7</u> | <u>59.5</u> | <u>66.3</u> |
| 21. Unit Avail Factor | <u>84.7</u> | <u>59.5</u> | <u>66.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>77.1</u> | <u>54.9</u> | <u>58.9</u> |
| 23. Unit Cap Factor (DER Net) | <u>77.8</u> | <u>55.3</u> | <u>59.4</u> |
| 24. Unit forced Outage Rate | <u>.0</u> | <u>37.3</u> | <u>15.8</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>771.7</u> | <u>10,593.2</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* NORTH ANNA 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NORTH ANNA 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * NORTH ANNA 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 88-03 | 03/16/88 | S | 0.0 | B | 5 | | | | COMMENCED RAMPDOWN TO 30% POWER, DUE TO EXCEEDING ACTION LEVEL II ON STEAM GENERATION CATIONS AND SODIUMS. |
| 88-04 | 03/17/88 | S | 113.8 | B | 1 | 88-013 | IT | PR | MARCH 17, 1988, COMMENCED TO RAMPDOWN TO 0% POWER, TO TEST COMPONENT COOLING TRIP VALVES ON 'C' REACTOR COOLANT PUMP. MARCH 19, AT 0133, A REACTOR TRIP OCCURRED DUE TO A FIRST STAGE PRESSURE SPIKE EXPERIENCED DURING TURBINE ROLL-UP. REPAIRS WERE COMPLETED AND UNIT RETURNED ON LINE MARCH 22, 1988 AT 1700. |

 * SUMMARY *

 NORTH ANNA 1 INCURRED 1 POWER REDUCTION AND 1 OUTAGE
 IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* NORTH ANNA 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA
COUNTY.....LOUISA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI NW OF
RICHMOND, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 5, 1978
DATE ELEC ENER 1ST GENER...APRIL 17, 1978
DATE COMMERCIAL OPERATE...JUNE 6, 1978
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ANNA
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....M. BRANCH
LICENSING PROJ MANAGER.....L. ENGLE
DOCKET NUMBER.....50-338
LICENSE & DATE ISSUANCE...NPF-4, APRIL 1, 1978
PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT.
UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901

INSPECTION STATUS

INSPECTION SUMMARY

* INSPECTION SEPTEMBER 28 - OCTOBER 2 (87-33): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF REVIEW OF THE CONTAINMENT ISOLATION SYSTEM LOCAL LEAK RATE PROGRAM INCLUDING REVIEW OF TEST PROCEDURES, VALVE ALIGNMENTS AND OBSERVATION OF TESTING. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION DECEMBER 19 - JANUARY 15 (87-42): THIS ROUTINE INSPECTION BY THE RESIDENT INSPECTORS INVOLVED THE FOLLOWING AREAS: PLANT STATUS, LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, LICENSEE EVENT REPORT (LER) FOLLOWUP, MONTHLY MAINTENANCE OBSERVATION, MONTHLY SURVEILLANCE OBSERVATION, OPERATOR SAFETY VERIFICATION, AND OPERATING REACTOR EVENTS. DURING THE PERFORMANCE OF THIS INSPECTION, THE RESIDENT INSPECTORS CONDUCTED REVIEWS OF THE LICENSEE'S BACKSHIFT OPERATIONS ON DECEMBER 26 AND 30, 1987 AND JANUARY 4, 5, 6, 13, 14 AND 15, 1988. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 16 - FEBRUARY 23 (88-01): THIS ROUTINE INSPECTION BY THE RESIDENT INSPECTORS INVOLVED THE FOLLOWING AREAS: PLANT STATUS, UNRESOLVED ITEMS, LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, LICENSEE EVENT REPORT (LER) FOLLOWUP, REVIEW OF INSPECTOR FOLLOW-UP ITEMS, MONTHLY MAINTENANCE OBSERVATION, MONTHLY SURVEILLANCE OBSERVATION, ESF WALKDOWN, AND OPERATOR SAFETY VERIFICATION. DURING THE PERFORMANCE OF THIS INSPECTION, THE RESIDENT INSPECTORS CONDUCTED REVIEWS OF THE LICENSEE'S BACKSHIFT OPERATIONS ON THE FOLLOWING DAYS - JANUARY 18, 24, 28, 29, 31, FEBRUARY 1, 2, 3, 5, 6, 9, 11, 12, 15 AND 16. ONE VIOLATION WITH TWO EXAMPLES FOR FAILURE TO FOLLOW PROCEDURE AND FAILURE TO HAVE AN ADEQUATE PROCEDURE.

INSPECTION JANUARY 25-29 AND FEBRUARY 8-12 (88-02): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF QUALITY ASSURANCE EFFECTIVENESS. THREE VIOLATIONS WERE IDENTIFIED - FAILURE TO ADEQUATELY IMPLEMENT THE INSERVICE TESTING PROGRAM; FAILURE TO CONDUCT ADEQUATE AUDITS; AND FAILURE TO PERFORM A DOCUMENTED DESIGN ANALYSIS WITH SUPPORTING CALCULATIONS AND TO

INSPECTION SUMMARY

DOCUMENT A DESIGN CHANGE. ONE UNRESOLVED ITEM WAS IDENTIFED CONCERNING FAILURE OF THE LICENSEE TO PROPERLY CONTROL ENTRY INTO POSTED HIGH RADIATION AREAS.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION III, AND THE LICENSEE'S ACCEPTED QUALITY ASSURANCE (QA) PROGRAM, UPDATE FINAL SAFETY ANALYSIS REPORT, SECTION 17.2.3, A DESIGN CHANGE WAS MADE TO PIPE HANGER 01-CC-R-173 AND THE ANALYSIS WAS NOT PERFORMED IN A PLANNED, CONTROLLED AND CORRECT MANNER IN THAT A DOCUMENTED ANALYSIS WAS NOT PERFORMED AND THE SUPPORTING CALCULATIONS WERE NOT IDENTIFIED. ADDITIONALLY, THE DESIGN CHANGE WAS NOT DOCUMENTED.
(8800 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ RESIN IN SECONDARY PLANT.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ COLD SHUTDOWN FOR RESIN CLEANUP.

LAST IE SITE INSPECTION DATE: JANUARY 25-29 - FEBRUARY 8-12, 1988 +

INSPECTION REPORT NO: 50-338/88-02 +

Report Period MAR 1988

REPORTS FROM LICENSEE

* NORTH ANNA 1 *

```
=====
```

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|--|
| 88-004 | 01/13/88 | 03/16/88 | RESIN INTRUSION INTO THE SECONDARY SIDE WATER SYSTEM |
| 88-007 | 01/26/88 | 02/24/88 | UNIDENTIFIED FIRE BARRIER PENETRATIONS; INADEQUATE DESIGN CONST CONTROLS DURING INITIAL CONST OF STATION |
| 88-008 | 02/02/88 | 02/24/88 | INADVERTANT PORV ACTUATION DURING SOLID WATER OPERATIONS |
| 88-009 | 02/11/88 | 03/10/88 | MISSED SURVEILLANCE ON A BLOWDOWN ISOLATION TRIP VALVE - INSIDE CONTAINMENT |

```
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Bucket: 50-339 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: B. GARNER (70,) 894-5151 X2527

4. Licensed Thermal Power (MWT): 2893

5. Nameplate Rating (Gross MWe): 947

6. Design Electrical Rating (Net MWe): 907

7. Maximum Dependable Capacity (Gross MWe): 963

8. Maximum Dependable Capacity (Net MWe): 915

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MW):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>63,960.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,134.3</u> | <u>50,595.7</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>69.1</u> | <u>4,093.1</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,108.2</u> | <u>49,536.3</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,150,968</u> | <u>6,062,565</u> | <u>130,385,319</u> |
| 18. Gross Elec Ener (MWH) | <u>718,025</u> | <u>2,018,951</u> | <u>43,246,142</u> |
| 19. Net Elec Ener (MWH) | <u>683,075</u> | <u>1,920,657</u> | <u>40,979,015</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>96.5</u> | <u>77.4</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>96.5</u> | <u>77.4</u> |
| 22. Unit Cap Factor (MDC Net) | <u>100.3</u> | <u>96.1</u> | <u>70.0</u> |
| 23. Unit Cap Factor (DER Net) | <u>101.2</u> | <u>97.0</u> | <u>70.6</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>8.8</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>4,768.9</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: M/A

* NORTH ANNA 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NORTH ANNA 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

XX
* NORTH ANNA 2 *
XX

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

NORTH ANNA 2 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES OR
SIGNIFICANT POWER REDUCTIONS.

| <u>Type</u> | <u>Reason</u> | <u>Method</u> | <u>System & Component</u> |
|-------------|--------------------------|----------------|-------------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| 5-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* NORTH ANNA 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....VIRGINIA
COUNTY.....LOUISA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI NW OF
RICHMOND, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 12, 1980
DATE ELEC ENER 1ST GENER...AUGUST 25, 1980
DATE COMMERCIAL OPERATE...DECEMBER 14, 1980
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ANNA
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY
LICENSEE.....VIRGINIA POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....M. BRANCH
LICENSING PROJ MANAGER.....L. ENGLE
DOCKET NUMBER.....50-339
LICENSE & DATE ISSUANCE...NPF-7, AUGUST 21, 1980
PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT.
UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

* INSPECTION SEPTEMBER 28 - OCTOBER 2 (87-33): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF REVIEW OF THE CONTAINMENT ISOLATION SYSTEM LOCAL LEAK RATE PROGRAM INCLUDING REVIEW OF TEST PROCEDURES, VALVE ALIGNMENTS AND OBSERVATION OF TESTING. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION DECEMBER 19 - JANUARY 15 (87-42): THIS ROUTINE INSPECTION BY THE RESIDENT INSPECTORS INVOLVED THE FOLLOWING AREAS: PLANT STATUS, LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, LICENSEE EVENT REPORT (LER FOLLOWUP), MONTHLY MAINTENANCE OBSERVATION, MONTHLY SURVEILLANCE OBSERVATION, OPERATOR SAFETY VERIFICATION, AND OPERATING REACTOR EVENTS. DURING THE PERFORMANCE OF THIS INSPECTION, THE RESIDENT INSPECTORS CONDUCTED REVIEWS OF THE LICENSEE'S BACKSHIFT OPERATIONS ON DECEMBER 26 AND 30, 1987 AND JANUARY 4, 5, 6, 13, 14 AND 15, 1988. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 16 - FEBRUARY 23 (88-01): THIS ROUTINE INSPECTION BY THE RESIDENT INSPECTORS INVOLVED THE FOLLOWING AREAS: PLANT STATUS, UNRESOLVED ITEMS, LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, LICENSEE EVENT REPORT (LER) FOLLOWUP, REVIEW OF INSPECTOR FOLLOW-UP ITEMS, MONTHLY MAINTENANCE OBSERVATION, MONTHLY SURVEILLANCE OBSERVATION, ESF WALKDOWN, AND OPERATOR SAFETY VERIFICATION. DURING THE PERFORMANCE OF THIS INSPECTION, THE RESIDENT INSPECTORS CONDUCTED REVIEWS OF THE LICENSEE'S BACKSHIFT OPERATIONS ON THE FOLLOWING DAYS - JANUARY 18, 24, 28, 29, 31, FEBRUARY 1, 2, 3, 5, 6, 9, 11, 12, 15 AND 16. ONE VIOLATION WITH TWO EXAMPLES FOR FAILURE TO FOLLOW PROCEDURE AND FAILURE TO HAVE AN ADEQUATE PROCEDURE.

INSPECTION JANUARY 25-29 AND FEBRUARY 8-12 (88-02): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF QUALITY ASSURANCE EFFECTIVENESS. THREE VIOLATIONS WERE IDENTIFIED - FAILURE TO ADEQUATELY IMPLEMENT THE INSERVICE TESTING PROGRAM; FAILURE TO CONDUCT ADEQUATE AUDITS; AND FAILURE TO PERFORM A DOCUMENTED DESIGN ANALYSIS WITH SUPPORTING CALCULATIONS AND TO

1. Docket: 50-269 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (Mwt): 2568

5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe): 887

7. Maximum Dependable Capacity (Gross MWe): 899

8. Maximum Dependable Capacity (Net MWe): 846

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level: To which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>128,953.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>95,493.3</u> |
| 14. Rx Reserve Shutdown Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,184.0</u> | <u>91,881.4</u> |
| 16. Unit Reserve Shutdown Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,898,880</u> | <u>5,447,016</u> | <u>221,932,081</u> |
| 18. Gross Elec Ener (MWH) | <u>659,709</u> | <u>1,885,578</u> | <u>76,993,235</u> |
| 19. Net Elec Ener (MWH) | <u>631,582</u> | <u>1,802,770</u> | <u>73,013,875</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>71.3</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>71.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>100.3</u> | <u>97.6</u> | <u>65.7*</u> |
| 23. Unit Cap Factor (DER Net) | <u>95.7</u> | <u>93.1</u> | <u>63.9*</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>13.6</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>13,514.7</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* OCONEE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

OCONEE 1



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* OCONEE 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 5-P | 03/27/88 | F | 0.0 | A | 5 | | HJ | PUMPXX | HIGH BEARING TEMPERATURE ON "1E1" HEATER DRAIN PUMP. |

* SUMMARY *

OCONEE 1 EXPERIENCED 1 POWER REDUCTION IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & d |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refuel | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NREG-0161) |

* OCONEE 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....OCONEE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI W OF
GREENVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 19, 1973
DATE ELEC ENER 1ST GENER...MAY 6, 1973
DATE COMMERCIAL OPERATE...JULY 15, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE KEOHEE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE & BECTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. BRYANT
LICENSING PROJ MANAGER.....H. PASTIS
DOCKET NUMBER.....50-269
LICENSE & DATE ISSUANCE...DPR-38, FEBRUARY 6, 1973
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY
501 W. SOUTH BROAD ST.
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 16-25 (88-04): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF INSERVICE INSPECTION (ISI) OF OCONEE UNIT-2, INCLUDING EDDY CURRENT TESTING (ET) OF ONCE THROUGH STEAM GENERATOR (OTSG) TUBES, ULTRASONIC EXAMINATION (UT) OF REACTOR VESSEL FLANGE TO SHELL WELD AND SAFETY-RELATED PIPING; RADIOGRAPHIC EXAMINATION OF OTHER PIPE WELDS; FEEDWATER NOZZLE SPRAY HEAD REPLACEMENT; OTSG NOZZLE DAM RETENTION RING INSTALLATION; PIPE/FITTING EROSION INSPECTION; AND VALVE MAINTENANCE. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 17 - MARCH 16 (88-05): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED RESIDENT INSPECTION ON-SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE, MAINTENANCE, PHYSICAL SECURITY, ENGINEERED SAFEGUARDS FEATURES (LINEUPS, NONROUTINE REPORTING AND DESIGN CHANGES. OF THE SEVEN AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 18 (88-06): THIS ANNOUNCED PHYSICAL SECURITY INSPECTION WAS CONDUCTED TO REVIEW THE GENERAL REQUIREMENTS FOR THE PHYSICAL PROTECTION OF IRRADIATED REACTOR FUEL DURING TRANSPORTATION BETWEEN LICENSEE SITES. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REGULATIONS AND ITS SPENT FUEL TRANSPORTATION PLAN.

INSPECTION MARCH 7-11 (88-07): THIS ROUTINE, ANNOUNCED INSPECTION WAS IN THE AREAS OF INSERVICE INSPECTION (ISI) INCLUDING NONDESTRUCTIVE EXAMINATION (NDE) PROCEDURES REVIEW, IN-PROCESS EXAMINATIONS OBSERVATIONS, EXAMINATION DATA REVIEW, AND EQUIPMENT AND PERSONNEL CERTIFICATION RECORDS REVIEW. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: MARCH 7-11, 1988 +

INSPECTION REPORT NO: 50-269/88-07 +

R E P O R T S F R O M L I C E N S E E

```
=====
```

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|--|
| 88-001 | 01/07/88 | 03/04/88 | TECHNICAL SPECIFICATION VIOLATIONS DUE TO MISSED ASME SECTION XI TESTING RESULTING FROM MANAGEMENT DEFICIENCY |
| 88-002 | 02/09/88 | 03/10/88 | VIOLATION OF TECHNICAL SPECIFICATIONS DUE TO MISSED INSERVICE TESTING OF VALVES RESULTING FROM PERSONNEL ERROR |
| 88-003 | 02/11/88 | 03/14/88 | VIOLATION OF TECH SPEC DUE TO MANAGEMENT DEFICIENCY IN THE CONTROL OF OFFSITE DOSE CALCULATIONS |

```
=====
```


1. Docket: 50-270 O P E R A T I N G S T A T U S
2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: J. A. REAVIS (704) 373-7567
4. Licensed Thermal Power (Mwt): 2568
5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934
6. Design Electrical Rating (Net MWe): 887
7. Maximum Dependable Capacity (Gross MWe): 899
8. Maximum Dependable Capacity (Net MWe): 846
9. If Changes Occur Above Since Last Report, Give Reasons:
NONE
10. Power Level To Which Restricted, If Any (Net MWe): _____
11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|---|---------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>118,873.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>797.4</u> | <u>89,494.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>796.1</u> | <u>88,089.5</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>0</u> | <u>1,736,808</u> | <u>209,376,909</u> |
| 18. Gross Elec Ener (MWH) | <u>0</u> | <u>580,690</u> | <u>71,263,371</u> |
| 19. Net Elec Ener (MWH) | <u>-1,950</u> | <u>546,312</u> | <u>67,743,630</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>36.5</u> | <u>74.1</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>36.5</u> | <u>74.1</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>29.6</u> | <u>66.1*</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>28.2</u> | <u>64.3*</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>11.8</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>10,963.0</u> |
| 26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u> | | | |

27. If Currently Shutdown Estimated Startup Date: 04/10/88

* OCONEE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
OCONEE 2



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* OCONEE 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 1 | 03/01/88 | S | 744.0 | C | 1 | | RC | FUELXX | NORMAL REFUELING. |

* SUMMARY *

OCONEE 2 REMAINED SHUTDOWN IN MARCH FOR SCHEDULED
REFUELING OUTAGE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....OCONEE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI W OF
GREENVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 11, 1973
DATE ELEC ENER 1ST GENER...DECEMBER 5, 1973
DATE COMMERCIAL OPERATE...SEPTEMBER 9, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE KEOWEE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCK STREET
CHARLOTTE, NORTH CAROLINA 28242

CONTRACTOR
ARCHITECT/ENGINEER.....BUKE & BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. BRYANT
LICENSING PROJ MANAGER....H. PASTIS
DOCKET NUMBER.....50-270
LICENSE & DATE ISSUANCE...DPR-47, OCTOBER 6, 1973
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY
501 W. SOUTH BROAD ST.
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

* INSPECTION FEBRUARY 16-25 (88-04): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF INSERVICE INSPECTION (ISI) OF OCONEE UNIT-2, INCLUDING EDDY CURRENT TESTING (ET) OF ONCE THROUGH STEAM GENERATOR (OTSG) TUBES, ULTRASONIC EXAMINATION (UT) OF REACTOR VESSEL FLANGE TO SHELL WELD AND SAFETY-RELATED PIPING; RADIOGRAPHIC EXAMINATION OF OTHER PIPE WELDS; FEEDWATER NOZZLE SPRAY HEAD REPLACEMENT; OTSG NOZZLE DAM RETENTION RING INSTALLATION; PIPE/FITTING EROSION INSPECTION; AND VALVE MAINTENANCE. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 17 - MARCH 16 (88-05): THIS ROUTINE ANNOUNCED INSPECTION INVOLVED RESIDENT INSPECTION ON-SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE, MAINTENANCE, PHYSICAL SECURITY, ENGINEERED SAFEGUARDS FEATURES LINEUPS, NONROUTINE REPORTING AND DESIGN CHANGES. OF THE SEVEN AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 18 (88-06): THIS ANNOUNCED PHYSICAL SECURITY INSPECTION WAS CONDUCTED TO REVIEW THE GENERAL REQUIREMENTS FOR THE PHYSICAL PROTECTION OF IRRADIATED REACTOR FUEL DURING TRANSPORTATION BETWEEN LICENSEE SITES. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REGULATIONS AND ITS SPENT FUEL TRANSPORTATION PLAN.

INSPECTION MARCH 7-11 (88-07): THIS ROUTINE, ANNOUNCED INSPECTION WAS IN THE AREAS OF INSERVICE INSPECTION (ISI) INCLUDING NONDESTRUCTIVE EXAMINATION (NDE) PROCEDURES REVIEW, IN-PROCESS EXAMINATIONS OBSERVATIONS, EXAMINATION DATA REVIEW, AND EQUIPMENT AND PERSONNEL CERTIFICATION RECORDS REVIEW. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

1. Docket: 50-287 O P E R A T I N G S T A T U S
2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: J. A. REAVIS (704) 373-7567
4. Licensed Thermal Power (MWT): 2568
5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934
6. Design Electrical Rating (Net MWe): 887
7. Maximum Dependable Capacity (Gross MWe): 899
8. Maximum Dependable Capacity (Net MWe): *46
9. If Changes Occur Above Since Last Report, Give Reasons:
NONE
10. Power Level To Which Restricted, If Any (Net MWe): _____
11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>116,520.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>85,533.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-line | <u>744.0</u> | <u>2,184.0</u> | <u>84,169.9</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,896,408</u> | <u>5,545,032</u> | <u>206,444,493</u> |
| 18. Gross Elec Ener (MWH) | <u>659,629</u> | <u>1,921,261</u> | <u>71,131,806</u> |
| 19. Net Elec Ener (MWH) | <u>633,093</u> | <u>1,843,206</u> | <u>67,771,836</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>72.2</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>72.2</u> |
| 22. Unit Cap Factor (MDC Net) | <u>100.6</u> | <u>99.8</u> | <u>67.5*</u> |
| 23. Unit Cap Factor (DER Net) | <u>95.9</u> | <u>95.1</u> | <u>65.7*</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>12.9</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>12,625.3</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING - AUGUST 3, 1988 - 7 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

* OCONEE 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

OCONEE 3



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* OCONEE 3 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 3-P | 03/29/88 | F | 0.0 | A | 5 | | RB | CONROD | INTEGRATED CONTROL SYSTEM ASYMMETRIC ROD RUNBACK. |
| 4-P | 03/29/88 | F | 0.6 | B | 5 | | IE | INSTRU | POWER REDUCTION ON HOLD FOR NUCLEAR INSTRUMENTATION CALIBRATION. |

* SUMMARY *

OCONEE 3 INCURRED 2 POWER REDUCTIONS IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* OCONEE 3 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA

COUNTY.....OCONEE

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI W OF
GREENVILLE, SC

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...SEPTEMBER 5, 1974
DATE ELEC ENER 1ST GENER...SEPTEMBER 18, 1974
DATE COMMERCIAL OPERATE...DECEMBER 16, 1974

CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE KEOWEE

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER

CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242

CONTRACTOR
ARCHITECT/ENGINEER.....DUKE & BECHTEL

NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX

CONSTRUCTOR.....DUKE POWER

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. BRYANT
LICENSING PROJ MANAGER....H. PASTIS
DOCKET NUMBER.....50-287

LICENSE & DATE ISSUANCE...DPR-55, JULY 19, 1974

PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY
501 W. SOUTH BROAD ST.
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 16-25 (88-04): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF INSERVICE INSPECTION (ISI) OF OCONEE UNIT-2, INCLUDING EDDY CURRENT TESTING (ET) OF ONCE THROUGH STEAM GENERATOR (OTSG) TUBES, ULTRASONIC EXAMINATION (UT) OF REACTOR VESSEL FLANGE TO SHELL WELD AND SAFETY-RELATED PIPING; RADIOGRAPHIC EXAMINATION OF OTHER PIPE WELDS; FEEDWATER NOZZLE SPRAY HEAD REPLACEMENT; OTSG NOZZLE DAM RETENTION RING INSTALLATION; PIPE/FITTING EROSION INSPECTION; AND VALVE MAINTENANCE. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 17 - MARCH 16 (88-05): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED RESIDENT INSPECTION ON-SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE, MAINTENANCE, PHYSICAL SECURITY, ENGINEERED SAFEGUARDS FEATURES LINEUPS, NONROUTINE REPORTING AND DESIGN CHANGES. OF THE SEVEN AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 18 (88-06): THIS ANNOUNCED PHYSICAL SECURITY INSPECTION WAS CONDUCTED TO REVIEW THE GENERAL REQUIREMENTS FOR THE PHYSICAL PROTECTION OF IRRADIATED REACTOR FUEL DURING TRANSPORTATION BETWEEN LICENSEE SITES. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REGULATIONS AND ITS SPENT FUEL TRANSPORTATION PLAN.

INSPECTION MARCH 7-11 (88-07): THIS ROUTINE, ANNOUNCED INSPECTION WAS IN THE AREAS OF INSERVICE INSPECTION (ISI) INCLUDING NONDESTRUCTIVE EXAMINATION (NDE) PROCEDURES REVIEW, IN-PROCESS EXAMINATIONS OBSERVATIONS, EXAMINATION DATA REVIEW, AND EQUIPMENT AND PERSONNEL CERTIFICATION RECORDS REVIEW. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

1. Docket: 50-219 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: JOHN H. SEDAR JR. (609) 971-4698

4. Licensed Thermal Power (MWT): 1930

5. Nameplate Rating (Gross MWe): 687.5 X .98 = 674

6. Design Electrical Rating (Net MWe): 650

7. Maximum Dependable Capacity (Gross MWe): 650

8. Maximum Dependable Capacity (Net MWe): 620

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>160,176.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>103,335.5</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>1,208.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,184.0</u> | <u>99,975.9</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>1,761.4</u> |
| 17. Gross Therm Ener (MWH) | <u>1,421,000</u> | <u>4,160,000</u> | <u>166,924,408</u> |
| 18. Gross Elec Ener (MWH) | <u>490,320</u> | <u>1,435,390</u> | <u>56,355,744</u> |
| 19. Net Elec Ener (MWH) | <u>472,800</u> | <u>1,384,149</u> | <u>54,107,037</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>62.4</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>63.5</u> |
| 22. Unit Cap Factor (MDC Net) | <u>102.5</u> | <u>102.2</u> | <u>54.5*</u> |
| 23. Unit Cap Factor (DER Net) | <u>97.8</u> | <u>97.5</u> | <u>52.0</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>14.1</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>14,446.5</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* OYSTER CREEK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
OYSTER CREEK 1



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1985

UNIT SHUTDOWNS / REDUCTIONS

XXX
X OYSTER CREEK 1 X
XXX

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

***** OYSTER CREEK OPERATED ROUTINELY IN MARCH WITH NO OUTAGES
* SUMMARY * OR SIGNIFICANT POWER REDUCTIONS.

| <u>Type</u> | <u>Reason</u> | <u>Method</u> | <u>System & Component</u> | |
|-------------|--------------------------|---------------|-------------------------------|-------------------------|
| F-Forced | A-Equip Failure | F-Admin | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | G-Oper Error | 2-Manual Scram | Instructions for |
| | C-Refueling | H-Other | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | | 4-Continued | Data Entry Sheet |
| | E-Operator Training | | 5-Reduced Load | licensee Event Report |
| | & License Examination | | 9-Other | (LER) File (NUREG-0161) |

* OYSTER CREEK 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NEW JERSEY
COUNTY.....OCEAN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9 MI S OF
TOMS RIVER, NJ
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MAY 3, 1969
DATE ELEC ENER 1ST GENER...SEPTEMBER 23, 1969
DATE COMMERCIAL OPERATE...DECEMBER 1, 1969
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...BARNEGAT BAY
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GPU NUCLEAR CORPORATION
CORPORATE ADDRESS.....100 INTERPACE PARKWAY
PARSIPPANY, NEW JERSEY 07054
CONTRACTOR
ARCHITECT/ENGINEER.....BURNS & ROE
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BURNS & ROE
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....J WECHSELBERG
LICENSING PROJ MANAGER.....A. DROMERICK
DOCKET NUMBER.....50-219
LICENSE & DATE ISSUANCE...DPR-16, AUGUST 1, 1969
PUBLIC DOCUMENT ROOM.....OCEAN COUNTY LIBRARY
101 WASHINGTON STREET
TOMS RIVER, NEW JERSEY 08753

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

FAILURE TO REQUALIFY ARMED PERSONNEL WITH FIREARMS WITHIN A 12 MONTH PERIOD.
(8702 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X O Y S T E R C R E E K 1 X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

.....

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

NO INPUT PROVIDED.

.....

1. Docket: 50-255 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: G. C. PACKARD (616) 764-8913

4. Licensed Thermal Power (Mwt): 2530

5. Nameplate Rating (Gross MWe): 955 X 0.85 = 812

6. Design Electrical Rating (Net MWe): 805

7. Maximum Dependable Capacity (Gross MWe): 770

8. Maximum Dependable Capacity (Net MWe): 730

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>142,743.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>1,574.2</u> | <u>75,591.7</u> |
| 14. Rx Reserve Shutdown Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>1,544.8</u> | <u>71,811.5</u> |
| 16. Unit Reserve Shutdown Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,878,312</u> | <u>3,567,792</u> | <u>150,755,709</u> |
| 18. Gross Elec Ener (MWH) | <u>608,670</u> | <u>1,154,835</u> | <u>47,065,355</u> |
| 19. Net Elec Ener (MWH) | <u>578,607</u> | <u>1,093,120</u> | <u>44,310,154</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>70.7</u> | <u>50.3</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>70.7</u> | <u>50.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>106.5</u> | <u>68.6</u> | <u>42.5</u> |
| 23. Unit Cap Factor (DER Net) | <u>96.6</u> | <u>62.2</u> | <u>38.6</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>29.3</u> | <u>35.8</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>639.2</u> | <u>25,898.7</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING, SEPTEMBER 9, 1988, 87 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
* PALISADES *
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PALISADES



MARCH 1988

 * PALISADES *

UNIT SHUTDOWNS / REDUCTIONS

Report Period MAR 1988

Cause & Corrective Action to Prevent Recurrence

System Component

LER Number

Method

Reason

Typg Hours

Date

No.

POWER REDUCTION TO REPAIR CONDENSER TUBE LEAK.

18 03/31/88 5 0.0 A 5

PALISADES INCURRED 1 POWER REDUCTION IN MARCH TO REPAIR
 CONDENSER TUBE LEAK.

 * SUMMARY *

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

 * PALISADES *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
 STATE.....MICHIGAN
 COUNTY.....VANBUREN
 DIST AND DIRECTION FROM
 NEAREST POPULATION CTR...5 MI S OF
 SOUTH HAVEN, MI
 TYPE OF REACTOR.....PWR
 DATE INITIAL CRITICALITY...MAY 24, 1971
 DATE ELEC ENER 1ST GENER...DECEMBER 31, 1971
 DATE COMMERCIAL OPERATE...DECEMBER 31, 1971
 CONDENSER COOLING METHOD...COOLING TOWERS
 CONDENSER COOLING WATER...LAKE MICHIGAN
 ELECTRIC RELIABILITY
 COUNCIL.....EAST CENTRAL AREA
 RELIABILITY COORDINATION
 AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
 LICENSEE.....CONSUMERS POWER
 CORPORATE ADDRESS.....212 WEST MICHIGAN AVENUE
 JACKSON, MICHIGAN 49201
 CONTRACTOR
 ARCHITECT/ENGINEER.....BECHTEL
 NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
 CONSTRUCTOR.....BECHTEL
 TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
 IE RESIDENT INSPECTOR.....E. SWANSON
 LICENSING PROJ MANAGER.....T. WAMBACH
 DOCKET NUMBER.....50-255
 LICENSE & DATE ISSUANCE...DPR-20, OCTOBER 16, 1972
 PUBLIC DOCUMENT ROOM.....VAN ZOEREN LIBRARY
 HOPE COLLEGE
 HOLLAND, MICHIGAN 49423

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION BETWEEN OCTOBER 22, 1987 AND JANUARY 27, 1988 (88003). SPECIAL INSPECTION PERTAINING TO FOUR ALLEGATIONS RELATING TO THE LICENSEE'S FITNESS FOR DUTY PROGRAM. THE ALLEGATIONS INCLUDED: (1) SOME PLANT PERSONNEL ON THE MIDNIGHT SHIFT WERE ABUSING DRUGS OR ALCOHOL AND WOULD BE ADVISED BY AN ANONYMOUS PERSON NOT TO COME TO WORK ON OCTOBER 20, 1987; (2) SELECTION OF PERSONNEL FOR DRUG/ALCOHOL TESTING ON OCTOBER 20, 1987, WAS NOT CONDUCTED ON A RANDOM BASIS; (3) EXISTING CONTROLS FOR URINE SAMPLE COLLECTION COULD ALLOW SUBSTITUTE SAMPLES BEING PROVIDED FOR TESTING PURPOSES; (4) TESTING FOR ALCOHOL USE WAS NOT COMPLETED IN A TIMELY MANNER DURING FITNESS FOR DUTY TESTING CONDUCTED ON OCTOBER 20, 1987. THE LICENSEE COMPLIED WITH THE PROVISIONS OF THEIR FITNESS FOR DUTY (FFD) POLICY AND PROCEDURE DURING TESTING CONDUCTED ON OCTOBER 20, 1987. THE ALLEGATION THAT PERSONNEL WERE NOT RANDOMLY SELECTED FOR FFD TESTING WAS SUBSTANTIATED, BUT THE LICENSEE'S FFD POLICY AND PROCEDURE DOES NOT REQUIRE "RANDOM" SELECTION OF PERSONNEL. OBSERVATIONS WERE NOTED WHICH WOULD STRENGTHEN CONTROLS TO FURTHER PREVENT THE POSSIBILITY OF PROVIDING SUBSTITUTE URINE SAMPLES DURING FFD TESTING. THE LICENSEE'S CRITERIA IN REFERENCE TO INITIATING AN INVESTIGATION FOR DRUG ABUSE ALLEGATIONS WERE CONSIDERED LENIENT. THE LICENSEE HAS BEEN REQUESTED TO RESPOND TO THE OBSERVATIONS PERTAINING TO URINE SAMPLE COLLECTION CONTROLS AND INVESTIGATION CRITERIA FOR DRUG RELATED ALLEGATIONS.

INSPECTION ON FEBRUARY 16-18, 1988 (88002). ROUTINE INSPECTION OF THE PALISADES NUCLEAR POWER PLANT'S EMERGENCY EXERCISE INVOLVING OBSERVATIONS BY THREE NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE. THE INSPECTION WAS CONDUCTED BY TWO NRC INSPECTORS AND ONE CONSULTANT. NO VIOLATIONS, DEFICIENCIES, OR DEVIATIONS WERE IDENTIFIED AS A RESULT OF THIS INSPECTION.

1. Docket: 50-528 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. L. HULL (602) 393-2679

4. Licensed Thermal Power (Mwt): 3800

5. Nameplate Rating (Gross MWe): 1403

6. Design Electrical Rating (Net MWe): 1270

7. Maximum Dependable Capacity (Gross MWe): 1303

8. Maximum Dependable Capacity (Net MWe): 1221

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>19,056.0</u> |
| 13. Hours Reactor Critical | <u>580.2</u> | <u>580.2</u> | <u>10,557.4</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>518.7</u> | <u>518.7</u> | <u>10,235.8</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,667,501</u> | <u>1,667,501</u> | <u>36,700,338</u> |
| 18. Gross Elec Ener (MWH) | <u>582,000</u> | <u>582,000</u> | <u>12,725,300</u> |
| 19. Net Elec Ener (MWH) | <u>530,379</u> | <u>530,379</u> | <u>11,858,493</u> |
| 20. Unit Service Factor | <u>69.7</u> | <u>23.8</u> | <u>53.7</u> |
| 21. Unit Avail Factor | <u>69.7</u> | <u>23.8</u> | <u>53.7</u> |
| 22. Unit Cap Factor (MDC Net) | <u>58.4</u> | <u>19.9</u> | <u>51.0</u> |
| 23. Unit Cap Factor (DER Net) | <u>56.1</u> | <u>19.1</u> | <u>49.0</u> |
| 24. Unit Forced Outage Rate | <u>30.0</u> | <u>72.7</u> | <u>35.6</u> |
| 25. Forced Outage Hours | <u>222.7</u> | <u>1,380.8</u> | <u>5,652.5</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* PALO VERDE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
PALO VERDE 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * PALO VERDE 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 10 | 01/12/88 | F | 222.7 | A | 4 | | | | UNIT SHUTDOWN TO REPAIR AN INOPERABLE CONTROL ELEMENT ASSEMBLY. |
| 1 | 03/10/88 | S | 2.6 | B | 1 | | | | MANUALLY TRIPPED MAIN TURBINE FOR OVERSPEED TESTING. |
| 2 | 03/22/88 | F | 0.0 | B | 5 | | | | REACTOR POWER REDUCED TO 80% DUE TO SG CHEMISTRY BEING OUT OF SPECIFICATION AS A RESULT OF THE POLISHERS BEING OUT OF SERVICE FOR REGENERATION. |

 * SUMMARY *

 PALO VERDE 1 ENTERED MONTH SHUTDOWN FOR REPAIRS. RETURNED TO POWER ON 3/11. SUBSEQUENTLY INCURRED 1 OUTAGE AND 1 POWER REDUCTION.

| Type | Reason | Method | System & Component |
|----------|---|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | F-Admin | 3-Auto Scram | Preparation of |
| | G-Oper Error | 4-Continued | Data Entry Sheet |
| | C-Refueling | 5-Reduced Load | Licensee Event Report |
| | H-Other | 9-Other | (LER) File (NUREG-0161) |
| | D-Regulatory Restriction | | |
| | E-Operator Training & license Examination | | |

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

A CONTROL ROD BECAME STUCK DURING ROD TESTING WHILE RECOVERING FROM THE PRESENT REFUELING OUTAGE. THE CAUSE WAS DETERMINED TO BE A BALL BEARING WHICH WAS INADVERTENTLY INTRODUCED INTO THE UPPER GUIDE STRUCTURE OF THE REACTOR VESSEL INTERNALS.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

AN ENFORCEMENT CONFERENCE AND MANAGEMENT MEETING WAS HELD ON FEBRUARY 29, 1988.

PLANT STATUS:

THE PLANT WENT BACK ON LINE FOLLOWING A REFUELING OUTAGE ON MARCH 10, 1988.

LAST IE SITE INSPECTION DATE: 05/16-27/88+

INSPECTION REPORT NO: 50-528/88-13+

R E P O R T S F R O M L I C E N S E E

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

NONE

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-529 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. L. HULL (602) 393-2679

4. Licensed Thermal Power (Mwt): 3800

5. Nameplate Rating (Gross MWe): 1403

6. Design Electrical Rating (Net MWe): 1270

7. Maximum Dependable Capacity (Gross MWe): 1303

8. Maximum Dependable Capacity (Net MWe): 1221

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|--------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>13,440.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>1,202.0</u> | <u>10,477.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>1,202.0</u> | <u>10,328.2</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>0</u> | <u>4,508,600</u> | <u>37,715,767</u> |
| 18. Gross Elec Ener (MWH) | <u>0</u> | <u>1,583,100</u> | <u>13,249,370</u> |
| 19. Net Elec Ener (MWH) | <u>0</u> | <u>1,487,775</u> | <u>12,424,657</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>55.0</u> | <u>76.8</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>55.0</u> | <u>76.8</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>55.8</u> | <u>75.7</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>53.6</u> | <u>72.8</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>5.8</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>637.1</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 05/15/88

* PALO VERDE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PALO VERDE 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* PALO VERDE 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|------------------|---|
| 2 | 02/20/88 | S | 744.0 | C | 4 | | | UNIT SHUTDOWN DUE TO REFUELING OUTAGE. |

 * SUMMARY *

 PALO VERDE 2 REMAINED SHUTDOWN IN MARCH FOR SCHEDULED
 REFUELING OUTAGE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| G-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* PALO VERDE 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ARIZONA
COUNTY.....MARICOPA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...36 MI W OF
PHOENIX, AZ
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 18, 1986
DATE ELEC ENER 1ST GENER...MAY 20, 1986
DATE COMMERCIAL OPERATE...SEPTEMBER 19, 1986
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...SEWAGE TREATMENT
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ARIZONA PUBLIC SERVICE
CORPORATE ADDRESS.....P.O. BOX 21666
PHOENIX, ARIZONA 85036
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....T. POLICH
LICENSING PROJ MANAGER.....E. LICITRA
DOCKET NUMBER.....50-529
LICENSE & DATE ISSUANCE...NPF-51, APRIL 24, 1986
PUBLIC DOCUMENT ROOM.....MS STEFANIE MORITZ
DOCUMENTS LIBRARIAN
PHOENIX PUBLIC LIBRARY
12 EAST MCDOWELL ROAD
PHOENIX, ARIZONA 85004

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON NOVEMBER 2-6, 1987 (REPORT NO. 50-529/87-36) TEAM INSPECTION CONDUCTED BY HEADQUARTERS' PERSONNEL. REPORT SENT MARCH 17, 1988.

+ INSPECTION ON NOVEMBER 9-13, 1987 (REPORT NO. 50-529/87-44) AREAS INSPECTED: AN ANNOUNCED TEAM INSPECTION WAS PERFORMED AT PALO VERDE NUCLEAR GENERATING STATION TO ASSESS THE IMPLEMENTATION OF THE ARIZONA PUBLIC SERVICE QUALITY ASSURANCE PROGRAM PARTICULARLY IN THE AREAS OF 10 CFR 21 REPORTABILITY REQUIREMENTS, CONTROL OF PURCHASED MATERIALS AND SERVICES, NONCONFORMANCES, AND CORRECTIVE ACTIONS. THE MAJOR INSPECTION EFFORT WAS FOCUSED ON THE PALO VERDE UNIT 3-3B EMERGENCY DIESEL GENERATOR, WHICH SUFFERED A CATASTROPHIC FAILURE ON DECEMBER 23, 1986.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JANUARY 4 - FEBRUARY 12, 1988 (REPORT NO. 50-529/88-01) REPORT CANCELLED.

+ INSPECTION ON JANUARY 5 - MARCH 5, 1988 (REPORT NO. 50-529/88-02) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 1-5, 1988 (REPORT NO. 50-529/88-06) AREAS INSPECTED: AN UNANNOUNCED INSPECTION TO CLOSE OUT PREVIOUSLY IDENTIFIED OPEN ITEMS AND TO EVALUATE THE ADEQUACY OF THE IMPLEMENTATION OF THE ROUTINE FIRE PROTECTION PROGRAM. DURING THIS

OTHER ITEMS

AN ORDER WAS ISSUED NOVEMBER 19, 1987, MODIFYING THE UNIT 2 LICENSE. THIS ORDER CONFIRMED COMMITMENTS BY THE LICENSEE TO PROVIDE VIBRATION MONITORING FOR REACTOR COOLANT PUMP SHAFTS.

AN ENFORCEMENT CONFERENCE AND MANAGEMENT MEETING AS HELD ON FEBRUARY 29, 1988.

PLANT STATUS:

THE LICENSEE DECLARED THE UNIT IN COMMERCIAL OPERATION ON SEPTEMBER 21, 1986.

THE UNIT SHUT DOWN FOR THE FIRST REFUELING OUTAGE ON FEBRUARY 10, 1988, AND IS PRESENTLY IN MODE 6.

LAST IE SITE INSPECTION DATE: 05/16-27/88+

INSPECTION REPORT NO: 50-529/88-14+

R E P O R T S F R O M L I C E N S E E

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

NONE

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-530 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J.M. COLVILLE 602-393-2679

4. Licensed Thermal Power (MWt): 3800

5. Nameplate Rating (Gross MWe): 1403

6. Design Electrical Rating (Net MWe): 1270

7. Maximum Dependable Capacity (Gross MWe): 1303

8. Maximum Dependable Capacity (Net MWe): 1221

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,016.0</u> | <u>2,016.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,016.0</u> | <u>2,016.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,016.0</u> | <u>2,016.0</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,811,696</u> | <u>7,587,912</u> | <u>7,587,912</u> |
| 18. Gross Elec Ener (MWH) | <u>995,400</u> | <u>2,682,000</u> | <u>2,682,000</u> |
| 19. Net Elec Ener (MWH) | <u>941,026</u> | <u>2,537,784</u> | <u>2,537,784</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>100.0</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>100.0</u> |
| 22. Unit Cap Factor (MDC Net) | <u>103.6</u> | <u>103.1</u> | <u>103.1</u> |
| 23. Unit Cap Factor (DER Net) | <u>99.6</u> | <u>99.1</u> | <u>99.1</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>.0</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * PALO VERDE 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PALO VERDE 3



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* PALO VERDE 3 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|------------------|---|
|-----|------|------|-------|--------|--------|------------|------------------|---|

NONE

 * SUMMARY *

 PALO VERDE 3 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES
 OR SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

 * PALO VERDE 3 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
 STATE.....ARIZONA
 COUNTY.....MARICOPA
 DIST AND DIRECTION FROM
 NEAREST POPULATION CTR...36 MI W OF
 PHOENIX, AZ
 TYPE OF REACTOR.....PWR
 DATE INITIAL CRITICALITY...OCTOBER 25, 1987
 DATE ELEC ENER 1ST GENER...NOVEMBER 28, 1987
 DATE COMMERCIAL OPERATE...JANUARY 8, 1988
 CONDENSER COOLING METHOD...COOLING TOWERS
 CONDENSER COOLING WATER...SEWAGE TREATMENT
 ELECTRIC RELIABILITY
 COUNCIL.....WESTERN SYSTEMS
 COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
 LICENSEE.....ARIZONA PUBLIC SERVICE
 CORPORATE ADDRESS.....P.O. BOX 21666
 PHOENIX, ARIZONA 85036
 CONTRACTOR
 ARCHITECT/ENGINEER.....BECHTEL
 NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
 CONSTRUCTOR.....BECHTEL
 TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
 IE RESIDENT INSPECTOR.....T. POLICH
 LICENSING PROJ MANAGER....M. DAVIS
 DOCKET NUMBER.....50-530
 LICENSE & DATE ISSUANCE...NPF-74, NOVEMBER 25, 1987
 PUBLIC DOCUMENT ROOM.....MS STEFANIE MORITZ
 DOCUMENTS LIBRARIAN
 PHOENIX PUBLIC LIBRARY
 12 EAST MCDOWELL ROAD
 PHOENIX, ARIZONA 85004

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 4 - FEBRUARY 12, 1988 (REPORT NO. 50-530/87-43) AREAS INSPECTED: AN ANNOUNCED TEAM INSPECTION WAS PERFORMED AT PALO VERDE NUCLEAR GENERATING STATION TO ASSESS THE IMPLEMENTATION OF THE ARIZONA PUBLIC SERVICE QUALITY ASSURANCE PROGRAM PARTICULARLY IN THE AREAS OF 10 CFR 21 REPORTABILITY REQUIREMENTS, CONTROL OF PURCHASED MATERIALS AND SERVICES, NONCONFORMANCES, AND CORRECTIVE ACTIONS. THE MAJOR INSPECTION EFFORT WAS FOCUSED ON THE PALO VERDE UNIT 3-3B EMERGENCY DIESEL GENERATOR, WHICH SUFFERED A CATASTROPHIC FAILURE ON DECEMBER 23, 1986.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE UTILIZED.

+ INSPECTION ON JANUARY 4 - FEBRUARY 12, 1988 (REPORT NO. 50-530/88-01) REPORT CANCELLED.

+ INSPECTION ON JANUARY 17 - MARCH 5, 1988 (REPORT NO. 50-530/88-02) REPORT BEING PREPARED; TO REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 1-5, 1988 (REPORT NO. 50-530/88-06) AREAS INSPECTED: AN UNANNOUNCED INSPECTION TO CLOSE OUT PREVIOUSLY IDENTIFIED OPEN ITEMS AND TO EVALUATE THE ADEQUACY OF THE IMPLEMENTATION OF THE ROUTINE FIRE PROTECTION PROGRAM. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE UTILIZED.

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

* PALO VERDE 3 *

OTHER ITEMS

NONE

LAST IE SITE INSPECTION DATE: 05/06-27/88+

INSPECTION REPORT NO: 50-530/88-13+

R E P O R T S F R O M L I C E N S E E

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

NONE
=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-277 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: L. L. MIDDLETON (215) 841-6374

4. Licensed Thermal Power (Mwt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1051

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NRC ORDER OF 3/31/87

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------------|----------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>120,456.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>.0</u> | <u>74,196.2</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>.0</u> | <u>71,866.8</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>0</u> | <u>0</u> | <u>212,810,745</u> |
| 18. Gross Elec Ener (MWH) | <u>0</u> | <u>0</u> | <u>70,019,230</u> |
| 19. Net Elec Ener (MWH) | <u>-4,064</u> | <u>-13,127</u> | <u>67,027,989</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>.0</u> | <u>59.7</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>.0</u> | <u>59.7</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>.0</u> | <u>52.9</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>.0</u> | <u>52.2</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>14.6</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>12,304.0</u> |

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* PEACH BOTTOM 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PEACH BOTTOM 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* PEACH BOTTOM 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 1 | 03/31/87 | S | 744.0 | C | 1 | | RC | FUELXX | NRC REQUIRED SHUTDOWN. |

 * SUMMARY *

 PEACH BOTTOM 2 REMAINED SHUTDOWN IN ACCORDANCE WITH NRC ORDER,
 HOWEVER, CONTINUED RESTART ACTIVITIES.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* PEACH BOTTOM 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....YORK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...19 MI S OF
LANCASTER, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 16, 1973
DATE ELEC ENER 1ST GENER...FEBRUARY 18, 1974
DATE COMMERCIAL OPERATE...JULY 5, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PHILADELPHIA ELECTRIC
CORPORATE ADDRESS.....2301 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19105
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. JOHNSON
LICENSING PROJ MANAGER....R. MARTIN
DOCKET NUMBER.....50-277
LICENSE & DATE ISSUANCE...DPR-44, DECEMBER 14, 1973
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION
STATE LIBRARY OF PENNSYLVANIA
FORUM BUILDING
COMMONWEALTH AND WALNUT STREET
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (C O N T I N U E D)

* PEACH BOTTOM 2 *

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------------------|------------------|-------------------|---------|
| NO INPUT PROVIDED. | | | |

NO INPUT PROVIDED.

1. Docket: 50-278 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: L. L. MIDDLETON (215) 841-6374

4. Licensed Thermal Power (Mwt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1035

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NRC ORDER OF 3/31/87

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------------|----------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>116,352.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>.0</u> | <u>76,366.3</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>.0</u> | <u>74,059.3</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>.0</u> | <u>.0</u> | <u>215,278,901</u> |
| 18. Gross Elec Ener (MWH) | <u>.0</u> | <u>.0</u> | <u>70,611,432</u> |
| 19. Net Elec Ener (MWH) | <u>-4,064</u> | <u>-13,127</u> | <u>67,689,028</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>.0</u> | <u>63.7</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>.0</u> | <u>63.7</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>.0</u> | <u>56.2</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>.0</u> | <u>54.6</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>13.3</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>11,372.7</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* PEACH BOTTOM 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PEACH BOTTOM 3



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* PEACH BOTTOM 3 *

* PEACH BOTTOM 3 *

Cause & Corrective Action to Prevent Recurrence

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|-------------------------|---|
| 1 | 03/31/87 | S | 744.0 | C | 1 | RC | FUELXX PIPE REPLACEMENT | OUTAGE. |

* SUMMARY *

PEACH BOTTOM 3 REMAINED SHUTDOWN IN ACCORDANCE WITH NRC ORDER, HOWEVER, CONTINUED RESTART ACTIVITIES.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* PEACH BOTTOM 3 *

F A C I L I T Y D A T A

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....YORK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...19 MI S 9F
LANCASTER, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...AUGUST 7, 1974
DATE ELEC ENER 1ST GENER...SEPTEMBER 1, 1974
DATE COMMERCIAL OPERATE...DECEMBER 25, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PHILADELPHIA ELECTRIC
CORPORATE ADDRESS.....2301 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19105
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. JOHNSON
LICENSING PROJ MANAGER.....R. MARTIN
DOCKET NUMBER.....50-278
LICENSE & DATE ISSUANCE...DPP-56, JULY 2, 1974
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION
STATE LIBRARY OF PENNSYLVANIA
FORUM BUILDING
COMMONWEALTH AND WALNUT STREET
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

1. Docket: 50-460 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: G. A. DUNN (216) 259-3737

4. Licensed Thermal Power (MWh): 3579

5. Nameplate Rating (Gross MWe): 1250

6. Design Electrical Rating (Net MWe): 1205

7. Maximum Dependable Capacity (Gross MWe): 1250

8. Maximum Dependable Capacity (Net MWe): 1205

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>3,228.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>1,525.5</u> | <u>2,336.8</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>1,441.3</u> | <u>2,214.7</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,510,544</u> | <u>4,759,711</u> | <u>7,321,230</u> |
| 18. Gross Elec Ener (MWH) | <u>872,166</u> | <u>1,642,909</u> | <u>2,521,371</u> |
| 19. Net Elec Ener (MWH) | <u>829,758</u> | <u>1,548,183</u> | <u>2,376,667</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>66.0</u> | <u>68.6</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>66.0</u> | <u>68.6</u> |
| 22. Unit Cap Factor (MDC Net) | <u>92.6</u> | <u>58.8</u> | <u>61.1</u> |
| 23. Unit Cap Factor (DER Net) | <u>92.6</u> | <u>58.8</u> | <u>61.1</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>7.5</u> | <u>14.9</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>116.8</u> | <u>387.4</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * PERRY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PERRY 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* PERRY 1

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 1 | 03/20/88 | F | 0.0 | A | 5 | | 5B | ISV | DURING MONTHLY TESTING ON MARCH 20, ONE INBOARD MAIN STEAM ISOLATION VALVE EXHIBITED A DELAY IN OPENING AFTER SUCCESSFUL CLOSURE. PENDING THE COMPLETION OF FURTHER TESTING TO ASSURE SAFETY FUNCTIONS WERE NOT AFFECTED, ONE MAIN STEAM LINE WAS ISOLATED AND POWER WAS CONSERVATIVELY REDUCED TO 80%. UPON SUCCESSFUL COMPLETION OF THE TESTING, NORMAL PLANT OPERATION WAS RESUMED ON MARCH 28. |

PERRY 1 INCURRED 1 POWER REDUCTION IN MARCH FOR REASONS

STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|---|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training & License Examination | 5-Reduced Load | Licensee Event Report |
| | | 9-Other | (LER) File (NUREG-0161) |

* PERRY 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....OHIO
COUNTY.....LAKE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...7 MI NE OF
PAINESVILLE, OHIO
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JUNE 6, 1986
DATE ELEC ENER 1ST GENER...DECEMBER 19, 1986
DATE COMMERCIAL OPERATE...NOVEMBER 18, 1987
CONDENSER COOLING METHOD...CC HNDCT
CONDENSER COOLING WATER...LAKE ERIE
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CLEVELAND ELECTRIC ILLUMINATING
CORPORATE ADDRESS.....P.O. BOX 5000
CLEVELAND, OHIO 44101
CONTRACTOR
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....KAISER ENGINEERS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

TE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....K. CONNAUGHTON
LICENSING PROJ MANAGER....T. COLBURN
DOCKET NUMBER.....50-440
LICENSE & DATE ISSUANCE...NPF-58, NOVEMBER 13, 1986
PUBLIC DOCUMENT ROOM.....PERRY PUBLIC LIBRARY
3753 MAIN ST.
PERRY, OH. 44081

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

1. Docket: 50-293 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: P. HAMILTON (617) 746-7900

4. Licensed Thermal Power (MWh): 1998

5. Nameplate Rating (Gross MWe): 780 X 0.87 = 678

6. Design Electrical Rating (Net MWe): 655

7. Maximum Dependable Capacity (Gross MWe): 690

8. Maximum Dependable Capacity (Net MWe): 670

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|--------------|----------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>134,208.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>.0</u> | <u>79,778.7</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>.0</u> | <u>77,216.9</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>.0</u> | <u>.0</u> | <u>135,480,048</u> |
| 18. Gross Elec Ener (MWH) | <u>.0</u> | <u>.0</u> | <u>45,444,604</u> |
| 19. Net Elec Ener (MWH) | <u>.0</u> | <u>.0</u> | <u>43,675,429</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>.0</u> | <u>57.5</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>.0</u> | <u>57.5</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>.0</u> | <u>48.6</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>.0</u> | <u>49.7</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>12.4</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>10,922.7</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 08/01/88

* PILGRIM 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PILGRIM 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* PILGRIM 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|------------------|---|
| 01 | 07/25/86 | S | 744.0 | C | 4 | | | SHUTDOWN FOR RFD 7. |

* SUMMARY *

PILGRIM 1 REMAINED SHUTDOWN IN MARCH FOR SCHEDULED
REFUELING OUTAGE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

FACILITY DESCRIPTION

LOCATION
STATE.....MASSACHUSETTS
COUNTY.....PLYMOUTH
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...6 MI SE OF
FLYKOUTH, MASS
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JUNE 16, 1972
DATE ELEC ENER 1ST GENER...JULY 19, 1972
DATE COMMERCIAL OPERATE...DECEMBER 1, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CAPE COD BAY
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....BOSTON EDISON
CORPORATE ADDRESS.....800 BOYLSTON STREET
BOSTON, MASSACHUSETTS 02199
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....C. WARREN
LICENSING PROJ MANAGER....D. McDONALD
DOCKET NUMBER.....59-293
LICENSE & DATE ISSUANCE...DPR-35, SEPTEMBER 15, 1972
PUBLIC DOCUMENT ROOM.....PLYMOUTH PUBLIC LIBRARY
11 NORTH STREET
PLYMOUTH, MASSACHUSETTS 02360

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

10 CFR 50.49(E)(1) REQUIRES FOR SAFETY RELATED ELECTRICAL EQUIPMENT LOCATED IN AN HARSH ENVIRONMENT THAT THE MOST SEVERE DESIGN BASIS TIME DEPENDENT TEMPERATURE BE ESTABLISHED AND THAT THE EQUIPMENT BE QUALIFIED FOR THE MOST SEVERE DESIGN BASIS TEMPERATURE CONDITION. CONTRARY TO THE ABOVE AS OF AUGUST 20, 1987, THE MOST SEVERE DESIGN BASIS TIME DEPENDENT TEMPERATURE HAD NOT BEEN ESTABLISHED FOR THE FOLLOWING ELECTRICAL EQUIPMENT IN THE DRYWELL: SOLENOID VALVE SV-220-44 AND CABLE SPLICE ASSEMBLIES Q102A, Q102B, Q203A AND Q103B. IT HAD BEEN ESTABLISHED ONLY THAT THE ABOVE DEVICES WERE QUALIFIED FOR A LARGE BREAK LOSS OF COOLANT ACCIDENT UP TO 290 DEGREES F. THIS TEMPERATURE WAS 30 DEGREES F LOWER THAN THE TEMPERATURE PROFILE FOR A SMALL BREAK LOCA TO WHICH DRYWELL EQUIPMENT WOULD BE SUBJECTED, SUBSEQUENT TO THE INSPECTION, IT WAS DETERMINED THAT THESE DEVICES WERE ACTUALLY QUALIFIED TO THE MOST SEVERE TEMPERATURE PROFILE.
(8703 4)

OTHER ITEMS

1. Docket: 50-266 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: C. W. KRAUSE (414) 221-2001

4. Licensed Thermal Power (Mwt): 1518

5. Nameplate Rating (Gross MWe): 582 X 0.9 = 524

6. Design Electrical Rating (Net MWe): 497

7. Maximum Dependable Capacity (Gross MWe): 509

8. Maximum Dependable Capacity (Net MWe): 485

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>152,544.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>129,951.8</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>652.7</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,184.0</u> | <u>122,228.7</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>837.3</u> |
| 17. Gross Therm Ener (MWH) | <u>1,128,055</u> | <u>3,310,269</u> | <u>168,937,323</u> |
| 18. Gross Elec Ener (MWH) | <u>386,720</u> | <u>1,132,750</u> | <u>56,956,100</u> |
| 19. Net Elec Ener (MWH) | <u>370,552</u> | <u>1,086,565</u> | <u>54,254,993</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>80.1</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>80.7</u> |
| 22. Unit Cap Factor (MDC Net) | <u>102.7</u> | <u>102.6</u> | <u>72.9*</u> |
| 23. Unit Cap Factor (DER Net) | <u>100.2</u> | <u>100.1</u> | <u>71.5</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>2.1</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>2,464.3</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING/MAINT - APRIL 8, 1988, - 35 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

* POINT BEACH 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

POINT BEACH 1



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* POINT BEACH 1 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

POINT BEACH 1 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES
OR SIGNIFICANT POWER REDUCTIONS.

| <u>Type</u> | <u>Reason</u> | <u>Method</u> | <u>System & Component</u> |
|-------------|--------------------------|----------------|-------------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* POINT BEACH 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION:
STATE.....WISCONSIN
COUNTY.....MANITOWOC
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...15 MI N OF
MANITOWOC, WISC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 2, 1970
DATE ELEC ENER 1ST GENER...NOVEMBER 6, 1970
DATE COMMERCIAL OPERATE...DECEMBER 21, 1970
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET
MILWAUKEE, WISCONSIN 53201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....R. HAGUE
LICENSING PROJ MANAGER.....D. WAGNER
DOCKET NUMBER.....50-266
LICENSE & DATE ISSUANCE...DPR-24, OCTOBER 5, 1970
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY
1516 16TH ST.
TWO RIVERS, WISCONSIN 54241

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON FEBRUARY 8-12, 1988 (88005). ROUTINE, ANNOUNCED INSPECTION OF: (1) QUALITY ASSURANCE AND CONFIRMATORY MEASUREMENTS FOR IN-PLANT RADIOCHEMICAL ANALYSES; (2) VERIFICATION OF TLD COLLOCATION; (3) ACTION ON AN OPEN ITEM AND A VIOLATION IDENTIFIED DURING PREVIOUS INSPECTIONS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED DURING THIS INSPECTION.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

1. Docket: 50-301 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: C. W. KRAUSE (414) 221-2001

4. Licensed Thermal Power (Mwt): 1518

5. Nameplate Rating (Gross MWe): 582 X 0.9 = 524

6. Design Electrical Rating (Net MWe): 497

7. Maximum Dependable Capacity (Gross MWe): 509

8. Maximum Dependable Capacity (Net MWe): 485

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>137,329.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>120,578.4</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>215.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,184.0</u> | <u>118,654.1</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>292.4</u> |
| 17. Gross Therm Ener (MWH) | <u>1,127,373</u> | <u>3,306,097</u> | <u>167,876,692</u> |
| 18. Gross Elec Ener (MWH) | <u>386,970</u> | <u>1,133,730</u> | <u>56,913,950</u> |
| 19. Net Elec Ener (MWH) | <u>370,084</u> | <u>1,085,581</u> | <u>54,229,995</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>86.4</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>86.6</u> |
| 22. Unit Cap Factor (MDC Net) | <u>102.6</u> | <u>102.5</u> | <u>80.6*</u> |
| 23. Unit Cap Factor (DER Net) | <u>100.1</u> | <u>100.0</u> | <u>79.5</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>1.2</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>351.2</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUEL/MAINT - SEPTEMBER 30, 1988 - 43 DAY DURATION

27. If Currently Shutdown Estimated Startup Date: N/A

* POINT BEACH 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

POINT BEACH 2



MARCH 1988

* Item calculated with a Weighted Average

PAGE 2-32:

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* POINT BEACH 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|------------------|---|
|-----|------|------|-------|--------|--------|------------|------------------|---|

NONE

* SUMMARY *

POINT BEACH 2 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES
OR SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* POINT BEACH 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....WISCONSIN
COUNTY.....MANITOWOC
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...15 MI N OF
MANITOWOC, WISC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 30, 1972
DATE ELEC ENER 1ST GENER...AUGUST 2, 1972
DATE COMMERCIAL OPERATE...OCTOBER 1, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET
MILWAUKEE, WISCONSIN 53201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....R. HAGUE
LICENSING PROJ MANAGER.....D. WAGNER
DOCKET NUMBER.....50-301
LICENSE & DATE ISSUANCE...DPR-27, MARCH 8, 1973
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY
1516 16TH ST.
TWO RIVERS, WISCONSIN 54241

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON FEBRUARY 8-12, 1988 (88005). ROUTINE, ANNOUNCED INSPECTION OF: (1) QUALITY ASSURANCE AND CONFIRMATORY MEASUREMENTS FOR IN-PLANT RADIOCHEMICAL ANALYSES; (2) VERIFICATION OF TLD COLLOCATION; (3) ACTION ON AN OPEN ITEM AND A VIOLATION IDENTIFIED DURING PREVIOUS INSPECTIONS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED DURING THIS INSPECTION.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
* POINT BEACH 2 *
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

OTHER ITEMS

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING AT POWER.

LAST IE SITE INSPECTION DATE: 03/11/88

INSPECTION REPORT NO: 88007

R E P O R T S F R O M L I C E N S E E

.....

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

.....

.....

1. Docket: 50-282 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: DALE DUGSTAD (612) 388-1121

4. Licensed Thermal Power (Mwt): 1550

5. Nameplate Rating (Gross MWe): 659 X 0.9 = 593

6. Design Electrical Rating (Net MWe): 530

7. Maximum Dependable Capacity (Gross MWe): 534

8. Maximum Dependable Capacity (Net MWe): 503

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>125,280.0</u> |
| 13. Hours Reactor Critical | <u>662.4</u> | <u>2,102.4</u> | <u>104,645.6</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>5,571.1</u> |
| 15. Hrs Generator On-Line | <u>658.8</u> | <u>2,098.8</u> | <u>103,206.8</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,027,715</u> | <u>3,384,427</u> | <u>162,438,351</u> |
| 18. Gross Elec Ener (MWH) | <u>342,970</u> | <u>1,141,700</u> | <u>53,215,710</u> |
| 19. Net Elec Ener (MWH) | <u>327,624</u> | <u>1,083,599</u> | <u>49,921,264</u> |
| 20. Unit Service Factor | <u>88.5</u> | <u>96.1</u> | <u>82.4</u> |
| 21. Unit Avail Factor | <u>88.5</u> | <u>96.1</u> | <u>82.4</u> |
| 22. Unit Cap Factor (MDC Net) | <u>87.5</u> | <u>98.6</u> | <u>79.2</u> |
| 23. Unit Cap Factor (DER Net) | <u>83.1</u> | <u>93.6</u> | <u>75.2</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>6.7</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>3,715.2</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING - AUGUST, 1988.

27. If Currently Shutdown Estimated Startup Date: N/A

X PRAIRIE ISLAND 1

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PRAIRIE ISLAND 1



MARCH 1988

 * PRAIRIE ISLAND 1 *

UNIT SHUTDOWNS / REDUCTIONS

Report Period MAR 1988

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|------------------|---|
| 8801 | 03/05/88 | S | 0.0 | B | 5 | | | TURBINE VALVES TESTING AND CONDENSER TUBE CLEANING. |
| 8802 | 03/06/88 | S | 0.0 | B | 5 | | | CONDENSER TUBE CLEANING CONTINUATION. |
| 8803 | 03/10/88 | S | 85.2 | B | 1 | | | REPAIR LEAK OF B4 CANOPY SEAL WELD ON THE REACTOR HEAD. |

 * PRAIRIE ISLAND 1 EXPERIENCED 2 POWER REDUCTIONS AND 1 OUTAGE
 * SUMMARY *

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licenses Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* PRAIRIE ISLAND 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....MINNESOTA
COUNTY.....GOODHUE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...28 MI SE OF
MINNEAPOLIS, MINN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 1, 1973
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1973
DATE COMMERCIAL OPERATE...DECEMBER 16, 1973
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHERN STATES POWER
CORPORATE ADDRESS.....414 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401
CONTRACTOR
ARCHITECT/ENGINEER.....FLUOR PIONEER, INC.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....NORTHERN STATES POWER COMPANY
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. HARD
LICENSING PROJ MANAGER.....D. DIANNI
DOCKET NUMBER.....50-282
LICENSE & DATE ISSUANCE...DPR-42, APRIL 5, 1974
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY
MINNEAPOLIS PUBLIC LIBRARY
300 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

OTHER ITEMS

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATED AT POWER TILL MARCH 10, 1988 TO REPAIR A LEAKING CANOPY SEAL WELD ON A REACTOR HEAD INSTRUMENT COLUMN. RESUMED POWER OPERATIONS ON MARCH 14, 1988.

LAST IE SITE INSPECTION DATE: 02/10/88

INSPECTION REPORT NO: 88003

R E P O R T S F R O M L I C E N S E E

```

=====
NUMBER    DATE OF    DATE OF    SUBJECT
          EVENT    REPORT
-----
88-01    021888    032188    INADEQUATE NET POSITIVE SUCTION HEAD IN LOW PRESSURE SAFETY INJECTION SYSTEM
=====

```

1. Docket: 50-306 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: DALE DUGSTAD (612) 388-1121

4. Licensed Thermal Power (Mht): 1650

5. Nameplate Rating (Gross MWe): 659 X 0.9 = 593

6. Design Electrical Rating (Net MWe): 530

7. Maximum Dependable Capacity (Gross MWe): 531

8. Maximum Dependable Capacity (Net MWe): 500

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>116,398.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>1,285.7</u> | <u>101,520.7</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>1,516.1</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>1,266.2</u> | <u>100,461.0</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,217,012</u> | <u>1,968,590</u> | <u>158,114,667</u> |
| 18. Gross Elec Ener (MWH) | <u>403,470</u> | <u>649,650</u> | <u>51,481,980</u> |
| 19. Net Elec Ener (MWH) | <u>384,053</u> | <u>613,727</u> | <u>48,393,150</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>58.0</u> | <u>86.3</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>58.0</u> | <u>86.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>103.2</u> | <u>56.2</u> | <u>83.2</u> |
| 23. Unit Cap Factor (DER Net) | <u>97.4</u> | <u>55.0</u> | <u>78.4</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.1</u> | <u>3.1</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>1.1</u> | <u>3,360.1</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* PRAIRIE ISLAND 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PRAIRIE ISLAND 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* PRAIRIE ISLAND 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|------------------|---|
| 8801 | 03/20/88 | S | 0.0 | B | 5 | | | TURBINE VALVE TEST AND 22 FEED WATER PUMP WORK. |

* SUMMARY *

PRAIRIE ISLAND 1 EXPERIENCED 1 POWER REDUCTION IN MARCH FOR VALVE TESTING AND FEEDWATER PUMP WORK.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & h |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examinztion | 9-Other | (LER) File (NUREG-0161) |

F A C I L I T Y D A : 4

* PRAIRIE ISLAND 2 *

FACILITY DESCRIPTION

LOCATION STATE.....MINNESOTA
COUNTY.....GOODHUE
DIST AND DIRECTION FROM NEAREST POPULATION CTR....28 MI SE OF MINNEAPOLIS, MINN
TYPE OF REACTOR.....PHR
DATE INITIAL CRITICALITY...DECEMBER 17, 1974
DATE ELEC ENER 1ST GENER...DECEMBER 21, 1974
DATE COMMERCIAL OPERATE...DECEMBER 21, 1974
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY COUNCIL.....MID-CONTINENT AREA RELIABILITY COORDINATION AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSE.....NORTHERN STATES POWER
CORPORATE ADDRESS.....414 NICOLLET MALL MINNEAPOLIS, MINNESOTA 55401
CONTRACTOR ARCHITECT/ENGINEER.....FLUOR PIONEER, INC.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....NORTHERN STATES POWER COMPANY
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. HARD
LICENSING PROJ MANAGER.....D. DIAMMI
DOCKET NUMBER.....50-306
LICENSE & DATE ISSUANCE...DPR-60, OCTOBER 29, 1974
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY MINNEAPOLIS PUBLIC LIBRARY 300 NICOLLET MALL MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

* PRAIRIE ISLAND 2 *

INSPECTION STATUS - (CONTINUED)

Report Period MAR 1988

OTHER ITEMS

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATED CONTINUALLY THROUGHOUT MONTH.

LAST IE SITE INSPECTION DATE: 01/14/88

INSPECTION REPORT NO: 88003

REPORTS FROM LICENSEE

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|---------|
|--------|---------------|----------------|---------|

NONE

1. Docket: 50-254 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: K.A. SCHMIDT (309) 654-2241 X2147

4. Licensed Thermal Power (Mwt): 2511

5. Nameplate Rating (Gross MWe): 920 x 0.9 = 828

6. Design Electrical Rating (Net MWe): 789

7. Maximum Dependable Capacity (Gross MWe): 813

8. Maximum Dependable Capacity (Net MWe): 769

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>139,272.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>111,248.4</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>3,421.9</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,177.1</u> | <u>107,634.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>909.2</u> |
| 17. Gross Therm Ener (MWH) | <u>1,790,359</u> | <u>5,193,055</u> | <u>228,533,812</u> |
| 18. Gross Elec Ener (MWH) | <u>586,941</u> | <u>1,699,236</u> | <u>74,124,854</u> |
| 19. Net Elec Ener (MWH) | <u>560,923</u> | <u>1,625,739</u> | <u>69,529,809</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>99.7</u> | <u>77.3</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>99.7</u> | <u>77.9</u> |
| 22. Unit Cap Factor (MDC Net) | <u>98.0</u> | <u>96.8</u> | <u>64.9</u> |
| 23. Unit Cap Factor (DER Net) | <u>95.6</u> | <u>94.3</u> | <u>63.3</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.3</u> | <u>5.1</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>6.9</u> | <u>3,443.3</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently shutdown Estimated Startup Date: N/A

X QUAD CITIES 1 X

AVERAGE DAILY POWER LEVEL (MWe) PLOT

QUAD CITIES 1



MARCH 1988

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|------------------|---|
|-----|------|------|-------|--------|--------|------------|------------------|---|

NONE

XXXXXXXXXX QUAD CITIES 1 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES
 * SUMMARY * OR SIGNIFICANT POWER REDUCTIONS.
 XXXXXXXXXXXX

| Type | Reason | Method | System & Component |
|----------|---|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Ruueling | 3-Auto Scram | Preparation of |
| | H-Other | 4-Continued | Data Entry Sheet |
| | D-Regulatory Restriction | 5-Reduced Load | Licensee Event Report |
| | E-Operator Training & License Examination | 5-Other | (LER) File (NUREG-0161) |

QUAD CITIES 1 #

F A C I L I T Y D A T A

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....ROCK ISLAND
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI NE OF
MOLINE, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...OCTOBER 18, 1971
DATE ELEC ENER 1ST GENER...APRIL 12, 1972
DATE COMMERCIAL OPERATE...FEBRUARY 18, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONHEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 747
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....A. MADISON
LICENSING PROJ MANAGER....T. ROSS
DOCKET NUMBER.....50-254
LICENSE & DATE ISSUANCE...DPR-29, DECEMBER 14, 1972
PUBLIC DOCUMENT ROOM.....DIXON PUBLIC LIBRARY
221 HENNEPIN AVENUE
DIXON, ILLINOIS 61021

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NONE

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.2 REQUIRES THAT PROCEDURES BE ADHERED TO DURING PREVENTATIVE AND CORRECTIVE MAINTENANCE OPERATIONS. CONTRARY TO THE ABOVE, STATION PROCEDURE QIP 5700-2, "FILLING PROCEDURE FOR THE CHLORINE ANALYZER PROBE," WHICH CAUTIONS THAT A CONTROL ROOM ISOLATION WILL OCCUR DURING THIS PROCEDURE AND THAT THE CONTROL ROOM SHOULD BE NOTIFIED, WAS NOT FOLLOWED ON FEBRUARY 1, 1988, RESULTING IN AN UNEXPECTED ESF ACTUATION. (8705 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING ROUTINELY AT FULL POWER OR EGC

LAST IE SITE INSPECTION DATE: 03/17/88

INSPECTION REPORT NO: 88006

R E P O R T S F R O M L I C E N S E E

```

=====
NUMBER    DATE OF    DATE OF    SUBJECT
          EVENT    REPORT
=====

```

1. Docket: 50-265 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: K.A. CHMIDI (309) 654-2241 X 2147

4. Licensed Thermal Power (MWt): 2511

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 789

7. Maximum Dependable Capacity (Gross MWe): 813

8. Maximum Dependable Capacity (Net MWe): 769

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>138,382.0</u> |
| 13. Hours Reactor Critical | <u>716.9</u> | <u>2,060.9</u> | <u>106,718.3</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>2,985.3</u> |
| 15. Hrs Generator On-line | <u>705.6</u> | <u>2,033.5</u> | <u>103,568.9</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>702.9</u> |
| 17. Gross Therm Ener (MWH) | <u>1,552,695</u> | <u>4,648,671</u> | <u>222,019,238</u> |
| 18. Gross Elec Ener (MWH) | <u>502,634</u> | <u>1,507,120</u> | <u>71,064,894</u> |
| 19. Net Elec Ener (MWH) | <u>481,847</u> | <u>1,444,891</u> | <u>66,996,322</u> |
| 20. Unit Service Factor | <u>94.8</u> | <u>93.1</u> | <u>74.8</u> |
| 21. Unit Avail Factor | <u>94.8</u> | <u>93.1</u> | <u>75.4</u> |
| 22. Unit Cap Factor (MDC Net) | <u>84.2</u> | <u>86.0</u> | <u>63.0</u> |
| 23. Unit Cap Factor (DER Net) | <u>82.1</u> | <u>83.9</u> | <u>61.4</u> |
| 24. Unit Forced Outage Rate | <u>5.2</u> | <u>6.9</u> | <u>8.3</u> |
| 25. Forced Outage Hours | <u>38.4</u> | <u>150.5</u> | <u>5,433.7</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

*****~***
* QUAD CITIES 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
QUAD CITIES 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * QUAD CITIES 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 88-3 | 03/04/88 | F | 0.0 | H | 5 | | HF | ZZZZZ | POWER REDUCTION DUE TO CONDENSER PROBLEMS RESULTING FROM ACCUMULATION OF FISH ON CIRC WATER SCREENS AND BAYS. |
| 88-4 | 03/20/88 | F | 38.4 | A | 3 | 2-88-015 | IA | VALVES | REACTOR SCRAM DUE TO PACKING LEAK ON "B" FEEDWATER REG VALVE - WHILE ATTEMPTING TO ISOLATE, WATER FELL ONTO INSTRUMENTATION THAT INITIATED TURBINE TRIP. |

 * SUMMARY *

 QUAD CITIES 2 INCURRED 1 OUTAGE AND 1 POWER REDUCTION IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

F A C I L I T Y D A T A

* QUAD CITIES 2 *

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....ROCK ISLAND
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI NE OF
MOLINE, ILL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....A. MADISON
LICENSING PROJ MANAGER.....T. ROSS
DOCKET NUMBER.....50-265
LICENSE & DATE ISSUANCE....DPR-30, DECEMBER 14, 1972
PUBLIC DOCUMENT ROOM.....DIXON PUBLIC LIBRARY
221 HENNEPIN AVENUE
DIXON, ILLINOIS 61021

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NONE

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYS.EMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

INSPECTION STATUS - (CONTINUED)

Report Period MAR 1988

OTHER ITEMS

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT S/D FOR REFUELING ON 4/10/88.

LAST IE SITE INSPECTION DATE: 03/17/88

INSPECTION REPORT NO: 88007

REPORTS FROM LICENSEE

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|--|
| 88-02 | 022388 | 031088 | HIGH PRESSURE COOLANT INJECTION INOPERABLE DUE TO ROOM COOLER LOSS FROM SHORT CIRCUIT OF CONTROL RELAY |
| 88-03 | 030188 | 031588 | RCIC INOPERABLE DUE TO FAILED GOVERNOR ACTUATOR |
| 88-04 | 030888 | 032488 | INSUFFICIENT NUMBER OF OPERABLE REACTOR PROTECTION SYSTEM (RPS) CHANNELS DUE TO PERSONNEL ERROR |

1. Docket: 50-312 O P E R A T I N G S T A T U S
2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: R. MILLER (916) 452-3211 X4477
4. Licensed Thermal Power (MWh): 2772
5. Nameplate Rating (Gross MWe): 1070 X 0.9 = 963
6. Design Electrical Rating (Net MWe): 918
7. Maximum Dependable Capacity (Gross MWe): 917
8. Maximum Dependable Capacity (Net MWe): 873
9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____
11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------|---------|-------------|
| 12. Report Period Hrs | 744.0 | 2,184.0 | 113,569.0 |
| 13. Hours Reactor Critical | 3.5 | 3.5 | 52,568.5 |
| 14. Rx Reserve Shtdwn Hrs | .0 | .0 | 10,647.7 |
| 15. Hrs Generator On-Line | .0 | .0 | 50,363.8 |
| 16. Unit Reserve Shtdwn Hrs | .0 | .0 | 1,210.2 |
| 17. Gross Therm Ener (MWh) | 0 | 0 | 124,228,535 |
| 18. Gross Elec Ener (MWh) | 0 | 0 | 41,528,149 |
| 19. Net Elec Ener (MWh) | -26,484 | -40,325 | 38,948,870 |
| 20. Unit Service Factor | .0 | .0 | 44.3 |
| 21. Unit Avail Factor | .0 | .0 | 45.4 |
| 22. Unit Cap Factor (MDC Net) | .0 | .0 | 39.3 |
| 23. Unit Cap Factor (DER Net) | .0 | .0 | 37.4 |
| 24. Unit Forced Outage Rate | 100.0 | 100.0 | 44.9 |
| 25. Forced Outage Hours | 703.0 | 2,143.0 | 41,048.5 |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * RANCHO SECO 1 *

 AVERAGE DAILY POWER LEVEL (MWh) PLOT
 RANCHO SECO 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * RANCHO SECO 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 1 | 12/26/85 | F | 703.0 | D | 3 | 85-25 | CB | INSTRU | REACTOR TRIP DUE TO HIGH RCS PRESSURE TRIP PRECEDED BY A TOTAL LOSS OF ICS POWER. |
| 2 | 03/30/88 | S | 41.0 | E | 9 | | | | OPERATOR TRAINING AND TESTING PRIOR TO POWER GENERATION. |

 * SUMMARY *

 RANCHO SECO REMAINED SHUTDOWN IN MARCH AS DISCUSSED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* RANCHO SECO 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SACRAMENTO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI SE OF
SACRAMENTO, CA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...SEPTEMBER 16, 1974
DATE ELEC ENER 1ST GENER...OCTOBER 13, 1974
DATE COMMERCIAL OPERATE...APRIL 17, 1975
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...FOLSOM CANAL
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SACRAMENTO MUN. UTIL. DISTRICT
CORPORATE ADDRESS.....6201 S STREET P.O. BOX 15830
SACRAMENTO, CALIFORNIA 95813
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....A. DANGELO
LICENSING PROJ MGR.....G. KALMAN
DOCKET NUMBER.....50-312
LICENSE & DATE ISSUANCE...DPR-54, AUGUST 16, 1974
PUBLIC DOCUMENT ROOM.....BUSINESS AND MUNICIPAL DEPARTMENT
SACRAMENTO LIBRARY
828 I STREET
SACRAMENTO, CALIFORNIA 95814

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON DECEMBER 7, 1987 - FEBRUARY 18, 1988 (REPORT NO. 50-312/87-40) HEADQUARTERS' REPORT - TO BE REPORTED AT A LATER DATE.
- + INSPECTION ON DECEMBER 5, 1987 - FEBRUARY 03, 1988 (REPORT NO. 50-312/87-44) AREAS INSPECTED: THIS ROUTINE INSPECTION BY THE RESIDENT INSPECTORS INVOLVED THE AREAS OF OPERATIONAL SAFETY VERIFICATIONS, MAINTENANCE, SURVEILLANCE, AND FOLLOWUP ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.
- RESULTS: IN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.
- + INSPECTION ON JANUARY 4 - MARCH 10, 1988 (REPORT NO. 50-312/88-02) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON FEBRUARY 4 - MARCH 25, 1988 (REPORT NO. 50-312/88-05) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON MARCH 7-22, 1988 (REPORT NO. 50-312/88-08) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON MARCH 7-8, 1988 (REPORT NO. 50-312/88-09) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF THE EMERGENCY PREPAREDNESS PROGRAM AND FOLLOW-UP ON OPEN ITEMS. DURING THIS INSPECTION, ONE INSPECTION PROCEDURE WAS UTILIZED.

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

* RANCHO SECO 1 *

INSPECTION SUMMARY

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

- + INSPECTION ON MARCH 20 - APRIL 8, 1988 (REPORT NO. 50-312/88-10) REPORT BEING PREPARED: TO BE REPORTED NEXT MONTH.
- + INSPECTION ON MARCH 17, 1988 (REPORT NO. 50-312/88-11) REPORT BEING PREPARED: TO BE REPORTED NEXT MONTH.
- + INSPECTION ON MARCH 26 - APRIL 30, 1988 (REPORT NO. 50-312/88-12) REPORT BEING PREPARED TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

QAP-17 AND 10 CFR 50 APPENDIX B REQUIRED COMPLETION OF ECN/DCN DISPOSITION PRIOR TO CLOSURE OF A RELATED NONCOMFORMANCE REPORT. CONTRARY TO THIS REQUIREMENT, ON THREE OCCASIONS NOTED, AN NCR WAS CLOSED PRIOR TO COMPLETION OF THE RELATED ENGINEERING CHANGE NOTICE (ECN) OR OF THE ACTIONS OF THE NCR ITSELF.

(8704 4)

10 CFR 50, APPENDIX B, CRITERION V, REQUIRES THAT ACTIVITIES AFFECTING QUALITY SHALL BE PRESCRIBED BY DOCUMENTED INSTRUCTIONS, PROCEDURES OR DRAWINGS AND SHALL BE ACCOMPLISHED IN ACCORDANCE WITH THESE INSTRUCTIONS, PROCEDURES, OR DRAWINGS. SMUD MATERIALS MANAGEMENT PROCEDURE MMP-0025, "PRESERVATION, STORAGE, AND MAINTENANCE OF ITEMS IN STORAGE," PARAGRAPH 7.6.5, REQUIRES THAT ITEMS WHOSE SHELF LIFE HAS EXPIRED SHALL BE REMOVED FROM THEIR STORAGE LOCATION AND PLACED IN A "HOLD" LOCATION. RANCHO SECO MANAGEMENT INFORMATION SYSTEM REPORT RSMM 0330, DATED JANUARY 4, 1988, IDENTIFIED MATERIALS WITH EXPIRATION DATES FOR THE FIRST QUARTER OF 1988. CONTRARY TO THE STATED REQUIREMENTS, ON FEBRUARY 4, 1988, THREE SAFETY-RELATED RSMM 0330 GASKET LINE ITEMS (9 PIECES), WITH EXPIRED SHELF LIVES, HAD NOT BEEN TAGGED OR PLACED IN A HOLD LOCATION. TECHNICAL SPECIFICATION 6.12, HIGH RADIATION AREA, READS IN PART: "IN LIEU OF THE "CONTROL DEVICE" OR "ALARM SIGNAL" REQUIRED BY PARAGRAPH 20.203(C)(2) OF 10 CFR 20, EACH HIGH RADIATION AREA IN WHICH THE INTENSITY OF RADIATION IS GREATER THAN 100 MREM/HR BUT LESS THAN 1000 MREM/HR SHALL BE BARRICADED AND CONSPICUOUSLY POSTED AS A HIGH RADIATION AREA AND ENTRANCE THERETO SHALL BE CONTROLLED BY REQUIRING ISSUANCE OF A RADIATION EXPOSURE PERMIT..." CONTRARY TO THE STATED REQUIREMENTS, ON MARCH 1, 1988, A HIGH RADIATION AREA BEHIND STEAM GENERATOR "A" ON THE 31' ELEVATION OF THE UNIT 1 CONTAINMENT IN WHICH THE INTENSITY OF RADIATION RANGED UP TO 200 MREM/HR WAS NOT BARRICADED AND POSTED AS A HIGH RADIATION AREA.

(8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PLANT IS PERFORMING HOT SHUTDOWN TESTING AND WILL BE PERFORMING STEPPED INCREASES TO COMMERCIAL OPERATION. TDI EDG TESTING IS ALSO IN PROGRESS.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

RESTART TESTING IS BEING MONITORED BY NRR AND REGION V PRIOR TO RETURN TO COMMERCIAL OPERATION.

ENFORCEMENT CONFERENCE WAS HELD ON MAY 16, 1986, ON VIOLATIONS RELATED TO THE DECEMBER 26, 1985, EVENT AND FOLLOWUP ACTIVITIES.

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-458 OPERATING STATUS
2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: R. H. MARTIN (504) 635-6094 X4836
4. Licensed Thermal Power (MWT): 2894
5. Nameplate Rating (Gross MWe): 2894
6. Design Electrical Rating (Net MWe): 936
7. Maximum Dependable Capacity (Gross MWe): 936
8. Maximum Dependable Capacity (Net MWe): 936
9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
 NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|-----------|-----------|------------|
| 12. Report Period Hrs | 744.0 | 2,184.0 | 20,400.0 |
| 13. Hours Reactor Critical | 744.0 | 2,016.7 | 13,730.8 |
| 14. Rx Reserve Shtdwn Hrs | .0 | .0 | .0 |
| 15. Hrs Generator On-Line | 744.0 | 1,959.3 | 12,491.1 |
| 16. Unit Reserve Shtdwn Hrs | .0 | .0 | .0 |
| 17. Gross Therm Ener (MMH) | 2,038,152 | 5,426,301 | 30,896,185 |
| 18. Gross Elec Ener (MMH) | 705,224 | 1,879,323 | 10,500,197 |
| 19. Net Elec Ener (MMH) | 660,693 | 1,763,475 | 9,788,680 |
| 20. Unit Service Factor | 100.0 | 89.7 | 61.2 |
| 21. Unit Avail Factor | 100.0 | 89.7 | 61.2 |
| 22. Unit Cap Factor (MDC Net) | 94.9 | 86.3 | 51.3 |
| 23. Unit Cap Factor (DER Net) | 94.9 | 86.3 | 51.3 |
| 24. Unit Forced Outage Rate | .0 | 9.0 | 12.3 |
| 25. Forced Outage Hours | .0 | 193.5 | 1,754.4 |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * RIVER BEND 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

RIVER BEND 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* RIVER BEND 1

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|------------------|--|
| 88-05 | 03/02/88 | S | 0.0 | A | 5 | | | REDUCED POWER TO RESOLVE FEEDWATER REG. VALVE "C" DRIFT AND STEAM LEAK OH "B" REACTOR FEED PUMP. |

* SUMMARY *

RIVER BEND 1 INCURRED 1 POWER REDUCTION IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* RIVER BEND 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....LOUISIANA
COUNTY.....WEST FELICIANA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...24 MI NNW OF
BATON ROUGE, LA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...OCTOBER 31, 1985
DATE ELEC ENER 1ST GENER...DECEMBER 3, 1985
DATE COMMERCIAL OPERATE...JUNE 16, 1986
CONDENSER COOLING METHOD...MDCT
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GULF STATES UTILITIES
CORPORATE ADDRESS.....P.O. BOX 2951
BEAUMONT, LOUISIANA 77704
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....D. CHAMBERLAIN
LICENSING PROJ MANAGER.....W. PAULSON
DOCKET NUMBER.....50-458
LICENSE & DATE ISSUANCE...NPF-47, NOVEMBER 20, 1985
PUBLIC DOCUMENT ROOM.....GOVERNMENT DOCUMENTS DEPARTMENT
TROY H. MIDDLETON LIBRARY
LOUISIANA STATE UNIVERSITY
BATON ROUGE, LOUISIANA 70803

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

RIVER BEND 1

PLANT STATUS:

INFO. NOT SUPPLIED BY REGION

LAST IE SITE INSPECTION DATE: INFO. NOT SUPPLIED BY REGION

INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

INFO. NOT SUPPLIED BY REGION

=====

1. Docket: 50-261 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: V.E. FRAZIER (803) 383-4524 X 1220

4. Licensed Thermal Power (Mwt): 2300

5. Nameplate Rating (Gross MWe): 854 X 0.9 = 769

6. Design Electrical Rating (Net MWe): 700

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 665

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): 420

11. Reasons for Restrictions, If Any:
ADMINISTRATIVE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|----------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>149,696.0</u> |
| 13. Hours Reactor Critical | <u>508.0</u> | <u>1,188.9</u> | <u>106,718.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>3,159.6</u> |
| 15. Hrs Generator On-Line | <u>502.4</u> | <u>1,151.6</u> | <u>104,175.9</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>23.2</u> |
| 17. Gross Therm Ener (MWH) | <u>675,438</u> | <u>2,102,159</u> | <u>210,256,720</u> |
| 18. Gross Elec Ener (MWH) | <u>215,906</u> | <u>696,232</u> | <u>68,079,569</u> |
| 19. Net Elec Ener (MWH) | <u>199,635</u> | <u>654,223</u> | <u>64,332,152</u> |
| 20. Unit Service factor | <u>67.5</u> | <u>52.7</u> | <u>69.6</u> |
| 21. Unit Avail Factor | <u>67.5</u> | <u>52.7</u> | <u>69.6</u> |
| 22. Unit Cap Factor (MDC Net) | <u>40.3</u> | <u>45.0</u> | <u>64.6</u> |
| 23. Unit Cap Factor (DER Net) | <u>38.3</u> | <u>42.8</u> | <u>61.6</u> |
| 24. Unit Forced Outage Rate | <u>32.4</u> | <u>47.2</u> | <u>14.0</u> |
| 25. Forced Outage Hours | <u>240.7</u> | <u>1,031.5</u> | <u>11,234.2</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

X ROBINSON 2 X

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ROBINSON 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * ROBINSON 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 0102 | 01/29/88 | F | 240.7 | D | 4 | 88-003 | IC | BATTERY | THE UNIT WAS TAKEN TO COLD SHUTDOWN ON 1/29/88 FOR REVIEW OF UNANALYZED SINGLE FAILURE THAT COULD TAKE TWO OR THREE SAFETY INJECTION PUMPS OUT OF SERVICE. MODIFICATIONS AND ANALYSES WERE PERFORMED TO CORRECT THE DEFICIENCIES, AND THE TECHNICAL SPECIFICATIONS WERE REVISED TO REFLECT THE NEW RESTRICTED OPERATING REQUIREMENTS. |
| 0009 | 03/11/88 | S | 0.9 | B | 9 | | HA | TURBIN | TURBINE OVERSPEED TEST |

 * SUMMARY *

 ROBINSON 2 ENTERED MARCH SHUTDOWN. RETURNED TO POWER AND OPERATED AT A NOMINAL POWER LEVEL OF 60% FOR REMAINDER OF MONTH WHILE INCURRING 1 OUTAGE ON MARCH 11.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* ROBINSON 2 *

F A C I L I T Y D A T A

Report Period MAR 1988

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....DARLINGTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI NW OF
HARTSVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...SEPTEMBER 20, 1970
DATE ELEC ENER 1ST GENER...SEPTEMBER 26, 1970
DATE COMMERCIAL OPERATE...MARCH 7, 1971
CONDENSER COOLING METHOD...RECIRCULATION
CONDENSER COOLING WATER...ROBINSON IMPOUNDMENT
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY
LICENSEE.....CAROLINA POWER & LIGHT
CORPORATE ADDRESS.....411 FAYETTEVILLE STREET
RALEIGH, NORTH CAROLINA 27601
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....P. KRUG
LICENSING PROJ MANAGER....R. LO
DOCKET NUMBER.....50-261
LICENSE & DATE ISSUANCE...DPR-23, SEPTEMBER 23, 1970
PUBLIC DOCUMENT ROOM.....HARTSVILLE MEMORIAL LIBRARY
220 N. FIFTH ST.
HARTSVILLE, SOUTH CAROLINA 29550

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JANUARY 11 - FEBRUARY 10, AND MARCH 7 (88-03): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF FOLLOWUP ON PREVIOUS INSPECTION ITEMS, OPERATIONAL SAFETY VERIFICATION, PHYSICAL PROTECTION, SURVEILLANCE OBSERVATION, MAINTENANCE OBSERVATION, ESF SYSTEM WALKDOWN, ONSITE FOLLOWUP OF EVENTS AT OPERATING POWER REACTORS, ONSITE REVIEW COMMITTEE, AND NATURAL CIRCULATION COOLDOWN. ONE VIOLATION WAS IDENTIFIED INVOLVING FOUR EXAMPLES OF FAILURE TO OPERATE THE PLANT WITHIN THE DESIGN BASIS. AN ADDITIONAL RELATED VIOLATION WAS IDENTIFIED INVOLVING FAILURE TO IDENTIFY AND CORRECT CONDITIONS ADVERSE TO QUALITY AS REQUIRED BY 10 CFR 50 APPENDIX B, CRITERION XVI.

INSPECTION FEBRUARY 12-13 (88-05): THIS SPECIAL, ANNOUNCED INSPECTION WAS TO OBSERVE POST MODIFICATION TESTING TO VERIFY THE PLANT'S ABILITY TO AUTOMATICALLY START TWO SAFETY INJECTION PUMPS AFTER EACH OF THE FIVE POSTULATED SINGLE FAILURE EVENTS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ DUE TO SINGLE FAILURE EDG/SI PUMP CONCERN, PLANT IS LIMITED TO 60% POWER OPER.

LAST IE SITE INSPECTION DATE: FEBRUARY 12-13, 1988 +

INSPECTION REPORT NO: 50-261/88-05 +

R E P O R T S F R O M L I C E N S E E

```
=====
```

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---|
| 88-003 | 01/28/88 | 02/27/88 | LOSS OF SAFETY INJECTION PUMP AUTOSTART DUE TO EIGHT SINGLE-FAILURE SCENARIOS |

```
=====
```

1. Docket: 50-272 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: BRYAN W. GORMAN (609) 339-3400

4. Licensed Thermal Power (Mwt): 3411

5. Nameplate Rating (Gross MWe): 1300 X 0.9 = 1170

6. Design Electrical Rating (Net MWe): 1115

7. Maximum Dependable Capacity (Gross MWe): 1149

8. Maximum Dependable Capacity (Net MWe): 1106

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>94,273.0</u> |
| 13. Hours Reactor Critical | <u>707.8</u> | <u>849.0</u> | <u>58,544.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>0</u> | <u>0</u> | <u>3,088.4</u> |
| 15. Hrs Generator On-Line | <u>707.8</u> | <u>771.5</u> | <u>56,563.1</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>0</u> | <u>0</u> | <u>0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,404,896</u> | <u>2,521,985</u> | <u>174,993,198</u> |
| 18. Gross Elec Ener (MWH) | <u>812,940</u> | <u>845,350</u> | <u>58,037,638</u> |
| 19. Net Elec Ener (MWH) | <u>780,378</u> | <u>788,565</u> | <u>55,185,274</u> |
| 20. Unit Service Factor | <u>95.1</u> | <u>35.3</u> | <u>60.0</u> |
| 21. Unit Avail Factor | <u>95.1</u> | <u>35.3</u> | <u>60.0</u> |
| 22. Unit Cap Factor (MDC Net) | <u>94.8</u> | <u>32.6</u> | <u>52.9</u> |
| 23. Unit Cap Factor (DER Net) | <u>94.1</u> | <u>32.4</u> | <u>52.5</u> |
| 24. Unit Forced Outage Rate | <u>2.8</u> | <u>4.7</u> | <u>25.4</u> |
| 25. Forced Outage Hours | <u>20.2</u> | <u>38.0</u> | <u>19,497.8</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 04/13/88

* SALEM 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
SALEM 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* SALEM 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 0031 | 03/30/88 | F | 20.2 | A | 2 | | HA | INSTRU | TURBINE HYDRAULIC SYSTEM. |
| 0032 | 03/31/88 | S | 16.0 | B | 9 | | CB | HTEXCH | NUCLEAR STEAM GENERATOR TUBE LEAK. |

***** SALEM 1 INCURRED 2 OUTAGES IN MARCH FOR REASONS STATED ABOVE.
* SUMMARY *

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* SALEM 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NEW JERSEY
COUNTY.....SALEM
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI S OF
WILMINGTON, DEL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 11, 1976
DATE ELEC ENER 1ST GENER...DECEMBER 25, 1976
DATE COMMERCIAL OPERATE...JUNE 30, 1977
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...DELAWARE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS
CORPORATE ADDRESS.....80 PARK PLACE
NEWARK, NEW JERSEY 07101
CONTRACTOR
ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....UNITED ENG & CONSTRUCTORS
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. LINVILLE
LICENSING PROJ MANAGER.....D. FISCHER
DOCKET NUMBER.....50-272
LICENSE & DATE ISSUANCE...DPR-70, DECEMBER 1, 1976
PUBLIC DOCUMENT ROOM.....SALEM FREE PUBLIC LIBRARY
112 WEST BROADWAY
SALEM, NEW JERSEY 08079

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

* SALEM 1 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------------------|------------------|-------------------|---------|
| NO INPUT PROVIDED. | | | |

=====

1. Docket: 50-311 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: BRYAN W. GORMAN (609) 339-3400

4. Licensed Thermal Power (MWh): 3411

5. Nameplate Rating (Gross MWe): 1162

6. Design Electrical Rating (Net MWe): 1115

7. Maximum Dependable Capacity (Gross MWe): 1149

8. Maximum Dependable Capacity (Net MWe): 1106

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>56,689.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>34,562.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>3,533.6</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,180.3</u> | <u>33,477.4</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,532,218</u> | <u>7,321,162</u> | <u>104,086,891</u> |
| 18. Gross Elec Ener (MWH) | <u>845,860</u> | <u>2,439,920</u> | <u>34,069,390</u> |
| 19. Net Elec Ener (MWH) | <u>811,935</u> | <u>2,342,864</u> | <u>32,362,332</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>99.8</u> | <u>59.1</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>99.8</u> | <u>59.1</u> |
| 22. Unit Cap Factor (MDC Net) | <u>98.7</u> | <u>97.0</u> | <u>51.6</u> |
| 23. Unit Cap Factor (DER Net) | <u>97.9</u> | <u>96.2</u> | <u>51.2</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.2</u> | <u>31.7</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>3.7</u> | <u>15,521.6</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * SALEM 2 *

 AVERAGE DAILY POWER LEVEL (MWe) PLOT
 SALEM 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* SALEM 2 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

:**
* SUMMARY *

SALEM 2 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES OR
SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* SALEM 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....NEW JERSEY
COUNTY.....SALEM
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI S OF
WILMINGTON, DEL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 8, 1980
DATE ELEC ENER 1ST GENER...JUNE 3, 1981
DATE COMMERCIAL OPERATE...OCTOBER 13, 1981
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...DELAWARE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS
CORPORATE ADDRESS.....80 PARK PLACE
NEWARK, NEW JERSEY 07101
CONTRACTOR
ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. LINVILLE
LICENSING PROJ MANAGER....D. FISCHER
DOCKET NUMBER.....50-311
LICENSE & DATE ISSUANCE...DPR-75, MAY 20, 1981
PUBLIC DOCUMENT ROOM.....SALEM FREE PUBLIC LIBRARY
112 WEST BROADWAY
SALEM, NEW JERSEY 08079

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

1. Docket: 50-206 OPERATING STATUS
2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: E. R. SIACOR (714) 368-6225
4. Licensed Thermal Power (MWh): 1347
5. Nameplate Rating (Gross MWe): 500 X 0.9 = 450
6. Design Electrical Rating (Net MWe): 436
7. Maximum Dependable Capacity (Gross MWe): 456
8. Maximum Dependable Capacity (Net MWe): 436
9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): 390

11. Reasons for Restrictions, If Any: _____

SELF-IMPOSED TO CONTROL S.G. TUBE CORROSION.

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|--------|-----------|-------------|
| 12. Report Period Hrs | 744.0 | 2,184.0 | 182,288.0 |
| 13. Hours Reactor Critical | .0 | 1,068.7 | 107,549.1 |
| 14. Rx Reserve Shtdn Hrs | .0 | .0 | .0 |
| 15. Hrs Generator On-Line | .0 | 1,063.1 | 103,493.5 |
| 16. Unit Reserve Shtdn Hrs | .0 | .0 | .0 |
| 17. Gross Therm Ener (MWh) | .0 | 1,304,993 | 130,436,853 |
| 18. Gross Elec Ener (MWh) | .0 | 430,200 | 44,107,926 |
| 19. Net Elec Ener (MWh) | -1,124 | 404,294 | 41,647,559 |
| 20. Unit Service Factor | .0 | 48.7 | 56.8 |
| 21. Unit Avail Factor | .0 | 48.7 | 56.8 |
| 22. Unit Cap Factor (MDC Net) | .0 | 42.5 | 52.4 |
| 23. Unit Cap Factor (DER Net) | .0 | 42.5 | 52.4 |
| 24. Unit Forced Outage Rate | .0 | .0 | 19.9 |
| 25. Forced Outage Hours | .0 | .0 | 13,140.4 |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): _____


NONE

27. If Currently Shutdown Estimated Startup Date: 04/28/88

* SAN ONDRE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SAN ONDRE 1



PERCENT MDC

MARCH 1988

Report Period APR 1988

UNIT SHUTDOWNS / REDUCTIONS

XX
 * SAN ONOFRE 1 *
 XX

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 117 | 02/14/88 | S | 672.0 | B | 4 | | | | MID-CYCLE MAINTENANCE OUTAGE. |
| 118 | 03/28/88 | S | 72.0 | H | 9 | 88-001 | BA | ISV | MID-CYCLE MAINTENANCE OUTAGE EXTENDED TO UPGRADE CERTAIN COMPONENTS IN ORDER TO MEET 10CFR 50.49 REQUIREMENTS. |

XXXXXXXXXXXX SAN ONOFRE 1 REMAINED SHUTDOWN IN MARCH FOR REASONS
 * SUMMARY * STATED ABOVE.
 XXXXXXXXXXXX

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* SAN ONOFRE 1 *

F A C I L I T Y D A T A

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SAN DIEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
SAN CLEMENTE, CA

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SOUTHERN CALIFORNIA EDISON
CORPORATE ADDRESS.....2244 WALNUT GROVE AVENUE
ROSEHEAD, CALIFORNIA 91770

CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCIOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.... R. HUEY
LICENSING PROJ MANAGER.....C. TRAMMELL
DOCKET NUMBER.....50-206
LICENSE & DATE ISSUANCE...DPR-13, MARCH 27, 1967
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF CALIFORNIA
GENERAL LIBRARY
IRVINE, CA. 92713

ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 4 - FEBRUARY 5, 1988 (REPORT NO. 50-206/88-02) AREAS INSPECTED: ROUTINE PROJECT INSPECTION IN THE AREAS OF LICENSED AND NON-LICENSED OPERATOR TRAINING PROGRAMS, INFORMATION NOTICES AND PART 21 REPORT FOLLOWUP, COMPLIANCE WITH ATWS RULE (10 CFR 50.62), DESIGN CHANGE AND MODIFICATION PROGRAMS, SURVEILLANCE TESTING, AND CALIBRATION CONTROL PROGRAMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION: ON JANUARY 10 - FEBRUARY 27, 1988 (REPORT NO. 50-206/88-03) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 29 - MARCH 4, 1988 (REPORT NO. 50-206/88-06) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF MAINTAINING EXPOSURES ALARA AND OCCUPATIONAL EXPOSURE DURING OUTAGES, INCLUDING TOURS OF LICENSEE FACILITIES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: ONE VIOLATION WAS IDENTIFIED INVOLVING THE POSTING OF A HIGH RADIATION AREA. ONE UNRESOLVED ITEM WAS IDENTIFIED INVOLVING THE DETECTION OF HOT PARTICLES BY THE LICENSEE'S WHOLEBODY COUNTING SYSTEM.

+ INSPECTION ON MARCH 8-11, 1988 (REPORT NO. 50-206/88-07) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 28 - APRIL 9, 1988 (REPORT NO. 50-206/88-08) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

K SAN ONOFRE 1

I N S P E C T I O N S T A T U S - (CONTINUED)

Report Period MAR 1988

INSPECTION SUMMARY

- + INSPECTION ON MARCH 14-23, 1988 (REPORT NO. 50-206/88-09) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON FEBRUARY 25 - MARCH 25, 1988 (REPORT NO. 50-206/88-10) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + MANAGEMENT MEETING ON MARCH 24, 1988 (REPORT NO. 50-206/88-11) A MANAGEMENT MEETING WAS HELD ON THE ABOVE DATE TO DISCUSS ISSUES OF CURRENT INTEREST RELATING TO THE SAN ONOFRE UNIT 1 NUCLEAR GENERATING STATION.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

ON FEBRUARY 25, 1988, SOUTHERN CALIFORNIA EDISON IDENTIFIED TO THE NRC THAT THEY HAD IDENTIFIED SOME ENVIRONMENTAL QUALIFICATION (EQ) PROBLEMS WITH VARIOUS COMPONENTS. THESE COMPONENTS WERE PRIMARILY SOLENOID VALVES IN THE AUXILIARY FEEDWATER, CHEMICAL AND VOLUME CONTROL, SAFETY INJECTION, AND CONTAINMENT ISOLATION SYSTEMS. IN A POSTULATED HARSH ENVIRONMENT, THESE COMPONENTS COULD BECOME INOPERABLE OR CAUSE SECONDARY ELECTRICAL PROBLEMS. THE LICENSEE IDENTIFIED THAT THESE DEFICIENCIES WOULD BE CORRECTED PRIOR TO STARTUP OR JUSTIFICATION WOULD BE PROVIDED FOR CONTINUED OPERATION.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ THE UNIT WAS SHUT DOWN ON FEBRUARY 13, 1988, FOR A 45-DAY PLANNED MAINTENANCE OUTAGE (NO REFUELING). THE PURPOSE OF THE OUTAGE WAS TO SHORTEN THE UNIT'S CYCLE X REFUELING OUTAGE AND TO PREVENT CONCURRENT REFUELING OUTAGES WITH UNIT 3. THE UNIT WAS STILL SHUT DOWN AS OF THE END OF MARCH 1988 TO CORRECT IDENTIFIED ENVIRONMENTAL QUALIFICATION DEFICIENCIES.

LAST IE SITE INSPECTION DATE: 02/28 - 04/09/88+

INSPECTION REPORT NO: 50-206/88-08+

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-361 OPERATING STATUS
2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: E. R. SIACOR (714) 368-6223
4. Licensed Thermal Power (Mwt): 3390
5. Nameplate Rating (Gross MWe): 1127
6. Design Electrical Rating (Net MWe): 1070
7. Maximum Dependable Capacity (Gross MWe): 1127
8. Maximum Dependable Capacity (Net MWe): 1070
9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____
11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>40,753.0</u> |
| 13. Hours Reactor Critical | <u>385.9</u> | <u>1,825.9</u> | <u>27,618.4</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>385.5</u> | <u>1,812.1</u> | <u>26,997.8</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,217,237</u> | <u>5,935,250</u> | <u>86,901,673</u> |
| 18. Gross Elec Ener (MWH) | <u>446,884</u> | <u>2,075,957</u> | <u>29,338,531</u> |
| 19. Net Elec Ener (MWH) | <u>419,085</u> | <u>1,973,844</u> | <u>27,762,724</u> |
| 20. Unit Service Factor | <u>51.8</u> | <u>83.0</u> | <u>66.2</u> |
| 21. Unit Avail Factor | <u>51.8</u> | <u>83.0</u> | <u>66.2</u> |
| 22. Unit Cap Factor (MDC Net) | <u>52.6</u> | <u>84.5</u> | <u>63.7</u> |
| 23. Unit Cap Factor (DER Net) | <u>52.6</u> | <u>84.5</u> | <u>63.7</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>4.2</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>1,183.5</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: 04/04/88

 * SAN ONOFRE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 SAN ONOFRE 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * SAN ONOFRE 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 42 | 03/17/88 | S | 358.5 | B | 1 | | | SG | UNIT NORMALLY SHUTDOWN FROM 100% POWER FOR INSPECTION AND REPAIRS TO STEAM GENERATOR E-088 TUBE LEAKS. |

 * SUMMARY *

 SAN ONOFRE INCURRED 1 POWER OUTAGE IN MARCH FOR REASONS STATED ABOVE, AND REMAINED SHUTDOWN AT MONTHS END.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* SAN ONOFRE 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SAN DIEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
SAN CLEMENTE, CA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 26, 1982
DATE ELEC ENER 1ST GENER...SEPTEMBER 20, 1982
DATE COMMERCIAL OPERATE...AUGUST 8, 1983
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...PACIFIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SOUTHERN CALIFORNIA EDISON
CORPORATE ADDRESS.....P.O. BOX 800
ROSEMEAD, CALIFORNIA 91770
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....R. HUEY
LICENSING PROJ MANAGER....D. HICKMAN
DOCKET NUMBER.....50-361
LICENSE & DATE ISSUANCE...NPF-10, SEPTEMBER 7, 1982
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF CALIFORNIA
GENERAL LIBRARY
IRVINE, CA. 92713

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 4 - FEBRUARY 5, 1988 (REPORT NO. 50-361/88-02) AREAS INSPECTED: ROUTINE PROJECT INSPECTION IN THE AREAS OF LICENSED AND NON-LICENSED OPERATOR TRAINING PROGRAMS, INFORMATION NOTICES AND PART 21 REPORT FOLLOWUP, COMPLIANCE WITH ATWS RULE (10 CFR 50.62), DESIGN CHANGE AND MODIFICATION PROGRAMS, SURVEILLANCE TESTING, AND CALIBRATION CONTROL PROGRAMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JANUARY 10 - FEBRUARY 27, 1988 (REPORT NO. 50-361/88-03) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 29 - MARCH 4, 1988 (REPORT NO. 50-361/88-06) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF MAINTAINING EXPOSURES ALARA, INCLUDING TOURS OF LICENSEE FACILITIES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MARCH 8-14, 1988 (REPORT NO. 50-361/88-07) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 28 - APRIL 9, 1988 (REPORT NO. 50-361/88-08) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ THE UNIT WAS SHUT DOWN ON MARCH 17, 1988 TO CORRECT TUBE LEAKAGE IN STEAM GENERATOR E088. THE LEAK WAS FOUND TO BE DUE TO A TUBE PLUG MISSING FROM A TUBE WHICH HAD PREVIOUSLY BEEN PREVENTIVELY PLUGGED. ONE PLUG WAS ALSO MISSING FROM STEAM GENERATOR E089. THE PLUGS WERE REPLACED, AND AN ADDITIONAL LEAKING PLUG IN EACH STEAM GENERATOR WAS CORRECTED. PREPARATION OF A SAFETY EVALUATION FOR THE MISSING PLUGS WAS IN PROGRESS AT THE END OF MARCH.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ UNIT 2 OPERATED AT FULL POWER UNTIL MARCH 17, 1988, WHEN IT WAS SHUT DOWN TO CORRECT STEAM GENERATOR TUBE LEAKAGE (SEE ABOVE). THE UNIT REMAINED SHUT DOWN FOR THE REMAINDER OF THE MONTH.

LAST IE SITE INSPECTION DATE: 02/28 - 04/09/88+

INSPECTION REPORT NO: 50-361/88-08+

R E P O R T S F R O M L I C E N S E E

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
| ----- | | | |
| NONE | | | |
| ===== | | | |

1. Docket: 50-362 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: E. R. SIACOR (714) 368-6223

4. Licensed Thermal Power (MMt): 3390

5. Nameplate Rating (Gross MWe): 1127

6. Design Electrical Rating (Net MWe): 1080

7. Maximum Dependable Capacity (Gross MWe): 1127

8. Maximum Dependable Capacity (Net MWe): 1080

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,189.0</u> | <u>35,064.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>1,935.7</u> | <u>25,658.2</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>1,884.2</u> | <u>24,758.1</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,505,525</u> | <u>6,270,329</u> | <u>75,726,090</u> |
| 18. Gross Elec Ener (MWH) | <u>862,796</u> | <u>2,155,483</u> | <u>25,633,377</u> |
| 19. Net Elec Ener (MWH) | <u>821,746</u> | <u>2,059,074</u> | <u>24,126,740</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>86.3</u> | <u>70.6</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>86.3</u> | <u>70.6</u> |
| 22. Unit Cap Factor (MDC Net) | <u>102.3</u> | <u>86.4</u> | <u>63.7</u> |
| 23. Unit Cap Factor (DER Net) | <u>102.3</u> | <u>86.4</u> | <u>63.7</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>13.7</u> | <u>9.9</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>299.8</u> | <u>2,708.6</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING - APRIL 30, 1988 - 78 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
 X SAN ONDFRE 3 X
 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SAN ONDFRE 3



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* SAN ONOFRE 3 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|--------|-----------|---|
|-----|------|------|-------|--------|--------|------------|--------|-----------|---|

NONE

* SUMMARY *

SAN ONOFRE 3 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES
OR SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* SAN ONOFRE 3 *

F A C I L I T Y D A T A

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SAN DIEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
 SAN CLEMENTE, CA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 29, 1983
DATE ELEC ENER 1ST GENER...SEPTEMBER 25, 1983
DATE COMMERCIAL OPERATE...APRIL 1, 1984
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...PACIFIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
 COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SOUTHERN CALIFORNIA EDISON
CORPORATE ADDRESS.....P.O. BOX 800
 ROSEMEAD, CALIFORNIA 91770
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....R. HUEY
LICENSING PROJ MANAGER.....D. HICKMAN
DOCKET NUMBER.....50-362
LICENSE & DATE ISSUANCE...NPF-15, NOVEMBER 15, 1982
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF CALIFORNIA
 GENERAL LIBRARY
 IRVINE, CA. 92713

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTIONS ON JANUARY 4 - FEBRUARY 5, 1988 (REPORT NO. 50-362/88-02) AREAS INSPECTED: ROUTINE PROJECT INSPECTION IN THE AREAS OF LICENSED AND NON-LICENSED OPERATOR TRAINING PROGRAMS, INFORMATION NOTICES AND PART 21 REPORT FOLLOWUP, COMPLIANCE WITH ATWS RULE (10 CFR 50.62), DESIGN CHANGE AND MODIFICATION PROGRAMS, SURVEILLANCE TESTING, AND CALIBRATION CONTROL PROGRAMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JANUARY 10 - FEBRUARY 27, 1988 (REPORT NO. 50-362/88-03) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 29 - MARCH 4, 1988 (REPORT NO. 50-362/88-06) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF MAINTAINING EXPOSURES ALARA, INCLUDING TOURS OF LICENSEE FACILITIES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MARCH 8-11, 1988 (REPORT NO. 50-362/88-07) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 28 - APRIL 9, 1988 (REPORT NO. 50-362/88-08) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
* S A N O N O F R E 3 *
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ THE UNIT CONTINUED FULL POWER OPERATION DURING MARCH.

LAST IE SITE INSPECTION DATE: 02/28 - 04/09/88+

INSPECTION REPORT NO: 50-362/88-08+

R E P O R T S F R O M L I C E N S E E

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

NONE

=====

1. Docket: 50-527 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: DAVID DUPREE (615) 870-6722

4. Licensed Thermal Power (Mwt): 3411

5. Nameplate Rating (Gross MWe): 1220

6. Design Electrical Rating (Net MWe): 1148

7. Maximum Dependable Capacity (Gross MWe): 1183

8. Maximum Dependable Capacity (Net MWe): 1148

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power level to which restricted, if any (Net MWe):

11. Reasons for restrictions, if any:

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------------|----------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>59,185.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>.0</u> | <u>24,444.7</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>.0</u> | <u>23,871.0</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>.0</u> | <u>.0</u> | <u>77,060,921</u> |
| 18. Gross Elec Ener (MWH) | <u>.0</u> | <u>.0</u> | <u>25,978,386</u> |
| 19. Net Elec Ener (MWH) | <u>-4,315</u> | <u>-18,901</u> | <u>24,835,422</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>.0</u> | <u>40.3</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>.0</u> | <u>40.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>.0</u> | <u>36.6</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>.0</u> | <u>36.6</u> |
| 24. Unit Forced Outage Rate | <u>100.0</u> | <u>100.0</u> | <u>52.2</u> |
| 25. Forced Outage Hours | <u>744.0</u> | <u>2,184.0</u> | <u>26,075.1</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If currently shutdown estimated startup date: N/A

 * SEQUOYAH 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 SEQUOYAH 1



MARCH 1988

F A C I L I T Y D A T A

* SEQUOYAH 1 *

FACILITY DESCRIPTION

LOCATION
STATE..... TENNESSEE
COUNTY..... HAMILTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR... 9.5 MI NE OF
CHATTANOOGA, TN
TYPE OF REACTOR..... PWR
DATE INITIAL CRITICALITY... JULY 5, 1980
DATE ELEC EMER 1ST GENER.... JULY 22, 1980
DATE COMMERCIAL OPERATE... JULY 1, 1981
CONDENSER COOLING METHOD... ONCE THRU
CONDENSER COOLING WATER... CHICKAMAUGA LAKE
ELECTRIC RELIABILITY
COUNCIL..... SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE..... TENNESSEE VALLEY AUTHORITY
CORPORATE ADDRESS..... 6 NORTH 38A LOOKOUT PLACE
CHATTANOOGA, TENNESSEE 37401
CONTRACTOR
ARCHITECT/ENGINEER..... TENNESSEE VALLEY AUTHORITY
NUC STEAM SYS SUPPLIER... WESTINGHOUSE
CONSTRUCTOR..... TENNESSEE VALLEY AUTHORITY
TURBINE SUPPLIER..... WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE..... II
IE RESIDENT INSPECTOR..... E. FORD
LICENSING PROJ MANAGER..... E. MCKENNA
DOCKET NUMBER..... 50-327

LICENSE & DATE ISSUANCE... DPR-77, SEPTEMBER 17, 1980

PUBLIC DOCUMENT ROOM..... CHATTANOOGA - HAMILTON BICENTENNIAL LIBRARY
1001 BROAD STREET
CHATTANOOGA, TENNESSEE 37402

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

* INSPECTION AUGUST 24-28 - SEPTEMBER 8-11 (87-59): THIS ANNOUNCED TEAM INSPECTION WAS CONDUCTED TO EVALUATE MANAGEMENT EFFECTIVENESS AT THE SEQUOYAH SITE IN THE AREAS OF OPERATIONS, MAINTENANCE, QUALITY ASSURANCE, MODIFICATIONS, ENGINEERING AND LICENSING. CORPORATE INTERFACES WITH SOME SITE DISCIPLINES WERE ALSO EXAMINED. IN ADDITION, CORPORATE PROGRAMS FOR MANAGEMENT IMPROVEMENT WERE EXAMINED. SELECTED COMMITMENTS MADE IN VOLUMES 1 AND 2 OF THE TVA NUCLEAR PERFORMANCE PLANS WERE ALSO MONITORED. THIS INSPECTION FOCUSED ON MANAGEMENT FUNCTIONS AND WAS NOT A TYPICAL MRC INSPECTION DEALING DIRECTLY WITH REGULATORY COMPLIANCE ISSUES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED DURING THIS INSPECTION. ONE ISSUE WAS IDENTIFIED AS A RESTART ITEM. OVERALL, THE RESULTS OF THIS INSPECTION INDICATE THAT THE SEQUOYAH SITE MANAGEMENT PROCESSES ARE SUFFICIENTLY EFFECTIVE TO SUPPORT PLANT RESTART.

INSPECTION OCTOBER 5-18 (87-68): THIS ROUTINE INSPECTION WAS CONDUCTED IN THE AREAS OF ALLEGATIONS AND LICENSEE ACTION ON INSPECTOR IDENTIFIED ITEMS. THREE VIOLATIONS WERE IDENTIFIED INVOLVING DIVISION OF NUCLEAR ENGINEERING (DNE) TRAINING, INEFFECTIVE FOLLOWUP ON AUDIT FINDINGS AND IMPROPER CORRECTIONS TO QUALITY ASSURANCE (QA) RECORDS.

INSPECTION OCTOBER 26-30, 1987 - JANUARY 4-14, 1988 (87-73): THIS SPECIAL ANNOUNCED INSPECTION WAS CONDUCTED TO ASSESS TVA'S READINESS TO SUPPORT SEQUOYAH UNIT 2 ENTRY INTO MODE 4 AND MODE 3. THE AREAS REVIEWED INCLUDED STATUS OF MC94300 ITEMS ASSOCIATED WITH HEATUP, TESTING ACTIVITIES, PLANT HEATUP PROCEDURE, TVA'S OPERATIONAL READINESS ASSESSMENT, COMPENSATORY MEASURES, AND CONTROL OF OPERATIONS. IN AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED THAT INVOLVED THE FAILURE TO PERFORM OR ADEQUATELY PERFORM A WRITTEN SAFETY EVALUATION FOR MODIFICATIONS TO THE FACILITY WHICH INVOLVED COMPENSATORY ACTION FOR DEFEATED SAFETY FUNCTIONS.

INSPECTION SUMMARY

INSPECTION DECEMBER 14-18 AND FEBRUARY 2-4 (87-78): THIS ANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF RESTART EMPLOYEE CONCERNS RECEIVED BY THE NRC. VIOLATIONS IDENTIFIED DURING THIS INSPECTION INCLUDE: TECHNICAL SPECIFICATION (TS) 6.8.1 FOR FAILURE TO ADEQUATELY IMPLEMENT THE REQUIREMENTS OF AI-30 AND AI-2 FOR CONTROL OF OPERATOR OVERTIME. EXAMPLES WERE NOTED WHERE PLANT MANAGER AUTHORIZATION WAS NOT OBTAINED TO EXCEED SPECIFIED OVERTIME LIMITS AND WHERE THE DEVIATION FORMS WERE NOT FORWARDED WITHIN ONE WORKING DAY AFTER THE DEVIATION OCCURRED. A VIOLATION OF 10 CFR 50, APPENDIX B, CRITERION V FOR FAILURE TO PRESCRIBE IN INSTRUCTIONS OR PROCEDURES THE TRAINING AND QUALIFICATION REQUIREMENTS FOR COMPOSITE CREWS. COMPOSITE CREWS WERE IMPLEMENTED PRIOR TO HAVING ESTABLISHED TRAINING AND QUALIFICATION REQUIREMENTS FOR FOREMEN AND GENERAL FOREMEN SUPERVISING PERSONNEL IN OTHER CRAFTS AND FOR CRAFTSMEN PERFORMING WORK AND INDEPENDENT VERIFICATION OUTSIDE OF THEIR CRAFT.

INSPECTION JANUARY 25-29 (88-11): THIS ROUTINE, UNANNOUNCED PHYSICAL SECURITY INSPECTION EXAMINED: MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM, SECURITY PROGRAM AUDIT, PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS, ACCESS CONTROL - PERSONNEL AND PACKAGES, DETECTION AIDS - PROTECTED AND VITAL AREAS, AND ALARM STATIONS. NO VIOLATIONS OF REGULATORY REQUIREMENTS WERE IDENTIFIED.

INSPECTION FEBRUARY 8-12 (88-15): THIS ANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, LICENSEE EVENT REPORT FOLLOW-UP, NRC INFORMATION NOTICES, POTENTIAL REPORTABLE OCCURRENCES, PROBLEM IDENTIFICATION REPORTS, INDUSTRY GENERATED NUCLEAR EXPERIENCE REVIEW ITEMS, IE BULLETINS, AND CONDITION ADVERSE TO QUALITY REPORTS (CAQRs). THE INSPECTION WAS CONDUCTED TO DETERMINE IF THE PROGRAMS AND CORRECTIVE ACTIONS IMPLEMENTED ARE EFFECTIVE IN ASSURING ADVERSE CONDITIONS, INCLUDING GENERIC ISSUES ARE DISPOSITIONED ADEQUATELY. NO VIOLATIONS WERE IDENTIFIED DURING THIS INSPECTION EFFORT. HOWEVER, BASED ON THE ISSUES DISCUSSED IN THE DETAILS SECTION OF THIS REPORT, THE LICENSEE'S CORRECTIVE ACTION PROGRAM NEEDS IMPROVEMENT IN THE FOLLOWING AREAS IN ORDER TO ENSURE PROMPT EVALUATION AND CORRECTION OF CONDITIONS ADVERSE TO QUALITY (CAQs), PROBLEM IDENTIFICATION REPORTS (PIRS) AND NUCLEAR EXPERIENCE REVIEW (NER) ITEMS AND IT IS NOT APPROPRIATE TO CONSIDER REMOVAL OF THE RESTRICTIONS APPLIED TO THE SEQUOYAH SITE BY ORDER EA 85-49. AREAS REQUIRING ADDITIONAL LICENSEE ACTION ARE: IMPROVE THE SPEED AND RELIABILITY OF OPERABILITY/SIGNIFICANCE DETERMINATIONS, AND ROOT CAUSE DETERMINATION. ENSURE THOSE PERSONNEL WHO MAKE OPERABILITY/SIGNIFICANCE DETERMINATIONS IN THE GENERIC CAQ, AND NUCLEAR EXPERIENCE REVIEW (NER) PROCESSES ARE ADEQUATELY TRAINED AND POSSESS THE CORRECT QUALIFICATIONS TO MAKE OPERABILITY/SIGNIFICANCE DETERMINATIONS. IMPROVE THE COMPLETENESS AND AUDITABILITY OF CAQ DOCUMENTATION REQUIRED FOR ADEQUATE MANAGEMENT REVIEWS PRIOR TO CLOSURE. ENSURE MANAGERIAL CAQR TRAINING REQUIREMENTS IMPOSED BY ORDER EA 85-49 ARE CURRENT. RESOLVE SPECIFIED TECHNICAL QUESTIONS UNIQUE TO CERTAIN INDIVIDUAL CAQRs. THE LICENSEE'S CORRECTIVE ACTIONS WILL BE REVIEWED IN A FOLLOWUP INSPECTION, 327,328/88-19.

INSPECTION FEBRUARY 12 - 26 (88-17): THIS ANNOUNCED INSPECTION INVOLVED ONSHIFT AND ONSITE INSPECTIONS BY THE NRC RESTART TASK FORCE. THE MAJORITY OF EXPENDED INSPECTION EFFORT WAS IN THE AREAS OF EXTENDED CONTROL ROOM OBSERVATION AND OPERATIONAL SAFETY VERIFICATION INCLUDING OPERATIONS PERFORMANCE, SYSTEM LINEUPS, RADIATION PROTECTION, AND SAFEGUARDS AND HOUSEKEEPING INSPECTIONS. OTHER AREAS INSPECTED INCLUDE: MAINTENANCE OBSERVATIONS, REVIEW OF PREVIOUS INSPECTION FINDINGS, FOLLOW-UP OF EVENTS, REVIEW OF LICENSEE IDENTIFIED ITEMS, AND REVIEW OF INSPECTOR FOLLOW-UP ITEMS. DURING THIS PERIOD THERE WAS EXTENDED CONTROL ROOM AND PLANT ACTIVITY COVERAGE BY NRC INSPECTORS AND MANAGERS. ONE VIOLATION WAS IDENTIFIED, 327,328/88-17-01; FAILURE TO FOLLOW PROCEDURE - THREE EXAMPLES. AN ADDITIONAL EXAMPLES OF PREVIOUS VIOLATION 327,328/87-78-01 WAS ALSO IDENTIFIED.

INSPECTION MARCH 3 (88-21): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED A REVIEW OF THE PREVIOUSLY IDENTIFIED VITAL AREA BARRIER ISSUES AND A FOLLOWUP TO THE LICENSEE'S INSPECTOR GENERAL'S OFFICE INVESTIGATION OF ALLEGED DRUG USE. NO VIOLATIONS WERE IDENTIFIED.

INSPECTION JANUARY 19-22 (88-23): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED INSPECTION ONSITE BY MEMBERS OF THE OFFICE OF SPECIAL PROJECTS STAFF IN THE AREA OF EVENT EVALUATION AND LICENSEE EVENT REPORT GENERATION. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. FOUR RECOMMENDED ACTIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION II, CRITERION V, CRITERION XVII, QA TOPICAL REPORT TABLE 17E-1, NUCLEAR QUALITY

 * SEQUOYAH 1

ENFORCEMENT SUMMARY

ASSURANCE MANUAL (NQAM), PART 1, SECTION 2.17, AND NUCLEAR ENGINEERING PROCEDURE 1.2, REV. 1, AS OF OCTOBER 1987. DNE TRAINING AND DOCUMENTATION FAILED TO MEET THE FOLLOWING REQUIREMENTS OF NEP-1.2: (1) THE ASSISTANT CHIEF MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 30 OF 40 REQUIRED TRAINING SUBJECTS. A LEAD MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 35 OF 40 REQUIRED TRAINING SUBJECTS. (2) WATTS BAR SITE-SPECIFIED TRAINING REQUIREMENTS WERE LESS THAN THE TRAINING PROGRAM SPECIFIED BY NEP-1.2. A TYPICAL EXAMPLE CONCERNS A WATTS BAR ASSISTANT PROJECT ENGINEER (APE), WHOSE SITE-SPECIFIED TRAINING REQUIREMENTS DID NOT INCLUDE SEVEN AREAS REQUIRED BY NEP-1.2. (3) THE LICENSEE WAS UNABLE TO CONFIRM THAT REQUIREMENTS OF THE TRAINING MATRIX HAD BEEN ACCOMPLISHED FOR FIVE MECHANICAL ENGINEERING BRANCH (MEB) PERSONNEL AND TWO WATTS BAR APES. SINCE AN ADDITIONAL OPPORTUNITY TO CONFIRM THE ABOVE TRAINING WAS AFFORDED SUBSEQUENT TO THE EXIT INTERVIEW AND THE TRAINING WAS NOT CONFIRMED, THE MRC CONCLUDES THAT THE TRAINING WAS NOT CONDUCTED.

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION XVIII, CRITERION XVI, AND NQAM, PART 1, SECTION 2.18, REV. 0.10 AUDITS FROM 1985 TO JANUARY 1987 IDENTIFIED TRAINING DEFICIENCIES WHICH, AT THE TIME OF THE INSPECTION, HAD NOT BEEN CORRECTED. (8706 4)

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION V, AND NEP 1.3, REV. 0. CORRECTIONS WERE MADE TO NUMEROUS DOCUMENTS IN A MANNER NOT IN CONFORMANCE WITH THE ONE LINE, INITIAL, AND DATE METHOD. (8706 5)

CONTRARY TO TECHNICAL SPECIFICATION (TS) 6.8.1, FROM FEBRUARY TO NOVEMBER, 1987, THE OVERTIME LIMITS SPECIFIED IN A1-50 WERE EXCEEDED ON NUMEROUS OCCASIONS WITHOUT PLANT MANAGER OR PLANT SUPERINTENDENT AUTHORIZATION. IN ADDITION, THE FORM DOCUMENTING DEVIATION FROM PLANT STAFF OVERTIME LIMITS WAS NOT ALWAYS FORWARDED TO THE PLANT MANAGER WITHIN THE REQUIRED TIME PERIOD. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, PRIOR TO DECEMBER 14, 1987, THE LICENSEE FAILED TO PRESCRIBE IN INSTRUCTIONS OR PROCEDURES THE TRAINING AND QUALIFICATION REQUIREMENTS FOR COMPOSITE CREWS. IN THAT COMPOSITE CREWS WERE IMPLEMENTED PRIOR TO HAVING ESTABLISHED TRAINING AND QUALIFICATION REQUIREMENTS FOR FOREMAN SUPERVISING PERSONNEL IN OTHER CRAFTS, AND FOR CRAFTSMEN PERFORMING WORK OUTSIDE OF THEIR CRAFT, AND FOR CRAFTSMEN PERFORMING INDEPENDENT VERIFICATION OUTSIDE OF THEIR CRAFT. (8707 4)

CONTRARY TO TS 6.8.1, REGULATORY GUIDE 1.33, SYSTEM OPERATING INSTRUCTION (SOI)-1.1, MAIN STEAM, ADMINISTRATIVE INSTRUCTION (AI)-25, (PART 1), REV. 23, "DRAWING CONTROL AFTER LICENSING", AND SURVEILLANCE INSTRUCTION (SI)-187, CONTAINMENT INSPECTION (1) ON FEBRUARY 7, 1988, SOI-1.1 WAS NOT COMPLIED WITH DURING STARTUP OF THE UNIT 2 MAIN STEAM SYSTEM IN THAT RCS TAVE WAS NOT BETWEEN 300 DEGREES FAHRENHEIT AND 350 DEGREES FAHRENHEIT PRIOR TO WARMING THE MAIN STEAM LINES AND PLACING MAIN STEAM IN SERVICE. THIS NONCOMPLIANCE CONTRIBUTED TO A HIGH STEAM FLOW INDICATION WHICH RESULTED IN A MSIV ISOLATION, GENERATION OF A REACTOR TRIP SIGNAL, AND A FEEDWATER ISOLATION. (2) DURING RECOVERY FROM THIS EVENT LATER ON FEBRUARY 7, 1988, ONLY THE #4 STEAM GENERATOR MSIV WAS OPENED TO EQUALIZE PRESSURE. THIS NONCOMPLIANCE RESULTED IN A STEAM GENERATOR SHELL CONDITION (3) ON JANUARY 31, 1988, A PORTION OF AN UNIDENTIFIED DRAWING MARKED "INFORMATION ONLY" WAS USED TO PERFORM WORK ON CONTAINMENT SPRAY SYSTEM FLOW INDICATOR 2-FI-72-34. (4) ON FEBRUARY 1, 1988, FOLLOWING THE LICENSEE'S PERFORMANCE OF SI-187, PORTIONS OF THE CONTAINMENT ICE CONDENSER WERE FOUND TO BE INADEQUATE TO SUPPORT PLANT RESTART DUE TO VARIOUS DEBRIS AND FOREIGN MATERIAL BEING PRESENT WITHIN THE ICE CONDENSER. ON FEBRUARY 2, 1988, FOLLOWING CLEANUP OF THE AREA, THE LICENSEE STATED THAT THE CONTAINMENT ICE CONDENSER WAS AGAIN READY TO SUPPORT RESTART, BUT UPON REINSPECTION THE ICE CONDENSER CONDITION WAS STILL FOUND TO BE DEFICIENT. CONTRARY TO TS 6.8.1 AND APPENDIX A OF REGULATORY GUIDE 1.33, REVISION 2, PRIOR TO JANUARY 4, 1988, THE LICENSEE FAILED TO ADEQUATELY ESTABLISH, IMPLEMENT, AND MAINTAIN PROCEDURES FOR CONEIGURATION CONTROL AS FOLLOWS: (1) THE LICENSEE FAILED TO SPECIFY THE MINIMUM QUALIFICATION LEVEL FOR INDIVIDUALS PERFORMING INDEPENDENT VERIFICATION OF SOI CHECKLISTS AS REQUIRED BY AI-57. THIS RESULTED IN A FAILURE TO PERFORM AND DOCUMENT ADEQUATE TRAINING FOR ALL INDIVIDUALS PERFORMING SOI CHECKLIST VERIFICATIONS. (2) THE LICENSEE FAILED TO IMPLEMENT THE REQUIREMENTS IN AI-58 FOR MAINTAINING CONFIGURATION CONTROL AFTER SOI CHECKLIST COMPLETION, IN THAT THE DOCUMENTED POSITIONS IN THE CONFIGURATION CONTROL SYSTEM FOR INSTRUMENT ROOT VALVE 1-268A, AND THE BREAKERS FOR POST ACCIDENT SAMPLING VALVES ON 120 V VITAL INSTRUMENT POWER BOARDS 2-III AND 2-IV (BREAKER 17 ON EACH BOARD) DISAGREED WITH THE ACTUAL POSITIONS. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVI, PRIOR TO JANUARY 4, 1988, THE LICENSEE FAILED TO ADEQUATELY IDENTIFY AND CORRECT SOI CHECKLIST DEFICIENCIES IN THAT NUMEROUS SOI CHECKLISTS WERE FOUND TO HAVE SIGNIFICANT DEFICIENCIES AFTER THE LICENSEE HAD COMPLETED CORRECTIVE ACTION FOR SIMILAR DEFICIENCIES AND HAD

ENFORCEMENT SUMMARY

RESTARTED THE SYSTEM ALIGNMENT PROGRAM USING THOSE CHECKLISTS. AS A RESULT, THE STATUS OF NUMEROUS PIECES OF EQUIPMENT HAD TO BE REVERIFIED TO ENSURE THAT THEIR POSITIONS WERE ADEQUATE FOR MODE CHANGE. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V. PRIOR TO JANUARY 6, 1988, THE LICENSEE FAILED TO ESTABLISH OR IMPLEMENT INSTRUCTIONS, PROCEDURES, OR DRAWINGS THAT WOULD HAVE PREVENTED THE STORAGE OF LOOSE CONDUCTIVE MATERIAL WITHIN SAFETY RELATED ELECTRICAL BOARDS. SPECIFICALLY, LOOSE SPARE FUSES WERE FOUND STORED WITHIN 480 VOLT SAFETY-RELATED DIESEL GENERATOR AUXILIARY BOARD 2A1-A WHICH COULD HAVE RENDERED THE PANEL INOPERABLE DURING A SEISMIC EVENT. SUBSEQUENT ELECTRICAL BOARD INSPECTIONS BY THE LICENSEE IDENTIFIED NUMEROUS ADDITIONAL SIGNIFICANT EXAMPLES OF LOOSE CONDUCTIVE MATERIAL STORAGE WITHIN SAFETY-RELATED ELECTRICAL BOARDS.
(8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

ENVIRONMENTAL QUALIFICATION OF EQUIPMENT.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

MODE 5.

LAST IE SITE INSPECTION DATE: JANUARY 19-22, 1988 +

INSPECTION REPORT NO: 50-327/88-23 +

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---|
| 88-006 | 01/27/88 | 02/25/88 | INSTRUMENT MAINTENANCE TECHNICIAN INADVERTENTLY REMOVED INCORRECT RAD MON MOD WHICH CAUSED CONTAINMENT VENT ISOLATION |
| 88-007 | 01/24/88 | 02/23/88 | OPENING OF U-1 CONTAINMENT RESULTS IN SEC CONTAINMENT ENV OUTSIDE THE BOUNDARY SET FOR SURVEY TESTING OF AUXILIARY BLDG 6TS |
| 88-008 | 01/30/88 | 02/25/88 | PERSONNEL NOT PROPERLY IMPLEMENTING APPROVED ADMIN PROCEDURE RESULTING IN INAPP EXITING A TS ACTION STMT ON RAD MON |
| 88-009 | 02/04/88 | 02/26/88 | INADEQUATE PROCEDURE CAUSED INACCURATE PRIMARY TO SECONDARY LEAK RATES TO BE MEASURED RESULTING IN NONCOM WITH A LCD |
| 88-010 | 02/05/88 | 03/05/88 | INADEQUATE REV OF DESIGN BASIS OF TWO ESF ACTUATED VALVES RESULTED IN POTENTIAL FOR PLANT OPER OUTSIDE THE DESIGN BASIS |
| 88-011 | 02/14/88 | 03/16/88 | INADEQUATE DETERMINATION OF THE EFFECT OF ROUTINE D/G TESTING RESULTED IN BOTH TRAINS OF THE CONTROL RM EMER VENT SYS IMO |
| 88-012 | 03/01/88 | 03/25/88 | ENG SAFETY FEATURE ACTUATION CONTAINMENT VENTILATION ISOLATION CAUSED BY ELECTROMAGNETIC INTERFERENCE |

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-528 OPERATING STATUS
2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: DAVID DUPREE (615) 870-6722
4. Licensed Thermal Power (Mwt): 5411
5. Nameplate Rating (Gross MWe): 1220
6. Design Electrical Rating (Net MWe): 1148
7. Maximum Dependable Capacity (Gross MWe): 1185
8. Maximum Dependable Capacity (Net MWe): 1148
9. If Changes Occur Above Since Last Report, Give Reasons:
 NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____
11. Reasons for Restrictions, If Any: _____
 NONE


| | MONTH | YEAR | CUMULATIVE |
|--|---------|---------|------------|
| 12. Report Period Hrs | 744.0 | 2,184.0 | 51,145.0 |
| 13. Hours Reactor Critical | .0 | .0 | 21,984.5 |
| 14. Rx Reserve Shtdn Hrs | .0 | .0 | .0 |
| 15. Hrs Generator On-Line | .0 | .0 | 21,494.4 |
| 16. Unit Reserve Shtdn Hrs | .0 | .0 | .0 |
| 17. Gross Therm Ener (MWH) | .0 | .0 | 69,127,974 |
| 18. Gross Elec Ener (MWH) | .0 | .0 | 23,536,780 |
| 19. Net Elec Ener (MWH) | -22,004 | -42,598 | 22,465,548 |
| 20. Unit Service Factor | .0 | .0 | 42.0 |
| 21. Unit Avail Factor | .0 | .0 | 42.0 |
| 22. Unit Cap Factor (MDC Net) | .0 | .0 | 38.3 |
| 23. Unit Cap Factor (DER Net) | .0 | .0 | 38.3 |
| 24. Unit Forced Outage Rate | 100.0 | 100.0 | 53.6 |
| 25. Forced Outage Hours | 744.0 | 2,184.0 | 24,827.3 |
| 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE | | | |

27. If Currently Shutdown Estimated Startup Date: 04/01/88

 * SEQUOYAH 2 *

 AVERAGE DAILY POWER LEVEL (MWe) PLOT

SEQUOYAH 2



MARCH 1988

 M SEQUOYAH 2

UNIT SHUTDOWNS / REDUCTIONS

Report Period MAR 1988

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

1 08/21/85 F 744.0 F 4 DESIGN CONTROL, CONFIGURATION UPDATING, AND EMPLOYEE CONCERNS.

 SUMMARY *

SEQUOYAH 2 REMAINED SHUTDOWN IN MARCH BECAUSE OF DESIGN CONTROL, CONFIGURATION UPDATING, AND EMPLOYEE CONCERNS.

| Type | Reason | Method | System & Component |
|----------|---|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training & License Examination | 5-Reduced Load | Licenses Evalut Report |
| | | 9-Other | (LER) File :AUREG-0161) |

F A C I L I T Y D A T A

 * SEQUOYAH 2 *

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION STATE.....TENNESSEE
 COUNTY.....HAMILTON
 DIST AND DIRECTION FROM NEAREST POPULATION CTR...9.5 MI NE OF CHATTANOOGA, TN

UTILITY LICENSE.....TENNESSEE VALLEY AUTHORITY
 CORPORATE ADDRESS.....6 NORTH 38A LOCKOUT PLACE CHATTANOOGA, TENNESSEE 37401
 CONTRACTOR ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY
 NUC STEAM SYS SUPPLIER...WESTINGHOUSE
 CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY
 TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
 IE RESIDENT INSPECTOR.....E. FORD
 LICENSING PROJ MANAGER.....E. MCKENNA
 DOCKET NUMBER.....50-328

LICENSE & DATE ISSUANCE...DPR-79, SEPTEMBER 15, 1981
 PUBLIC DOCUMENT ROOM.....CHATTANOOGA - HAMILTON BICENTENNIAL LIBRARY
 1001 BROAD STREET
 CHATTANOOGA, TENNESSEE 37402

I N S P E C T I O N S T A T I S

INSPECTION SUMMARY

* INSPECTION AUGUST 24-28 - SEPTEMBER 8-11 (87-59): THIS ANNOUNCED TEAM INSPECTION WAS CONDUCTED TO EVALUATE MANAGEMENT EFFECTIVENESS AT THE SEQUOYAH SITE IN THE AREAS OF OPERATIONS, MAINTENANCE, QUALITY ASSURANCE, MODIFICATIONS, ENGINEERING AND LICENSING. CORPORATE INTERFACES WITH SOME SITE DISCIPLINES WERE ALSO EXAMINED. IN ADDITION, CORPORATE PROGRAMS FOR MANAGEMENT IMPROVEMENT WERE EXAMINED. SELECTED COMMITMENTS MADE IN VOLUMES 1 AND 2 OF THE TVA NUCLEAR PERFORMANCE PLANS WERE ALSO MONITORED. THIS INSPECTION FOCUSED ON MANAGEMENT FUNCTIONS AND WAS NOT A TYPICAL NRC INSPECTION DEALING DIRECTLY WITH REGULATORY COMPLIANCE ISSUES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED DURING THIS INSPECTION. ONE ISSUE WAS IDENTIFIED AS A RESTART ITEM. OVERALL, THE RESULTS OF THIS INSPECTION INDICATE THAT THE SEQUOYAH SITE MANAGEMENT PROCESSES ARE SUFFICIENTLY EFFECTIVE TO SUPPORT PLANT RESTART.

INSPECTION OCTOBER 5-18 (87-68): THIS ROUTINE INSPECTION WAS CONDUCTED IN THE AREAS OF ALLEGATIONS AND LICENSEE ACTION ON INSPECTOR IDENTIFIED ITEMS. THREE VIOLATIONS WERE IDENTIFIED INVOLVING DIVISION OF NUCLEAR ENGINEERING (DNE) TRAINING. INEFFECTIVE FOLLOWUP ON AUDIT FINDINGS AND IMPROPER CORRECTIONS TO QUALITY ASSURANCE (QA) RECORDS.

INSPECTION OCTOBER 26-30, 1987 - JANUARY 4-14, 1988 (87-73): THIS SPECIAL ANNOUNCED INSPECTION WAS CONDUCTED TO ASSESS TVA'S READINESS TO SUPPORT SEQUOYAH UNIT 2 ENTRY INTO MODE 4 AND MODE 3. THE AREAS REVIEWED INCLUDED STATUS OF MC94300 ITEMS ASSOCIATED WITH HEATUP, TESTING ACTIVITIES, PLANT HEATUP PROCEDURE, TVA'S OPERATIONAL READINESS ASSESSMENT, COMPENSATORY MEASURES, AND CONTROL OF OPERATIONS. IN AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED THAT INVOLVED THE FAILURE TO PERFORM OR ADEQUATELY PERFORM A WRITTEN SAFETY EVALUATION FOR MODIFICATIONS TO THE FACILITY WHICH INVOLVED COMPENSATORY ACTION FOR DEFEATED SAFETY FUNCTIONS.

ENFORCEMENT SUMMARY

ASSURANCE MANUAL (NQAM), PART 1, SECTION 2.17, AND NUCLEAR ENGINEERING PROCEDURE 1.2, REV. 1, AS OF OCTOBER 1987. DNE TRAINING AND DOCUMENTATION FAILED TO MEET THE FOLLOWING REQUIREMENTS OF NEP-1.2: (1) THE ASSISTANT CHIEF MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 30 OF 40 REQUIRED TRAINING SUBJECTS. A LEAD MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 35 OF 40 REQUIRED TRAINING SUBJECTS. (2) MATTS BAR SITE-SPECIFIED TRAINING REQUIREMENTS WERE LESS THAN THE TRAINING PROGRAM SPECIFIED BY NEP-1.2. A TYPICAL EXAMPLE CONCERNS A MATTS BAR ASSISTANT PROJECT ENGINEER (APE), WHOSE SITE-SPECIFIED TRAINING REQUIREMENTS DID NOT INCLUDE SEVEN AREAS REQUIRED BY NEP-1.2. (3) THE LICENSEE WAS UNABLE TO CONFIRM THAT REQUIREMENTS OF THE TRAINING MATRIX HAD BEEN ACCOMPLISHED FOR FIVE MECHANICAL ENGINEERING BRANCH (MEB) PERSONNEL AND TWO MATTS BAR APES. SINCE AN ADDITIONAL OPPORTUNITY TO CONFIRM THE ABOVE TRAINING WAS AFFORDED SUBSEQUENT TO THE EXIT INTERVIEW AND THE TRAINING WAS NOT CONFIRMED, THE NRC CONCLUDES THAT THE TRAINING WAS NOT CONDUCTED.

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION XVIII, CRITERION XVI, AND NQAM, PART 1, SECTION 2.18, REV. 0, 10 AUDITS FROM 1985 TO JANUARY 1987 IDENTIFIED TRAINING DEFICIENCIES WHICH, AT THE TIME OF THE INSPECTION, HAD NOT BEEN CORRECTED. (18706, 4)

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION V, AND NEP 1.5, REV. 0, CORRECTIONS WERE MADE TO NUMEROUS DOCUMENTS IN A MANNER NOT IN CONFORMANCE WITH THE ONE LINE, INITIAL, AND DATE METHOD. (18706, 5)

CONTRARY TO TECHNICAL SPECIFICATION (TS) 6.8.1, FROM FEBRUARY TO NOVEMBER, 1987, THE OVERTIME LIMITS SPECIFIED IN AI-30 WERE EXCEEDED ON NUMEROUS OCCASIONS WITHOUT PLANT MANAGER OR PLANT SUPERINTENDENT AUTHORIZATION. IN ADDITION, THE FORM DOCUMENTING DEVIATION FROM PLANT STAFF OVERTIME LIMITS WAS NOT ALWAYS FORWARDED TO THE PLANT MANAGER WITHIN THE REQUIRED TIME PERIOD. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, PRIOR TO DECEMBER 14, 1987, THE LICENSEE FAILED TO PRESCRIBE IN INSTRUCTIONS OR PROCEDURES THE TRAINING AND QUALIFICATION REQUIREMENTS FOR COMPOSITE CREWS, IN THAT COMPOSITE CREWS WERE IMPLEMENTED PRIOR TO HAVING ESTABLISHED TRAINING AND QUALIFICATION REQUIREMENTS FOR FOREMEN AND GENERAL FOREMAN SUPERVISING PERSONNEL IN OTHER CRAFTS, FOR CRAFTSMEN PERFORMING WORK OUTSIDE OF THEIR CRAFT, AND FOR CRAFTSMEN PERFORMING INDEPENDENT VERIFICATION OUTSIDE OF THEIR CRAFT. (18707, 4)

CONTRARY TO TS 5.8.1, REGULATORY GUIDE 1.33, SYSTEM OPERATING INSTRUCTION (SOI)-1.1, MAIN STEAM, ADMINISTRATIVE INSTRUCTION (AI)-25, (PART 1), REV. 23, "DRAWING CONTROL AFTER LICENSING", AND SURVEILLANCE INSTRUCTION (SI)-187, CONTAINMENT INSPECTION (CI) ON FEBRUARY 7, 1988, SOI-1.1 WAS NOT COMPLIED WITH DURING STARTUP OF THE UNIT 2 MAIN STEAM SYSTEM IN THAT RCS YAVE WAS NOT BETWEEN 500 DEGREES FAHRENHEIT AND 550 DEGREES FAHRENHEIT PRIOR TO WARMING THE MAIN STEAM LINES AND PLACING MAIN STEAM IN SERVICE. THIS NONCOMPLIANCE CONTRIBUTED TO A HIGH STEAM FLOW INDICATION WHICH RESULTED IN A MSTV ISOLATION, GENERATION OF A REACTOR TRIP SIGNAL, AND A FEEDWATER ISOLATION. (2) DURING RECOVERY FROM THIS EVENT LATER ON FEBRUARY 7, 1988, ONLY THE #4 STEAM GENERATOR MSTV WAS OPENED TO EQUALIZE PRESSURE IN THE MAIN STEAM HEADER. THIS NONCOMPLIANCE RESULTED IN A STEAM GENERATOR SWELL CONDITION AND RESULTANT FEEDWATER ISOLATION. (3) ON JANUARY 31, 1988, A PORTION OF AN UNIDENTIFIED DRAWING MARKED "INFORMATION ONLY" WAS USED TO PERFORM WORK ON CONTAINMENT SPRAY SYSTEM FLOW INDICATOR 2-FI-72-34. (4) ON FEBRUARY 1, 1988, FOLLOWING THE LICENSEE'S PERFORMANCE OF 51-187, PORTIONS OF THE CONTAINMENT ICE CONDENSER WERE FOUND TO BE INADEQUATE TO SUPPORT PLANT RESTART DUE TO WARIOUS DEBRIS AND FOREIGN MATERIAL BEING PRESENT WITHIN THE ICE CONDENSER. ON FEBRUARY 2, 1988, FOLLOWING CLEANUP OF THE AREA, THE LICENSEE STATED THAT THE CONTAINMENT ICE CONDENSER WAS AGAIN READY TO SUPPORT RESTART, BUT UPON REINSPECTION THE ICE CONDENSER CONDITION WAS STILL FOUND TO BE DEFICIENT. CONTRARY TO TS 6.8.1 AND APPENDIX A OF REGULATORY GUIDE 1.33, REVISION 2, PRIOR TO JANUARY 6, 1988, THE LICENSEE FAILED TO ADEQUATELY ESTABLISH, IMPLEMENT, AND MAINTAIN PROCEDURES FOR CONFIGURATION CONTROL AS FOLLOWS: (4) THE LICENSEE FAILED TO SPECIFY THE MINIMUM QUALIFICATION LEVEL FOR INDIVIDUALS PERFORMING INDEPENDENT VERIFICATION OF SOI CHECKLISTS AS REQUIRED BY AI-57. THIS RESULTED IN A FAILURE TO PERFORM AND DOCUMENT ADEQUATE TRAINING FOR ALL INDIVIDUALS PERFORMING SOI CHECKLIST VERIFICATIONS. (2) THE LICENSEE FAILED TO IMPLEMENT THE REQUIREMENTS IN AI-58 FOR MAINTAINING CONFIGURATION CONTROL AFTER SOI CHECKLIST COMPLETION. IN THAT THE DOCUMENTED POSITIONS IN THE CONFIGURATION CONTROL SYSTEM FOR INSTRUMENT ROOT VALVE 1-268A, AND THE BREAKERS FOR POST ACCIDENT SAMPLING VALVES ON 120 V VITAL INSTRUMENT POWER BOY #5 2-111 AND 2-114 (BREAKER 17 ON EACH BOARD) DISAGREED WITH THE ACTUAL POSITIONS. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVI, PRIOR TO JANUARY 4, 1988, THE LICENSEE FAILED TO ADEQUATELY IDENTIFY AND CORRECT SOI CHECKLIST DEFICIENCIES IN THAT NUMEROUS SOI CHECKLISTS WERE FOUND TO HAVE SIGNIFICANT DEFICIENCIES AFTER THE LICENSEE HAD COMPLETED CORRECTIVE ACTION FOR SIMILAR DEFICIENCIES AND HAD

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
 * SEQUOYAH 2 *
 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

R E P O R T S F R O M L I C E N S E E

Report Period MAR 1988

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|--|
| 88-003 | 01/19/88 | 02/25/88 | ICE BUILDUP IN THE FLOW PASSAGE OF THE ICE CONDENSER DUE TO SUBLIMATION WHICH COULD RESULT IN INCREASED CONT. PRESSURE |
| 88-004 | 01/27/86 | 02/18/88 | INADVERTENT START OF ALL EMERGENCY DIESEL GENERATORS DURING SURVEILLANCE TESTING DUE TO DAMAGED LOCKOUT RELAY |
| 88-005 | 02/12/88 | 03/08/88 | LOOSENING OF GLAND SEALS BOLTS ON SPEED INCREASER LUBE OIL PUMPS; POTENTIAL INOPERABILITY OF U-2 CENTERIFUGAL PUMPS |
| 88-006 | 02/07/88 | 03/05/88 | ESF MAIN STEAM LINE ISOLATION AND RX TRIP DUE TO MAINTENANCE ACT. AND INHERENT INSTR RESPONSE DURING STEAM PLANT HEATUP |
| 88-007 | 02/10/88 | 02/08/88 | MAIN STEAM ISOLATION OCCURRED (ESF ACTUATION) DUE TO AN INADEQUATE CALIBRATION PROCEDURE |
| 88-008 | 02/09/88 | 03/08/88 | FAILURE TO INITIATE PERFORMANCE OF A REQ'D SURV INSTRUCTION IN A TIMELY MANNER; TECH SPEC SURV INTERVAL BEING EXCEEDED |
| 88-009 | 02/07/88 | 03/25/88 | ESF MAIN STEAM LINE ISOLATION ACTUATION DURING MAINTENANCE ACTIVITIES DUE TO IMPROPER VERIFICATION OF ACTUATION LOGIC |
| 88-010 | 03/09/88 | 03/25/88 | CCP PLACED IN THE PULL-TO-LOCK POSITION WHILE THE SECOND CCP WAS INOPERABLE RESULTED IN AN INADVERT. ENTRY INTO TS 3.0.3 |

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-498 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 39.1

3. Utility Contact: C.A. AYALA (512) 972-8628

4. Licensed Thermal Power (Mwt): 3817

5. Nameplate Rating (Gross MWe): _____

6. Design Electrical Rating (Net MWe): 1250

7. Maximum Dependable Capacity (Gross MWe): 1250

8. Maximum Dependable Capacity (Net MWe): 1250

9. If Changes Occur Above Since Last Report, Give Reasons: _____

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------------|---------------|---------------|
| 12. Report Period Hrs | <u>39.1</u> | <u>39.1</u> | <u>39.1</u> |
| 13. Hours Reactor Critical | <u>12.3</u> | <u>12.3</u> | <u>12.3</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>.6</u> | <u>.6</u> | <u>.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>3,439</u> | <u>3,439</u> | <u>3,439</u> |
| 18. Gross Elec Ener (MWH) | <u>43</u> | <u>43</u> | <u>43</u> |
| 19. Net Elec Ener (MWH) | <u>-1,371</u> | <u>-1,371</u> | <u>-1,371</u> |
| 20. Unit Service Factor | | | |
| 21. Unit Avail Factor | | NOT IN | |
| 22. Unit Cap Factor (MDC Net) | | COMMERCIAL | |
| 23. Unit Cap Factor (DER Net) | | OPERATION | |
| 24. Unit Forced Outage Rate | | | |
| 25. Forced Outage Hours | <u>38.5</u> | <u>38.5</u> | <u>38.5</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): _____


NONE

27. If Currently Shutdown Estimated Startup Date: 04/03/88

* SOUTH TEXAS 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SOUTH TEXAS 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* SOUTH TEXAS 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 88-01 | 03/30/88 | F | 38.5 | B | 3 | 88-026 | EL | RLY-86 | REACTOR TRIP DUE TO SERIES OF MAIN GENERATOR LOCKOUT AND MAIN TRANSFORMER LOCKOUT RELAYS TRIPPING WHEN A TEST SIGNAL WAS INCORRECTLY INSERTED INTO THE GENERATOR CONTROL CIRCUITS. |

* SUMMARY *

SOUTH TEXAS 1 GENERATED INITIAL ELECTRICITY ON MARCH 30, 1988.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* SOUTH TEXAS 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....TEXAS
COUNTY.....MATAGORDA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI SSW OF
BAY CITY, TEX
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 8, 1988
DATE ELEC ENER 1ST GENER...MARCH 30, 1988
DATE COMMERCIAL OPERATE...*****
CONDENSER COOLING METHOD...CC
CONDENSER COOLING WATER...COLORADO RIVER
ELECTRIC RELIABILITY
COUNCIL.....ELECTRIC RELIABILITY
COUNCIL OF TEXAS

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....HOUSTON LIGHTING & POWER COMPANY
CORPORATE ADDRESS.....P.O. BOX 1700
HOUSTON, TEXAS 77001
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....C. JOHNSON
LICENSING PROJ MANAGER.....N. KADAMBI
DOCKET NUMBER.....50-498
LICENSE & DATE ISSUANCE...NPF-76, MARCH 22, 1988
PUBLIC DOCUMENT ROOM.....GLEN ROSE-SOMERVELL LIBRARY
BERNARD AND HIGHWAY 144
P.O. BOX 417
GLEN ROSE, TX. 76043

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:


INFO. NOT SUPPLIED BY REGION

 * ST LUCIE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ST LUCIE 1

1. Docket: 50-335 OPERATING STATUS
2. Reporting Period: 05/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: N. W. GRANT (305) 694-4432
4. Licensed Thermal Power (MWT): 2700
5. Nameplate Rating (Gross MWe): 1000 X 0.89 = 890
6. Design Electrical Rating (Net MWe): 830
7. Maximum Dependable Capacity (Gross MWe): 872
8. Maximum Dependable Capacity (Net MWe): 839
9. If Changes Occur Above Since Last Report, Give Reasons:
NONE
10. Power Level To Which Restricted, If Any (Net MWe): _____
11. Reasons for Restrictions, If Any: _____
NONE



| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>98,856.0</u> |
| 13. Hours Reactor Critical | <u>723.1</u> | <u>2,163.1</u> | <u>74,714.9</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>205.3</u> |
| 15. Hrs Generator On-Line | <u>717.0</u> | <u>2,157.0</u> | <u>73,127.5</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>39.5</u> |
| 17. Gross Therm Ener (MWH) | <u>1,903,649</u> | <u>5,787,912</u> | <u>187,133,549</u> |
| 18. Gross Elec Ener (MWH) | <u>640,430</u> | <u>1,949,430</u> | <u>61,473,015</u> |
| 19. Net Elec Ener (MWH) | <u>607,535</u> | <u>1,851,795</u> | <u>58,043,384</u> |
| 20. Unit Service Factor | <u>96.4</u> | <u>98.8</u> | <u>74.0</u> |
| 21. Unit Avail Factor | <u>96.4</u> | <u>98.8</u> | <u>74.0</u> |
| 22. Unit Cap Factor (MDC Net) | <u>97.3</u> | <u>101.1</u> | <u>70.0</u> |
| 23. Unit Cap Factor (DER Net) | <u>98.4</u> | <u>102.2</u> | <u>70.7</u> |
| 24. Unit Forced Outage Rate | <u>3.6</u> | <u>1.2</u> | <u>3.9</u> |
| 25. Forced Outage Hours | <u>27.0</u> | <u>27.0</u> | <u>2,967.9</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE
27. If Currently Shutdown Estimated Startup Date: N/A

MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * ST LUCIE 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 01 | 03/28/88 | F | 27.0 | A | 1 | | CH | VALVEX | MANUAL CONTROL OF THE FEEDWATER REGULATING VALVES WAS TAKEN WHEN CONTROL ROOM PERSONNEL NOTED INCREASING STEAM GENERATOR LEVEL ON A STEAM GENERATOR. THIS MANUAL CONTROL RESULTED IN A DECREASING LEVEL AND PERSONNEL WERE UNABLE TO RECOVER LEVEL PRIOR TO A REACTOR TRIP ON LOW STEAM GENERATOR LEVEL. THE PROBLEM WAS RESOLVED AND THE UNIT RETURNED TO FULL POWER OPERATION. |

***** ST. LUCIE 1 INCURRED 1 FORCED OUTAGE IN MARCH FOR
 * SUMMARY * REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & license Examination | 9-Other | (LER) File (NUREG-0161) |

* ST LUCIE 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA
COUNTY.....ST LUCIE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI SE OF
FT. PIERCE, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 22, 1976
DATE ELEC ENER 1ST GENER...MAY 7, 1976
DATE COMMERCIAL OPERATE...DECEMBER 21, 1976
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...ATLANTIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 529100
MIAMI, FLORIDA 33152
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....R. CRENJAK
LICENSING PROJ MANAGER.....E. TOURIGNY
DOCKET NUMBER.....50-335
LICENSE & DATE ISSUANCE...DPR-67, MARCH 1, 1976
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY
3209 VIRGINIA AVENUE
FT. PIERCE, FLORIDA 33450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JANUARY 3 - FEBRUARY 6 (88-01): THIS INSPECTION INVOLVED ON SITE ACTIVITIES IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES, AND SURVEILLANCE ACTIVITIES. OF THE AREAS INSPECTION, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 7 - MARCH 5 (88-03): THIS INSPECTION INVOLVED ON SITE ACTIVITIES IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES AND SURVEILLANCE ACTIVITIES. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MARCH 7-11 (88-05): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF FIRE PROTECTION/ PREVENTION. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY:

None

OTHER ITEMS:

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: MARCH 7-11, 1988 +

INSPECTION REPORT NO: 50-335/88-05 +

R E P O R T S F R O M L I C E N S E E

```

=====
NUMBER      DATE OF      DATE OF      SUBJECT
            EVENT        REPORT
-----
88-001      02/05/88    03/07/88    INADVERTENT START OF 1C HIGH PRESSURE SAFETY INJECTION PUMP DUE TO ELECTRICAL TRANSIENT
88-002      02/10/88    03/11/88    TOTAL BYPASS LEAKAGE ON CONTAINMENT RAD MON ISOLATION VALVE EXCEEDED TECH SPEC LIMIT DUE TO STEAM CORROSION
=====

```

1. Docket: 50-389 OPERATING STATUS
2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: N. W. GRANT (305) 694-4432
4. Licensed Thermal Power (Mht): 2700
5. Nameplate Rating (Gross MWe): 850
6. Design Electrical Rating (Net MWe): 830
7. Maximum Dependable Capacity (Gross MWe): 882
8. Maximum Dependable Capacity (Net MWe): 839
9. If Changes Occur Above Since Last Report, Give Reasons:
 NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
 NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|-----------|-----------|------------|
| 12. Report Period Hrs | 744.0 | 2,184.0 | 40,753.0 |
| 13. Hours Reactor Critical | 744.0 | 2,184.0 | 34,941.9 |
| 14. Rx Reserve Shtdwn Hrs | .0 | .0 | .0 |
| 15. Hrs Generator On-Line | 744.0 | 2,184.0 | 34,221.4 |
| 16. Unit Reserve Shtdwn Hrs | .0 | .0 | .0 |
| 17. Gross Therm Ener (MWH) | 2,005,459 | 5,887,264 | 88,883,906 |
| 18. Gross Elec Ener (MWH) | 675,480 | 1,985,020 | 29,683,680 |
| 19. Net Elec Ener (MWH) | 641,508 | 1,885,687 | 28,053,475 |
| 20. Unit Service Factor | 100.0 | 100.0 | 84.0 |
| 21. Unit Avail Factor | 100.0 | 100.0 | 84.0 |
| 22. Unit Cap Factor (MDC Net) | 102.8 | 102.9 | 82.0 |
| 23. Unit Cap Factor (DER Net) | 103.9 | 104.0 | 82.9 |
| 24. Unit Forced Outage Rate | .0 | .0 | 6.8 |
| 25. Forced Outage Hours | .0 | .0 | 2,511.7 |

26. Shutdowns Scheduled Over Next 6 Months (Type, Date, Duration):
 NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * ST LUCIE 2 *

 AVERAGE DAILY POWER LEVEL (MWe) PLOT
 ST LUCIE 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* ST LUCIE 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|------|------|-------|--------|--------|------------|--------|-----------|---|
|-----|------|------|-------|--------|--------|------------|--------|-----------|---|

NONE

* SUMMARY *

ST. LUCIE 2 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES
OR SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* ST LUCIE 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA
COUNTY.....ST LUCIE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI SE OF
FT. PIERCE, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 2, 1983
DATE ELEC ENER 1ST GENER...JUNE 13, 1983
DATE COMMERCIAL OPERATE...AUGUST 8, 1983
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...ATLANTIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER ST., P.O. BOX 529100
MIAMI, FLORIDA 33152
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....R. CRLENJAK
LICENSING PROJ MANAGER.....E. TOURIGNY
DOCKET NUMBER.....50-389
LICENSE & DATE ISSUANCE...NPF-16, JUNE 10, 1983
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY
3209 VIRGINIA AVENUE
FT. PIERCE, FLORIDA 33450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JANUARY 3 - FEBRUARY 6 (88-01): THIS INSPECTION INVOLVED ON SITE ACTIVITIES IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES, AND SURVEILLANCE ACTIVITIES. OF THE AREAS INSPECTION, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 7 - MARCH 5 (88-03): THIS INSPECTION INVOLVED ON SITE ACTIVITIES IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES,, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES AND SURVEILLANCE ACTIVITIES. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MARCH 7-11 (88-05): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF FIRE PROTECTION/ PREVENTION. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

* ST LUCIE 2 *

INSPECTION STATUS - (CONTINUED)

Report Period MAR 1988

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: MARCH 7-11, 1988 +

INSPECTION REPORT NO: 50-389/88-05 +

REPORTS FROM LICENSEE

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|---------|
|--------|---------------|----------------|---------|

| | | | |
|--------|----------|----------|---|
| 88-001 | 02/01/88 | 03/01/88 | SAFETY INJECTION TANKS SIMULTANEOUSLY OUT OF SERVICE DUE TO UNRELATED VALVE RESEATING PROBLEMS |
| 88-002 | 02/18/88 | 03/19/88 | REACTOR CONTAINMENT BLDG POLAR POWER SUPPLY BREAKER FOUND IN ITS REQ TAGGED OPEN POSITION BUT NOT LOCKED; PERSONNEL ERROR |

=====

1. Docket: 50-395 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. H. HALLINGER (803) 345-5209

4. Licensed Thermal Power (Mwt): 2775

5. Nameplate Rating (Gross MWe): 900

6. Design Electrical Rating (Net MWe): 900

7. Maximum Dependable Capacity (Gross MWe): 900

8. Maximum Dependable Capacity (Net MWe): 885

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|-----------|-----------|------------|
| 12. Report Period Hrs | 744.0 | 2,184.0 | 37,248.0 |
| 13. Hours Reactor Critical | 744.0 | 2,149.1 | 28,818.0 |
| 14. Kx Reserve Shtdwn Hrs | .0 | .0 | .0 |
| 15. Hrs Generator On-Line | 744.0 | 2,140.9 | 28,269.0 |
| 16. Unit Reserve Shtdwn Hrs | .0 | .0 | .0 |
| 17. Gross Therm Ener (MWH) | 2,063,020 | 5,907,481 | 74,691,161 |
| 18. Gross Elec Ener (MWH) | 689,820 | 1,975,120 | 24,804,533 |
| 19. Net Elec Ener (MWH) | 662,255 | 1,894,213 | 23,633,796 |
| 20. Unit Service Factor | 100.0 | 98.0 | 75.9 |
| 21. Unit Avail Factor | 100.0 | 98.0 | 75.9 |
| 22. Unit Cap Factor (MDC Net) | 100.6 | 98.0 | 71.7 |
| 23. Unit Cap Factor (DER Net) | 98.9 | 96.4 | 70.5 |
| 24. Unit Forced Outage Rate | .0 | 2.0 | 6.2 |
| 25. Forced Outage Hours | .0 | 43.1 | 1,866.2 |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING OUTAGE-9/16/88, 85 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

 * SUMMER 1 *

 AVERAGE DAILY POWER LEVEL (MWe) PLOT
 SUMMER 1



MARCH 1988

 * SUMMER 1 *

UNIT SHUTDOWNS / REDUCTIONS

Report Period MAR 1988

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

SUMMER 1 OPERATED ROUTINELY IN MARCH WITH NO OUTAGES OR SIGNIFICANT POWER REDUCTIONS.

 * SUMMARY *

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* SUMMER 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....FAIRFIELD
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...26 MI NW OF
COLUMBIA, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 22, 1982
DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982
DATE COMMERCIAL OPERATE...JANUARY 1, 1984
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MONTICELLO RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SOUTH CAROLINA ELECTRIC & GAS CO.
CORPORATE ADDRESS.....P.O. BOX 764
COLUMBIA, SOUTH CAROLINA 29202
CONTRACTOR
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DANIEL INTERNATIONAL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....R. PREVATTE
LICENSING PROJ MANAGER.....J. HAYES
DOCKET NUMBER.....50-395
LICENSE & DATE ISSUANCE...NPF-12, NOVEMBER 12, 1982
PUBLIC DOCUMENT ROOM.....FAIRFIELD COUNTY LIBRARY
GARDEN & WASHINGTON STREETS
WINNSBORO, SOUTH CAROLINA 29180

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 1-5 (88-04): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF THE SEISMIC MONITORING PROGRAM AND THE FIRE PROTECTION/PREVENTION PROGRAM. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

INSPECTION FEBRUARY 1-29 (88-05): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED BY THE RESIDENT INSPECTORS ONSITE, IN THE AREAS OF MONTHLY SURVEILLANCE OBSERVATIONS, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY FEATURES SYSTEM WALKDOWN, RADIOLOGICAL PROTECTION, PHYSICAL SECURITY, AND ONSITE FOLLOWUP OF EVENTS AND SUBSEQUENT WRITTEN REPORTS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 29 - MARCH 4 (88-07): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF REVIEW OF POST-REFUELING STARTUP TESTS, AND REVIEW OF LOCAL LEAK RATE TESTING. ONE VIOLATION WAS IDENTIFIED: FAILURE TO PROPERLY IMPLEMENT PROCEDURES.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

XX
* SUMMER 1 *
XX

Report Period MAR 1988 INSPECTION STATUS - (CONTINUED)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: FEBRUARY 29 - MARCH 4, 1988 +

INSPECTION REPORT NO: 50-395/88-07 +

===== R E P O R T S F R O M L I C E N S E E =====

NUMBER DATE OF DATE OF SUBJECT
EVENT REPORT REPORT

88-001 02/04/88 03/01/88 THREE VIDEO CAMERAS: LOST VARIOUS SECURITY DOORS FAILED UNLOCKED DUE TO SYSTEM VOLTAGE
88-002 02/16/88 03/11/88 REACTOR TRIP DURING SURVEILLANCE TESTING WITH H-42 INOPERABLE
88-003 02/01/88 03/08/88 LEVEL INDICATION ERRORS CAUSED BY CONDENSATION IN SENSING LINES

1. Docket: 50-280 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: L. A. WARREN (804) 357-3184

4. Licensed Thermal Power (MWT): 2441

5. Nameplate Rating (Gross MWe): 942 X 0.9 = 848

6. Design Electrical Rating (Net MWe): 788

7. Maximum Dependable Capacity (Gross MWe): 820

8. Maximum Dependable Capacity (Net MWe): 781

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>133,896.0</u> |
| 13. Hours Reactor Critical | <u>695.5</u> | <u>2,119.0</u> | <u>86,858.6</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>3,774.5</u> |
| 15. Hrs Generator On-Line | <u>688.8</u> | <u>2,104.8</u> | <u>85,075.6</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>3,736.2</u> |
| 17. Gross Therm Ener (MWH) | <u>1,535,816</u> | <u>4,953,560</u> | <u>197,180,826</u> |
| 18. Gross Elec Ener (MWH) | <u>516,735</u> | <u>1,674,430</u> | <u>64,049,603</u> |
| 19. Net Elec Ener (MWH) | <u>490,151</u> | <u>1,592,556</u> | <u>60,744,718</u> |
| 20. Unit Service Factor | <u>92.6</u> | <u>96.4</u> | <u>63.5</u> |
| 21. Unit Avail Factor | <u>92.6</u> | <u>96.4</u> | <u>66.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>84.4</u> | <u>93.4</u> | <u>58.1</u> |
| 23. Unit Cap Factor (DER Net) | <u>83.6</u> | <u>92.5</u> | <u>57.6</u> |
| 24. Unit Forced Outage Rate | <u>7.4</u> | <u>3.6</u> | <u>17.6</u> |
| 25. Forced Outage Hours | <u>55.2</u> | <u>79.2</u> | <u>14,499.5</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING - 4/8/88 - 62 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

* S U R R Y 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SURRY 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* SURRY 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 88-04 | 03/10/88 | F | 55.2 | A | 1 | 88-008 | | | PLANT WAS SHUTDOWN DUE TO AN INOPERABLE 1-SI-P-1B. PUMP MOTOR WAS REPLACED AND PUMP WAS RETURNED TO SERVICE. |

* SUMMARY *

SURRY 1 INCURRED 1 POWER OUTAGE IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* SURRY 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA
COUNTY.....SURRY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI NW OF
NEWPORT NEWS, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 1, 1972
DATE ELEC ENER 1ST GENER...JULY 4, 1972
DATE COMMERCIAL OPERATE...DECEMBER 22, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...JAMES RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. BURKE
LICENSING PROJ MANAGER.....C. PATEL
DOCKET NUMBER.....50-280
LICENSE & DATE ISSUANCE...DPR-32, MAY 25, 1972
PUBLIC DOCUMENT ROOM.....SWEM LIBRARY
COLLEGE OF WILLIAM AND MARY
WILLIAMSBURG, VIRGINIA 23185

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 1-5 (88-02): THIS SPECIAL, ANNOUNCED INSPECTION WAS CONDUCTED IN ACCORDANCE WITH TI 2515/83, "BALANCE OF PLANT TRIAL INSPECTION PROGRAM (FEEDWATER SYSTEM)" TO ASSESS THE LICENSEE'S PRACTICES CONCERNING BALANCE OF PLANT IN PROGRAMMATIC AREAS OF OPERATIONS AND TRAINING, MAINTENANCE, DESIGN CONTROL AND MODIFICATIONS, AND MANAGEMENT SUPPORT AND QUALITY ASSURANCE. OUTSTANDING OPEN ITEMS WERE ALSO INSPECTED. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

INSPECTION FEBRUARY 1-27 (88-04): THIS ROUTINE INSPECTION WAS CONDUCTED IN THE AREAS OF PLANT OPERATIONS, PLANT MAINTENANCE, PLANT SURVEILLANCE, FOLLOWUP ON INSPECTOR IDENTIFIED ITEMS, AND LICENSEE EVENT REPORT REVIEW. ONE VIOLATION WAS IDENTIFIED FOR FAILURE TO MAINTAIN AND VERIFY OPERABILITY OF HEAT TRACE CIRCUITRY FOR BORTIC ACID FLOW PATH AS REQUIRED BY THE TECHNICAL SPECIFICATIONS. THIS VIOLATION IS BEING CONSIDERED FOR ESCALATED ENFORCEMENT ACTION AND WILL BE FORWARDED UNDER SEPARATE COVER.

INSPECTION FEBRUARY 16-19 (88-06): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF PLANT CHEMISTRY. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 22-26 (88-07): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF FIRE PROTECTION/PREVENTION AND FOLLOW-UP ON PREVIOUSLY IDENTIFIED INSPECTION ITEMS. ONE VIOLATION WAS IDENTIFIED: USE OF FIRE PROTECTION EQUIPMENT FOR NON-FIRE PROTECTION ACTIVITIES.


```

=====
NUMBER   DATE OF   DATE OF   SUBJECT
EVENT    REPORT
-----
88-001   01/31/88  03/01/88  CONTAINMENT ISOLATION VALVE NOT PROPERLY LOCKED UNDER ADMINISTRATIVE CONTROL DUE TO HUMAN ERROR
88-002   02/06/88  02/29/88  INOPERABLE INDIVIDUAL ROD POSITION INDICATORS DUE TO INSTRUMENT DRIFT
88-003   02/16/88  03/17/88  REACTOR TRIP DUE TO PERSONNEL FAILING TO FOLLOW PROCEDURE
88-004   02/16/88  03/04/88  IODINE SPIKE DUE TO DEFECTIVE FUEL ELEMENT
88-005   02/19/88  03/18/88  INOPERABLE HEAT TRACING DUE TO INADEQUATE PROCEDURES
88-006   02/19/88  03/09/88  INDIVIDUAL ROD POSITION INDICATORS INOPERABLE DUE TO INSTRUMENT DRIFT
88-007   02/24/88  03/17/88  CONTROL/RELAY ROOM CHILLERS INOPERABLE DUE TO INADEQUATE SERVICE WATER FLOW
=====
  
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-281 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: L. A. WARREN (804) 357-3184

4. Licensed Thermal Power (MWh): 2441

5. Nameplate Rating (Gross MWe): 942 X 0.9 = 848

6. Design Electrical Rating (Net MWe): 788

7. Maximum Dependable Capacity (Gross MWe): 820

8. Maximum Dependable Capacity (Net MWe): 781

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>130,776.0</u> |
| 13. Hours Reactor Critical | <u>640.4</u> | <u>2,080.4</u> | <u>86,749.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>23.8</u> |
| 15. Hrs Generator On-Line | <u>640.4</u> | <u>2,080.4</u> | <u>85,378.7</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,552,907</u> | <u>5,037,815</u> | <u>200,208,164</u> |
| 18. Gross Elec Ener (MWH) | <u>515,810</u> | <u>1,679,650</u> | <u>65,047,474</u> |
| 19. Net Elec Ener (MWH) | <u>490,865</u> | <u>1,598,681</u> | <u>61,677,462</u> |
| 20. Unit Service Factor | <u>86.1</u> | <u>95.3</u> | <u>65.3</u> |
| 21. Unit Avail Factor | <u>86.1</u> | <u>95.3</u> | <u>65.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>84.5</u> | <u>93.7</u> | <u>60.4</u> |
| 23. Unit Cap Factor (DER Net) | <u>83.7</u> | <u>92.9</u> | <u>59.9</u> |
| 24. Unit Forced Outage Rate | <u>13.9</u> | <u>4.7</u> | <u>13.8</u> |
| 25. Forced Outage Hours | <u>103.6</u> | <u>103.6</u> | <u>10,962.7</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING - 9/3/88 - 48 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

* S U R R Y 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SURRY 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * SURRY 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|------------------|--|
| 88-03 | 03/20/88 | S | 0.0 | B | 5 | | | UNIT WAS REDUCED TO 73% POWER, 600 MW'S TO ALLOW TESTING OF TURBINE VALVES (PT-29.1). |
| 88-04 | 03/25/88 | S | 0.0 | B | 5 | | | UNIT WAS REDUCED TO 72% POWER, 600 MW'S TO ALLOW TESTING OF TURBINE VALVES (PT-29.1). |
| 88-05 | 03/27/88 | F | 103.6 | A | 2 | 88-004 | | REACTOR WAS MANUALLY TRIPPED DUE TO A LOSS OF VITAL BUS 2-III INVERTER WHICH REQUIRES SECURING "A" RCP. VITAL BUS 2-III INVERTER WAS REPAIRED AND WILL BE REPLACED WITH A NEW UPS SYSTEM DURING THE NEXT REFUELING OUTAGE. |

 * SUMMARY *

 SURRY 2 INCURRED 1 OUTAGE AND 2 POWER REDUCTIONS IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* SURRY 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA
COUNTY.....SURRY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI NW OF
NEWPORT NEWS, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 7, 1973
DATE ELEC ENER 1ST GENER...MARCH 10, 1973
DATE COMMERCIAL OPERATE...MAY 1, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...JAMES RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. BURKE
LICENSING PROJ MANAGER.....C. PATEL
DOCKET NUMBER.....50-281
LICENSE & DATE ISSUANCE...DPR-37, JANUARY 29, 1973
PUBLIC DOCUMENT ROOM.....SWEM LIBRARY
COLLEGE OF WILLIAM AND MARY
WILLIAMSBURG, VIRGINIA 23185

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

* INSPECTION FEBRUARY 1-5 (88-02): THIS SPECIAL, ANNOUNCED INSPECTION WAS CONDUCTED IN ACCORDANCE WITH TI 2515/83, "BALANCE OF PLANT TRIAL INSPECTION PROGRAM (FEEDWATER SYSTEM)" TO ASSESS THE LICENSEE'S PRACTICES CONCERNING BALANCE OF PLANT IN PROGRAMMATIC AREAS OF OPERATIONS AND TRAINING, MAINTENANCE, DESIGN CONTROL AND MODIFICATIONS, AND MANAGEMENT SUPPORT AND QUALITY ASSURANCE. OUTSTANDING OPEN ITEMS WERE ALSO INSPECTED. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

INSPECTION FEBRUARY 1-27 (88-04): THIS ROUTINE INSPECTION WAS CONDUCTED IN THE AREAS OF PLANT OPERATIONS, PLANT MAINTENANCE, PLANT SURVEILLANCE, FOLLOWUP ON INSPECTOR IDENTIFIED ITEMS, AND LICENSEE EVENT REPORT REVIEW. ONE VIOLATION WAS IDENTIFIED FOR FAILURE TO MAINTAIN AND VERIFY OPERABILITY OF HEAT TRACE CIRCUITRY FOR BORIC ACID FLOW PATH AS REQUIRED BY THE TECHNICAL SPECIFICATIONS. THIS VIOLATION IS BEING CONSIDERED FOR ESCALATED ENFORCEMENT ACTION AND WILL BE FORWARDED UNDER SEPARATE COVER.

INSPECTION FEBRUARY 16-19 (88-06): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF PLANT CHEMISTRY. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 22-26 (88-07): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF FIRE PROTECTION/PREVENTION AND FOLLOW-UP ON PREVIOUSLY IDENTIFIED INSPECTION ITEMS. ONE VIOLATION WAS IDENTIFIED: USE OF FIRE PROTECTION EQUIPMENT FOR NON-FIRE PROTECTION ACTIVITIES.

ENFORCEMENT SUMMARY

CONTRARY TO TECHNICAL SPECIFICATION 6.4, DETAILED WRITTEN PROCEDURES WERE NOT FOLLOWED BY EITHER COMPLYING WITH THE STEPS OR IMPLEMENTING A CHANGE PRIOR TO PROCEEDING. THIS RESULTED IN THE FAILURE TO PROPERLY ESTABLISH THE INITIAL CONDITIONS LISTED BELOW: (1) ON JANUARY 9, 1988, TEST PROCEDURE 1-PT-29.1, "TURBINE INLET VALVE TEST", WAS PERFORMED WITHOUT MEETING INITIAL CONDITION 3.5 OF THE TEST, WHICH REQUIRES THE ROD CONTROL SYSTEM TO BE IN THE AUTOMATIC CONTROL MODE. THE TEST WAS PERFORMED WITH THE ROD CONTROL SYSTEM IN THE MANUAL MODE. (2) ON JANUARY 9 AND 23, 1988, UNIT 1 AND UNIT 2 RESPECTIVELY, WERE RAMPED DOWN FROM 100% TO LESS THAN 75% POWER IN ACCORDANCE WITH OPERATIONS PROCEDURE OP-2.1.2, "DECREASING POWER FROM EXISTING POWER LEVEL TO 2%", WITHOUT MEETING INITIAL CONDITION 3.4 OF THE PROCEDURE, WHICH REQUIRED THE PORTABLE NARROW RANGE STEAM GENERATOR LEVEL INDICATORS TO BE IN PLACE AND OPERATING. (3) ON JANUARY 9, 1988, UNIT 1 WAS RAMPED DOWN FROM 100% TO LESS THAN 75% POWER IN ACCORDANCE WITH OPERATIONS PROCEDURE OP-2.1.2, "DECREASING POWER FROM EXISTING POWER LEVEL TO 2%", WITHOUT PERFORMING STEPS 3.7.1 THROUGH 3.7.4 OF THE PROCEDURE, WHICH REQUIRED THAT JUMPERS BE INSTALLED TO REMOVE THE SEAL-IN FUNCTION FROM CONTROLLERS OF MOISTURE SEPARATOR REHEATER STEAM SUPPLY ISOLATION VALVES. CONTRARY TO TS 6.4J, ON FEBRUARY 23, 1988, FIRE PROTECTION EQUIPMENT REQUIRED TO BE MAINTAINED IN SITE FIRE HOSE HOUSES WAS REMOVED AND USED FOR NON-FIRE PROTECTION PURPOSES WITHOUT THE WRITTEN PERMISSION OF THE LOSS PREVENTION COORDINATOR. REVIEW OF TWELVE SURVEILLANCES OF HOSE HOUSES PERFORMED BY THE LICENSE IN 1987 AND 1988 IDENTIFIED TEN ADDITIONAL CASES WHERE EQUIPMENT HAD BEEN REMOVED WITHOUT WRITTEN PERMISSION OF THE LOSS PREVENTION COORDINATOR.

(8800 4)

CONTRARY TO 10 CFR 50 APPENDIX B, CRITERION V AS IMPLEMENTED BY THE LICENSEE'S ACCEPTED QUALITY ASSURANCE PROGRAM (VIRGINIA POWER TOPICAL REPORT VEP-1-5A, SECTION 17.2.5), AS OF JANUARY 3, 1988, MEASURES FOR THE SELECTION AND REVIEW FOR SUITABILITY OF APPLICATION OF MATERIALS, PARTS, AND EQUIPMENT THAT ARE ESSENTIAL TO THE SAFETY-RELATED FUNCTIONS OF COMPONENTS WERE NOT ADEQUATELY PRESCRIBED BY PROCEDURES. THIS CONDITION CONTRIBUTED TO THE FAILURE MECHANISM, WHICH WAS IDENTIFIED IN DECEMBER, 1987, OF SAFETY-RELATED VALVE 2-CH-MOV-2289B.

(8800 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION. +

LAST IE SITE INSPECTION DATE: FEBRUARY 22-26, 1988 +

INSPECTION REPORT NO: 50-281/88-07 +

Report Period MAR 1988

REPORTS FROM LICENSEE

* SURRY 2 *

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|--|
| 88-001 | 01/27/88 | 02/26/88 | IMPROPER ADMINISTRATIVE CONTROL OF CONTAINMENT ISOLATION VALVES DUE TO PERSONNEL ERROR |
| 88-002 | 02/02/88 | 03/03/88 | INOPERABLE CONTAINMENT ISOLATION VALVES DUE TO EXCESSIVE LEAKAGE |
| 88-003 | 02/20/88 | 03/04/88 | INDIVIDUAL ROD POSITION INDICATORS INOPERABLE DUE TO INSTRUMENT DRIFT |
| 88-005 | 03/05/88 | 03/30/88 | INOPERABLE CONTROL RODS DUE TO FAILED PHASE CONTROL CARD |

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-387 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. HIRT (717) 542-3917

4. Licensed Thermal Power (MWT): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1068

8. Maximum Dependable Capacity (Net MWe): 1032

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>42,217.0</u> |
| 13. Hours Reactor Critical | <u>469.0</u> | <u>1,909.0</u> | <u>30,563.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>773.2</u> |
| 15. Hrs Generator On-Line | <u>425.4</u> | <u>1,865.4</u> | <u>29,814.2</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,284,559</u> | <u>5,898,026</u> | <u>91,944,451</u> |
| 18. Gross Elec Ener (MWH) | <u>422,628</u> | <u>1,949,392</u> | <u>29,959,991</u> |
| 19. Net Elec Ener (MWH) | <u>407,597</u> | <u>1,879,159</u> | <u>28,726,555</u> |
| 20. Unit Service Factor | <u>57.2</u> | <u>85.4</u> | <u>70.6</u> |
| 21. Unit Avail Factor | <u>57.2</u> | <u>85.4</u> | <u>70.6</u> |
| 22. Unit Cap Factor (MDC Net) | <u>53.1</u> | <u>83.4</u> | <u>65.9</u> |
| 23. Unit Cap Factor (DER Net) | <u>51.4</u> | <u>80.8</u> | <u>63.9</u> |
| 24. Unit Forced Outage Rate | <u>25.9</u> | <u>7.4</u> | <u>10.7</u> |
| 25. Forced Outage Hours | <u>149.0</u> | <u>149.0</u> | <u>3,565.6</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

XXXXXXXXXXXXXXXXXXXXXXXXXXXX
 X SUSQUEHANNA 1 X
 XXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUSQUEHANNA 1



MARCH 1988

 * SUSQUEHANNA 1 *

UNIT SHUTDOWNS / REDUCTIONS

Report Period MAR 1988

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 2 | 03/04/88 | F | 149.0 | G | 3 | 88-006-00 | JC | ZZZZZZ | ON MARCH 4, 1988, AN OPERATOR BUMPED AGAINST THE SPAN PROTECTION AUXILIARY RELAY IN THE 230 KV SWITCHYARD. THIS CAUSED A GENERATOR LOAD REJECT AND A SUBSEQUENT REACTOR SCRAM. NO EMERGENCY CORE COOLING SYSTEMS ACTIVATED AND NONE WERE REQUIRED. JC OPERATOR ACTIONS WERE REQUIRED TO PLACE THE UNIT IN A STABLE CONDITION. THE SUBJECT RELAY, WHICH PROTRUDED ABOUT SIX INCHES OUT OF THE FRONT OF THE RELAY PANEL, WAS REPLACED WITH A FLUSH MOUNTED RELAY. IN ADDITION, PROTECTIVE BARRIERS HAVE BEEN INSTALLED ABOVE AND BELOW THE SUBJECT RELAY TO PROTECT AGAINST BUMPING. THE UNIT RETURNED TO SERVICE ON MARCH 10, 1988, AT 1705 HOURS. |

| | | | | | | | | | |
|---|----------|---|-------|---|---|--|----|------|---|
| 3 | 03/17/88 | S | 169.6 | B | 1 | | AD | SEAL | ON MARCH 16, 1988, AT APPROXIMATELY 1900 HOURS, OPERATIONS PERSONNEL BEGAN REDUCING REACTOR POWER IN PREPARATION FOR A PLANNED MAINTENANCE OUTAGE. PLANT OPERATORS MANUALLY INSERTED THE CONTROL RODS AND AT 0025 HOURS, ON MARCH 17, 1988, THEY REMOVED THE TURBINE/GENERATOR FROM SERVICE. APPROXIMATELY ONE HOUR LATER THE REACTOR MODE SWITCH WAS PLACED IN THE 'START-UP' POSITION. THE SHUTDOWN WAS COMPLETED AT 0425 HOURS ON MARCH 17, 1988. THE MAJOR WORK ITEM FOR THE OUTAGE WAS THE REPAIR OF A LEAKING REACTOR RECIRCULATION PUMP SEAL. THE UNIT WAS RETURNED TO SERVICE ON MARCH 24, 1988, AT 0254 HOURS. |
|---|----------|---|-------|---|---|--|----|------|---|

SUSQUEHANNA 1 INCURRED 2 POWER OUTAGES IN MARCH FOR REASONS STATED ABOVE.

 * SUMMARY *

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

F A C I L I T Y D A T A

* SUSQUEHANNA 1 *

FACILITY DESCRIPTION

LOCATION STATE.....PENNSYLVANIA
COUNTY.....LUZERNE

DIST AND DIRECTION FROM NEAREST POPULATION CTR...7 MI NE OF BERWICK, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITIICALITY...SEPTEMBER 10, 1982
DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982
DATE COMMERCIAL OPERATE....JUNE 8, 1983

CONDENSER COOLING METHOD...CC,HNDCT
CONDENSER COOLING WATER.....SUSQUEHANNA RIVER
ELECTRIC RELIABILITY COUNCIL.....MID-ATLANTIC AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSE.....PENNSYLVANIA POWER & LIGHT
CORPORATE ADDRESS.....2 NORTH NINTH STREET ALLENTOWN, PENNSYLVANIA 18101

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....F. YOUNG
LICENSING PROJ MANAGER.....M. THADAMI
DOCKET NUMBER.....50-587
LICENSE & DATE ISSUANCE...NPF-14, NOVEMBER 12, 1982
PUBLIC DOCUMENT ROOM.....OSTERHOUT FREE LIBRARY
71 SOUTH FRANKLIN STREET
WILKES-BARRE, PENNSYLVANIA 18701

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:
NO INPUT PROVIDED.
FACILITY ITEMS (PLANS AND PROCEDURES):
NO INPUT PROVIDED.

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

```
=====
```

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------------------|------------------|-------------------|---------|
| NO INPUT PROVIDED. | | | |

```
=====
```

1. Docket: 50-388 O P E R A T I N G S T A T U S
 2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
 3. Utility Contact: J. A. HIRT (717) 542-3917
 4. Licensed Thermal Power (Mwt): 3293
 5. Nameplate Rating (Gross MWe): 1152
 6. Design Electrical Rating (Net MWe): 1065
 7. Maximum Dependable Capacity (Gross MWe): 1068
 8. Maximum Dependable Capacity (Net MWe): 1032
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____
 11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|----------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>27,456.0</u> |
| 13. Hours Reactor Critical | <u>120.0</u> | <u>1,560.0</u> | <u>23,111.8</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>693.9</u> |
| 15. Hrs Generator On-Line | <u>96.5</u> | <u>1,536.5</u> | <u>22,697.4</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>186,551</u> | <u>4,798,980</u> | <u>71,424,698</u> |
| 18. Gross Elec Ener (MWH) | <u>57,640</u> | <u>1,572,662</u> | <u>23,379,424</u> |
| 19. Net Elec Ener (MWH) | <u>55,176</u> | <u>1,517,394</u> | <u>22,518,858</u> |
| 20. Unit Service Factor | <u>13.0</u> | <u>70.4</u> | <u>82.7</u> |
| 21. Unit Avail Factor | <u>13.0</u> | <u>70.4</u> | <u>82.7</u> |
| 22. Unit Cap Factor (MDC Net) | <u>7.2</u> | <u>67.3</u> | <u>79.5</u> |
| 23. Unit Cap Factor (DER Net) | <u>7.0</u> | <u>65.3</u> | <u>77.0</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>8.6</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>2,149.0</u> |

26. Shutdowns Sche? Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 05/21/88

 * SUSQUEHANNA 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUSQUEHANNA 2



MARCH 1988

F A C I L I T Y D A T A

* SUSQUEHANNA 2

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....LUZERNE

DIST AND DIRECTION FROM
NEAREST POPULATION CTR....7 MI NE OF
BERWICK, PA

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...MAY 8, 1984

DATE ELEC ENER 1ST GENER....JULY 3, 1984

DATE COMMERCIAL OPERATE....FEBRUARY 12, 1985

CONDENSER COOLING METHOD....CC,HNDCT

CONDENSER COOLING WATER....SUSQUEHANNA RIVER

ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PENNSYLVANIA POWER & LIGHT
CORPORATE ADDRESS.....2 NORTH NINTH STREET
ALLENTOWN, PENNSYLVANIA 18101

CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....F. YOUNG
LICENSING PROJ MANAGER.....M. THADANI
DOCKET NUMBER.....50-388
LICENSE & DATE ISSUANCE....NPF-22, JUNE 27, 1984
PUBLIC DOCUMENT ROOM.....OSTERHOUT FREE LIBRARY
71 SOUTH FRANKLIN STREET
MILKES-BARRE, PENNSYLVANIA 18701

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period MAR 1988

INSPECTION STATUS - (CONTINUED)

* SUSQUEHANNA 2 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------------------|------------------|-------------------|---------|
| ***** | | | |
| NO INPUT PROVIDED. | | | |
| ***** | | | |

NO INPUT PROVIDED.

1. Docket: 50-289 OPERATING STATUS
2. Reporting Period: 05/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: C. W. SMYTH (717) 948-8551
4. Licensed Thermal Power (Mwt): 2535
5. Nameplate Rating (Gross MWe): 968 X 0.9 = 871
6. Design Electrical Rating (Net MWe): 819
7. Maximum Dependable Capacity (Gross MWe): 824
8. Maximum Dependable Capacity (Net MWe): 776
9. If Changes Occur Above Since Last Report, Give Reasons:
 NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____
11. Reasons for Restrictions, If Any: _____
 NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|-----------|-----------|-------------|
| 12. Report Period Hrs | 744.0 | 2,184.0 | 119,041.0 |
| 13. Hours Reactor Critical | 744.0 | 2,122.4 | 48,642.8 |
| 14. Rx Reserve Shtdn Hrs | .0 | 61.6 | 1,947.8 |
| 15. Hrs Generator On-Line | 744.0 | 2,120.4 | 47,720.2 |
| 16. Unit Reserve Shtdn Hrs | .0 | .0 | .0 |
| 17. Gross Therm Ener (MMH) | 1,881,173 | 5,341,752 | 115,829,452 |
| 18. Gross Elec Ener (MMH) | 647,679 | 1,842,141 | 38,710,362 |
| 19. Net Elec Ener (MMH) | 612,425 | 1,739,127 | 36,243,410 |
| 20. Unit Service Factor | 100.0 | 97.1 | 40.1 |
| 21. Unit Avail Factor | 100.0 | 97.1 | 40.1 |
| 22. Unit Cap Factor (MDC Net) | 106.1 | 102.6 | 39.0* |
| 23. Unit Cap Factor (DER Net) | 100.5 | 97.2 | 37.2 |
| 24. Unit Forced Outage Rate | .0 | 2.2 | 55.5 |
| 25. Forced Outage Hours | .0 | 63.6 | 59,376.5 |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

REFUELING - JUNE 17, 1988 - 63 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

 * THREE MILE ISLAND 1

 AVERAGE DAILY POWER LEVEL (MWe) PLOT
 THREE MILE ISLAND 1



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* THREE MILE ISLAND 1 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

THREE MILE ISLAND 1 OPERATED ROUTINELY IN MARCH WITH NO
OUTAGES OR SIGNIFICANT POWER REDUCTIONS.

| <u>Type</u> | <u>Reason</u> | <u>Method</u> | <u>System & Component</u> |
|-------------|--------------------------------|----------------|-------------------------------|
| F-Forced | A-Equip Failure F-Admin | 1-Manual | Exhibit F & H |
| S-Sched | B Maint or Test G-Oper Error | 2-Manual Scram | Instructions for |
| | C-Refueling H-Other | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

F A C I L I T Y D A T A

* THREE MILE ISLAND 1 *

FACILITY DESCRIPTION

LOCATION STATE.....PENNSYLVANIA
COUNTY.....DAUPHIN
DIST AND DIRECTION FROM NEAREST POPULATION CTR...10 MI SE OF HARRISBURG, PA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 5, 1974
DATE ELEC ENER 1ST GENER...JUNE 19, 1974
DATE COMMERCIAL OPERATE...SEPTEMBER 2, 1974
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...SUSQUEHANNA RIVER
ELECTRIC RELIABILITY COUNCIL.....MID-ATLANTIC AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....GPU NUCLEAR CORP.
CORPORATE ADDRESS.....P.O. BOX 480 MIDDLETON, PENNSYLVANIA 17057
CONTRACTOR ARCHITECT/ENGINEER.....GILBERT ASSOCIATES
HUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....R. CONTE
LICENSING PROJ MANAGER.....R. HERNAN
DOCKET NUMBER.....59-289
LICENSE & DATE ISSUANCE....DPR-50, APRIL 19, 1974
PUBLIC DOCUMENT ROOMGOVERNMENT PUBLICATIONS SECTION
STATE LIBRARY OF PENNSYLVANIA
FORUM BUILDING
COMMONWEALTH AND WALNUT STREET
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period MAR 1988

I N S P E C T I O N S T A T U S - (CONTINUED)

* THREE MILE ISLAND 1 *

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
|--------|------------------|-------------------|---------|

NO INPUT PROVIDED.

=====

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

XXXXXXXXXXXXXXXXXXXX XXXX XXX
* TROJAN *
XXXXXXXXXXXXXXXXXXXX XXXX XXX

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

***** TROJAN OPERATED ROUTINELY IN MARCH WITH NO OUTAGES OR
* SUMMARY * SIGNIFICANT POWER REDUCTIONS.

Table with 4 columns: Type, Reason, Method, System & Component. It lists various operational methods and reasons such as 'Manual Scram', 'Auto Scram', and 'Reduced Load'.

* TROJAN *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....OREGON
COUNTY.....COLUMBIA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...32 MI N OF
PORTLAND, ORE
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 15, 1975
DATE ELEC ENER 1ST GENER...DECEMBER 23, 1975
DATE COMMERCIAL OPERATE...MAY 20, 1976
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...COOLING TOWER
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PORTLAND GENERAL ELECTRIC
CORPORATE ADDRESS.....121 S.W. SALMON STREET
PORTLAND, OREGON 97204
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....R. BARR
LICENSING PROJ MANAGER.....T. CHAN
DOCKET NUMBER.....50-344
LICENSE & DATE ISSUANCE...NPF-1, NOVEMBER 21, 1975
PUBLIC DOCUMENT ROOM.....LIBRARY ASSOCIATION OF PORTLAND
SOCIAL SCIENCES & SCIENCE DEPARTMENT
801 SW 10TH AVENUE
PORTLAND, OREGON 97207

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON NOVEMBER 1, 1986 - NOVEMBER 30, 1987 (REPORT NO. 50-344/87-41) YEARLY SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE; REPORT SENT MARCH 30, 1988.
- + INSPECTION ON FEBRUARY 8 - MARCH 4, 1988 (REPORT NO. 50-344/88-04) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, ORGANIZATION AND MANAGEMENT, TRAINING AND QUALIFICATIONS, SOLID WASTES, TRANSPORTATION, AND FACILITY TOURS (SURVEYS AND MONITORING). DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.
RESULTS: IN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED: TECHNICAL SPECIFICATION 6.11, FAILURE TO FOLLOW PROCEDURES.
- + INSPECTION ON FEBRUARY 19 - MARCH 11, 1988 (REPORT NO. 50-344/88-05) AREAS INSPECTED: SECURITY PLAN AND IMPLEMENTING PROCEDURES; RECORDS AND REPORTS; PHYSICAL BARRIERS; LIGHTING; ACCESS CONTROL; SAFEGUARDS CONTINGENCY PLAN IMPLEMENTATION REVIEW; AND FOLLOW-UP. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.
RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.
- + INSPECTION ON MARCH 28 - APRIL 1, 1988 (REPORT NO. 50-344/88-08) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON MARCH 28 - APRIL 14, 1988 (REPORT NO. 50-344/88-09) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

1. Docket: 50-250 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 694-4432

4. Licensed Thermal Power (Mwt): 2200

5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760

6. Design Electrical Rating (Net MWe): 693

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 666

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____


11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|---|----------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>134,312.6</u> |
| 13. Hours Reactor Critical | <u>483.5</u> | <u>995.4</u> | <u>90,690.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>844.3</u> |
| 15. Hrs Generator On-Line | <u>440.9</u> | <u>910.0</u> | <u>87,705.2</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>121.8</u> |
| 17. Gross Therm Ener (MWH) | <u>888,882</u> | <u>1,777,923</u> | <u>181,582,188</u> |
| 18. Gross Elec Ener (MWH) | <u>292,245</u> | <u>572,930</u> | <u>58,170,931</u> |
| 19. Net Elec Ener (MWH) | <u>271,711</u> | <u>526,223</u> | <u>55,005,009</u> |
| 20. Unit Service Factor | <u>59.3</u> | <u>41.7</u> | <u>65.3</u> |
| 21. Unit Avail Factor | <u>59.3</u> | <u>41.7</u> | <u>65.4</u> |
| 22. Unit Cap Factor (MDC Net) | <u>54.8</u> | <u>36.2</u> | <u>62.9*</u> |
| 23. Unit Cap Factor (DER Net) | <u>52.7</u> | <u>34.8</u> | <u>59.1</u> |
| 24. Unit Forced Outage Rate | <u>40.7</u> | <u>58.0</u> | <u>11.2</u> |
| 25. Forced Outage Hours | <u>303.1</u> | <u>1,258.1</u> | <u>10,505.4</u> |
| 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>NONE</u> | | | |

27. If Currently Shutdown Estimated Startup Date: N/A

* TURKEY POINT 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
TURKEY POINT 3



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * TURKEY POINT 3 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 03 | 03/16/88 | F | 169.5 | A | 1 | | HB | HTEXCH | FOLLOWING AN INITIAL POWER REDUCTION TO INVESTIGATE EXCESSIVE NOISE IN THE 3D MOISTURE SEPARATOR REHEATER (MSR), THE UNIT WAS SHUTDOWN, REPAIRS WERE IMPLEMENTED ON THE MSR AND THE UNIT BEGAN RETURN TO POWER WHERE A HOLD WAS EXPERIENCED TO ADJUST NUCLEAR INSTRUMENTATION. |
| 04 | 03/24/88 | F | 133.6 | A | 1 | | HC | HTEXCH | WHILE RETURNING TO POWER THE UNIT WAS SHUTDOWN FROM APPROXIMATELY 30% POWER DUE TO HIGH SECONDARY CONDENSATE CONDUCTIVITY CAUSED BY A CONDENSER TUBE LEAK. THE LEAK WAS REPAIRED AND THE UNIT BEGAN TO RETURN TO POWER WHERE SEVERAL HOLDS WERE EXPERIENCED FOR SECONDARY CHEMISTRY. |

 * SUMMARY *

 TURKEY POINT 3 INCURRED 2 OUTAGES IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| f-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* TURKEY POINT 3 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION.....FLORIDA
STATE.....DADE
AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI S OF
MIAMI, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 20, 1972
DATE EC ENER 1ST GENER...NOVEMBER 2, 1972
DATE COMMERCIAL OPERATE...DECEMBER 14, 1972
CONDENSER COOLING METHOD...CLOSED CANAL
CONDENSER COOLING WATER...CLOSED CYCLE CANAL
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 013100
MIAMI, FLORIDA 33174
CONTRACTOR
ARCHITECT/ENGINEER.....BEC TEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BEC TEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....R. BRENER
LICENSING PROJ MANAGER.....G. EDISON
DOCKET NUMBER.....50-250
LICENSE & DATE ISSUANCE...DPR-31, JULY 19, 1972
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY
FLORIDA INTERNATIONAL UNIVERSITY
MIAMI, FLORIDA 33199

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

* INSPECTION DECEMBER 28 - JANUARY '8 (87-54): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED DIRECT INSPECTION AT THE SITE, INCLUDING BACKSHIFT INSPECTION, IN THE AREAS OF ANNUAL AND MONTHLY SURVEILLANCE, MAINTENANCE OBSERVATIONS AND REVIEWS, ENGINEERED SAFETY FEATURES, OPERATIONAL SAFETY, FACILITY MODIFICATIONS AND PLANT EVENTS. TWO VIOLATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 22-26 (88-04): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF LICENSEE ACTIONS ON PREVIOUS ENFORCEMENT MATTERS (92701B) (92702B), HOUSEKEEPING (54834B), MATERIAL IDENTIFICATION AND CONTROL (4290213) MATERIAL CONTROL (42940B), WELDING (55050), MAINTENANCE NONDESTRUCTIVE (NDR) ACTIVITIES, NRC BULLETIN 87-01, AND INFORMATION NOTICE 87-36. IN THE AREAS INSPECTED, VIOLATIONS WERE NOT IDENTIFIED.

INSPECTION MARCH 7-11 (88-06): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF PLANT CHEMISTRY AND CORROSION. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TS 6.8.1 REQUIRES THAT WRITTEN PROCEDURES AND ADMINISTRATIVE POLICIES SHALL BE ESTABLISHED, IMPLEMENTED AND MAINTAINED THAT MEET OR EXCEED THE REQUIREMENTS AND RECOMMENDATIONS OF APPENDIX A OF USNRC REGULATORY GUIDE 1.33 AND SECTION 5.1 AND 5.3 OF ANSI N18-7-1972. CONTRARY TO THE ABOVE: (1) ON JANUARY 6, 1988, PROCEDURES 3/4-OSP-075.3 FAILED TO ESTABLISH ADMINISTRATIVE

Report Period MAR 1988

R E P O R T S F R O M L I C E N S E E

XX
X TURKEY POINT 3 X
XX

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|--|
| 88-002 | 01/15/88 | 02/22/88 | REACTOR COOLANT SYSTEM PRESSURE DECREASE DUE TO MALFUNCTIONING PRESSURIZER SPRAY VALVE CAUSES PARTIAL ACCUMULATOR DISCHARGE |

THIS PAGE INTENTIONALLY LEFT BLANK

1. Bucket: 50-251 O P E R A T I N G S T A T U S
 2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
 3. Utility Contact: N. W. GRANT (305) 694-632
 4. Licensed Thermal Power (MWh): 2209
 5. Nameplate Rating (Gross MWe): 894.3 @ .85 = 760
 6. Design Electrical Rating (Net MWe): 693
 7. Maximum Dependable Capacity (Gross MWe): 700
 8. Maximum Dependable Capacity (Net MWe): 666
 9. If Changes Occur Above Since Last Report, Give Reasons:
 NONE

10. Power Level To Which Restricted, If Any (Net MWe):
 11. Reasons for Restrictions, If Any:
 NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|-----------|-----------|-------------|
| 12. Report Period Hrs | 744.0 | 2,124.0 | 128,041.0 |
| 13. Hours Reactor Critical | 744.0 | 1,780.5 | 86,967.0 |
| 14. Rv Reserve Shtdwn Hrs | .0 | .0 | 166.6 |
| 15. Hrs Generator On-Line | 744.0 | 1,770.5 | 83,983.9 |
| 16. Unit Reserve Shtdwn Hrs | .0 | .0 | 31.2 |
| 17. Gross Therm Ener (MMH) | 1,557,647 | 3,765,807 | 177,230,530 |
| 18. Gross Elec Ener (MWH) | 513,155 | 1,243,310 | 56,543,134 |
| 19. Net Elec Ener (MWH) | 489,659 | 1,181,998 | 53,503,829 |
| 20. Unit Service Factor | 100.0 | 81.1 | 65.6 |
| 21. Unit Avail Factor | 100.0 | 81.1 | 65.6 |
| 22. Unit Cap Factor (MDC Net) | 98.8 | 81.3 | 64.1* |
| 23. Unit Cap Factor (DER Net) | 96.9 | 78.1 | 60.3 |
| 24. Unit Forced Outage Rate | .0 | 18.9 | 11.0 |
| 25. Forced Outage Hours | .0 | 612.3 | 9,993.2 |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
 NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * TURKEY POINT 4 *

 AVERAGE DAILY POWER LEVEL (MWe) PLOT
 TURKEY POINT 4



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
 X TURKEY POINT 4 X
 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 06 | 03/07/88 | F | 0.0 | A | 5 | | HH | PIPEXX | UNIT NO.4 REDUCED POWER TO REPAIR A LEAK IN THE 4A STEAM GENERATOR FEEDWATER PUMP SUCTION LINE. THE UNIT WAS THEN RETURNED TO FULL POWER OPERATIONS. |

XXXXXXXXXXXX TURKEY POINT 4 INCURRED 1 POWER REDUCTION IN MARCH FOR
 * SUMMARY * REASONS STATED ABOVE.
 XXXXXXXXXXXX

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | licensee Event Report |
| | 8 License Examination | 9-Other | (LER) File (NUREG-0161) |

F A C I L I T Y D A T A

UTILITY & CONTRACTOR INFORMATION

UTILITY
 LICENSEE.....FLORIDA POWER & LIGHT
 CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 013100
 MIAMI, FLORIDA 33174

CONTRACTOR
 ARCHITECT/ENGINEER.....BECHTEL

MUC STEAM SYS SUPPLIER...WESTINGHOUSE
 CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....R. BREWER

LICENSING PROJ MANAGER.....G. EDISON
 DOCKET NUMBER.....50-251

LICENSE & DATE ISSUANCE....DPR-41, APRIL 10, 1975

PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY
 FLORIDA INTERNATIONAL UNIVERSITY
 MIAMI, FLORIDA 33199

I N S P E C T I O N S T A T U S

FACILITY DESCRIPTION

LOCATION
 STATE.....FLORIDA
 COUNTY.....DADE
 DIST AND DIRECTION FROM
 NEAREST POPULATION CTR...25 MI S OF
 MIAMI, FLA

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...JUNE 11, 1973

DATE ELEC EMER 1ST GENER...JUNE 21, 1973

DATE COMMERCIAL OPERATE...SEPTEMBER 7, 1973

CONDENSER COOLING METHOD...CLOSED CANAL

CONDENSER COOLING WATER...CLOSED CYCLE CANAL

ELECTRIC RELIABILITY
 COUNCIL.....SOUTHEASTERN ELECTRIC
 RELIABILITY COUNCIL

INSPECTION SUMMARY

* INSPECTION DECEMBER 28 - JANUARY 18 (87-54): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED DIRECT INSPECTION AT THE SITE, INCLUDING BACKSHIFT INSPECTION, IN THE AREAS OF ANNUAL AND MONTHLY SURVEILLANCE, MAINTENANCE OBSERVATIONS AND REVIEWS. ENGINEERED SAFETY FEATURES, OPERATIONAL SAFETY, FACILITY MODIFICATIONS AND PLANT EVENTS. TWO VIOLATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 22-26 (88-04): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF LICENSEE ACTIONS ON PREVIOUS ENFORCEMENT MATTERS (92701B) (92702B), HOUSEKEEPING (548348), MATERIAL IDENTIFICATION AND CONTROL (4290213) MATERIAL CONTROL (42940B), WELDING (55050), MAINTENANCE NONDESTRUCTIVE (NDR) ACTIVITIES, NRC BULLETIN 87-01, AND INFORMATION NOTICE 87-36. IN THE AREAS INSPECTED, VIOLATIONS WERE NOT IDENTIFIED.

INSPECTION MARCH 7-11 (88-06): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF PLANT CHEMISTRY AND CORROSION. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

15 6 8.1 REQUIRES THAT WRITTEN PROCEDURES AND ADMINISTRATIVE POLICIES SHALL BE ESTABLISHED. IMPLEMENTED AND MAINTAINED THAT MEET OR EXCEED THE REQUIREMENTS AND RECOMMENDATIONS OF APPENDIX A OF USNRC REGULATORY GUIDE 1.33 AND SECTION 5.1 AND 5.3 OF ANSI N18-7-1972. CONTRARY TO THE ABOVE: (1) ON JANUARY 6, 1988, PROCEDURES 3/4-05P-075.3 FAILED TO ESTABLISH ADMINISTRATIVE

ENFORCEMENT SUMMARY

REQUIREMENTS TO INDEPENDENTLY VERIFY AFW NITROGEN VALVE POSITIONS, WHICH RESULTED IN A FAILURE TO IMPLEMENT STEP 7.2.20 OF PROCEDURE 4-OSP-75.3 IN THAT A VALVE WAS NOT OPENED AS REQUIRED. CONSEQUENTLY, ONLY TWO OF THREE NITROGEN BOTTLES WERE RESTORED TO THEIR NORMAL ALIGNMENT FOLLOWING SURVEILLANCE TESTING. (2) ON JANUARY 12, 1988, THE CONTINUOUS FIRE WATCH POSTED AT FIRE DOOR 108A-1 TO COMPENSATE FOR AN IMPAIRED HALON SYSTEM WAS FOUND ASLEEP. CONSEQUENTLY, THE EFFECTIVENESS OF THE HALON SYSTEM MIGHT NOT HAVE BEEN RE-ESTABLISHED (THROUGH DOOR CLOSURE) WITHIN THE REQUIRED 60 SECOND TIME INTERVAL. (3) ON JANUARY 13, 1988, MAINTENANCE WAS PERFORMED ON THE UNIT 3 ROD CONTROL SYSTEM WITHOUT DOCUMENTED INSTRUCTIONS OR DRAWINGS APPROPRIATE TO THE CIRCUMSTANCES. FUSES WERE REMOVED FROM THE SYSTEM WITHOUT A COMPLETE UNDERSTANDING OF WHAT CIRCUITRY THE FUSES SUPPLIED. CONSEQUENTLY, PORTIONS OF THE ROD CONTROL CIRCUITRY FOR 3 RODS WERE DE-ENERGIZED WHILE ONLY ONE ROD WAS THOUGHT TO BE AFFECTED. DURING A UNIT 3 REACTOR SHUTDOWN, THIS UNEXPECTEDLY RESULTED IN MULTIPLE RODS DROPPING INTO THE CORE, REQUIRING AS MANUAL REACTOR TRIP. (4) ON JANUARY 10, 1988, GTSC 5676 WAS APPROVED TO ONOP 0208.11, AN ANNUNCIATOR RESPONSE PROCEDURE, AND AS OF JANUARY 13, 1988, IT HAD NOT BEEN ENTERED INTO THE ONOP. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION III, AS IMPLEMENTED BY THE APPROVED FLORIDA POWER AND LIGHT COMPANY TOPICAL QUALITY ASSURANCE REPORT (FPLTQAR) 1-76A, REVISION 10, TOPICAL QUALITY REQUIREMENT (TQR) 5.0, REVISION 5, IN JANUARY 1988, INSPECTIONS IDENTIFIED THAT DESIGN INPUTS CONTAINED INPLANT CHANGE MODIFICATIONS (PCMS) 85-175 AND 85-176, HAD NOT BEEN CORRECTLY TRANSLATED INTO OPERATING PROCEDURES AND THE SYSTEM DESCRIPTION. (8705 4)

UNDERGROUND PA BARRIER. UNALARMED PA BARRIER. INADEQUATE ALARM TEST. (8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

SELECT SAFETY SYSTEM OPERABILITY REVIEW IN PROGRESS.

FACILITY ITEMS (PLANS AND PROCEDURES):

PROCEDURE UPGRADE PROGRAM (PUP) IN PROGRESS.

MANAGERIAL ITEMS:

PEP IN PROGRESS.

PLANT STATUS:

REFUELING OUTAGE. PLANT IN COLD SHUTDOWN.

LAST IE SITE INSPECTION DATE: MARCH 7-11, 1988 +

INSPECTION REPORT NO: 50-251/88-06 +

Report Period MAR 1988

R E P O R T S F R O M L I C E N S E E

W TURKEY POINT 4

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|---|
| 88-001 | 01-29/88 | 02-26/88 | TECH SPEC LIMITS EXCEEDED FOR SAFETY SYSTEM SETTINGS DUE TO NON-CONSERVATIVE ACCEPTANCE CRITERIA IN PLANT PROCEDURES |
| 88-002 | 02-02/88 | 03-03/88 | CONTAINMENT AND CONTROL ROOM VENTILATION ISOLATION DUE TO PERSONNEL ERROR WHILE PERFORM MOD TO REMOVE REMOTE ALARM FUNCTION |
| 88-003 | 02-07/88 | 03-08/88 | UNIT 4 SHUTDOWN WHEN THREE BATTERY CHARGERS BECAME INOPERABLE DUE TO FAILURE OF A GATE FILTER MODULE |

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-271 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: G. A. HALLIN (802) 257-7711 X2272

4. Licensed Thermal Power (MWT): 1593

5. Nameplate Rating (Gross MWe): 626 X 0.9 = 563

6. Design Electrical Rating (Net MWe): 514

7. Maximum Dependable Capacity (Gross MWe): 535

8. Maximum Dependable Capacity (Net MWe): 504

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>136,106.8</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>107,029.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,184.0</u> | <u>104,474.0</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>1,163,020</u> | <u>3,439,002</u> | <u>153,179,700</u> |
| 18. Gross Elec Ener (MWH) | <u>393,216</u> | <u>1,163,883</u> | <u>51,003,827</u> |
| 19. Net Elec Ener (MWH) | <u>377,284</u> | <u>1,116,806</u> | <u>48,411,893</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>76.8</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>76.8</u> |
| 22. Unit Cap Factor (MDC Net) | <u>100.6</u> | <u>101.5</u> | <u>70.6</u> |
| 23. Unit Cap Factor (DER Net) | <u>98.7</u> | <u>99.5</u> | <u>69.2</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>6.2</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>5,593.4</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* VERMONT YANKEE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
VERMONT YANKEE 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * VERMONT YANKEE 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|--------|-----------|--|
| 88-02 | 03/11/88 | F | 0.0 | B | 5 | | RB | CONROD | SPECTACLE FLANGE BOLTS LOOSENED. ALL BOLTS TORQUED TO SPECIFICATION. CONTROL ROD AND TURBINE SURVEILLANCE TESTING. |
| 88-03 | 03/19/88 | S | 0.0 | B | 5 | | RB | CONROD | CONTROL ROD PATTERN EXCHANGE, SURVEILLANCE TESTING AND SCHEDULED MAINTENANCE. |

 * SUMMARY *

 VERMONT YANKEE INCURRED 2 POWER REDUCTIONS IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* VERMONT YANKEE 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....VERMONT
COUNTY.....WINDHAM
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
BRATTLEBORO, VT
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 24, 1972
DATE ELEC ENER 1ST GENER...SEPTEMBER 20, 1972
DATE COMMERCIAL OPERATE...NOVEMBER 30, 1972
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...CONNECTICUT RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VERMONT YANKEE NUCLEAR POWER
CORPORATE ADDRESS.....RD #5, BOX 169, FERRY ROAD
BRATTLEBORO, VERMONT 05301
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....W. RAYMOND
LICENSING PROJ MANAGER....V. ROONEY
DOCKET NUMBER.....50-271
LICENSE & DATE ISSUANCE....DPR-28, FEBRUARY 28, 1973
PUBLIC DOCUMENT ROOM.....BROOKS MEMORIAL LIBRARY
224 MAIN STREET
BRATTLEBORO, VERMONT 05301

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

10 CFR 50.49 PARA (F) AND (G), AND PARA (K) (FOR DOR GUIDELINE PROVISION) REQUIRE THAT EACH ITEM OF ELECTRICAL EQUIPMENT IMPORTANT TO SAFETY BE QUALIFIED AND THAT QUALIFICATIONS MUST BE COMPLETED NO LATER THAN NOVEMBER 30, 1985. CONTRARY TO THE ABOVE, ON OCTOBER 23, 1987, QUALIFICATION OF THE EP/HYPALON CABLES WAS NOT ESTABLISHED AT THE TIME OF THE INSPECTION IN THAT THE QUALIFICATION TEST REPORT WAS INVALID BECAUSE OF PROBLEMS IDENTIFIED IN IEIN 84-44 (INADEQUATE QA PROGRAM, TEST EQUIPMENT NOT PROPERLY CALIBRATED, TEST DEFICIENCIES AND TEST ANOMALIES IMPROPERLY DOCUMENTED, AND TEST DOCUMENTS IMPROPERLY CONTROLLED). 10 CFR 50.49 PARA (F) AND (G), AND PARA (K) (FOR DOR GUIDELINE PROVISION) REQUIRE THAT EACH ITEM OF ELECTRICAL EQUIPMENT IMPORTANT TO SAFETY BE QUALIFIED AND THAT QUALIFICATIONS MUST BE COMPLETED NO LATER THAN NOVEMBER 30, 1985. CONTRARY TO THE ABOVE, ON OCTOBER 23, 1987, QUALIFICATION OF 3M TAPE SPLICE WAS NOT ESTABLISHED AT THE TIME OF THE INSPECTION IN THAT NO TYPE TEST REPORT NOR ADEQUATE SIMILARITY ANALYSIS WAS AVAILABLE IN THE EQ FILE TO SUPPORT THE TAPE SPLICES QUALIFICATION.

10 CFR 50.49 PARA (F) AND (G), AND PARA (K) (FOR DOR GUIDELINE PROVISION) REQUIRE THAT EACH ITEM OF ELECTRICAL EQUIPMENT IMPORTANT TO SAFETY BE QUALIFIED AND THAT QUALIFICATIONS MUST BE COMPLETED NO LATER THAN NOVEMBER 30, 1985. CONTRARY TO THE ABOVE, ON OCTOBER 23, 1987, QUALIFICATION OF DISCS BRAKES IN THE LIMITORQUE VALVE OPERATOR WAS NOT ESTABLISHED AT THE TIME OF THE INSPECTION

* VERMONT YANKEE 1

ENFORCEMENT SUMMARY

IN THAT THE EQ FILE DID NOT CONTAIN EVIDENCE TO DEMONSTRATE THE RADIATION QUALIFICATION OF THE DINGS BRAKES FOR APPLICATION INSIDE THE DRYWELL. 10 CFR 50.49 PARA (F) AND (G), AND PARA (K) (FOR DOR GUIDELINE PROVISION) REQUIRE THAT EACH ITEM OF ELECTRICAL EQUIPMENT IMPORTANT TO SAFETY BE QUALIFIED AND THAT QUALIFICATIONS MUST BE COMPLETED NO LATER THAN NOVEMBER 30, 1985. CONTRARY TO THE ABOVE. ON OCTOBER 23, 1987, QUALIFICATION OF GE EB-5 TERMINAL BLOCK WAS NOT ESTABLISHED AT THE TIME OF THE INSPECTION IN THAT (1) THE TYPE TEST REPORT DID NOT DEMONSTRATE THAT THIS TERMINAL BLOCK CAN PERFORM ITS SAFETY FUNCTION BECAUSE LOW INSULATION RESISTANCE VALUES WERE OBSERVED DURING THE TEST; (2) NO SIMILARITY ANALYSIS WAS AVAILABLE IN THE EQ FILE FOR GE EB-5 AND GE CR 151B TERMINAL BLOCKS. 10 CFR 50.49 PARA (F) AND (G), AND PARA (K) (FOR DOR GUIDELINE PROVISION) REQUIRE THAT EACH ITEM OF ELECTRICAL EQUIPMENT IMPORTANT TO SAFETY BE QUALIFIED AND THAT QUALIFICATIONS MUST BE COMPLETED NO LATER THAN NOVEMBER 30, 1985. CONTRARY TO THE ABOVE. ON OCTOBER 23, 1987, QUALIFICATION OF FOME XLPE/PVC CABLES WAS NOT ESTABLISHED AT THE TIME OF THE INSPECTION IN THAT THE TEST CONDITIONS DID NOT ENVELOPE THE REQUIRED SERVICE CONDITIONS (303 DEG F FOR FOUR HOURS VS. 325 DEG F FOR THREE HOURS). 10 CFR 50.49 PARA (F) AND (G), AND PARA (K) (FOR DOR GUIDELINE PROVISION) REQUIRE THAT EACH ITEM OF ELECTRICAL EQUIPMENT IMPORTANT TO SAFETY BE QUALIFIED AND THAT QUALIFICATIONS MUST BE COMPLETED NO LATER THAN NOVEMBER 30, 1985. CONTRARY TO THE ABOVE. ON OCTOBER 23, 1987, QUALIFICATION OF LEWIS PF/PVC INSTRUMENTATION CABLES WAS NOT ESTABLISHED AT THE TIME OF THE INSPECTION IN THAT NO VALID TEST REPORT WAS AVAILABLE IN THE EQ FILE TO SUPPORT THE QUALIFICATION OF THIS TYPE OF CABLES.

(8701 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------------------|---------------|----------------|---------|
| NO INPUT PROVIDED. | | | |

NO INPUT PROVIDED.

1. Docket: 50-424 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: S. C. DILWORTH (404) 724-8114 X3870

4. Licensed Thermal Power (Mwt): 3411

5. Nameplate Rating (Gross MWe): 1157

6. Design Electrical Rating (Net MWe): 1101

7. Maximum Dependable Capacity (Gross MWe): 1133

8. Maximum Dependable Capacity (Net MWe): 1079

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>7,321.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>1,620.3</u> | <u>5,668.4</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>1,580.1</u> | <u>5,500.5</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,456,340</u> | <u>5,208,997</u> | <u>17,869,935</u> |
| 18. Gross Elec Ener (MWH) | <u>819,810</u> | <u>1,735,340</u> | <u>5,919,230</u> |
| 19. Net Elec Ener (MWH) | <u>779,730</u> | <u>1,626,460</u> | <u>5,547,980</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>72.3</u> | <u>75.1</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>72.3</u> | <u>75.1</u> |
| 22. Unit Cap Factor (MDC Net) | <u>97.1</u> | <u>69.0</u> | <u>70.2</u> |
| 23. Unit Cap Factor (DER Net) | <u>95.2</u> | <u>67.6</u> | <u>68.8</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>26.1</u> | <u>21.4</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>556.8</u> | <u>1,500.4</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING - SEPTEMBER 19, 1988, 50 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

* VOGTLE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

VOGTLE 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * VOGTLE 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 88-5 | 03/19/88 | F | 0.0 | A | 5 | | IG | JX | REACTOR POWER RADIAL TILT CAUSED BY AN INOPERABLE NUCLEAR INSTRUMENTATION CHANNEL (NI-43). IN ACCORDANCE WITH TECHNICAL SPECIFICATIONS, POWER WAS REDUCED TO 75%. THE POWER SUPPLY FEEDING NI-43 WAS FOUND TO BE INOPERABLE AND WAS REPLACED. THIS REPAIRED THE NI BUT THEN THE PLANT ENTERED A SCHEDULED MAINTENANCE DERATING TO REPAIR A LEAKING SEAL ON THE HEATER DRAIN PUMP "A". |
| 88-6 | 03/21/88 | S | 0.0 | A | 5 | | TF | SEAL | HEATER DRAIN PUMP "A" SEAL WAS LEAKING. POWER WAS REDUCED TO 80% TO REPLACE THE SEAL. REPLACED HEATER DRAIN PUMP "A" SEAL AND RETURNED THE PLANT TO FULL POWER. |

***** VOGTLE INCURRED 2 POWER REDUCTIONS IN MARCH FOR REASONS
 * SUMMARY * STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* VOGTLE 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....GEORGIA
COUNTY.....BURKE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI SSE OF
AUGUSTA, GA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 9, 1987
DATE ELEC ENER 1ST GENER...MARCH 27, 1987
DATE COMMERCIAL OPERATE...JUNE 1, 1987
CONDENSER COOLING METHOD...CCCT
CONDENSER COOLING WATER...SAVANNAH RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GEORGIA POWER
CORPORATE ADDRESS.....333 PIEDMONT AVENUE, N.E., P. O. BOX 4545
ATLANTA, GEORGIA 30302
CONTRACTOR
ARCHITECT/ENGINEER.....SOUTHERN SERVICES & BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....GEORGIA POWER CO.
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. ROGGE
LICENSING PROJ MANAGER....J. HOPKINS
DOCKET NUMBER.....50-424
LICENSE & DATE ISSUANCE...NPF-68, MARCH 16, 1987
PUBLIC DOCUMENT ROOM.....BURKE COUNTY LIBRARY
412 FOURTH ST.
WAYNESBORO, GA. 30830

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JANUARY 25-29 (88-07): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF LICENSED OPERATOR TRAINING, NON-LICENSED OPERATOR TRAINING, MAINTENANCE TRAINING, AND NATURAL CIRCULATION COOLDOWN EMERGENCY OPERATING PROCEDURES. ONE DEVIATION WAS IDENTIFIED WHEREIN THE LICENSEE DEVIATED FROM COMMITMENTS MADE IN THEIR NRC APPROVED PROCEDURE GENERATION PACKAGE (PGP) IN WRITING THEIR EMERGENCY OPERATING PROCEDURES FOR NATURAL CIRCULATION COOLDOWN.

INSPECTION JANUARY 30 -FEBRUARY 26 (88-09): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED RESIDENT INSPECTION IN THE FOLLOWING AREAS: PLANT OPERATIONS, RADIOLOGICAL CONTROLS, MAINTENANCE, SURVEILLANCE, FIRE PROTECTION, SECURITY, AND QUALITY PROGRAMS AND ADMINISTRATIVE CONTROLS AFFECTING QUALITY. TWO VIOLATIONS WERE IDENTIFIED IN THE AREAS OF SURVEILLANCE AND QUALITY PROGRAMS (FAILURE TO ESTABLISH AN ADEQUATE SURVEILLANCE PROCEDURE FOR THE HYDROGEN MONITORS AND FAILURE TO SUBMIT A LER FOR MISSED SURVEILLANCES).

INSPECTION FEBRUARY 9-11 (88-10): THIS ROUTINE, ANNOUNCED INSPECTION OF THE LICENSEE INVESTIGATION AND CORRECTION OF THE FAILURES EXPERIENCED IN RESIDUAL HEAT REMOVAL (RHR) SYSTEM VALVES 1-HV-8716A AND B. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 22-26 (88-13): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF LICENSEE ACTION ON* PREVIOUS ENFORCEMENT MATTERS, AUDITS, ONSITE FOLLOWUP OF EVENTS, EXTERNAL EXPOSURE CONTROL, ORGANIZATION AND MANAGEMENT CONTROLS, SOLID WASTES, TRANSPORTATION, AND FOLLOWUP ON INSPECTOR IDENTIFIED ITEMS. FOUR VIOLATIONS WITH EXAMPLES WERE IDENTIFIED - THREE EXAMPLES OF FAILURE TO PROVIDE ADEQUATE HIGH RADIATION AREA CONTRLS, FAILURE TO ADHERE TO PROCEDURES FOR INSTALLATION OF TEMPORARY SHIELDING, FAILURE TO PERFORM ADEQUATE RADIATION SURVEYS AND TWO EXAMPLES OF FAILURE TO DOCUMENT SURVEYS.

1. Docket: 50-397 O P E R A T I N G S T A T U S

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: LEONARD HUTCHISON (509) 377-2486

4. Licensed Thermal Power (Mwt): 3323

5. Nameplate Rating (Gross MWe): 1201

6. Design Electrical Rating (Net MWe): 1100

7. Maximum Dependable Capacity (Gross MWe): 1140

8. Maximum Dependable Capacity (Net MWe): 1095

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>28,904.2</u> |
| 13. Hours Reactor Critical | <u>544.3</u> | <u>1,520.2</u> | <u>21,427.3</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>340.4</u> |
| 15. Hrs Generator On-Line | <u>519.2</u> | <u>1,474.8</u> | <u>20,616.7</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>381.7</u> |
| 17. Gross Therm Ener (MWH) | <u>1,497,600</u> | <u>4,439,698</u> | <u>54,822,465</u> |
| 18. Gross Elec Ener (MWH) | <u>509,490</u> | <u>1,497,610</u> | <u>18,314,750</u> |
| 19. Net Elec Ener (MWH) | <u>491,111</u> | <u>1,445,297</u> | <u>17,613,249</u> |
| 20. Unit Service Factor | <u>69.8</u> | <u>67.5</u> | <u>71.3</u> |
| 21. Unit Avail Factor | <u>69.8</u> | <u>67.5</u> | <u>72.6</u> |
| 22. Unit Cap Factor (MDC Net) | <u>60.3</u> | <u>60.4</u> | <u>55.6</u> |
| 23. Unit Cap Factor (DER Net) | <u>60.0</u> | <u>60.2</u> | <u>55.4</u> |
| 24. Unit Forced Outage Rate | <u>30.2</u> | <u>32.5</u> | <u>10.2</u> |
| 25. Forced Outage Hours | <u>224.8</u> | <u>709.2</u> | <u>2,354.3</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING/MAINT-APRIL 25, 1988 - 45 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

 * WASHINGTON NUCLEAR 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

WASHINGTON NUCLEAR 2



MARCH 1988

 * WASHINGTON NUCLEAR 2

UNIT SHUTDOWNS / REDUCTIONS

Report Period MAR 1988

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|------------------|--|
| 88-05 | 02/13/88 | F | 138.3 | A | 4 | 88-07 | HTEXCH | CONCLUDED EXTENDED OUTAGE FOR ROOF REPAIR. |
| 88-06 | 03/23/88 | F | 86.5 | A | 1 | HC | HTEXCH | PLANT WAS SHUT DOWN DUE TO HIGH CONDUCTIVITY AS A RESULT OF A CONDENSER IN-LEAKAGE PROBLEM. REPAIRS WERE PERFORMED AND UNIT RETURNED TO SERVICE. |

WASHINGTON NUCLEAR 2 EXPERIENCED 2 POWER OUTAGES IN MARCH FOR REASONS STATED ABOVE.

 * SUMMARY *

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

INSPECTION SUMMARY

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MARCH 11 - APRIL 7, 1988 (REPORT NO. 50-397/88-10) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON MARCH 14-18, 1988 (REPORT NO. 50-397/88-11) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY A REGIONALLY BASED INSPECTOR OF THE LICENSEE'S ACTIONS TAKEN TO IMPLEMENT GENERIC LETTER 84-11, "INSPECTIONS OF BWR STAINLESS STEEL PIPING," AND THEIR RESPONSE TO NRC BULLETIN 87-01, "THINNING OF PIPE WALLS IN NUCLEAR POWER PLANTS." DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE UTILIZED.

+ INSPECTION ON APRIL 25 - MAY 13, 1988 (REPORT NO. 50-397/88-12) INSPECTION CONTINUING; TO BE REPORTED AT A LATER DATE.

+ INSPECTION ON APRIL 5-13, 1988 (REPORT NO. 50-397/88-13) REPORT BEING PREPARED TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ REPAIRS TO THE REACTOR BUILDING ROOF AND VENTILATION FANS (REFER TO LAST MONTH'S REPORT) CONTINUED UNTIL PLANT RESTART ON MARCH 6, 1988.

FACILITY ITEMS (PLANS AND PROCEDURES)

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ THE PLANT RESTARTED ON MARCH 6, 1988, AFTER COMPLETING REPAIRS TO THE REACTOR BUILDING ROOF AND OPERATED AT OR NEAR FULL POWER DURING THE REMAINDER OF THE MONTH EXCEPT FOR A CONDENSER TUBE REPAIR OUTAGE ON MARCH 23-26, 1988.

LAST IE SITE INSPECTION DATE: 06/01/1987 - 05/31/1988+

INSPECTION REPORT NO: 50-397/88-08+

 * WASHINGTON NUCLEAR 2 *

R E P O R T S F R O M L I C E N S E E

Report Period MAR 1988

NUMBER DATE OF DATE OF SUBJECT
 EVENT REPORT

88-01-10 01-18-88 02-15-88 REACTOR PROTECTIVE SYSTEM AUTO ACTION DURING PLANT SHUTDOWN DUE TO INADEQUATE PROCEDURES
 88-02-10 01-22-88 02-19-88 RCIC PUMP SUCTION LINE NOT SEISMICALLY QUALIFIED DUE TO A/E DESIGN ERROR
 88-03-10 02-04-88 03-07-88 REACTOR SCRAM DUE TO MAIN STEAMLINE ISOLATION CAUSED BY PERSONNEL ERROR
 88-04-10 02-04-88 03-04-88 SLC SYSTEM INOPERABLE LONGER
 88-05-10 02-08-88 03-09-88 CONTROL ROOM EMERGENCY FILTRATION SYSTEM BYPASS FLOW NOT IN COMPLIANCE WITH TECH SPECS.

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-382 OPERATING STATUS
 2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0
 3. Utility Contact: GEORGE MILLER (504) 467-8211
 4. Licensed Thermal Power (Mwt): 3390
 5. Nameplate Rating (Gross MWe): 1153
 6. Design Electrical Rating (Net MWe): 1104
 7. Maximum Dependable Capacity (Gross MWe): 1120
 8. Maximum Dependable Capacity (Net MWe): 1075
 9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____
 11. Reasons for Restrictions, If Any: _____
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>22,081.0</u> |
| 13. Hours Reactor Critical | <u>698.3</u> | <u>2,084.1</u> | <u>18,188.7</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>688.3</u> | <u>2,029.5</u> | <u>17,843.9</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,298,501</u> | <u>6,781,518</u> | <u>58,242,490</u> |
| 18. Gross Elec Ener (MWH) | <u>779,400</u> | <u>2,298,230</u> | <u>19,679,040</u> |
| 19. Net Elec Ener (MWH) | <u>745,084</u> | <u>2,198,775</u> | <u>18,731,233</u> |
| 20. Unit Service Factor | <u>92.5</u> | <u>92.9</u> | <u>80.8</u> |
| 21. Unit Avail Factor | <u>92.5</u> | <u>92.9</u> | <u>80.8</u> |
| 22. Unit Cap Factor (MDC Net) | <u>93.2</u> | <u>93.7</u> | <u>78.9</u> |
| 23. Unit Cap Factor (DER Net) | <u>90.7</u> | <u>91.2</u> | <u>76.8</u> |
| 24. Unit Forced Outage Rate | <u>7.5</u> | <u>5.2</u> | <u>9.3</u> |
| 25. Forced Outage Hours | <u>55.7</u> | <u>111.3</u> | <u>1,840.1</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING/MAINT OUTAGE, 4/2/88, 60 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

 * WATERFORD 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

WATERFORD 3



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* WATERFORD 3 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 08-02 | 03/21/88 | F | 55.7 | B | 1 | AB | STR | | UNIT SHUTDOWN TO REMOVE LUBE OIL STRAINER ON REACTOR COOLANT PUMP 2B. |

WATERFORD 3 INCURRED 1 OUTAGE IN MARCH FOR REASONS STATED ABOVE.

* SUMMARY *

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NURLO-0161) |

* WATERFORD 3 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....LOUISIANA
COUNTY.....ST CHARLES
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI W OF
NEW ORLEANS, LA
TYPE OF REACTOR.....FWR
DATE INITIAL CRITICALITY...MARCH 4, 1985
DATE ELEC ENER 1ST GENER...MARCH 18, 1985
DATE COMMERCIAL OPERATE...SEPTEMBER 24, 1985
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....LOUISIANA POWER & LIGHT
CORPORATE ADDRESS.....142 DELARONDE STREET
NEW ORLEANS, LOUISIANA 70174
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....T. STAKER
LICENSING PROJ MANAGER.....D. WIGGINTON
DOCKET NUMBER.....50-382
LICENSE & DATE ISSUANCE...NPF-38, MARCH 16, 1985
PUBLIC DOCUMENT ROOM.....HEAD LIBRARIAN
LOUISIANA COLLECTION
EARL K. LONG LIBRARY
UNIVERSITY OF NEW ORLEANS
LAKEFRONT DRIVE
NEW ORLEANS, LOUISIANA 70148

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED FEB. 1 - MARCH 15, 1988 (88-04) ROUTINE, UNANNOUNCED INSPECTION CONSISTING OF: (1) OPERATIONAL SAFETY VERIFICATION, (2) MONTHLY MAINTENANCE OBSERVATION, (3) ONSITE FOLLOWUP OF EVENTS, (4) ENGINEERED SAFETY FEATURE (ESF) SYSTEM WALKDOWN, (5) MONTHLY SURVEILLANCE OBSERVATION, (6) FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS, (7) LICENSEE EVENT REPORT FOLLOWUP, (8) COLD WEATHER PREPARATION, AND (9) PLANT STATUS. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED. THIS VIOLATION INVOLVED A FAILURE TO ADHERE TO FIRE PROTECTION PROCEDURES.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

RCP 2B EXPERIENCING EXCESSIVE UPPER MOTOR BEARING TEMPERATURES DUE TO CLOGGING LUBE OIL STRAINER. MAY REQUIRE A BRIEF FORCED OUTAGE PRIOR TO SHUTDOWN FOR RFO-2 TO CLEAN THE STRAINER.

FACILITY ITEMS (PLANS AND PROCEDURES):

FACILITY WILL COMMENCE RFO-2 ON APRIL 1, 1988 (UNLESS DELAYED BY FORCED OUTAGE).

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING AT FULL POWER

LAST IE SITE INSPECTION DATE: MARCH 15, 1988

INSPECTION REPORT NO: 50-382/88-04

R E P O R T S F R O M L I C E N S E E

=====

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|------------------|-------------------|---------|
| NONE | | | |

=====

1. Docket: 50-482 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: M. WILLIAMS (316) 364-8831

4. Licensed Thermal Power (MWT): 3411

5. Nameplate Rating (Gross MWe): 1250

6. Design Electrical Rating (Net MWe): 1170

7. Maximum Dependable Capacity (Gross MWe): 1170

8. Maximum Dependable Capacity (Net MWe): 1128

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
 NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|-------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>22,583.7</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>1,580.6</u> | <u>17,047.1</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>89.5</u> | <u>339.8</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>1,427.4</u> | <u>16,630.5</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>19.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,526,972</u> | <u>4,700,104</u> | <u>54,126,488</u> |
| 18. Gross Elec Ener (MWH) | <u>891,867</u> | <u>1,648,260</u> | <u>18,837,151</u> |
| 19. Net Elec Ener (MWH) | <u>858,455</u> | <u>1,562,809</u> | <u>17,975,117</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>65.4</u> | <u>73.6</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>65.4</u> | <u>73.7</u> |
| 22. Unit Cap Factor (MDC Net) | <u>102.3</u> | <u>63.4</u> | <u>54.5*</u> |
| 23. Unit Cap Factor (DER Net) | <u>98.6</u> | <u>61.2</u> | <u>68.0</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>31.0</u> | <u>8.4</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>640.7</u> | <u>1,517.0</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
 NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * WOLF CREEK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 WOLF CREEK 1



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* WOLF CREEK 1 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

WOLF CREEK OPERATED ROUTINELY IN MARCH WITH NO POWER
OUTAGES OR SIGNIFICANT POWER REDUCTIONS.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* WOLF CREEK 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....KANSAS
COUNTY.....COFFEY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...3.5 MI NE OF
BURLINGTON, KAN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 22, 1985
DATE ELEC ENER 1ST GENER...JUNE 12, 1985
DATE COMMERCIAL OPERATE...SEPTEMBER 3, 1985
CONDENSER COOLING METHOD...COOLING LAKE
CONDENSER COOLING WATER...COOLING LAKE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....KANSAS GAS & ELECTRIC
CORPORATE ADDRESS.....P.O. BOX 208
WICHITA, KANSAS 67201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DANIEL INTERNATIONAL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....J. CUMMINS
LICENSING PROJ MANAGER.....P. OCONNOR
DOCKET NUMBER.....50-482
LICENSE & DATE ISSUANCE...NPF-42, JUNE 4, 1985
PUBLIC DOCUMENT ROOM.....WILLIAM ALLAN WHITE LIBRARY
GOVERNMENT DOCUMENTS DIVISION
EMPORIA STATE UNIVERSITY
1200 COMMERCIAL STREET
EMPORIA, KANSAS 66801

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION CONDUCTED NOV. 19, 1987 - JAN. 3, 1988 (87-33) ROUTINE, UNANNOUNCED INSPECTION INCLUDING PLANT STARTUP FROM REFUELING, OPERATIONAL SAFETY VERIFICATION, MONTHLY MAINTENANCE OBSERVATION, MONTHLY SURVEILLANCE OBSERVATION, ONSITE EVENT FOLLOWUP, PHYSICAL SECURITY VERIFICATION, RADIOLOGICAL PROTECTION, COLD WEATHER PREPARATION, AND CATHODIC PROTECTION SYSTEM. WITHIN THE NINE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED (FAILURE TO REPORT AS REQUIRED BY 10 CFR 50.72).

INSPECTION CONDUCTED JAN 4 - FEB 14, 1988 (88-01) ROUTINE, UNANNOUNCED INSPECTION INCLUDING ONSITE EVENT FOLLOWUP, ENGINEERED SAFETY FEATURES SYSTEM WALKDOWN, OPERATIONAL SAFETY VERIFICATION, MONTHLY MAINTENANCE OBSERVATION, MONTHLY SURVEILLANCE OBSERVATION, PART 21 FOLLOWUP, ALLEGATION FOLLOWUP, PHYSICAL SECURITY VERIFICATION, AND RADIOLOGICAL PROTECTION. WITHIN THE NINE AREAS INSPECTED, ONE VIOLATION (FAILURE TO COMPLY WITH THE LICENSEE'S TEMPORARY MODIFICATION PROCEDURE WAS IDENTIFIED).

INSPECTION CONDUCTED JAN 25-29, 1988 (88-04) NONROUTINE AND ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S ACTIONS IN REGARD TO A REPORTED LEAK FROM THE REACTOR VESSEL TO VESSEL HEAD SEALS, REVIEW OF THE LICENSEE'S QUALITY ASSURANCE PROGRAM IMPLEMENTATION INCLUDING THE AREAS OF AUDIT PROGRAMS; AUDIT PROGRAM IMPLEMENTATION; RECEIPT, STORAGE, AND HANDLING OF MATERIALS; AND CONTROL OF RECORDS. WITHIN THE AREAS INSPECTED, A VIOLATION WAS IDENTIFIED (FAILURE TO HAVE PROCEDURES APPROPRIATE TO THE CIRCUMSTANCES). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN THE REMAINING AREAS.

INSPECTION CONDUCTED JAN 25-29, 1988 (88-05) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S PHYSICAL SECURITY PROGRAM INCLUDING

INSPECTION SUMMARY

VITAL AREA BARRIERS AND DETECTION AIDS, COMPENSATORY MEASURES, ALARM STATIONS, COMMUNICATIONS, AND FOLLOWUP ON PREVIOUS INSPECTION FINDINGS. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED (INADEQUATE ACCESS CONTROL, PARAGRAPH 3).

INSPECTION CONDUCTED JAN 25-29, 1988 (88-06) ROUTINE, UNANNOUNCED INSPECTION OF EVENTS ASSOCIATED WITH THE REACTOR PRESSURE VESSEL WATER LEVEL AND THE RHR SYSTEM, VERIFICATION OF CONTAINMENT INTEGRITY, AND CONTAINMENT LOCAL LEAK RATE TESTING. WITHIN THE THREE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED (FAILURE TO HAVE PROCEDURES APPROPRIATE TO THE CIRCUMSTANCES, PARAGRAPHS 2 & 3).

INSPECTION CONDUCTED FEB 8-12, 1988 (88-08) ROUTINE, UNANNOUNCED INSPECTION OF ACTIONS TAKEN IN RESPONSE TO IE BULLETIN 85-03 AND A REVIEW OF THE EVALUATION OF THE RECENT COMPONENT COOLING WATER (CCW) WATERHAMMER PROBLEM. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED FEB 22-26, 1988 (88-11) ROUTINE, UNANNOUNCED INSPECTION OF INSERVICE TESTING OF PUMPS AND VALVES. SUBJECTS ADDRESSED IN THIS AREA OF INSPECTION INCLUDED PROGRAM AND ORGANIZATION, PROCEDURE AND RECORDS, TEST WITNESS, AND PERSONNEL QUALIFICATION AND TRAINING. WITHIN THE ONE AREA INSPECTED, ONE VIOLATION WAS IDENTIFIED (FAILURE TO MAKE PERTINENT PUMP STATUS ENTRIES IN PUMP AND VALVE EVENTS LOG).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

PLANT STATUS:

LAST IE SITE INSPECTION DATE: NOV 17, 1987

INSPECTION REPORT NO: 50-482/87-36

R E P O R T S F R O M L I C E N S E E

| NUMBER | DATE OF EVENT | DATE OF REPORT | SUBJECT |
|--------|---------------|----------------|---------|
| NONE | | | |

1. Docket: 50-029 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: S. WHIPPLE (617) 872-8100

4. Licensed Thermal Power (MWT): 600

5. Nameplate Rating (Gross MWe): 185 X 1.0 = 185

6. Design Electrical Rating (Net MWe): 175

7. Maximum Dependable Capacity (Gross MWe): 180

8. Maximum Dependable Capacity (Net MWe): 167

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|----------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>239,949.0</u> |
| 13. Hours Reactor Critical | <u>677.1</u> | <u>2,117.1</u> | <u>193,230.0</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 15. Hrs Generator On-Line | <u>654.6</u> | <u>2,094.6</u> | <u>188,176.0</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>361,734</u> | <u>1,181,514</u> | <u>102,794,539</u> |
| 18. Gross Elec Ener (MWH) | <u>110,514</u> | <u>358,861</u> | <u>31,143,806</u> |
| 19. Net Elec Ener (MWH) | <u>103,228</u> | <u>335,428</u> | <u>29,139,972</u> |
| 20. Unit Service Factor | <u>88.0</u> | <u>95.9</u> | <u>78.4</u> |
| 21. Unit Avail Factor | <u>88.0</u> | <u>95.9</u> | <u>78.4</u> |
| 22. Unit Cap Factor (MDC Net) | <u>83.1</u> | <u>92.0</u> | <u>74.5*</u> |
| 23. Unit Cap Factor (DER Net) | <u>79.3</u> | <u>87.8</u> | <u>71.0*</u> |
| 24. Unit Forced Outage Rate | <u>12.0</u> | <u>4.1</u> | <u>5.1</u> |
| 25. Forced Outage Hours | <u>89.4</u> | <u>89.4</u> | <u>8,993.3</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* YANKEE-ROWE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
YANKEE-ROWE 1



MARCH 1988

* Item calculated with a Weighted Average

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * YANKEE-ROWE 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|------|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 88-5 | 03/03/88 | F | 0.0 | B | 5 | | | | LOAD REDUCTION - REPAIR NO. 1 HEATER DRAIN PUMP. |
| 88-6 | 03/12/88 | F | 0.0 | A | 5 | | | | LOAD REDUCTION - CONDENSER LEAK CHECK/TUBE PLUGGING. |
| 88-7 | 03/16/88 | F | 0.0 | A | 5 | | | | LOAD REDUCTIONS - REPAIR NO. 1 AND NO. 2 HEATER DRAIN PUMP. |
| 88-8 | 03/22/88 | F | 68.7 | A | 3 | 88-2 | JC | XFMR | FAILED SOLA TRANSFORMER FOR NUCLEAR INSTRUMENTATION CABINET A. REPLACED TRANSFORMER. |
| 88-9 | 03/26/88 | F | 20.7 | A | 3 | 88-3 | JB | JX | STEAM GENERATOR NO. 2 FEEDWATER FLOW CONTROLLER ERRATIC. REPLACED FLOW CONTROLLER POWER SUPPLY. |

 * SUMMARY *

 YANKEE ROWE INCURRED 3 FORCED POWER REDUCTIONS AND 2 FORCED OUTAGES IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* YANKEE-ROWE 1 *

F A C I L I T Y D A T A

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....MASSACHUSETTS
COUNTY.....FRANKLIN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI NE OF
PITTSFIELD, MASS
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 19, 1960
DATE ELEC ENER 1ST GENER...NOVEMBER 10, 1960
DATE COMMERCIAL OPERATE...JULY 1, 1961
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...DEERFIELD RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....YANKEE ATOMIC ELECTRIC
CORPORATE ADDRESS.....1671 WORCESTER RD.
FRAMINGHAM, MASSACHUSETTS 01701
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....H. EICHENHOLZ
LICENSING PROJ MANAGER....M. FAIRTILE
DOCKET NUMBER.....59-029
LICENSE & DATE ISSUANCE...DPR-3, DECEMBER 24, 1963
PUBLIC DOCUMENT ROOM.....GREENFIELD COMMUNITY COLLEGE
1 COLLEGE DRIVE
GREENFIELD, MASSACHUSETTS 01301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

10 CFR 50, PART 50.72(B)(I)(A) REQUIRES THE LICENSEE TO NOTIFY THE NRC OPERATIONS CENTER VIA THE EMERGENCY NOTIFICATION SYSTEM AS SOON AS PRACTICAL AND IN ALL CASES WITHIN ONE HOUR OF THE OCCURENCE OF THE INITIATION OF ANY NUCLEAR PLANT SHUTDOWN REQUIRED BY THE PLANT'S TS. CONTRARY TO THE ABOVE, THE REQUIERMENT OF 10 CFR 50.72(B)(I)(A) WAS NOT MET ON DECEMBER 3, 1987, IN THAT THE NRC WAS NOT NOTIFIED WITHIN ONE HOUR OF THE INITIATION OF PLANT SHUTDOWN AS REQUIRED BY TS 3.0.3. SPECIFICALLY, THE CHANNEL 1 MAIN STEAM LINE PRESSURE SWITCH ON THE NO 3 STEAM LINE WAS DECLARED INOPERABLE AT 10:40 A.M. TS TABLE 3.3.2 ACTION STATEMENT 6 REQUIRES THAT THE INOPERABLE CHANNEL BE PLACES IN THE TRIPPED CONDITION WITHIN ONE HOUR; IF NOT, PLANT SHUTDOWN IS TO BE INITIATED IN ACCORDANCE WITH TS 3.0.3. PLANT SHUTDOWN WAS INITIATED AT 11:40 A.M. AS REQUIRED BY TS; HOWEVER, THE REQUIRED ENS NOTIFICATION TO THE NRC PER 10 CFR 50.72(B) WAS NOT MADE UNTIL 1:40 P.M., ONE HOUR LATE.
(8701 5)

OTHER ITEMS

XX
* YARKEE-ROWE 1 *
XX

INSPECTION STATUS - (CONTINUED)

Report Period MAR 1988

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

=====

| NUMBER | DATE OF EVENT | DATE OF REPT | SUBJECT |
|--------|------------------|-----------------|---------|
|--------|------------------|-----------------|---------|

NO INPUT PROVIDED.

1. Docket: 50-295 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: GERRI AUSTIN (312) 746-2084

4. Licensed Thermal Power (Mwt): 3250

5. Nameplate Rating (Gross MWe): 1220 X 0.9 = 1098

6. Design Electrical Rating (Net MWe): 1040

7. Maximum Dependable Capacity (Gross MWe): 1085

8. Maximum Dependable Capacity (Net MWe): 1040

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any:
NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|---------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>124,920.0</u> |
| 13. Hours Reactor Critical | <u>.0</u> | <u>1,306.2</u> | <u>87,391.6</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>2,621.8</u> |
| 15. Hrs Generator On-Line | <u>.0</u> | <u>1,306.2</u> | <u>84,846.7</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>.0</u> | <u>3,999,310</u> | <u>245,225,637</u> |
| 18. Gross Elec Ener (MWH) | <u>.0</u> | <u>1,362,489</u> | <u>78,578,098</u> |
| 19. Net Elec Ener (MWH) | <u>-5,218</u> | <u>1,300,046</u> | <u>74,672,439</u> |
| 20. Unit Service Factor | <u>.0</u> | <u>59.8</u> | <u>67.9</u> |
| 21. Unit Avail Factor | <u>.0</u> | <u>59.8</u> | <u>67.9</u> |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u> | <u>57.2</u> | <u>57.5</u> |
| 23. Unit Cap Factor (DER Net) | <u>.0</u> | <u>57.2</u> | <u>57.5</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.9</u> | <u>12.7</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>12.0</u> | <u>11,680.2</u> |


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 04/30/88

* ZION 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ZION 1



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

* ZION 1 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System | Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|--------|-----------|---|
| 1 | 02/24/88 | S | 744.0 | C | 4 | | | | CYCLE 10-11 REFUELING OUTAGE. |

 * SUMMARY *

 ZION 1 REMAINED SHUTDOWN IN MARCH FOR SCHEDULED REFUELING
 OUTAGE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* ZION 1 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LAKE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI N OF
CHICAGO, ILL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 19, 1973
DATE ELEC ENER 1ST GENER...JUNE 28, 1973
DATE COMMERCIAL OPERATE...DECEMBER 31, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....M. HCLZMER
LICENSING PROJ MANAGER.....J. NORRIS
DOCKET NUMBER.....50-295
LICENSE & DATE ISSUANCE...DPR-39, OCTOBER 19, 1973
PUBLIC DOCUMENT ROOM.....WAUKEGAN PUBLIC LIBRARY
128 N. COUNTY STREET
WAUKEGAN, ILLINOIS 60085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON FEBRUARY 1 THROUGH 19, 1988 (88008; 88009). THE SPECIAL INSPECTION REVIEWED THE CIRCUMSTANCES SURROUNDING THE INADEQUATE SEARCH OF PACKAGED MATERIAL WHICH WAS OBSERVED ON FEBRUARY 1, 1988. ONE VIOLATION WAS IDENTIFIED AND IS DESCRIBED BELOW:

ACCESS CONTROL PACKAGES: A PACKAGE ENTERING THE PROTECTED AREA WAS NOT SEARCHED AS REQUIRED. (DETAILS: UNCLASSIFIED SAFEGUARDS INFORMATION)

INSPECTION ON SEPTEMBER 14-18, 1987 (87024; 87025). SPECIAL, ANNOUNCED INSPECTION OF THE CHECK VALVE TESTING PROGRAM, CHECK VALVE LOCATION, CHECK VALVE MAINTENANCE AND FAILURE HISTORY, AND THE RESPONSE TO THE INSTITUTE OF NUCLEAR POWER OPERATION'S (INPO) SIGNIFICANT OPERATING EVENT REPORT (SOER) 86-3. THE FINDINGS OF THIS INSPECTION WERE THAT (1) PRESSURE ISOLATION VALVES ARE NOT BEING TESTED INDIVIDUALLY AS REQUIRED BY AN NRC CONFIRMATORY ORDER ISSUED FEBRUARY 29, 1980; (2) VALVE TESTING DOES NOT ENSURE THAT ALL SAFETY FUNCTIONS WILL BE FULFILLED; (3) TEST PROCEDURES DO NOT RESULT IN VALID TESTS OF ALL VALVES LISTED AS BEING TESTED; AND (4) VALVES FAILING LEAK.

1. Docket: 50-304 OPERATING STATUS

2. Reporting Period: 03/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: GERRI AUSTIN (312) 746-2084

4. Licensed Thermal Power (MWh): 3250

5. Nameplate Rating (Gross MWe): 1220 X 0.9 = 1098

6. Design Electrical Rating (Net MWe): 1040

7. Maximum Dependable Capacity (Gross MWe): 1085

8. Maximum Dependable Capacity (Net MWe): 1040

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

| | MONTH | YEAR | CUMULATIVE |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs | <u>744.0</u> | <u>2,184.0</u> | <u>118,633.0</u> |
| 13. Hours Reactor Critical | <u>744.0</u> | <u>2,184.0</u> | <u>86,956.6</u> |
| 14. Rx Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>226.1</u> |
| 15. Hrs Generator On-Line | <u>744.0</u> | <u>2,184.0</u> | <u>84,548.3</u> |
| 16. Unit Reserve Shtdwn Hrs | <u>.0</u> | <u>.0</u> | <u>.0</u> |
| 17. Gross Therm Ener (MWH) | <u>2,172,524</u> | <u>6,683,176</u> | <u>251,376,943</u> |
| 18. Gross Elec Ener (MWH) | <u>729,724</u> | <u>2,251,596</u> | <u>79,593,729</u> |
| 19. Net Elec Ener (MWH) | <u>700,469</u> | <u>2,158,976</u> | <u>75,784,796</u> |
| 20. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>71.3</u> |
| 21. Unit Avail Factor | <u>100.0</u> | <u>100.0</u> | <u>71.3</u> |
| 22. Unit Cap Factor (MDC Net) | <u>90.5</u> | <u>95.1</u> | <u>61.4</u> |
| 23. Unit Cap Factor (DER Net) | <u>93.5</u> | <u>95.1</u> | <u>61.4</u> |
| 24. Unit Forced Outage Rate | <u>.0</u> | <u>.0</u> | <u>14.0</u> |
| 25. Forced Outage Hours | <u>.0</u> | <u>.0</u> | <u>13,795.9</u> |

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown, Estimated Startup Date: N/A

XX
* ZION 2 *
XX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ZION 2



MARCH 1988

Report Period MAR 1988

UNIT SHUTDOWNS / REDUCTIONS

 * ZION 2 *

| No. | Date | Type | Hours | Reason | Method | LER Number | System Component | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|------|-------|--------|--------|------------|------------------|---|
| 3 | 03/12/88 | S | 0.0 | A | 5 | | | STARTED RAMP DOWN TO 65% DUE TO DISCOVERY THAT 3 "Q" TYPE STEAM GENERATOR SAFETIES WERE IMPROPERLY SET. |
| 4 | 03/29/88 | S | 0.0 | A | 5 | | | LOAD REDUCTION DUE TO LOSS OF CONTROL ROD DRIVE VENT FANS. 2A CONTROL ROD DRIVE VENT FAN WAS RESTARTED AND LOAD REDUCTION WAS THEN STOPPED. |

 * SUMMARY *

 ZION 2 INCURRED 2 LOAD REDUCTIONS IN MARCH FOR REASONS STATED ABOVE.

| Type | Reason | Method | System & Component |
|----------|--------------------------|----------------|-------------------------|
| F-Forced | A-Equip Failure | 1-Manual | Exhibit F & H |
| S-Sched | B-Maint or Test | 2-Manual Scram | Instructions for |
| | C-Refueling | 3-Auto Scram | Preparation of |
| | D-Regulatory Restriction | 4-Continued | Data Entry Sheet |
| | E-Operator Training | 5-Reduced Load | Licensee Event Report |
| | & License Examination | 9-Other | (LER) File (NUREG-0161) |

* ZION 2 *

FACILITY DATA

Report Period MAR 1988

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LAKE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI N OF
CHICAGO, ILL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 24, 1973
DATE ELEC ENER 1ST GENER...DECEMBER 26, 1973
DATE COMMERCIAL OPERATE....SEPTEMBER 17, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....M. HOLZMER
LICENSING PROJ MANAGER.....J. NOPRIS
DOCKET NUMBER.....50-304
LICENSE & DATE ISSUANCE....DPR-48, NOVEMBER 14, 1973
PUBLIC DOCUMENT ROOM.....WAUKEGAN PUBLIC LIBRARY
128 N. COUNTY ST/LET
WAUKEGAN, ILLINOIS 60085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON FEBRUARY 1 THROUGH 19, 1988 (88008; 88009). THE SPECIAL INSPECTION REVIEWED THE CIRCUMSTANCES SURROUNDING THE INADEQUATE SEARCH OF PACKAGED MATERIAL WHICH WAS OBSERVED ON FEBRUARY 1, 1988. ONE VIOLATION WAS IDENTIFIED AND IS DESCRIBED BELOW:

ACCESS CONTROL PACKAGES: A PACKAGE ENTERING THE PROTECTED AREA WAS NOT SEARCHED AS REQUIRES. (DETAILS: UNCLASSIFIED SAFEGUARDS INFORMATION)

INSPECTION ON SEPTEMBER 14-18, 1987 (87024; 87025). SPECIAL, ANNOUNCED INSPECTION OF THE CHECK VALVE TESTING PROGRAM, CHECK VALVE LOCATION, CHECK VALVE MAINTENANCE AND FAILURE HISTORY, AND THE RESPONSE TO THE INSTITUTE OF NUCLEAR POWER OPERATION'S (INPO) SIGNIFICANT OPERATING EVENT REPORT (SOER) 86-3. THE FINDINGS OF THIS INSPECTION WERE THAT (1) PRESSURE ISOLATION VALVES ARE NOT BEING TESTED INDIVIDUALLY AS REQUIRED BY AN NRC CONFIRMATORY ORDER ISSUED FEBRUARY 29, 1980; (2) VALVE TESTING DOES NOT ENSURE THAT ALL SAFETY FUNCTIONS WILL BE FULFILLED; (3) TEST PROCEDURES DO NOT RESULT IN VALID TESTS OF ALL VALVES LISTED AS BEING TESTED; AND (4) VALVES FAILING LEAK.

SECTION 3

APPENDIX

* PRESSURIZED STATUS OF SPENT FUEL STORAGE CAPABILITY

* WATER

* REACTORS * (a)

| FACILITY ***** | CORE SIZE (NO. OF ASSEMBLIES) ***** | PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) ***** | NO. OF ASSEMBLIES STORED ***** | REMAINING CAPACITY (NO. OF ASSEMBLIES) ***** | REMAINING CAPACITY IF PENDING REQUEST | NEXT REFUEL SCHD. DATE ***** | WILL FILL PRESENT AUTH. CAPACITY ***** |
|-------------------|--|--|--------------------------------------|--|--|------------------------------------|--|
| | | | | | APPROVED (NO. OF ASSEMBLIES) ***** | | |
| ARKANSAS 1 | 177 | 968 | 488 | 480 | | 09-88 | 1997 |
| ARKANSAS 2 | 177 | 988 | 289 | 699 | | 02-88 | 1999 |
| BEAVER VALLEY 1 | 157 | 833 | 284 | 549 | | 12-87 | 1995 |
| BEAVER VALLEY 2 | | | | | | N/S | |
| BRAIDWOOD 1 | 193 | 1050 | 0 | 1050 | | N/S | |
| BYRON 1 | 193 | 1050 | 0 | 1050 | | N/S | 1995 |
| BYRON 2 | 193 | 1050 | 0 | 1050 | | N/S | |
| CALLAWAY 1 | 193 | 1340 | 180 | 1160 | | 03-89 | 2005 |
| CALVERT CLIFFS 1 | 217 | 1830(c) | 1138(c) | 692(c) | | 04-88 | 1991 |
| CALVERT CLIFFS 2 | 217 | | | | | 04-89 | 1991 |
| CATAWBA 1 | 193 | 1418 | 132 | 1286 | | 12-88 | 2011 |
| CATAWBA 2 | 193 | 1418 | 0 | 1418 | | 12-87 | 2013 |
| COOK 1 | 193 | 2050(c) | 866(c) | 1184(c) | | N/S | 1994 |
| COOK 2 | 193 | | | | | N/S | 1994 |
| CRYSTAL RIVER 3 | 177 | 1163 | 328 | 829 | | 09-87 | 1997 |
| DAVIS-BESSE 1 | 177 | 735 | 204 | 531 | | 03-88 | 1993 |
| DIABLO CANYON 1 | 193 | 1400 | 0 | 1400 | | 03-88 | 1993 |
| DIABLO CANYON 2 | 193 | 1400 | | 1400 | | N/S | |
| FARLEY 1 | 157 | 1407 | 273 | 1134 | | 03-88 | 1991 |
| FARLEY 2 | 157 | 1407 | 240 | 1167 | | 10-87 | 1994 |
| FORT CALHOUN 1 | 133 | 729 | 393 | 336 | | 09-88 | 1996 |
| GINNA | 121 | 1016 | 420 | 596 | | 02-88 | 1993 |
| HADDAM NECK | 157 | 1168 | 653 | 515 | | 07-87 | 1996 |
| HARRIS 1 | 157 | | 0 | | | N/S | |
| INDIAN POINT 1(d) | 0 | 288 | 160 | 128 | | N/S | |
| INDIAN POINT 2 | 193 | 980 | 460 | 520 | | 10-87 | 1993 |
| INDIAN POINT 3 | 193 | 840 | 292 | 548 | | N/S | 1993 |
| KEWAUNEE | 121 | 990 | 376 | 614(m) | | 03-88 | 1993 |
| MAINE YANKEE | 217 | 1476 | 721 | 755 | | N/S | 1987 |
| MCGUIRE 1 | 193 | 1463 | 293 | 1170(n) | | 11-88 | 2010 |
| MCGUIRE 2 | 193 | 1463 | 424 | 1039 | | 05-88 | 2010 |
| MILLSTONE 2 | 217 | 1277 | 512 | 765 | | 01-88 | 1994 |
| MILLSTONE 3 | 193 | 756 | 84 | 672 | | 06-89 | 1996 |
| NORTH ANNA 1 | 157 | 1737(c) | 520(c) | 1217 | | 04-87 | 1993 |
| NORTH ANNA 2 | 157 | | | | | 10-87 | 1993 |
| OCONEE 1 | 177 | 1312(1) | 874 | 438(1)(n) | | 02-89 | 1991 |
| OCONEE 2 | 177 | | | | | 02-88 | 1991 |
| OCONEE 3 | 177 | 875 | 513 | 362 | | 07-88 | 1991 |
| FALISADES | 204 | 798 | 477 | 321 | | N/S | 2002 |
| PALO VERDE 1 | 241 | 1329 | 80 | 1249 | | 10-87 | 2006 |
| PALO VERDE 2 | 241 | 1329 | 0 | 1329 | | 02-88 | 2006 |
| PALO VERDE 3 | 241 | 1329 | 0 | 0 | | 02-89 | 2007 |
| POINT BEACH 1 | 121 | 1502(c) | 875(c) | 626(c) | | 04-88 | 1995 |
| POINT BEACH 2 | 121 | | | | | N/S | 1995 |
| PRAIRIE ISLAND 1 | 121 | 1586(c) | 781(c) | 805(c)(m) | | N/S | 1993 |
| PRAIRIE ISLAND 2 | 121 | | | | | 01-88 | 1993 |
| RANCHO SECO 1 | 177 | 1080 | 316 | 764 | | 03-89 | 2001 |

* PRESSURIZED* STATUS OF SPENT FUEL STORAGE CAPABILITY
 * WATER *
 * REACTORS * (a)

| FACILITY ***** | (a) | | NO. OF ASSEMBLIES STORED ***** | REMAINING CAPACITY (NO. OF ASSEMBLIES) ***** | REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) ***** | NEXT REFUEL SCHED. DATE ***** | (b) WILL FILL PRESENT AUTH. CAPACITY ***** |
|---------------------|--|--|--------------------------------------|--|--|-------------------------------------|---|
| | CORE SIZE (NO. OF ASSEMBLIES) ***** | PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) ***** | | | | | |
| ROBINSON 2 | 157 | 541 | 274 | 266(e) | 379 | N/S | 1988(g) |
| SALEM 1 | 193 | 1170 | 464 | 706 | | 03-89 | 2001 |
| SALEM 2 | 193 | 1170 | 224 | 946 | | 09-88 | 2003 |
| SAN ONOFRE 1 | 157 | 216 | 146 | 70 | | 07-88 | 1988 |
| SAN ONOFRE 2 | 217 | 803 | 268 | 532 | | 08-89 | 1997 |
| SAN ONOFRE 3 | 217 | 800 | 160 | 640 | | 04-88 | 1997 |
| SEQUOYAH 1 | 193 | 1386 | 348 | 1033 | | N/S | 1994 |
| SEQUOYAH 2 | 193 | | | | | N/S | 1994 |
| SOUTH TEXAS 1 | 0 | 0 | 0 | 0 | | | |
| ST LUCIE 1 | 217 | 728 | 372 | 356 | | N/S | 1993 |
| ST LUCIE 2 | 217 | 1076 | 152 | 924 | | N/S | 1993 |
| SUMMER 1 | 157 | 1276 | 96 | 1180 | | N/S | 2008 |
| SURRY 1 | 157 | 1044(c) | 901(c) | 143(c) | | N/S | 1987 |
| SURRY 2 | 157 | | | | | N/S | 1987 |
| THREE MILE ISLAND 1 | 177 | 752 | 284 | 468 | | 07-88 | 1991 |
| THREE MILE ISLAND 2 | 177 | 442 | 0 | 442 | | N/S | |
| TROJAN | 193 | 1408 | 425 | 983 | | 04-88 | 1993 |
| TURKEY POINT 3 | 157 | 1404 | 445 | 959(m) | | N/S | 1993 |
| TURKEY POINT 4 | 157 | 1404 | 482 | 922 | | N/S | 1993 |
| VOGTLE 1 | 0 | 0 | 0 | 0 | | N/S | |
| WATERFORD 3 | 217 | 1088 | 0 | 1088 | | N/S | 1993 |
| WOLF CREEK 1 | 193 | 1340 | 0 | 1340 | | 04-88 | |
| YANKEE-ROWE 1 | 76 | 721 | 325 | 396 | | N/S | 1993 |
| ZION 1 | 193 | 2112(c) | 1148(c) | 964(c) | | 02-88 | 1995 |
| ZION 2 | 193 | | | | | 10-88 | 1995 |

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

| | | | | |
|-------------------|------------|---------|------------|-------------|
| MORRIS OPERATIONS | 750 MTU(j) | 315 | 385 MTU(j) | 1490 MTU(j) |
| NFS(i) | 250 MTU | 170 MTU | 80 MTU | |

(a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.

(b) Some of these dates have been adjusted by staff assumptions.

(c) This is the total for both units.

(d) Plant not in commercial operation.

(e) Some spent fuel stored at Brunswick.

(f) Authorized a total 2772 BWR and 1232 PWR assemblies for both pools.

(g) Robinson 2 assemblies being shipped to Brunswick for storage.

(h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.

(i) No longer accepting spent fuel.

(j) Racked for 700 MTU.

(k) Reserved.

(l) This is the station total.

(m) Installed capacity is less than that authorized.

(n) McGuire 1 authorized to accept Oconee fuel assemblies.

 N/S = Not Scheduled

* BOILING * STATUS OF SPENT FUEL STORAGE CAPABILITY

* WATER *

* REACTORS *

| FACILITY | (a) | PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) | NO. OF ASSEMBLIES STORED | REMAINING CAPACITY (NO. OF ASSEMBLIES) | REMAINING CAPACITY | NEXT REFUEL SCHED. DATE | (b) |
|------------------|-------------------------------|---|--------------------------|--|---|-------------------------|----------------------------------|
| | CORE SIZE (NO. OF ASSEMBLIES) | | | | IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) | | WILL FILL PRESENT AUTH. CAPACITY |
| BIG ROCK POINT 1 | 84 | 441 | 212 | 229 | | 04-88 | 1995 |
| BROWNS FERRY 1 | 764 | 3471 | 1288 | 2183 | | N/S | 1993 |
| BROWNS FERRY 2 | 764 | 3471 | 1161 | 2310(m) | 1819 | N/S | 1993 |
| BROWNS FERRY 3 | 764 | 3471 | 1004 | 2467(m) | | N/S | 1993 |
| BRUNSWICK 1 | 560 | 1803 | 169PWR+1016BWR | 787 | | 11-88 | 1990 |
| BRUNSWICK 2 | 560 | 1839 | 144PWR+940BWR | 899 | | 01-88 | 1991 |
| CLINTON 1 | 624 | 2672 | 0 | 2672 | | 12-89 | 2010 |
| COOPER STATION | 548 | 2366 | 790 | 1576 | | 03-88 | 1996 |
| DRESDEN 1 (d) | 464 | 672 | 221 | 451 | | N/S | 1990 |
| DRESDEN 2 | 724 | 3537 | 1413 | 2124 | | N/S | 1993 |
| DRESDEN 3 | 724 | 3537 | 1271 | 2266 | | 03-88 | 1993 |
| DUANE ARNOLD | 368 | 2050 | 824 | 1226 | | 10-88 | 1998 |
| FERMI 2 | | | | | | N/S | |
| FITZPATRICK | 560 | 2244 | 1200 | 484 | | 08-88 | 1992 |
| GRAND GULF 1 | 800 | 1440 | 0 | 1440 | | 11-87 | 1993 |
| HATCH 1 | 560 | 6026 | 1580 | 4446 | | N/S | 1999 |
| HATCH 2 | 560 | | | 1325 | | 03-88 | 1999 |
| HOPE CREEK 1 | | | | | | 02-88 | |
| HUMBOLDT BAY(d) | 172 | 487 | 251 | 236 | | N/S | |
| LA CROSSE (d) | 72 | 440 | 261 | 179 | | N/S | 1992 |
| LASALLE 1 | 764 | 2162 | 191 | 1971 | | 03-88 | 1988 |
| LASALLE 2 | 764 | | | | | N/S | 1988 |
| LIMERICK 1 | 764 | 2040 | 0 | 2040 | | N/S | 1993 |
| MILLSTONE 1 | 580 | 2184 | 1732 | 452 | | 03-89 | 1987 |

* BOILING * STATUS OF SPENT FUEL STORAGE CAPABILITY
 * WATER *
 * REACTORS * (a)

| FACILITY ***** | (a) | | NO. OF ASSEMBLIES STORED ***** | REMAINING CAPACITY (NO. OF ASSEMBLIES) ***** | REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) ***** | NEXT REFUEL SCHED. DATE ***** | (b) WILL FILL PRESENT AUTH. CAPACITY ***** |
|---------------------|--|--|--------------------------------------|--|--|-------------------------------------|---|
| | CORE SIZE (NO. OF ASSEMBLIES) ***** | PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) ***** | | | | | |
| MONTICELLO | 484 | 2237 | 822 | 1415 | | 12-87 | 1999 |
| NINE MILE POINT 1 | 532 | 2776 | 1377 | 1399 | | 03-88 | 1996 |
| NINE MILE POINT 2 | | | | | 1788 | N/S | |
| OYSTER CREEK 1 | 560 | 2600 | 1392 | 1208 | | N/S | |
| PEACH BOTTOM 2 | 764 | 3819 | 1462 | 2357 | | 03-87 | 1994 |
| PEACH BOTTOM 3 | 764 | 3819 | 1496 | 2323 | | 03-87 | 1995 |
| PERRY 1 | 0 | 0 | 0 | 0 | | 03-87 | 1996 |
| PILGRIM 1 | 580 | 2320 | 1320 | 1000 | | N/S | |
| QUAD CITIES 1 | 724 | 3657 | 1773 | 1884 | | 09-89 | 1990 |
| QUAD CITIES 2 | 724 | 3897 | 1311 | 2586 | | 06-89 | 2008 |
| RIVER BEND 1 | | | | | | 04-88 | 2008 |
| SUSQUEHANNA 1 | 764 | 2840 | 382 | 2458 | | 09-87 | |
| SUSQUEHANNA 2 | 764 | 2840 | 0 | 2840 | | N/S | 1997 |
| VERMONT YANKEE 1 | 368 | 2000 | 1296 | 704 | | 03-88 | 1997 |
| WASHINGTON NUCLEAR* | 764 | 2658 | 272 | 2386 | | N/S | 1992 |
| | | | | | | 04-88 | 1995 |

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

| | | | | |
|-------------------|------------|---------|------------|-------------|
| MORRIS OPERATIONS | 750 MTU(j) | 315 | 385 MTU(j) | 1490 MTU(j) |
| NFS(i) | 250 MTU | 170 MTU | 80 MTU | |

- (a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.
- (b) Some of these dates have been adjusted by staff assumptions.
- (c) This is the total for both units.
- (d) Plant not in commercial operation.
- (e) Some spent fuel stored at Brunswick.
- (f) Authorized a total 2772 BWR and 1232 PWR assemblies for both pools.
- (g) Robinson 2 assemblies being shipped to Brunswick for storage.
- (h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.
- (i) No longer accepting spent fuel.
- (j) Racked for 700 MTU.
- (k) Reserved.
- (l) This is the station total.
- (m) Installed capacity is less than that authorized.
- (n) McGuire 1 authorized to accept Oconee fuel assemblies.

 N/S = Not Scheduled

| ***** | | | | ***** | | | | ***** | | | |
|----------------|-------|----------------------|------------------|-------|----------------------|-------------------|-------|----------------------|----------------------|--|--|
| | YEARS | 1ST ELEC GENERATE | UNIT | YEARS | 1ST ELEC GENERATE | UNIT | YEARS | 1ST ELEC GENERATE | UNIT | | |
| * LICENSED * | 13.67 | 08/01/74 | ARKANSAS 1 | 9.26 | 12/26/78 | ARKANSAS 2 | 11.80 | 06/14/76 | BEAVER VALLEY 1 | | |
| * OPERATING * | .62 | 08/17/87 | BEAVER VALLEY 2 | 25.31 | 12/03/62 | BIG ROCK POINT 1 | .72 | 07/12/87 | BRAEDHOOD 1 | | |
| * ELECTRICAL * | 14.46 | 10/15/73 | BROWNS FERRY 1 | 13.59 | 08/28/74 | BROWNS FERRY 2 | 11.55 | 09/12/76 | BROWNS FERRY 3 | | |
| * PRODUCING * | 11.32 | 12/04/76 | BRUNSWICK 1 | 12.93 | 04/29/75 | BRUNSHICK 2 | 3.09 | 03/01/85 | BYRON 1 | | |
| * UNITS * | 1.15 | 02/06/87 | BYRON 2 | 3.44 | 10/24/84 | CALLAHAY 1 | 13.24 | 01/03/75 | CALVERT CLIFFS 1 | | |
| ***** | 11.32 | 12/07/76 | CALVERT CLIFFS 2 | 3.19 | 01/22/85 | CATAWBA 1 | 1.87 | 05/18/86 | CATAWBA 2 | | |
| | .94 | 04/24/87 | CLINTON 1 | 13.14 | 02/10/75 | COOK 1 | 10.03 | 03/22/78 | COOK 2 | | |
| | 13.89 | 05/10/75 | COOPER STATION | 11.17 | 01/30/77 | CRYSTAL RIVER 3 | 10.59 | 08/28/77 | DAVIS-BESSE 1 | | |
| | 3.39 | 11/11/84 | DIABLO CANYON 1 | 2.45 | 10/20/85 | DIABLO CANYON 2 | 17.97 | 04/13/70 | DRESDEN 2 | | |
| | 16.70 | 07/22/71 | DRESDEN 3 | 13.87 | 05/19/74 | DUANE ARNOLD | 10.62 | 08/18/77 | FARLEY 1 | | |
| | 6.85 | 05/25/81 | FARLEY 2 | 1.53 | 09/21/86 | FERMI 2 | 13.16 | 02/01/75 | FITZPATRICK | | |
| | 14.60 | 08/25/73 | FORT CALHOUN 1 | 11.30 | 12/11/76 | FORT ST VRAIN | 18.33 | 12/02/69 | GINNA | | |
| | 3.45 | 10/20/84 | GRAND GULF 1 | 20.65 | 08/07/67 | HADDAM NECK | 1.20 | 01/19/87 | HARRIS 1 | | |
| | 13.39 | 11/11/74 | HATCH 1 | 9.52 | 09/22/78 | HATCH 2 | 1.67 | 08/01/86 | HOPE CREEK 1 | | |
| | 14.77 | 06/26/73 | INDIAN POINT 2 | 11.93 | 04/27/76 | INDIAN POINT 3 | 13.98 | 04/08/74 | KEWAUNEE | | |
| | 5.57 | 09/04/82 | LASALLE 1 | 3.95 | 04/20/84 | LASALLE 2 | 2.97 | 04/13/85 | LIMERICK 1 | | |
| | 15.39 | 11/08/72 | MAINE YANKEE | 6.75 | 06/30/81 | MCGUIRE 1 | 4.86 | 05/23/83 | MCGUIRE 2 | | |
| | 17.34 | 11/29/70 | MILLSTONE 1 | 12.39 | 11/09/75 | MILLSTONE 2 | 2.13 | 02/12/86 | MILLSTONE 3 | | |
| | 17.08 | 03/05/71 | MONTICELLO | 18.39 | 11/09/69 | NINE MILE POINT 1 | .65 | 08/08/87 | NINE MILE POINT 2 | | |
| | 9.96 | 04/17/78 | NORTH ANNA 1 | 7.60 | 08/25/80 | NORTH ANNA 2 | 14.90 | 05/06/73 | OCONEE 1 | | |
| | 14.32 | 12/05/73 | OCONEE 2 | 13.58 | 09/01/74 | OCONEE 3 | 18.52 | 09/23/69 | OYSTER CREEK 1 | | |
| | 16.25 | 12/31/71 | PALISADES | 2.81 | 06/10/85 | PALO VERDE 1 | 1.87 | 05/20/86 | PALO VERDE 2 | | |
| | .34 | 11/28/87 | PALO VERDE 3 | 14.12 | 02/18/74 | PEACH BOTTOM 2 | 13.58 | 09/01/74 | PEACH BOTTOM 3 | | |
| | 1.28 | 12/19/86 | PERRY 1 | 15.70 | 07/19/72 | PILGRIM 1 | 17.40 | 11/06/70 | POINT BEACH 1 | | |
| | 15.66 | 08/02/72 | POINT BEACH 2 | 14.32 | 12/04/73 | PRAIRIE ISLAND 1 | 13.28 | 12/21/74 | PRAIRIE ISLAND 2 | | |
| | 15.97 | 04/12/72 | QUAD CITIES 1 | 15.86 | 05/23/72 | QUAD CITIES 2 | 13.47 | 10/13/74 | RANCHO SECO 1 | | |
| | 2.33 | 12/03/85 | RIVER BEND 1 | 17.51 | 09/26/70 | ROBINSON 2 | 11.27 | 12/25/76 | SALEM 1 | | |
| | 6.83 | 06/03/81 | SALEM 2 | 20.71 | 07/16/67 | SAN ONOFRE 1 | 5.53 | 09/20/82 | SAN ONOFRE 2 | | |
| | 4.52 | 09/25/83 | SAN ONOFRE 3 | 7.69 | 07/22/80 | SEQUOYAH 1 | 6.27 | 12/23/81 | SEQUOYAH 2 | | |
| | .01 | 03/30/88 | SOUTH TEXAS 1 | 11.90 | 05/07/76 | ST LUCIE 1 | 4.80 | 06/13/83 | ST LUCIE 2 | | |
| | 5.37 | 11/16/82 | SUMNER 1 | 15.74 | 07/04/72 | SURRY 1 | 15.06 | 05/10/73 | SURRY 2 | | |
| | 5.37 | 11/16/82 | SUSQUEHANNA 1 | 3.75 | 07/03/84 | SUSQUEHANNA 2 | 13.79 | 06/19/74 | THREE MILE ISLAND 1 | | |
| | 12.27 | 12/23/75 | TROJAN | 15.41 | 11/02/72 | TURKEY POINT 3 | 14.78 | 06/21/73 | TURKEY POINT 4 | | |
| | 15.53 | 09/20/72 | VERMONT YANKEE 1 | 1.02 | 03/27/87 | VOGTE 1 | 3.85 | 05/27/84 | WASHINGTON NUCLEAR 2 | | |
| | 3.04 | 03/18/85 | WATERFORD 3 | 2.80 | 06/12/85 | WOLF CREEK 1 | 27.39 | 11/10/60 | YANKEE-ROWE 1 | | |
| | 14.76 | 06/28/73 | ZION 1 | 14.26 | 12/26/73 | ZION 2 | | | | | |

TOTAL 1085.48 YRS

| ***** | | | | | ***** | | | | |
|------------------|-------|----------------------|------------------|---------------------|-------|----------------------|------------------|----------------|--|
| | YEARS | 1ST ELEC GENERATE | SHUTDOWN DATE | UNIT | YEARS | 1ST ELEC GENERATE | SHUTDOWN DATE | UNIT | |
| * PERMANENTLY * | 3.80 | 08/14/64 | 06/01/68 | BONUS | 3.04 | 12/18/63 | 01/01/67 | CVTR | |
| * OR * | 18.54 | 04/15/60 | 10/31/73 | DRESDEN 1 | 4.44 | 08/24/63 | 02/01/68 | ELK RIVER | |
| * INDEFINITELY * | 6.32 | 08/05/66 | 11/29/72 | FERMI 1 | 1.26 | 05/29/63 | 09/01/64 | HALLAM | |
| * SHUTDOWN * | 13.21 | 04/18/63 | 07/02/76 | HUMBOLDT BAY | 12.12 | 09/16/62 | 10/31/74 | INDIAN POINT 1 | |
| * UNITS * | 19.01 | 04/26/68 | 04/30/87 | LA CROSSE | 1.19 | 07/25/66 | 10/01/67 | PATHFINDER | |
| ***** | 7.76 | 01/27/67 | 11/01/74 | PEACH BOTTOM 1 | 2.16 | 11/04/63 | 01/01/66 | PIQUA | |
| | .93 | 04/21/78 | 03/28/79 | THREE MILE ISLAND 2 | | | | | |

TOTAL 93.78 YRS

 * RESEARCH *
 * REACTORS *

NON - POWER REACTORS IN THE U. S.

| STATE | CITY | LICENSEE | REACTOR TYPE | DOCKET | LICENSE NUMBER | DATE OF ISSUED | AUTHORIZED POWER LEVEL (KW) |
|------------------|---|--|---------------|--------|----------------|----------------|-----------------------------|
| ALABAMA | TUSKEGEE | TUSKEGEE INSTITUTE | AGN-201 #102 | 50-406 | R-122 | 08-30-74 | 0.0001 |
| ARIZONA | TUCSON | UNIVERSITY OF ARIZONA | TRIGA MARK I | 50-113 | R-52 | 12-05-58 | 100.0 |
| CALIFORNIA | BERKELEY | UNIVERSITY OF CALIFORNIA, BERKELEY COLLEGE | TRIGA MK. III | 50-224 | R-101 | 08-10-66 | 1000.0 |
| | CANOGA PARK | ROCKWELL INTERNATIONAL CORP. | L-85 | 50-375 | R-188 | 01-05-72 | 0.003 |
| | HAWTHORNE | NORTHROP CORP. LABORATORIES | TRIGA MARK F | 50-187 | R-90 | 03-04-63 | 1000.0 |
| | IRVINE | UNIVERSITY OF CALIFORNIA, IRVINE | TRIGA MARK I | 50-326 | R-116 | 11-24-69 | 250.0 |
| | LOS ANGELES | UNIVERSITY OF CALIFORNIA, L.A. | ARGONAUT | 50-142 | R-71 | 10-03-60 | 100.0 |
| | SAN DIEGO | GENERAL ATOMIC COMPANY | TRIGA MARK F | 50-163 | R-67 | 07-01-60 | 1500.0 |
| | SAN DIEGO | GENERAL ATOMIC COMPANY | TRIGA MARK I | 50-089 | R-38 | 05-03-58 | 250.0 |
| | SAN JOSE | GENERAL ELECTRIC COMPANY | NTR | 50-073 | R-33 | 10-31-57 | 100.0 |
| | SAN LUIS OBISPO | CALIFORNIA STATE POLYTECHNIC COLLEGE | AGN-201 #100 | 50-394 | R-121 | 05-16-73 | 0.0001 |
| | SAN RAMON | AEROTEST OPERATIONS, INC. | TRIGA (INDUS) | 50-228 | R-98 | 07-02-65 | 250.0 |
| SANTA BARBARA | UNIVERSITY OF CALIFORNIA, SANTA BARBARA | L-77 | 50-433 | R-124 | 12-03-74 | 0.01 | |
| COLORADO | DENVER | U.S. GEOLOGICAL SURVEY DEPARTMENT | TRIGA MARK I | 50-274 | R-113 | 02-24-69 | 1000.0 |
| DELAWARE | NEWARK | UNIVERSITY OF DELAWARE | AGN-201 #113 | 50-098 | R-43 | 07-03-58 | 0.0001 |
| DIST OF COLUMBIA | WASHINGTON | THE CATHOLIC UNIVERSITY OF AMERICA | AGN-201 #101 | 50-077 | R-31 | 11-15-67 | 0.0001 |
| FLORIDA | GAINESVILLE | UNIVERSITY OF FLORIDA | ARGONAUT | 50-083 | R-56 | 05-21-59 | 100.0 |
| GEORGIA | ATLANTA | GEORGIA INSTITUTE OF TECHNOLOGY | HEAVY WATER | 50-160 | R-97 | 12-29-64 | 5000.0 |
| IDAHO | POCATELLO | IDAHO STATE UNIVERSITY | AGN-201 #103 | 50-284 | R-110 | 10-11-67 | 0.0001 |
| ILLINOIS | URBANA | UNIVERSITY OF ILLINOIS | LOPRA | 50-356 | R-117 | 12-27-71 | 10.0 |
| | URBANA | UNIVERSITY OF ILLINOIS | TRIGA | 50-151 | R-115 | 07-22-69 | 1500.0 |
| | ZION | WESTINGHOUSE ELECTRIC CORP. | NTR | 50-087 | R-119 | 01-28-72 | 10.0 |
| INDIANA | LAFAYETTE | PURDUE UNIVERSITY | LOCKHEED | 50-182 | R-87 | 08-16-62 | 10.0 |
| IOWA | AMES | IOWA STATE UNIVERSITY | UTR-10 | 50-116 | R-59 | 10-16-59 | 10.0 |
| KANSAS | LAWRENCE | UNIVERSITY OF KANSAS | LOCKHEED | 50-148 | R-78 | 06-23-61 | 250.0 |
| | MANHATTAN | KANSAS STATE UNIVERSITY | TRIGA | 50-188 | R-88 | 10-16-62 | 250.0 |
| MARYLAND | BETHESDA | ARMED FORCES RADIOBIOLOGY RESEARCH INSTITUTE | TRIGA | 50-170 | R-84 | 06-26-62 | 1000.0 |
| | COLLEGE PARK | UNIVERSITY OF MARYLAND | TRIGA | 50-166 | R-70 | 10-14-60 | 250.0 |
| MASSACHUSETTS | CAMBRIDGE | MASSACHUSETTS INSTITUTE OF TECHNOLOGY | HWR REFLECTED | 50-020 | R-37 | 06-09-58 | 5000.0 |

 * RESEARCH *
 * REACTORS *

NON-POWER REACTORS IN THE U. S.

| STATE | CITY | LICENSEE | REACTOR TYPE | DOCKET | LICENSE NUMBER | DATE OF ISSUED | AUTHORIZED POWER LEVEL (KW) |
|----------------|--|--|---------------|--------|----------------|----------------|-----------------------------|
| MASSACHUSETTS | LOWELL WORCESTER | UNIVERSITY OF LOWELL WORCESTER POLYTECHNIC INSTITUTE | GE | 50-223 | R-125 | 12-24-74 | 1000.0 |
| | | | GE | 50-134 | R-61 | 12-16-59 | 10.0 |
| MICHIGAN | ANN ARBOR EAST LANSING MIDLAND | UNIVERSITY OF MICHIGAN MICHIGAN STATE UNIVERSITY DOW CHEMICAL COMPANY | POOL | 50-002 | R-28 | 09-13-57 | 2000.0 |
| | | | TRIGA MARK I | 50-294 | R-114 | 03-21-69 | 250.0 |
| | | | TRIGA | 50-264 | R-108 | 07-03-67 | 100.0 |
| MISSOURI | COLUMBIA ROLLA | UNIVERSITY OF MISSOURI, COLUMBIA UNIVERSITY OF MISSOURI | TANK | 50-186 | R-103 | 10-11-66 | 10000.0 |
| | | | POOL | 50-123 | R-79 | 11-21-61 | 200.0 |
| NEBRASKA | OMAHA | THE VETERANS ADMINISTRATION HOSPITAL | TRIGA | 50-131 | R-57 | 06-26-59 | 18.0 |
| NEW MEXICO | ALBUQUERQUE | UNIVERSITY OF NEW MEXICO | AGN-201M #112 | 50-252 | R-102 | 09-17-66 | 0.005 |
| NEW YORK | BRONX BUFFALO ITHACA ITHACA NEW YORK TUXEDO | MANHATTAN COLLEGE - PYHSICS DEPT. STATE UNIVERSITY OF NEW YORK CORNELL UNIVERSITY CORNELL UNIVERSITY COLUMBIA UNIVERSITY IN THE CITY OF NEW YORK CINTICHEM INC. | TANK | 50-199 | R-94 | 03-24-64 | 0.0001 |
| | | | PULSTAR | 50-057 | R-77 | 03-24-61 | 2000.0 |
| | | | TRIGA MARK II | 50-157 | R-80 | 01-11-62 | 100.0 |
| | | | ZPR | 50-097 | R-89 | 12-11-62 | 0.1 |
| | | | TRIGA MARK II | 50-208 | R-128 | 04-14-77 | 250.0 |
| | | | POOL | 50-054 | R-81 | 09-07-61 | 5000.0 |
| NORTH CAROLINA | RALEIGH | NORTH CAROLINA STATE UNIVERSITY AT RALEIGH | PULSTAR | 50-297 | R-120 | 08-25-72 | 1000.0 |
| OHIO | COLUMBUS | OHIO STATE UNIVERSITY | POOL | 50-150 | R-75 | 02-24-61 | 10.0 |
| OKLAHOMA | NORMAN | THE UNIVERSITY OF OKLAHOMA | AGN-211 #102 | 50-112 | R-53 | 12-29-58 | 0.015 |
| OREGON | CORVALLIS PORTLAND | OREGON STATE UNIVERSITY REED COLLEGE | TRIGA MARK II | 50-243 | R-106 | 03-07-67 | 1000.0 |
| | | | TRIGA MARK I | 50-288 | R-112 | 07-02-68 | 250.0 |
| PENNSYLVANIA | UNIVERSITY PARK | PENNSYLVANIA STATE UNIVERSITY | TRIGA MK. III | 50-005 | R-2 | 07-08-55 | 1000.0 |
| RHODE ISLAND | NARRAGANSETT | RHODE ISLAND NUCLEAR SCIENCE CENTER | GE POOL | 50-193 | R-95 | 07-21-64 | 2000.0 |
| TENNESSEE | MEMPHIS | MEMPHIS STATE UNIVERSITY | AGN-201 #108 | 50-538 | R-127 | 12-10-76 | 0.0001 |
| TEXAS | AUSTIN COLLEGE STATION COLLEGE STATION | UNIVERSITY OF TEXAS TEXAS A&M UNIVERSITY TEXAS A&M UNIVERSITY | TRIGA MARK I | 50-192 | R-92 | 08-26-63 | 250.0 |
| | | | AGN-201M #106 | 50-059 | R-23 | 08-26-57 | 0.005 |
| | | | TRIGA | 50-128 | R-83 | 12-07-61 | 1000.0 |
| UTAH | PROVO SALT LAKE CITY | BRIGHAM YOUNG UNIVERSITY THE UNIVERSITY OF UTAH | L-77 | 50-262 | R-109 | 09-07-67 | 0.01 |
| | | | TRIGA MARK I | 50-407 | R-126 | 09-30-75 | 100.0 |

 * RESEARCH *
 * REACTORS *

NON-POWER REACTORS IN THE U. S.

| STATE | CITY | LICENSEE | REACTOR TYPE | DOCKET | LICENSE NUMBER | DATE OF ISSUED | AUTHORIZED POWER LEVEL (KW) | |
|--|-----------------|----------------------------------|--------------|--------|----------------|----------------|-----------------------------|--------|
| UTAH | SALT LAKE CITY | UNIVERSITY OF UTAH | AGN-201M | #107 | 50-072 | R-25 | 09-12-57 | 0.005 |
| VIRGINIA | BLACKSBURG | VIRGINIA POLYTECHNIC INSTITUTE | UTR-10 | | 50-124 | R-62 | 12-18-59 | 100.0 |
| | CHARLOTTESVILLE | UNIVERSITY OF VIRGINIA | CAVALIER | | 50-396 | R-123 | 09-24-74 | 0.1 |
| | CHARLOTTESVILLE | UNIVERSITY OF VIRGINIA | POOL | | 50-062 | R-66 | 06-27-60 | 2000.0 |
| | LYNCHBURG | BABCOCK & WILCOX COMPANY | LPR | | 50-099 | R-47 | 09-05-58 | 1000.0 |
| WASHINGTON | PULLMAN | WASHINGTON STATE UNIVERSITY | TRIGA | | 50-027 | R-76 | 03-06-61 | 1000.0 |
| | SEATTLE | UNIVERSITY OF WASHINGTON | ARGONAUT | | 50-139 | R-73 | 03-31-61 | 100.0 |
| WISCONSIN | MADISON | UNIVERSITY OF WISCONSIN | TRIGA | | 50-156 | R-74 | 11-23-60 | 1000.0 |
| ***** * EXPERIMENTAL AND TEST REACTORS * ***** | | | | | | | | |
| CALIFORNIA | SAN JOSE | GENERAL ELECTRIC COMPANY | GETR | | 50-070 | TR-1 | 01-07-59 | 50.0 |
| DIST OF COLUMBIA | WASHINGTON | NATIONAL BUREAU OF STANDARDS | TEST | | 50-184 | TR-5 | 06-30-70 | 10.0 |
| ***** * CRITICAL EXPERIMENT FACILITIES * ***** | | | | | | | | |
| NEW YORK | TROY | RENSSELAER POLYTECHNIC INSTITUTE | | | 50-225 | CX-22 | 07-03-64 | 0.0 |
| WASHINGTON | RICHLAND | BATTELLE MEMORIAL INSTITUTE | | | 50-360 | CX-26 | 11-29-71 | 0.0 |

BIBLIOGRAPHIC DATA SHEET

NUREG-0020, Volume 12, No. 4

SEE INSTRUCTIONS ON THE REVERSE

2. TITLE AND SUB-TITLE

Licensed Operating Reactors
Status Summary Report

3. LEAVE BLANK

4. DATE REPORT COMPLETED

MONTH

YEAR

May

1988

5. DATE REPORT ISSUED

MONTH

YEAR

May

1988

5. AUTHOR(S)

Ina Schwartz

7. PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)

Division of Computer and Telecommunications Services/IRM
Office of Administration and Resources Management
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8. PROJECT/TASK/WORK UNIT NUMBER

9. FUNDING NUMBER

10. SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)

Division of Computer and Telecommunication Services/IRM
Office of Administration and Resources Management
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

11a. TYPE OF REPORT

b. PERIOD COVERED (Inclusive Dates)

March 1988

12. SUPPLEMENTARY NOTES

Status Summary Report

13. ABSTRACT (200 words or less)

The OPERATING UNITS STATUS REPORT - LICENSED OPERATING REACTORS provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Administration and Resources Management from the Headquarters staff of NRC's Office of Enforcement (OE), from NRC's Regional Offices, and from utilities. The three sections of the report are: monthly highlights and statistics for commercial operating units, and errata from previously reported data; a compilation of detailed information on each unit, provided by NRC's Regional Offices, OE Headquarters and the utilities; and an appendix for miscellaneous information such as spent fuel storage capability, reactor-years of experience and non-power reactors in the U. S. It is hoped the report is helpful to all agencies and individuals interested in maintaining an awareness of the U. S. energy situation as a whole.

14. DOCUMENT ANALYSIS - a. KEYWORDS/DESCRIPTORS

Licensed Operating Reactors
Commercial Operating Units

15. AVAILABILITY STATEMENT

16. SECURITY CLASSIFICATION

(This page)

(This report)

b. IDENTIFIERS/OPEN ENDED TERMS

17. NUMBER OF PAGES

18. PRICE

DISTRIBUTION LIST - NRC

INTERNAL DISTRIBUTION

| | |
|---|------------|
| Office of the Commissioners | 5 |
| Atomic Safety and Licensing Appeal Panel | 3 |
| Advisory Committee on Reactor Safeguards | 6 |
| Office of Inspector and Auditor | 1 |
| Office of Policy Evaluation | 1 |
| Office of the General Counsel | 1 |
| Office of Public Affairs | 21 |
| Office of Congressional Affairs | 3 |
| Office of the Executive Director for Operations | 7 |
| Office of Administration | 2 |
| Office of the Executive Legal Director | 2 |
| Office of Analysis and Evaluation of Operational Data | 2 |
| Office of International Programs | 3 |
| Office of State Programs | 1 |
| Office of Information Resources Management | 19 |
| Office of Nuclear Material Safety and Safeguards | 2 |
| - Division of Fuel Cycle and Material Safety | 3 |
| - Division of Safeguards | 2 |
| Office of Nuclear Reactor Regulation | 138 |
| - Division of Engineering | |
| - Division of Safety Technology | |
| - Division of Licensing | |
| - Division of Systems Integration | |
| - Division of Human Factors Safety | |
| Office of Nuclear Regulatory Research | 4 |
| Office of Inspection and Enforcement | 7 |
| - Region I | 11 |
| - Region II | 10 |
| - Region III | 10 |
| - Region IV | 10 |
| - Region V | 7 |
| | <u>281</u> |

EXTERNAL DISTRIBUTION

SPECIAL REQUESTS

| | |
|-----------------------------------|-----------|
| Air Force | 1 |
| Congress | 10 |
| Department of Energy | 32 |
| Government Accounting Office | 1 |
| Environmental Protection Agency | 1 |
| Electric Power Research Institute | 1 |
| Argonne National Laboratory | 3 |
| Bureau of Mines | 1 |
| Department of Agriculture | 1 |
| Department of the Commerce | 1 |
| Department of the Interior | 1 |
| | <u>53</u> |

OTHER

| | |
|--|-------------|
| GPO Depository | 440 |
| GPO Stores | 75 |
| National Technical Information Service | 25 |
| Subscriptions (NTIS) | 250 |
| Colleges and Libraries (including Public Document Rooms) | 128 |
| Utilities and Other Requests | 227 |
| | <u>1145</u> |

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

FIRST CLASS MAIL
POSTAGE & FEES PAID
USNRC
PERMIT NO. G-67

120555078877 1 1AN1NU
US NRC-0ARM-ADM
DIV OF PUB SVCS
POLICY & PUB MGT BR-PDR NUREG
W-537
WASHINGTON DC 20555