

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

NAME - PERMA. POWER & LIGHT COMPANY
 ADDRESS - 110 NORTH NINTH ST.
 ALLENTOUR, PA 18101
 ATTN: J.S. FIELDS, SR. ENV. SCIENTIST-MUC.
 TELEPHONE #215-770-7089
 FACILITY-SUSQUEHANNA S.E.S.

PERMIT NUMBER-PA0047325 DISCHARGE NUMBER-070

DESCRIPTION:
 C-2 SEDIMENTATION POND

MONITORING PERIOD - FROM 86/01/01 TO 86/01/31
 YR MO DY YR MO DY F - FINAL LIMITS

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. OF EXCURSIONS	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT							
50050 1 NOTE 2 EFFLUENT GROSS VALUE		MGD				NOT DETERMINED	PUMP RT. OR HEIR
PH						NOT DETERMINED	
00400 1 EFFLUENT GROSS VALUE			6.0 MINIMUM			1/DAY	GRAB
SOLIDS, TOTAL SUSPENDED							
00530 1 EFFLUENT GROSS VALUE				7.2	0	1/MONTH	GRAB
OIL AND GREASE, FRESH EXTRACT - GRAB				30.0 AV MONTH		1/MONTH	GRAB
00556 1 NOTE 3 EFFLUENT GROSS VALUE				15.0 AV MONTH		NOT DETERMINED	GRAB

NOTE 2: There were no discharges to the S-2 pond during January.

NOTE 3: The analysis for Oil and Grease for January was inadvertently missed. However, we have no reason to believe the discharge was in violation of the limit.

NOTE 1: FLOW AND PH MEASURED ONCE PER DAY WHEN DISCHARGED TO. HE ALSO HAVE EPA APPROVAL TO USE MODIFIED PARTITION-IR METHOD FOR OIL AND GREASE ANALYSIS.

NAME/TITLE PR. EXEC. OFFICER I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SIGNIFYING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.

H. W. Keiser
 VICE PRESIDENT - NUCLEAR OPERATIONS

H. W. Keiser
 SIGNATURE OF PRINC. EXEC. OFFICER OR AUTHORIZED AGENT

DATE 86 02 26
 YEAR MONTH DAY

CORRECT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME - PENNA. POWER & LIGHT COMPANY
ADDRESS - 1150 NORTH MINN ST.
ALLENTOWN, PA 18101
ATTN: J.S. FIELDS, SR. ENV. SCIENTIST-NUC.
TELEPHONE #215-770-7839
FACILITY - SUSQUEHANNA S.E.S.

PERMIT NUMBER - PA0047325 DISCHARGE NUMBER - 071

DESCRIPTION:
COOLING TOWER BLOWDOWN

MONITORING PERIOD - FROM 8/6/01 TO 8/6/01/31
YR MO DY YR MO DY

F - FINAL LIMITS

PARAMETER	SAMPLE MEASUREMENT REQUIREMENT	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. OF EXCURSIONS	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	MINIMUM	AVERAGE			
FLOU, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	10.0	10.3	*****	*****	*****	1/DAY	ESTIMATED
50060 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	MGD	*****	*****	*****	1/DAY	RECORDER
PH	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	1/DAY	RECORDER
00400 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	7.8	8.9	*****	1/DAY	GRAB
CHLORINE, FREE AVAILABLE	SAMPLE MEASUREMENT	*****	*****	6.0	9.0	*****	1/DAY	GRAB
50064 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	0.15	*****	1/DAY	GRAB
CHLORINE, TOTAL (AS CR)	SAMPLE MEASUREMENT	*****	*****	*****	0.50	*****	1/DAY	GRAB
01024 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	0.08	*****	1/YEAR	8 HR. COMP.
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	*****	*****	*****	0.20	*****	1/YEAR	8 HR. COMP.
01045 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	851.1	2804	*****	10.2	*****	1/WEEK	8 HR. COMP.
IRON, DISSOLVED (AS FE)	SAMPLE MEASUREMENT	817.0	*****	*****	6.8	*****	1/WEEK	8 HR. COMP.
01046 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	1.3	*****	1/WEEK	8 HR. COMP.
NOTE 1: CHLORINE AVERAGE = MAXIMUM MONTHLY 2-HOUR AVERAGE. CHLORINE MONITORED ONLY DURING CHLORINATION.	PERMIT REQUIREMENT	*****	*****	*****	7.0	*****	1/WEEK	8 HR. COMP.

NAME/TITLE PR. EXEC. OFFICER: I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.

H.W. Keiser
VICE PRESIDENT -
NUCLEAR OPERATIONS

H.W. Keiser
SIGNATURE OF PRINC. EXEC.
OFFICER OR AUTHORIZED AGENT

DATE
86 02 26
YEAR MONTH DAY

CORRECT AND EXPLANATION OF ANY VIOLATIONS/REFERENCE ALL ATTACHMENTS HERE

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME - PENNA. POWER & LIGHT COMPANY
ADDRESS- 110 NORTH NINTH ST.
ALLENTOWN, PA 18101
ATTN: J.S. FIELDS, SR. ENV. SCIENTIST-MUC.
TELEPHONE #215-770-7889
FACILITY-SUSQUEHANNA S.E.S.

PERMIT NUMBER-PA0047325 DISCHARGE NUMBER-071

DESCRIPTION:

COOLING TOWER BLOWDOWN

MONITORING PERIOD- FROM 86/01/01 TO 86/01/31
YR MO DY YR MO DY

F - FINAL LIMITS

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. OF EXCURSIONS	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
ZINC, TOTAL (AS ZN)	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.15	0.43		0	1/WEEK	8 HR COMP.
01092] EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	1.0 DAILY MAX			1/HEEK	8 HR COMP.

NOTE 2: Flows are estimated.


NOTE 3: The average total iron concentration limit for January was exceeded with an average of 10.2 mg/liter. The individual concentrations were as follows:

1-02-86	3.82 mg/l	
1-10-86	3.66 mg/l	
1-17-86	5.00 mg/l	Cooling Tower Blowdown Total Iron
1-23-86	33.6 mg/l	mean value = 10.2 mg/liter
1-30-86	4.95 mg/l	

The mean value without the 1-23-86 sample would have been only 4.36 mg/liter. The raw river water concentrations of total iron on the four days preeding the 1-23-86 sample were as follows:

1-19-86	4.28 mg/l	
1-20-86	3.53 mg/l	
1-21-86	10.1 mg/l	Susquehanna River Water Total Iron
1-22-86	24.6 mg/l	
1-23-86	7.65 mg/l	

NOTE 1: CHLORINE AVERAGE = MAXIMUM MONTHLY 2-HOUR AVERAGE.
CHLORINE MONITORED ONLY DURING CHLORINATION.

NAME/TITLE PR. EXEC. OFFICER H.W. Keiser VICE PRESIDENT- NUCLEAR OPERATIONS	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	 SIGNATURE OF PRINC. EXEC. OFFICER OR AUTHORIZED AGENT	DATE		
			86	02 26	
COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)			YEAR	MONTH	DAY

NOTE 3 continued:

As can readily be seen, the intake river water itself exceeded our discharge limit by as much as 3.6 times on the day before the high discharge value. The high iron values also caused the monthly average limit of 817 pounds per day to be exceeded when a calculated 851.1 pounds per day were discharged.

Due to the nature of the river water quality preceding the sample of 1-23-86, we plan no corrective actions.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME - PERIA, POWER & LIGHT COMPANY
ADDRESS - 110 NORTH NINTH ST.
ALLENTOWN, PA 18101
ATTN: J.S. FIELDS, SR. ENV. SCIENTIST-NUC.
TELEPHONE #215-770-7089
FACILITY - SUDBURY S.E.S.

PERMIT NUMBER - PA0047325 DISCHARGE NUMBER - 072

DESCRIPTION:
SERVICE & ADMINISTRATION
BY JG SURIP

MONITORING PERIOD - FROM 06/01/01 TO 06/01/01
YR MO DY YR MO DY

F - FINAL LIMITS

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. OF EXCURSIONS	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0	0	*****	*****	*****	*****	*****
50050 1 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	1/DAY	ESTIMATE
PH	*****	*****	*****	*****	*****	*****	*****
00400 1 EFFLUENT GROSS VALUE	*****	*****	6.0 MINIMUM	*****	*****	1/DAY	GRAB
SOLIDS, TOTAL	*****	*****	*****	*****	*****	*****	*****
00530 1 EFFLUENT GROSS VALUE	*****	*****	*****	30.0 AV MONTH DAILY MAX	*****	1/MONTH	GRAB
OIL AND GREASE, FROM EXTRACT, -GRAV	*****	*****	*****	*****	*****	*****	*****
00556 1 EFFLUENT GROSS VALUE	*****	*****	*****	15.0 AV MONTH DAILY MAX	*****	1/MONTH	GRAB

NOTE 2: There were no discharges from this outfall during January.

NOTE 1: FLOW AND PH MEASURED WHEN DISCHARGED.

WE ALSO HAVE EPA APPROVAL TO USE MODIFIED PARTITION-IR METHOD FOR OIL AND GREASE ANALYSIS.

NAME/TITLE PR. EXEC. OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY JUDGMENT OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT, OFFICER OR AUTHORIZED AGENT	DATE
H.W. Keiser VICE PRESIDENT - NUCLEAR OPERATIONS	<i>H.W. Keiser</i>	06 02 26
CONTENT AND EXPLANATION OF ANY VIOLATIONS/REFERENCE ALL ATTACHMENTS HERE		YEAR/MONTH/DAY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME - PERIA, POWER & LIGHT COMPANY
ADDRESS - 110 NORTH NINTH ST.
ALLENTOWN, PA 18101

ATTN: J.S. FIELDS, SR. ENV. SCIENTIST-TRAC.
TELEPHONE #215-770-7789
FACILITY-SUCKERHATTA S.E.S.

PERMIT NUMBER-PA0047325 DISCHARGE NUMBER-073

MONITORING PERIOD- FROM 86/01/01 TO 86/01/31
YR MO DY YR MO DY

DESCRIPTION:

UNIT 1 TURBINE BLDG
OUTER AREA SUMP
F - FINAL LIMITS

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. OF EXCURSIONS	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	8700	8700					
50050 EFFLUENT GROSS VALUE		GAL				1/DAY	MEASURED
PH			7.70			1/DAY	ESTIMATE
00400 EFFLUENT GROSS VALUE			6.0	7.95	0	1/DAY	GRAB
SOLIDS, TOTAL SUSPENDED				9.0		1/DAY	GRAB
00570 EFFLUENT GROSS VALUE				4.0	0	2/MONTH	GRAB
OIL AND GREASE, FRESH EXTRACT.-GRAB				100.0		1/MONTH	GRAB
00556 EFFLUENT GROSS VALUE				2.41	0	2/MONTH	GRAB
				20.0		1/MONTH	GRAB

NOTE 2: There were two discharges from this outfall in January.

NOTE 1: FLOW AND PH MEASURED WHEN DISCHARGED.

HE ALSO HAVE EPA APPROVAL TO USE MODIFIED PARTITION-IR METHOD FOR OIL AND GREASE ANALYSIS.

STATE/TITLE PR. EXEC. OFFICER I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INSURANCE OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE FURNISHED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.

H.W. Keiser
VICE PRESIDENT -
NUCLEAR OPERATIONS

H.W. Keiser
SIGNATURE OF PRINC. EXEC.
OFFICER OR AUTHORIZED AGENT

DATE
86 02 26
YEAR MONTH DAY

CONTENT AND EXPLANATION OF ANY VIOLATIONS/PREFERENCE ALL ATTACHMENTS HERE

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME- PENN. POWER & LIGHT COMPANY
ADDRESS- 110 NORTH NINTH ST.
ALLENWICK, PA 18101
ATTN: J.S. FIELDS, SR. ENV. SCIENTIST-MNC.
TELEPHONE #215-770-7989
FACILITY-SUSQUEHANNA S.E.S.

PERMIT NUMBER-PA0047325 DISCHARGE NUMBER-074

DESCRIPTION:

UNIT 2 TURBINE BLDG
OUTER AREA SURF


MONITORING PERIOD- FROM 86/01/01 TO 86/01/31
YR MO DY YR MO DY

F - FINAL LIMITS

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. OF EXCURSIONS	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0	0	*****	*****	*****	*****	*****	*		
50050 1 NOTE 2 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****	---	1/DAY	ESTIMATE
PH	SAMPLE MEASUREMENT	*****	*****	*****		*****					
00400 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM	STD. UNITS	---	1/DAY	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00530 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	30.0 AV MONTH	100.0 DAILY MX	MG/L	---	1/MONTH	GRAB
OIL AND GREASE, FREQN EXTRACT.-GRAV	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00556 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	15.0 AV MONTH	20.0 DAILY MX	MG/L	---	1/MONTH	GRAB

NOTE 2: There were no discharges from this outfall during January.

NOTE 1: FLOW AND PH MEASURED WHEN DISCHARGED.
WE ALSO HAVE EPA APPROVAL TO USE MODIFIED PARTITION-IR METHOD FOR OIL AND GREASE ANALYSIS.

NAME/TITLE PR. EXEC. OFFICER H.W. Keiser VICE PRESIDENT- NUCLEAR OPERATIONS	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	SIGNATURE OF PRINC. EXEC. OFFICER OR AUTHORIZED AGENT 	DATE		
			86	02	26
COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)			YEAR	MONTH	DAY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME- PEPIA. POWER & LIGHT COMPANY
ADDRESS- 110 NORTH NINTH ST.
ALLENHORN, PA 18101
ATTN: J.S. FIELDS, SR. ENV. SCIENTIST-NUC.
TELEPHONE #215-770-7889
FACILITY-SUSQUEHANNA S.E.S.

PERMIT NUMBER-PA0047325 DISCHARGE NUMBER-076

DESCRIPTION:

ACID & CHLORINE
BLDG SUMP


MONITORING PERIOD- FROM 86/01/01 TO 86/01/31
YR MO DY YR MO DY

F - FINAL LIMITS

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. OF EXCUR	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0	0	*****	*****	*****	*****	*****	*		
50050 1 NOTE 2 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****	---	1/DAY	ESTIMATE
PH	SAMPLE MEASUREMENT	*****	*****	*****		*****					
00400 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM	STD. UNITS	---	1/DAY	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00530 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	30.0 AV MONTH	100.0 DAILY MX	MG/L	---	1/MONTH	GRAB
OIL AND GREASE, FREON EXTRACT, -GRAV	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00556 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	15.0 AV MONTH	20.0 DAILY MX	MG/L	---	1/MONTH	GRAB

NOTE 2: There were no discharges from this outfall during January.

NOTE 1: FLOW AND PH MEASURED WHEN DISCHARGED.
HE ALSO HAVE EPA APPROVAL TO USE MODIFIED PARTITION-IR METHOD FOR OIL AND GREASE ANALYSIS.

NAME/TITLE PR. EXEC. OFFICER: H.W. Keiser VICE PRESIDENT- NUCLEAR OPERATIONS	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	 SIGNATURE OF PRINC. EXEC. OFFICER OR AUTHORIZED AGENT	DATE		
			86	02	26
COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)			YEAR	MONTH	DAY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME - PENNA. POWER & LIGHT COMPANY
ADDRESS - 110 NORTH NINTH ST.
ALLENTOWN, PA 18101
ATTN: J.S. FIELDS, SR. ENV. SCIENTIST-MUC.
TELEPHONE #215-770-7889
FACILITY-SUGRUENHAINA S.E.S.

PERMIT NUMBER-PA0047325 DISCHARGE NUMBER-077

DESCRIPTION:


UNIT 1 CONDENSATE
STORAGE TANK AREA

MONITORING PERIOD- FROM 8/01/01 TO 8/01/31
YR MO DY YR MO DY

F - FINAL LIMITS

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. OF EXCUR	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0	0		*****	*****	*****	*****	N		
50050 1 NOTE 2 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****		SEE PERMIT	SEE PERMIT

NOTE 2: There were no discharges from this outfall during January.

NAME/TITLE PR. EXEC. OFFICER H.W. Keiser VICE PRESIDENT- NUCLEAR OPERATIONS	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	 SIGNATURE OF PRINC. EXEC. OFFICER OR AUTHORIZED AGENT	DATE		
			86	02	26
COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)			YEAR	MON	DAY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME- PENNA. POWER & LIGHT COMPANY
ADDRESS- 110 NORTH NINTH ST.
ALLENTOWN, PA 18101
ATTN: J.S. FIELDS, SR. ENV. SCIENTIST-MUC.
TELEPHONE #215-770-7889
FACILITY-SUSQUEHANNA S.E.S.

PERMIT NUMBER-PA0047325 DISCHARGE NUMBER-07A

DESCRIPTION:


UNIT 2 CONDENSATE
STORAGE TANK AREA

MONITORING PERIOD- FROM 86/01/01 TO 86/01/31
IN MO BY YR MO BY

F - FINAL LIMITS

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. OF EXCURSIONS	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0	0		*****	*****	*****	*****	*		
50050 1 NOTE 2 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****		SEE PERMIT	SEE PERMIT

NOTE 2: There were no discharges from this outfall during January.

NAME/TITLE PR. EXEC. OFFICER H.W. Keiser VICE PRESIDENT- NUCLEAR OPERATIONS	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	SIGNATURE OF PRINC. EXEC. OFFICER OR AUTHORIZED AGENT 	DATE		
			86	02	26
COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)			YEAR	MONTH	DAY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME - PEPPIA, POWER & LIGHT COMPANY
ADDRESS - 210 NORTH HINCH ST.
ALLENHOLM, PA 18101
AITH: J.S. FIELDS, SR. ENV. SCIENTIST-MUC.
TELEPHONE #215-770-7089
FACILITY-SUSQUEHANNA S.E.S.

PERMIT NUMBER-PA0047325 DISCHARGE NUMBER-079

DESCRIPTION:
SEWAGE TREATMENT PLANT

MONITORING PERIOD- FROM 8/01/01 TO 8/01/01
YR MO DY YR MO DY
F - FINAL LIMITS

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. OF EXCURSIONS	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.021	0.038				1/DAY	WEIR
500°F EFFLUENT GROSS VALUE	0.000					1/DAY	PUMP RT. FOR HEIR
PH			6.21		0	1/DAY	GRAB
00400 EFFLUENT GROSS VALUE			6.0	8.03		1/DAY	GRAB
SOLIDS, TOTAL SUSPENDED	4.1	9.6		16.5		1/MONTH	8 HR COMP.
00570 EFFLUENT GROSS VALUE	20.0			30.0		1/MONTH	8 HR COMP.
BOO, 5-DAY (20 DEC. C)	< 1.4	< 1.8		< 6.0		1/MONTH	8 HR COMP.
00310 EFFLUENT GROSS VALUE	20.0			30.0		1/MONTH	8 HR COMP.
SOLIDS, TOTAL SUSPENDED REMOVED	87.5					1/MONTH	8 HR COMP.
81011 PERCENT REMOVAL	85					1/MONTH	8 HR COMP.
BOO, 5-DAY PERCENT REMOVED	97.1					1/MONTH	8 HR COMP.
81010 PERCENT REMOVAL	85					1/MONTH	8 HR COMP.

I, TITLE PR. EXEC. OFFICER, CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.

H. W. Keiser
VICE PRESIDENT -
NUCLEAR OPERATIONS

DATE: 86 02 26

YEAR: 86 MONTH: 02 DAY: 26

OFFICER OR AUTHORIZED AGENT

COMMENT AND EXPLANATION OF ANY VIOLATIONS: REFERENCE ALL ATTACHMENTS HERE I

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME- PENNA. POWER & LIGHT COMPANY
ADDRESS- 110 NORTH NINTH ST.

PERMIT NUMBER-PA0047325 DISCHARGE NUMBER-079

DESCRIPTION:


ALLENTOWN, PA 18101
ATTN: J.S. FIELDS, SR. ENV. SCIENTIST-PAUC.
TELEPHONE #215-770-7899
FACILITY-SUSQUEHANNA S.E.S.

SEWAGE TREATMENT PLANT

MONITORING PERIOD- FROM 86/01/01 TO 86/01/31
YR MO DY YR MO DY

F - FINAL LIMITS

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. OF EXCUR	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
CHLORINE, FREE AVAILABLE	SAMPLE MEASUREMENT	*****	*****	*****	<0.05	3.98	24.0		0	1/DAY	GRAB
50064 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	MG/L	—	1/DAY	GRAB
COLIFORM, FECAL	SAMPLE MEASUREMENT	*****	*****	*****	*****	<3	<3		0	4/MONTH	GRAB
74055 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	2000 AV MONTH	*****	#/100ML	—	1/MONTH	GRAB

NAME/TITLE PR. EXEC. OFFICER H.W. Keiser VICE PRESIDENT- NUCLEAR OPERATIONS	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	SIGNATURE OF PRINC. EXEC. OFFICER OR AUTHORIZED AGENT 	DATE		
			86	02	26
COMMENT AND EXPLANATION OF ANY VIOLATIONS/REFERENCE ALL ATTACHMENTS HERE I			YEAR	MONTH	DAY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME - PERMA, POWER & LIGHT COMPANY
ADDRESS - 110 NORTH NINTH ST.
ALLENTOWN, PA 18101
ATTN: J. S. FIELDS, SR., ENV. SCIENTIST-MC.
TELEPHONE #215-770-7809
FACILITY - SUSQUEHANNA S.E.S.

PERMIT NUMBER - PA0047525 DISCHARGE NUMBER - 171

DESCRIPTION:
RADWASTE TREATMENT

MONITORING PERIOD - FROM 86/01/01 TO 86/01/31
YR MO DY YR MO DY

F - FINAL LIMITS

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. OF EXCURSIONS	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	MINIMUM	AVERAGE			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT		0.057	0.087	*****	*****	*	1/DAY	MEASURED
5000 P SEE NOTE 1 BELOW	PERMIT REQUIREMENT	*****	MGD	*****	*****	*****	1/DAY	ESTIMATE
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	1/MONTH	GRAB
00530 P SEE NOTE 1 BELOW	PERMIT REQUIREMENT	*****	*****	0.0	0.0	0	1/MONTH	GRAB
OIL AND GREASE, FRESH EXTRACT, -GRAB	SAMPLE MEASUREMENT	*****	*****	30.0	100.0	---	1/MONTH	GRAB
00556 P SEE NOTE 1 BELOW	PERMIT REQUIREMENT	*****	*****	0.0	0.0	0	1/YEAR	GRAB
		*****	*****	15.0	20.0	---	1/YEAR	GRAB

NOTE 1: LOCATION P=AT DISCHARGE FROM RADWASTE TREATMENT PRIOR TO COMBINING WITH THE CIRCULATING WATER SYSTEM. HE ALSO HAVE EPA APPROVAL TO USE MODIFIED PARTITION-IR METHOD FOR OIL AND GREASE ANALYSIS.

NAME/TITLE PR. EXEC. OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	DATE
H.W. Keiser VICE PRESIDENT - NUCLEAR OPERATIONS	<i>H.W. Keiser</i> SIGNATURE OF PRINC. EXEC. OFFICER OR AUTHORIZED AGENT	86 02 26
CURRENT AND EXPLANATION OF ANY VIOLATIONS/REFERENCE ALL ATTACHMENTS HERE		YEAR MONTH DAY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME- PENNIA. POWER & LIGHT COMPANY
ADDRESS- 110 NORTH NINTH ST.
ALLENTOWN, PA 18101
ATTN: J.S. FIELDS, SR. ENV. SCIENTIST-MUC.
TELEPHONE #215-770-7889
FACILITY-SUSQUEHANNA S.E.S.

PERMIT NUMBER-PA0047325 DISCHARGE NUMBER-271

DESCRIPTION:

WASTE FILTER BYPASS


MONITORING PERIOD- FROM 86/01/01 TO 86/01/31
YR MO DY YR MO DY

F - FINAL LIMITS

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. OF EXCUR	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.002	0.002		*****	*****	*****	*****	*	1/DAY	ESTIMATED
50050 P SEE NOTE 1 BELOW	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****	---	1/DAY	PUMP RT. OR WEIR
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	*****	*****	1820	1820		1	1/MONTH	GRAB
00530 P SEE NOTE 1 BELOW	PERMIT REQUIREMENT	*****	*****	*****	*****	30.0 AV MONTH	100.0 DAILY MX	MG/L	---	1/MONTH	GRAB
OIL AND GREASE, FRESH EXTRACT.-GRAY	SAMPLE MEASUREMENT	*****	*****	*****	*****	12.7	12.7		0	1/MONTH	GRAB
00556 P SEE NOTE 1 BELOW	PERMIT REQUIREMENT	*****	*****	*****	*****	15.0 AV MONTH	20.0 DAILY MX	MG/L	---	1/MONTH	GRAB

NOTE 2: The concentration of Total suspended solids exceeded the permit limits during January. A test filtration system arrived on site in January and tests will begin when warmer weather returns, since the test system is stationed outside.

NOTE 1: LOCATION P=AT DISCHARGE FROM WASTE FILTER BYPASS PRIOR TO COMBINING WITH THE CIRCULATING WATER SYSTEM. HE ALSO HAVE EPA APPROVAL TO USE MODIFIED PARTITION-IR METHOD FOR OIL AND GREASE ANALYSIS.

NAME/TITLE PR. EXEC. OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	SIGNATURE OF PRINC. EXEC. OFFICER OR AUTHORIZED AGENT	DATE
H.W. Keiser VICE PRESIDENT- NUCLEAR OPERATIONS			86 02 26
COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)			YEAR MONTH DAY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME- PENNA. POWER & LIGHT COMPANY
ADDRESS- 110 NORTH NINTH ST.
ALLENTOWN, PA 18101
ATTN: J.S. FIELDS, SR. ENV. SCIENTIST-MUC.
TELEPHONE #215-770-7989
FACILITY-SUSQUEHANNA S.E.S.

PERMIT NUMBER-PA0047325 DISCHARGE NUMBER-371

DESCRIPTION:


NEUTRALIZATION BASIN

MONITORING PERIOD- FROM 86/01/01 TO 86/01/31
YR MO DY YR MO DY

F - FINAL LIMITS

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. OF EXCUR	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.023	0.036		*****	*****	*****	*****	0	1/DAY	MEASURED
50050 P SEE NOTE 1 BELOW	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****	---	1/DAY	ESTIMATE
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	*****	*****	9.8	9.8		0	1/MONTH	GRAB
00570 P SEE NOTE 1 BELOW	PERMIT REQUIREMENT	*****	*****	*****	*****	30.0 AV MONTH	100.0 DAILY MX	MG/L	---	1/MONTH	GRAB
OIL AND GREASE, FREQW EXTRACT.-GRAY	SAMPLE MEASUREMENT	*****	*****	*****	*****	7.0	7.0		0	1/MONTH	GRAB
00556 P SEE NOTE 1 BELOW	PERMIT REQUIREMENT	*****	*****	*****	*****	15.0 AV MONTH	20.0 DAILY MX	MG/L	---	1/MONTH	GRAB

NOTE 1: LOCATION P=AT DISCHARGE FROM NEUTRALIZATION BASIN PRIOR TO COMBINING WITH THE CIRCULATING WATER SYSTEM.
WE ALSO HAVE EPA APPROVAL TO USE MODIFIED PARTITION-IR METHOD FOR OIL AND GREASE ANALYSIS.

NAME/TITLE PR. EXEC. OFFICER: H.W. Keiser VICE PRESIDENT- NUCLEAR OPERATIONS	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	 SIGNATURE OF PRINC. EXEC. OFFICER OR AUTHORIZED AGENT	DATE		
			86	02	26
COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)			YEAR	MONTH	DAY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME - PERMA, POWERS & LIGHT COMPANY
ADDRESS - 170 NORTH HINCH ST.
ALLENTOWN, PA 18101
ATTN: J.S. FIELDS, SR. ENV. SCIENTIST-NRC.
TELEPHONE #215-770-7289
FACILITY-SUCQUENAISSA S.E.S.

PERMIT NUMBER-PA0047325 DISCHARGE NUMBER-471

DESCRIPTION:
WASTE FILTER EFFLUENT

MONITORING PERIOD- FROM 8/01/01 TO 8/01/31
YR MO DY YR MO DY

F - FINAL LIMITS

PARAMETER	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. OF EXCURSIONS	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
1/2" IN CONDUIT OR 1/2" TREATMENT PLANT	0	0		*****	*****	*****	1		
5050 P NOTE 2 SEE NOTE 1 BELOW	*****	*****	MGD	*****	*****	*****		1/DAY	PUMP RT. OR MEIR
SOLIDS, TOTAL SUSPENDED	*****	*****	*****	*****	*****	*****			
00570 P SEE NOTE 1 BELOW	*****	*****	*****	*****	50.0 AV MONTH	100.0 DAILY MAX		1/MONTH	GRAB
OIL AND GREASE, FRESH EXTRACT.-GRAY	*****	*****	*****	*****	*****	*****			
00566 P SEE NOTE 1 BELOW	*****	*****	*****	*****	15.0 AV MONTH	20.0 DAILY MAX		1/MONTH	GRAB

NOTE 2: There were no discharges from this outfall during January.

NOTE 1: LOCATION P=AT DISCHARGE FROM WASTE FILTER PRIOR TO COMBINING WITH THE CIRCULATING WATER SYSTEM.
HE ALSO HAVE EPA APPROVAL TO USE MODIFIED PARTITION-IR METHOD FOR OIL AND GREASE ANALYSIS.

NAME/TITLE PR. EXEC. OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFO., INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	DATE
H.W. Keiser VICE PRESIDENT- NUCLEAR OPERATIONS	<i>H.W. Keiser</i> SIGNATURE OF PRINC. EXEC. OFFICER OR AUTHORIZED AGENT	86 02 26 YEAR MONTH DAY
CONTENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)		