

May 13, 1969

J. P. O'Reilly, Chief
Reactor Inspection and Enforcement Branch
Division of Compliance, Headquarters

PACIFIC GAS & ELECTRIC COMPANY (DIABLO CANYON UNIT NO. 1)
DOCKET NO. 50-275

The attached report contains the details of a recent visit to PG&E's home offices in San Francisco, California on April 30, 1969.

In view of the absence of significant construction activities to date, the applicant's quality assurance efforts have primarily been directed toward design activities and vendor inspections. You will note that PG&E has not yet formulated and implemented a formal QA-QC program to be followed for the construction of the Diablo Canyon No. 1 nuclear plant. However, PG&E plans to implement such a plan prior to start of construction of the major civil structures for the unit, currently scheduled for the last week of June, 1969.

Although it appears that PG&E personnel have evaluated the changes made to the containment building design from that described in the PSAR and have found the changes not to be detrimental, DRL may wish to review the changes and confirm or deny PG&E's evaluation. You will also note that PG&E has not and does not intend to have Westinghouse approve the containment building design as indicated in the PSAR.

BB05230040 BB0510
PDR FOIA
MCMILLAN88-156 PDR

A-34

OFFICE ▶	CO:V				
SURNAME ▶	Spencer;pmr				
DATE ▶	5/13/69				

J. P. O'Reilly

-2-

May 13, 1969

Concerning the question raised during the vendor inspection at ESCO Corporation relative to disposition of the radiograph films of the pipe fittings manufactured by ESCO, PG&E does not intend to secure and retain the radiographs.

G. S. Spencer
Senior Reactor Inspector

Attachment:
CO Rpt. No. 50-275/69-4
by A. D. Johnson
dtd 5/13/69

DISTRIBUTION:
J. P. O'Reilly, CO:HQ (Orig. and one copy)
E. G. Case, DRS
R. S. Boyd, DRL (2)
S. Levine, DRL (6)
D. J. Skovholt, DRL (3)
L. Kornblith, Jr., CO:HQ
Regional Directors
REG File