



UNITED STATES
ATOMIC ENERGY COMMISSION
DIVISION OF COMPLIANCE
REGION V
2111 BANCROFT WAY
BERKELEY, CALIFORNIA 94704

TELEPHONE: 641-5121
EXT. 681

April 14, 1969

G. S. Spencer, Senior Reactor Inspector
Region V, Division of Compliance

PACIFIC GAS AND ELECTRIC COMPANY (DIABLO CANYON UNIT NO. 1)
VENDOR INSPECTION
DOCKET NO. 50-275

Attached is my report of a vendor visit to Electric Steel Company (ESCO), Portland Oregon, on March 28, 1969. ESCO is manufacturing the fittings to be used in the piping of the primary coolant system of PG&E's Diablo Canyon nuclear plant No. 1.

Based on the information obtained during the visit, it appears that the activities of PG&E, Westinghouse and ESCO are sufficient to provide reasonable assurance that the pipe fittings manufactured by ESCO will be of a quality consistent with the requirements prescribed in the preliminary safety analysis report for the Diablo Canyon No. 1 nuclear power station.

409 You will note that ESCO retains the radiographs of the fittings. During the next visit to PG&E to review PG&E's quality assurance-quality control program, I intend to determine the ultimate disposition of the film.

A. D. Johnson
A. D. Johnson
Reactor Inspector

8805230065 880510
PDR FOIA
MCMILLAN88-156 PDR

A-37