

March 21, 1969

J. P. O'Reilly, Chief
Reactor Inspection and Enforcement Branch
Division of Compliance, Headquarters

PACIFIC GAS AND ELECTRIC COMPANY (DIABLO CANYON UNIT NO. 1)
DOCKET NO. 50-275

The attached report by our field inspector of a visit to the subject facility on March 11, 1969 is forwarded for information. No items of noncompliance or of safety significance were noted during the visit.

Based on our observations and information obtained from the applicant personnel, the tentative schedule for the start of construction of the containment building appears to be a reasonable forecast. Also, of interest, was an obvious awareness on the part of the applicant personnel of the stress expected to be placed on quality assurance and quality control programs.

You will note that PG&E's specifications for the tensile testing of Cadweld splices in the concrete reinforcing steel calls for a lesser number of splices to be tested than are suggested in the RTM which covers this subject. However, in view of the (internal) classification of RTMs, the discrepancy was not discussed with the PG&E representatives.

ORIGINAL SIGNED BY
G. S. SPENCER

G. S. Spencer
Senior Reactor Inspector

Attachment:
CO Rpt. No. 50-275/69-2
by A. D. Johnson
dtd 3/21/69

A-39

3

BB05230094 BB0510
PDR FOIA
MCMILLANBB-156 PDR

OFFICE ▶	CO:V				
SURNAME ▶	Spencer:pmr				
DATE ▶	3/21/69				

J. P. O'Reilly

-2-

March 21, 1969

DISTRIBUTION:

J. P. O'Reilly, CO:HQ (Orig. and one copy)

E. G. Case, DRS

R. S. Boyd, DRL (2)

S. Levine, DRL (6)

D. J. Skovholt, DRL (3)

L. Kornblith, Jr., CO:HQ

Regional Directors

REG File