



**GPU Nuclear Corporation**  
Post Office Box 388  
Route 9 South  
Forked River, New Jersey 08731-0388  
609 971-4000  
Writer's Direct Dial Number:

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

May 10, 1988

Gentlemen:

Subject: Oyster Creek Nuclear Generating Station (OCNGS)  
Docket No. 50-219  
Technical Specification Change Request (TSCR) No. 162

In accordance with 10CFR50.90 and 10CFR50.91 GPU Nuclear Corporation, operator of the OCNGS, Provisional Operating License No. DPR-16, requests a change to Appendix A of the license.

The Standby Liquid Control System (SLCS) will be modified during the OCNGS Cycle 12 refueling outage pursuant to the requirements of 10CFR50.62(c)(4). As a result, Sections 3.2, 4.2 and 6.9 of the Technical Specifications will be changed to reflect the use of an enriched sodium pentaborate solution.

This change request has been reviewed in accordance with Section 6.5 of the Oyster Creek Technical Specifications. Pursuant to 10CFR50.91(b)(1), a copy of this change request has been sent to the State of New Jersey Department of Environmental Protection. In addition, a check for \$150.00 pursuant to 10CFR170.12 is enclosed.

Very truly yours,

*E. E. Fitzpatrick*  
E. E. Fitzpatrick  
Vice President & Director  
Oyster Creek

EEF/JDL/pa(6224f/0491A)  
Attachment  
cc's on next page

8805230176 880510  
PDR ADOCK 05000219  
P DCD

A001  
w/check #150  
#318123

cc: Mr. William T. Russell, Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

NRC Resident Inspector  
Oyster Creek Nuclear Generating Station  
Forked River, N.J. 08731

Mr. Alex Dromerick  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555