

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) <p style="text-align:center;">Fermi 2</p>	DOCKET NUMBER (2) <p style="text-align:center;">0 5 0 0 0 3 4 1 1</p>	PAGE (3) <p style="text-align:center;">1 OF 0 1</p>
--	--	--

TITLE (4) Potentially Reportable Condition - Design calculations and Stress Reports are not Current

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
0 1	3 0	8 6	8 6	0 0 2	0 0 0 3	0 1	8 6				0 5 0 0 0
THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)											

OPERATING MODE (9) <p style="text-align:center;">4</p>	POWER LEVEL (10) <p style="text-align:center;">0 1 0 0</p>	20.402(b)	20.405(e)	50.73(a)(2)(iv)	73.71(b)
		20.405(a)(1)(i)	50.38(c)(1)	50.73(a)(2)(v)	73.71(c)
		20.405(a)(1)(ii)	50.38(c)(2)	50.73(a)(2)(vi)	<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)
		20.405(a)(1)(iii)	50.73(a)(2)(i)	50.73(a)(2)(viii)(A)	
		20.405(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(viii)(B)	
		20.405(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(ix)	

LICENSEE CONTACT FOR THIS LER (12)

NAME <p style="text-align:center;">L. P. Bregni, Compliance Engineer</p>	TELEPHONE NUMBER AREA CODE: 3 1 3 5 8 6 - 5 3 1 3
---	---

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS

SUPPLEMENTAL REPORT EXPECTED (14)

<input checked="" type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE) See Below	<input type="checkbox"/> NO	EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On January 30, 1986, the Nuclear Engineering Organization identified a situation where some design calculations for safety-related piping and pipe hangers had not been updated to reflect change documents that were issued after the as-built calculations were completed. Calculations or reviews had been performed to determine the potential impact of the change documents on the overall design but objective evidence of these actions may not exist in all cases. These design changes are reflected in Detroit Edison's controlled design documentation file. A log was created from the file information to facilitate turnover of work from the Troy engineering organization to Nuclear Engineering at the Fermi 2 site. This situation is in apparent conflict with information Detroit Edison obtained in meetings with the NRC on January 22, 1986, regarding the required status of calculations prior to declaring systems operable. A review is being performed to determine the calculations that are not current. This deviation is considered potentially reportable under 10CFR50.72 and 50.73. This report is being submitted to notify the Commission of this potentially reportable event. A supplemental report will be submitted within thirty days after a final determination on reportability has been made.

IE 72
11

8603070530 860301
PDR ADOCK 05000341
S PDR

Robert S. Lenart
Plant Manager

Detroit
Edison

Fermi-2
6400 North Dixie Highway
Newport, Michigan 48166
(313) 586-5201

March 1, 1986
NP860102



Nuclear
Operations

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Reference: Fermi 2
NRC Docket No. 50-341
NRC Operating License No. NPF-43

Subject: Transmittal of Licensee
Event Report 86-002-00

Please find enclosed LER No. 86-002-00, dated March 1, 1986, for a potentially reportable event. As indicated below, a copy of this LER is being sent to the Administrator Region III.

If you have any questions, please contact us.

Sincerely,

R. S. Lenart
Plant Manager

Enclosure: NRC Form 366

cc: W.G. Rogers
M.D. Lynch

Regional Administrator
USNRC Region III
799 Roosevelt Rd.
Glen Ellyn, IL 60137

Wayne County Emergency
Management Division
1250 Middlebelt Road
Detroit, MI 48242

Director/Coordinator
Monroe City-County Office of Civil Preparedness
965 South Raisinville Road
Monroe, MI 48161

LE22
1/1