Mr. Joseph V. Sinek Director - Licensing Clinton Power Station P.O. Box 678 Mail Code V920 Clinton, IL 61727

SUBJECT: RELIEF REQUEST FOR THE PUMP AND VALVE INSERVICE TESTING PROGRAM - CLINTON POWER STATION (TAC NO. MA2146)

Dear Mr. Sipek:

By letter dated June 18, 1998, Illinois Power (IP) submitted a relief request for 21 selected Category A valves. IP had a conference call with the NRC staff on August 19, 1998, and submitted a supplemental letter on September 4, 1998.

The staff's evaluation of the relief request is contained in the enclosed safety evaluation (SE). The NRC staff has found that the proposed alternative to the test frequency requirements of OMa-1988, Part 10, Section 4.2.2.3, for the 21 reactor coolant system pressure isolation valves is authorized pursuant to 10 CFR 50.55a (a)(3)(ii) based on the determination that compliance with the specified requirements results in a hardship without a compensating increase in the level of quality and safety. The alternative is authorized for an interim period from the date of this SE until the next refueling outage.

Please contact Jon Hopkins at (301) 415-3027 if you have any questions.

Sincerely,

Original signed by:

Stuart A. Richards, Director Project Directorate III-2 Division of Reactor Projects III/IV Office of Nuclear Reactor Regulation

Docket No. 50-461

Enclosure: Safety Evaluation

cc w/encl: See next page

9810090403 981006 PDR ADOCK 05000461 Distribution:

Docket File PD3-3 F/F

MKotzalas

EGA1

PUBLIC

ACRS OGC

GGrant, RIII

Document Name: G:\CLINTON\MA2146.LTR

OFC	PM:PDIII-2	E	PA:PDIII-2	E	0000		D:PDIII-2
NAME	JHopkins	NY	EBarnhill (3	RBachma	nn	SRichards 564
DATE	9 12-5198	M	9/25/98		9 130 1	98	10/6/98

OFFICIAL RECORD COPY

090021



Mr. Joseph V. Sipek Director - Licensing Clinton Power Station P.0. Box 678 Mail Code V920 Clinton, IL 61727

SUBJECT: RELIEF REQUEST FOR THE PUMP AND VALVE INSERVICE TESTING PROGRAM - CLINTON POWER STATION (TAC NO. MA2146)

Dear Mr. Sipek:

By letter dated June 18, 1998, Illinois Power (IP) submitted a relief request for 21 selected Category A valves. IP had a conference call with the NRC staff on August 19, 1998, and submitted a supplemental letter on September 4, 1998.

The staff's evaluation of the relief request is contained in the enclosed safety evaluation (SE). The NRC staff has found that the proposed alternative to the test frequency requirements of OMa-1988, Part 10, Section 4.2.2.3, for the 21 reactor coolant system pressure isolation valves is authorized pursuant to 10 CFR 50.55a (a)(3)(ii) based on the determination that compliance with the specified requirements results in a hardship without a compensating increase in the level of quality and safety. The alternative is authorized for an interim period from the date of this SE until the next refueling outage.

Please contact Jon Hopkins at (301) 415-3027 if you have any questions.

Sincerely,

Original signed by:
Stuart A. Richards, Director
Project Directorate III-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-461

Enclosure: Safety Evaluation

cc w/encl: See next page

Distribution:

Docket File PD3-3 R/F PUBLIC

MKotzalas

OGC

EGA1

GGrant, RIII

Document Name: G:\CLINTON\MA2146 LTR

Part and and and and	PM:PDIII-2	DASANNY.		TOTAL DE	THE RESIDENCE OF THE PARTY OF T	D:PDIII-2
basis and company of	The state of the s	IIIVensa	MARCHIN, AND LESS OF STREET, S	(Account)	TOTAL STREET,	SRichards 564
DATE	9 12-5/98 1		7/75/98		9 /36 /98	10/6/98

OFFICIAL RECORD COPY



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20566-0001

October 6, 1998

Mr. Joseph V. Sipek Director - Licensing Clinton Power Station P.0. Box 678 Mail Code V920 Clinton, IL 61727

SUBJECT: RELIEF REQUEST FOR THE PUMP AND VALVE INSERVICE TESTING PROGRAM - CLINTON POWER STATION (TAC NO. MA2146)

Dear Mr. Sipek:

By letter dated June 18, 1998, Illinois Power (IP) submitted a relief request for 21 selected Category A valves. IP had a conference call with the NRC staff on August 19, 1998, and submitted a supplemental letter on September 4, 1998.

The staff's evaluation of the relief request is contained in the enclosed safety evaluation (SE). The NRC staff has found that the proposed alternative to the test frequency requirements of OMa-1988, Part 10, Section 4.2.2.3, for the 21 reactor coolant system pressure isolation valves is authorized pursuant to 10 CFR 50.55a (a)(3)(ii) based on the determination that compliance with the specified requirements results in a hardship without a compensating increase in the level of quality and safety. The alternative is authorized for an interim period from the date of this SE until the next refueling outage.

Please contact Jon Hopkins at (301) 415-3027 if you have any questions.

Sincerely.

Stuart A. Richards, Director

Project Directorate III-2

Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-461

Enclosure: Safety Evaluation

cc w/encl: See next page

Joseph V. Sipek Illinois Power Company

CC:

Walter G. MacFarland IV Senior Vice President Clinton Power Station P.O. Box 678 Clinton, IL 61727

Wayne Romberg
Manager Nuclear Station
Engineering Department
Clinton Power Station
P.O. Box 678
Clinton, IL 61727

Resident Inspector L.S. Nuclear Regulatory Commission RR#3, Box 229 A Clinton, IL 61727

R. T. Hill Licensing Services Manager General Electric Company 175 Curtner Avenue, M/C 481 San Jose, CA 95125

Regional Administrator, Region III U.S. Nuclear Regulatory Commission 801 Warrenville Road Lisle, IL 60532-4351

Chairman of DeWitt County c/o County Clerk's Office DeWitt County Courthouse Clinton, IL 61727

J. W. Blattner
Project Manager
Sargent & Lundy Engineers
55 East Monroe Street
Chicago, IL 60603

Clinton Power Station, Unit 1

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
ATTN: Mr. Frank Nizidlek
1035 Outer Park Drive
Springfield, IL 62704

Leah Manning Stetzner
VP, General Counsel & Corp. Secretary
500 South 27th Street
Decatur, IL 62525