



Northern States Power Company

414 Nicollet Mall  
Minneapolis, Minnesota 55401  
Telephone (612) 330-5500

September 16, 1988

Technical Specification  
4.12.E.1

Director Office of Nuclear Reactor Regulation  
U S Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

PRAIRIE ISLAND NUCLEAR GENERATING PLANT  
Docket Nos. 50-282 License Nos. DPR-42  
50-306 DPR-60

Steam Generator Tube Plugging and sleeving

In accordance with Technical Specification 4.12.E.1, the following steam generator tube plugging and sleeving information is provided for the information of the NRC Staff.


Following the recent inservice inspection of Unit 1 steam generators, tubes were plugged or sleeved as follows:

Steam Generator 11 - 9 tubes plugged  
total of 69 now plugged (2%)

Steam Generator 12 - 8 tubes plugged  
total of 71 now plugged (2.1%)

73 tubes sleeved  
total of 100 now sleeved (3%)

Detailed information related to the inservice inspection and the tube plugging and sleeving will be provided in an Inservice Inspection Summary Report which will be submitted within 90 days of the completion of the refueling outage. Also, Table 4.3-13 of the Prairie Island Updated Safety Analysis Report will be updated with this information in the next revision. Please contact us if you have any questions related to this information.

  
David Musolf  
Manager - Nuclear Support Services

c: Regional Administrator-III, NRC  
NRR Project Manager, NRC  
Resident Inspector, NRC  
G Charnoff

8809200188 880916  
PDR ADOCK 05000282  
G PNU

A047  
1/0