

50-318



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

October 5, 1998

Mr. Charles H. Cruse  
Vice President Nuclear Energy  
Baltimore Gas and Electric Company  
Calvert Cliffs Nuclear Power Plant  
1650 Calvert Cliffs Parkway  
Lusby, MD 20657

SUBJECT: CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NO. 2 - EVALUATION OF  
THE PRESSURIZER INSTRUMENT NOZZLE REPAIR (TAC NO. MA2456)

Dear Mr. Cruse:

By letter dated August 4, 1998, the Baltimore Gas and Electric Company (the licensee) submitted, for NRC review, its flaw tolerance evaluation for an assumed flaw in the inboard instrument weld of the pressurizer for Calvert Cliffs Nuclear Power Plant, Unit No. 2. During a walkdown while Unit 2 was in hot standby (Mode 3), the licensee detected leakage from the pressurizer upper level tap (instrument nozzle 2-LT-110-X). As a result, the licensee performed ultrasonic (UT) examination of the pressurizer vessel shell. The inspection results showed no defects in the vessel shell. However, no UT examination was performed on the weld of the pressurizer instrument nozzle. In the subsequent repair, the licensee welded the outboard portion of the nozzle to a weld pad on the outside of the pressurizer head to form a new pressure boundary for the coolant. No repair of the inboard instrument weld where the leakage was identified was performed. Instead, the licensee utilized the evaluation procedure and criteria in Appendix A of Section XI of the American Society of Engineers (ASME) Code to demonstrate that the assumed crack is acceptable without repair for the design life of the vessel which includes 500 heatups and cooldowns.

The NRC staff completed the review and concluded that the flaw tolerance evaluation meets the rules of the ASME Code. Since the predicted number of heatups and cooldowns needed to reach the allowable flaw depth is far greater than the number of design cycles, the staff concluded that the pressurizer of Calvert Cliffs Unit 2 should be able to operate with a flaw in the instrument weld. However, to ensure that the flaw does not grow to a critical size during the remaining life of the pressurizer, the staff has requested the licensee to provide an inspection plan for future outages. The licensee indicated in a letter dated August 25, 1998, that it will perform an inspection in the next outage and will make the results of the inspection available to the NRC. In addition, the licensee is committed to provide an action plan for inspection of the pressurizer instrument nozzle weld flaw by February 26, 1999. The staff will review all information at that time and determine whether the unit can be operated with a flaw in the instrument weld to the expiration of the license.

*DFO/1*

9810130133 981005  
PDR ADOCK 05000318  
P PDR


**NRC FILE CENTER COPY**

C. Cruse

- 2 -

Enclosed is the staff's safety evaluation. BGE followed the procedure and criteria in Appendix A of Section XI of the ASME Code in demonstrating that the pressurizer of Calvert Cliffs Unit 2 should be able to operate with a flaw in the instrument weld. The quality in preparing the submittal is very good. This completes the staff's effort for TAC No. MA2456.

Sincerely,



Alexander W. Dromerick, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-318

Enclosure: Safety Evaluation

cc/w encl: See next page

October 5, 1998

C. Cruse

- 2 -

Enclosed is the staff's safety evaluation. 3GE followed the procedure and criteria in Appendix A of Section XI of the ASME Code in demonstrating that the pressurizer of Calvert Cliffs Unit 2 should be able to operate with a flaw in the instrument weld. The quality in preparing the submittal is very good. This completes the staff's effort for TAC No. MA2456.

Sincerely,

Original Signed by:

Alexander W. Dromerick, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-318

Enclosure: Safety Evaluation

cc/w encl: See next page

**DISTRIBUTION:**

Docket File

PUBLIC

PDI-1 R/F

J. Zwolinski

S. Bajwa

S. Little

A. Dromerick

S. Sheng

T. Harris (e-mail only, TLH3) safety evaluation

OGC

ACRS

C. Hehl, Region I

DOCUMENT NAME: G:\CC1-2\MA2456.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDI-1	E	LA:PDI-1	D:PDI-1			
NAME	ADromerick/rsf		SLittle	SBajwa			
DATE	09/05/98		09/18/98	09/15/98			

Official Record Copy

October 5, 1998

C. Cruse

- 2 -

Enclosed is the staff's safety evaluation. BGE followed the procedure and criteria in Appendix A of Section XI of the ASME Code in demonstrating that the pressurizer of Calvert Cliffs Unit 2 should be able to operate with a flaw in the instrument weld. The quality in preparing the submittal is very good. This completes the staff's effort for TAC No. MA2456.

Sincerely,

Original Signed by:

Alexander W. Dromerick, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-318

Enclosure: Safety Evaluation

cc/w encl: See next page

DISTRIBUTION:

- Docket File
- PUBLIC
- PDI-1 R/F
- J. Zwolinski
- S. Bajwa
- S. Little
- A. Dromerick
- S. Sheng
- T. Harris (e-mail only, TLH3) safety evaluation
- OGC
- ACRS
- C. Hehl, Region I

DOCUMENT NAME: G:\CC1-2\MA2456.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDI-A/I	E	LA:PDI-1	D:PDI-1		
NAME	ADromerick/rs1		SLittle	SBajwa		
DATE	09/15/98		09/18/98	09/15/98		

Official Record Copy

Mr. Charles H. Cruse  
Baltimore Gas & Electric Company

Calvert Cliffs Nuclear Power Plant

cc:

President  
Calvert County Board of  
Commissioners  
175 Main Street  
Prince Frederick, MD 20678

Mr. Joseph H. Walter, Chief Engineer  
Public Service Commission of  
Maryland  
Engineering Division  
6 St. Paul Centre  
Baltimore, MD 21202-6806

James P. Bennett, Esquire  
Counsel  
Baltimore Gas and Electric Company  
P.O. Box 1475  
Baltimore, MD 21203

Kristen A. Burger, Esquire  
Maryland People's Counsel  
6 St. Paul Centre  
Suite 2102  
Baltimore, MD 21202-1631

Jay E. Silberg, Esquire  
Shaw, Pittman, Potts, and Trowbridge  
2300 N Street, NW  
Washington, DC 20037

Patricia T. Birnie, Esquire  
Co-Director  
Maryland Safe Energy Coalition  
P.O. Box 33111  
Baltimore, MD 21218

Mr. Bruce S. Montgomery, Director  
NRM  
Calvert Cliffs Nuclear Power Plant  
1650 Calvert Cliffs Parkway  
Lusby, MD 20657-4702

Mr. Loren F. Donatell  
NRC Technical Training Center  
5700 Brainerd Road  
Chattanooga, TN 37411-4017

Resident Inspector  
U.S. Nuclear Regulatory  
Commission  
P.O. Box 287  
St. Leonard, MD 20685

Mr. Richard I. McLean, Manager  
Nuclear Programs  
Power Plant Research Program  
Maryland Dept. of Natural Resources  
Tawes State Office Building, B3  
Annapolis, MD 21401

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406