



*Southern California Edison Company*

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN  
STATION MANAGER

TELEPHONE  
(714) 368-6241

September 12, 1988

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Subject: Docket No. 50-362  
Report of NPDES Permit Violation  
San Onofre Nuclear Generating Station, Unit 3

Pursuant to Section 3.2 of Appendix B, Environmental Protection Plan, to Operating License No. NPF-15 for San Onofre Unit 3, enclosed is a copy of the July 1988 monthly NPDES report summary which includes a description of a violation of the San Onofre Unit 3 NPDES permit.

If you require any additional information, please so advise.

Sincerely,

*H E Morgan*

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2, and 3)

J. B. Martin (Regional Administrator, USNRC Region V)

8809210016 880912  
PDR ADOCK 05000362  
R PDC

COO1  
1/1

*Southern California Edison Company*

SAN ONOFRE NUCLEAR GENERATING STATION  
P.O. BOX 128  
SAN CLEMENTE, CALIFORNIA 92672

August 29, 1988

Mr. Ladin Delaney, Executive Officer  
California Regional Water Quality Control Board  
San Diego Region  
9771 Clairemont Mesa Boulevard, Suite B  
San Diego, California 92124-1331

Dear Mr. Delaney:

Subject: NPDES Monitoring Report  
San Onofre Nuclear Generating Station, Unit 3


The SONGS monitoring report covering the month of July is submitted in accordance with the requirements of CRWQCB Order 85-13 (NPDES Permit No. CA0108181). A summary of the generating unit's status and significant analytical results is provided below.

The unit was shutdown for refueling during July. All sampled water sources were found to be within permit limits, except one chlorination on 7/6/88 which exceeded limits. The chlorination was stopped when the sample indicated excessive chlorine. The chemical pumps were reset and testing the following day was within limits. This incident occurred with only two of the four circulating pumps running. Procedural changes have been made to prevent future reoccurrence.

Pursuant to Order No. 85-13, Reporting Requirement 12, your letter dated June 25, 1985, authorizes the following representative(s) to sign and certify all reports required by this order: Arthur Kneisel, Environmental Engineer.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in the attached document, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Sincerely,



B. Katz  
Manager, Operations and Maintenance Support

Enclosure

cc: Environmental Protection Agency, Region IX