



Northeast
Nuclear Energy

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

OCT 8 1998

Docket No. 50-336
B17470

Re: 10 CFR 50.73(a)(2)(i)
10 CFR 50.73(a)(2)(ii)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station, Unit No. 2
Licensee Event Report 98-021-00
Inadequate Radiation Monitoring of Containment
Atmosphere During Refueling Operations

This letter forwards Licensee Event Report (LER) 98-021-00, documenting a condition that was discovered at Millstone Nuclear Power Station, Unit No. 2 on August 25, 1998. This LER is being submitted pursuant to 10 CFR 50.73(a)(2)(i) and 10 CFR 50.73(a)(2)(ii). This report was delayed in being submitted because calculations and analysis were required to determine reportability.

The Northeast Nuclear Energy Company's (NNECO) commitments made within this letter are included in Attachment 1.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

FOR: J. A. Price
Director - Millstone Unit No. 2

J. T. Swientoniewski
Assistant Unit Director - Millstone Unit No. 2

100050

cc: see page 2

9810130311 981008
PDR ADOCK 05000336
S PDR

1/1
IE22

Attachments: 1. List of Regulatory Commitments
2. LER 98-021-00

cc: H. J. Miller, Region I Administrator
D. G. McDonald, Jr., NRC Senior Project Manager, Millstone Unit No. 2
D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2
E. V. Imbro, Director, Millstone IC/AVP Inspections

Docket No. 50-336
B17470

Attachment 1
Millstone Nuclear Power Station, Unit No. 2
Commitments

October 1998

Attachment 1

Regulatory Commitment Enclosure
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document.

REGULATORY COMMITMENT	COMMITTED DATE OR OUTAGE
B17470.01: As a result of this condition, prior to entering Mode 6 from the current outage, the appropriate plant procedure will be revised to ensure operation in accordance with design basis assumptions.	Mode 6 from current outage

Docket No. 50-336
B17470

Attachment 2

Millstone Nuclear Power Station, Unit No. 2

LER 98-021-00

October 1998