

ENCLOSURE  
NOTICE OF DEVIATION

Alabama Power Corporation  
Farley Unit 1

Docket No. 50-348  
License No. NPF-2

The following deviation was identified during a Nuclear Regulatory Commission (NRC) inspection conducted on April 4-8, 1988.

Farley FSAR Section 9B.2.2.2 states that storage of combustible materials is authorized only in areas separated from safe shutdown related areas by approved fire walls, doors and ceilings (i.e., proper storage areas).

Contrary to the above, at the time of the inspection, Unit 1, Room 444, was being utilized as a designated combustible storage area; however, the partial height separation walls of the room were not approved rated fire walls.

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector, in writing within 30 days of the date of this Notice, the reasons for the deviation, the corrective steps which have been taken and the results achieved, the corrective steps which will be taken to avoid further deviations, and the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

FOR THE NUCLEAR REGULATORY COMMISSION

*Frank Gape*  
151  
*original*  
Alan R. Herdt, Chief  
Engineering Branch  
Division of Reactor Safety

Dated at Atlanta, Georgia  
this 13<sup>th</sup> day of May 1988