



A Centenor Energy Company

DONALD C. SHELTON
Vice President - Nuclear
(419) 249-2300

Docket No. 50-346

License No. NPF-3

Serial No. 1516

May 18, 1988

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: Cycle 6 Reload Report License Amendment Request (TAC No. 66730)

Gentlemen:

Enclosed is an application for an Amendment to the Davis-Besse Nuclear Power Station, Unit No. 1 Operating License No. NPF-3, Appendix A, Technical Specifications.

This application requests that the Technical Specifications be revised to reflect the changes attached. The proposed changes involve revising Technical Specifications to permit operation of the Davis-Besse Nuclear Power Station, Unit No. 1, at the noted core power of 2772 MWT for Cycle 6. Cycle 6 operation is based on a fuel loading of 64 new fuel assemblies (3.13 wt% U-235) and 64 burnable poison rod assemblies located in the fresh fuel. Cycle 6 is designed to operate in a feed-and-bleed mode and has a design lifetime of 405 effective full power days (EFPD).

Toledo Edison requests that the Technical Specification Amendment be issued prior to entry into Mode 2, currently scheduled for September 2, 1988.

Enclosed is a check for \$150 as required by 10CFR170.12(c) for a License Amendment application.

Very truly yours,

DC Shelton / [Signature]

CAB:tlt

Enclosure

cc: DB-1 Resident Inspector
A. B. Davis, Regional Administrator
A. W. DeAgazio, NRC/NRR
State of Ohio

*IE26
11
w/check
\$150
#596830*