

TABLE 15.4.1-1 (continued)

NO.	CHANNEL DESCRIPTION	CHECK	CALIBRATE	TEST	PLANT CONDITIONS WHEN REQUIRED
20.	Auxiliary Feedwater Flowrate	(13)	R	-	ALL
21.	Boric Acid Control System	-	R	-	ALL
22.	Boric Acid Tank Level	D	R	-	ALL
23.	Charging Flow	-	R	-	ALL
24.	Condensate Storage Tank Level	S(1)	R	-	ALL
25.	Containment High Range Radiation	S(1)	R(14)	M(1)	ALL
26.	Containment Hydrogen Monitor	D	-	-	ALL
	-Gas Calibration	-	Q(15)	-	ALL
	-Electronic Calibration	-	R	-	ALL
27.	Containment Pressure	S	R	Q(1,3,9)	ALL
28.	Containment Water Level	M	R	-	ALL
29.	Emergency Plan Radiation Survey Instruments	Q	R	Q	ALL
30.	Environmental Monitors Deleted	M	-	-	ALL
31.	In-Core Thermocouples	M	R(14)	-	ALL
32.	Low Temperature Overpressure Protection System	S(12)	R	(10)	ALL
33.	PORV Block Valve Position Indicator	Q	R	-	ALL
34.	PORV Operability	-	R	Q(11)	ALL
35.	PORV Position Indicator	S(21)	R	R	ALL

Unit 1 - Amendment No. 172

Unit 2 - Amendment No. 176

9810140177 981005
PDR ADOCK 05000266
P PDR

Page 3 of 6

February 20, 1997