

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

March 3, 1986

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555


Attention: Mr. B. J. Youngblood, Project Director
PWR Project Directorate No. 4

Re: Catawba Nuclear Station, Units 1 and 2
Docket Nos. 50-413 and 50-414

Dear Mr. Denton:

Enclosed are six copies of Revision 12 (Unit 1) and Revision 2 (Unit 2) to the Catawba Nuclear Station Pump and Valve Inservice Testing Program. These should be incorporated into the existing Pump and Valve Inservice Testing Manual removing any earlier revision pages of the program.

Very truly yours,



Hal B. Tucker

RWO:slb

Enclosures

cc: (w/o enclosures)
Dr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

NRC Resident Inspector
Catawba Nuclear Station

8603100415 860303
PDR ADOCK 05000413
P PDR

A047
1/1

INSERVICE TESTING PROGRAM FOR
PUMPS AND VALVES

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
UNIT 1

Docket No. 50-413

Revision 12

INTRODUCTION

The Inservice Testing Program for Pumps and Valves provides a comprehensive testing plan as required by 10CFR50.55 a(g). This program is based on The ASME Boiler and Pressure Vessel Code, Section XI, Subsections IWP and IWV, 1983 Edition including Addenda through the Summer 1983 Addenda. This test program will be applicable for the initial 120 month interval beginning upon issuance of the operating license, after which the program will be reviewed and updated to that edition and addenda of the Code in effect not more than twelve months prior to the beginning of the next 120 month interval.

Rev. 12

Pump and valve testing requirements are presented in Parts I and II of this submittal. Each part provides summary, program format, data sheet and relief request sections.

INSERVICE TESTING PROGRAM FOR
PUMPS AND VALVES

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
UNIT 2

Docket No. 50-414

REVISION 2

INTRODUCTION

The Inservice Testing Program for Pumps and Valves provides a comprehensive testing plan as required by 10CFR50.55 a(g). This program is based on The ASME Boiler and Pressure Vessel Code, Section XI, Subsections IWP and IWV, 1983 Edition including Addenda through the Summer 1983 Addenda. This test program will be applicable for the initial 120 month interval beginning upon issuance of the operating license, after which the program will be reviewed and updated to that edition and addenda of the Code in effect not more than twelve months prior to the beginning of the next 120 month interval.

Rev. 2

Pump and valve testing requirements are presented in Parts I and II of this submittal. Each part provides summary, program format, data sheet and relief request sections.