



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20565-0001

ILLINOIS POWER COMPANY

DOCKET NO. 50-461

CLINTON POWER STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 117  
License No. NPF-62


1. The U.S. Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Illinois Power Company (the licensee), dated May 4, 1998 as supplemented September 23, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-62 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. , are hereby incorporated into this license. Illinois Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 45 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Jon B. Hopkins, Senior Project Manager  
Project Directorate III-3  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: October 9, 1998

ATTACHMENT TO LICENSE AMENDMENT NO. 117

FACILITY OPERATING LICENSE NO. NPF-62

DOCKET NO. 50-461

Replace the following pages of the Appendix "A" Technical Specifications with the attached pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change.

Remove Pages

--

--

Insert Pages

3.8-44

3.8-45

3.8 ELECTRICAL POWER SYSTEMS

3.8.11 Static VAR Compensator (SVC) Protection Systems

LCO 3.8.11 An SVC Protection System consisting of two redundant protection subsystems shall be OPERABLE for each inservice SVC.

APPLICABILITY: During SVC operation

ACTIONS

-----NOTE-----  
Separate Condition entry is allowed for each SVC Protection System.  
-----

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One subsystem of an SVC Protection System inoperable.	A.1 Restore SVC protection subsystem to OPERABLE status.	30 days
B. Both subsystems of an SVC Protection System inoperable.	B.1 Restore one SVC protection subsystem to OPERABLE status.	24 hours
C. Required Action and associated Completion Time not met.	C.1 Open SVC output breaker(s) to remove SVC from service.	1 hour

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.8.11.1 For each required SVC Protection System, perform a local, visual check of the SVC system control and status panel to confirm satisfactory operation.	24 hours
SR 3.8.11.2 Perform a system functional test of each SVC protection subsystem, including breaker actuation.	18 months