

DOCKET NO. 50/458
RIVER BEND STATION UNIT 1
REPORT NO. R-88-004
DATE May 6, 1988
COMPLETED BY R. E. Cole
TITLE Sr. Systems Engr.
TELEPHONE 635-6094 X4826

MONTH APRIL, 1988

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>926</u>
2.	<u>917</u>
3.	<u>934</u>
4.	<u>935</u>
5.	<u>934</u>
6.	<u>941</u>
7.	<u>945</u>
8.	<u>943</u>
9.	<u>919</u>
10.	<u>942</u>
11.	<u>946</u>
12.	<u>918</u>
13.	<u>934</u>
14.	<u>939</u>
15.	<u>728</u>
16.	<u>940</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>936</u>
18.	<u>935</u>
19.	<u>943</u>
20.	<u>942</u>
21.	<u>939</u>
22.	<u>933</u>
23.	<u>894</u>
24.	<u>938</u>
25.	<u>935</u>
26.	<u>939</u>
27.	<u>939</u>
28.	<u>943</u>
29.	<u>939</u>
30.	<u>910</u>
31.	<u>N/A</u>

Je24
111

DOCKET NO. 50/458
 RIVER BEND STATION UNIT 1
 REPORT NO. R-88-004
 DATE May 6, 1988
 COMPLETED BY R. E. Cole
 TITLE Sr. Systems Engr.
 TELEPHONE 635-6094 X4826

PAGE 1 OF 2

OPERATING STATUS

1. REPORTING PERIOD: APRIL, 1988 GROSS HOURS IN REPORTING PERIOD: 719
2. CURRENTLY AUTHORIZED POWER LEVEL (Mwt): 2894
 MAX. DEPEND CAPACITY (MWe-Net): 936
 DESIGN ELECTRICAL RATING (Mwe-Net): 936
3. PCWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): N/A
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMU- LATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL...	<u>719.0</u>	<u>2,735.6</u>	<u>14,978.7</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
7. HOURS GENERATOR ON LINE.....	<u>719.0</u>	<u>2,678.3</u>	<u>13,210.0</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)..	<u>2,058,013</u>	<u>7,484,314</u>	<u>33,084,126</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>710,468.0</u>	<u>2,589,791.0</u>	<u>11,211,165.7</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH).	<u>666,420.0</u>	<u>2,429,895.0</u>	<u>10,485,102.0</u>

DOCKET NO. 50/458
 RIVER BEND STATION UNIT 1
 REPORT NO. R-88-004
 DATE May 6, 1988
 COMPLETED BY R. E. Cole
 TITLE Sr. Systems Engr.
 TELEPHONE 635-6094 X4826

OPERATING STATUS

	THIS MONTH	YR TO DATE	CUMU-LATIVE
12. REACTOR SERVICE FACTOR	<u>100.0</u>	<u>94.2</u>	<u>69.8</u>
13. REACTOR AVAILABILITY FACTOR	<u>100.0</u>	<u>94.2</u>	<u>69.8</u>
14. UNIT SERVICE FACTOR	<u>100.0</u>	<u>92.3</u>	<u>66.9</u>
15. UNIT AVAILABILITY FACTOR	<u>100.0</u>	<u>92.3</u>	<u>66.9</u>
16. UNIT CAPACITY FACTOR (Using MDC) ..	<u>99.0</u>	<u>89.4</u>	<u>61.9</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)	<u>99.0</u>	<u>89.4</u>	<u>61.9</u>
18. UNIT FORCED OUTAGE RATE	<u>0.0</u>	<u>6.7</u>	<u>11.9</u>
19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH): NONE			
20. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: <u>N/A</u>			
21. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): <u>N/A</u>			

UNIT SHUTDOWNS AND POWER REDUCTIONS

NO.	DATE	TIME START OF OCCURRENCE	TIME RECOVER FROM OCCURRENCE	DURATION (HOURS)	TYPE NOTE (1)	REASON NOTE (2)	METHOD NOTE (3)	CORRECTIVE ACTIONS/COMMENTS
88-06	880415	0330	1525 880415	0.0	S	A	4	Reduced power to 65% to fix actuator on first point feedwater heater level valve 1HDH-SOV6A.

SUMMARY:

- NOTE (1) TYPE OF OCCURRENCE: ENTER CODE
 F: FORCED
 S: SCHEDULED
- NOTE (2) REASON FOR OCCURRENCE: ENTER CODE
 A: EQUIPMENT FAILURE (EXPLAIN IN CORRECTIVE ACTIONS/COMMENTS)
 B: MAINTENANCE OR TEST
 C: REFUELING
 D: REGULATORY RESTRICTION
 E: OPERATOR TRAINING AND LICENSE EXAMINATION
 F: ADMINISTRATIVE
 G: OPERATIONAL ERROR (EXPLAIN IN CORRECTIVE ACTIONS/COMMENTS)
 H: OTHER (EXPLAIN IN CORRECTIVE ACTIONS/COMMENTS)
- NOTE (3) METHOD OF SHUTTING DOWN REACTOR OR REDUCING POWER: ENTER CODE
 1: MANUAL
 2: MANUAL SCRAM
 3: AUTOMATIC SCRAM
 4: OTHER (EXPLAIN IN CORRECTIVE ACTION/COMMENTS)

DOCKET NO. 50/458
 RIVER BEND STATION UNIT 1

REPORT NO. R-88-004

REPORT MONTH April, 1988

DATE May 6, 1988

R. E. Cole

COMPLETED BY:

R. E. Cole
 SIGNATURE

Sr. Systems Engineer

TITLE

TELEPHONE 504 635-5094
extension 4826



GULF STATES UTILITIES COMPANY

RIVER BEND STATION POST OFFICE BOX 220 ST. FRANCISVILLE, LOUISIANA 70775

AREA CODE 504 635-6094 346-8651

May 13, 1988
RBG-27838
File Nos. G9.5, G9.25.1.5

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Gentlemen:

River Bend Station - Unit 1
Docket No. 50-458

Enclosed is Gulf States Utilities Company's Monthly Operating Report for April 1988 for River Bend Station (RBS) - Unit 1. This report is submitted in accordance with RBS Technical Specification 6.9.1.6.

Sincerely,

L. A. England

for J. E. Booker
Manager-River Bend Oversight
River Bend Nuclear Group

JEB/LAE/RJK/MF/ch

Enclosure

cc: U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

NRC Resident Inspector
P.O. Box 1051
St. Francisville, LA 70775

INPO Records Center
1100 Circle 75 Parkway
Atlanta, GA 30339

Cajun Electric Power Coop., Inc.

IE24
11