


TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER - 400 NORTH OLIVE STREET, L.B. 81 - DALLAS, TEXAS 75201

February 28, 1986

WILLIAM G. COUNCIL
EXECUTIVE VICE PRESIDENT



Mr. Eric H. Johnson, Director
Division of Reactor Safety and Projects
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76012

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NO. 50-446
COMPUTER PROGRAM ERRORS
SDAR: CP-85-41 (FINAL REPORT)

Dear Mr. Johnson:

On September 18, 1985, we verbally notified your Mr. T. Westerman of a deficiency involving errors identified in checking routines of computer program P Delta STRUDL 0385. The program is used by an engineering contractor in the analysis of cable tray and conduit supports for Unit 2. We have submitted interim reports logged TXX-4614 and TXX-4590, dated November 7, 1985, and October 10, 1985, respectively.

Computer routines for approximately 1,000 of 3,800 affected calculation packages potentially affected by the program errors have been rerun. This sample has not identified a single support where the errors have had an adverse effect on the integrity of the cable tray supports. The issue is not reportable under the provisions of 10CFR50.55(e). Records supporting this determination are available for your inspectors to review at the CPSES site.

Very truly yours,

W. G. Council

JCH/arm

c - NRC Region IV (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

1/0
1E27

86-223