

APPENDIX

U.S. NUCLEAR REGULATORY COMMISSION
REGION IV

NRC Inspection Report: 50-382/86-01

License: NPF-38

Docket: 50-382


Licensee: Louisiana Power & Light Company
142 Delaronde Street
New Orleans, Louisiana 70174

Facility Name: Waterford 3


Inspection At: Taft, Louisiana

Inspection Conducted: January 27-31, 1986

Inspectors:



R. A. Caldwell, Physical Security Inspector
Emergency Preparedness and Safeguards
Programs Section

2/28/86
Date


A. B. Earnest, Physical Security Inspector
Emergency Preparedness and Safeguards
Programs Section

2/28/86
Date

Approved:


L. A. Yandell, Chief, Emergency Preparedness
and Safeguards Programs Section

2/28/86
Date

Inspection Summary

Inspection Conducted January 27-31, 1986 (Report 50-382/86-01)

Areas Inspected: Routine, unannounced inspection of locks, keys, and combinations, physical barriers-protected area, physical barriers-vital area, lighting, assessment aids, access control-personnel, access control-packages,

8603100584 860228
PDR ADOCK 05000382
G PDR

ENCLOSURE CONTAINS
SAFEGUARDS INFORMATION.
UPON SEPARATION THIS
PAGE IS DECONTROLLED.

access control-vehicles, detections aids-protected area, detection aids-vital area, and communications. The inspection involved 114 inspector-hours by two NRC inspectors.

Results: Within the 11 areas inspected, 6 violations were identified: (two instances of failure to control access, (paragraph 2), failure to control keys, (paragraph 3), failure to search packages, (paragraph 4), inadequate response to vital area alarm, (paragraph 5), and inadequate assessment aids, (paragraph 9).

ENCLOSURE CONTAINS
SAFEGUARDS INFORMATION.
UPON SEPARATION THIS
PAGE IS DECONTROLLED.