


Log # TXX-4718
File # 10110
903.7

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 51 • DALLAS, TEXAS 75201

February 28, 1986

WILLIAM G. COUNCIL
EXECUTIVE VICE PRESIDENT



Mr. Eric H. Johnson, Director
Division of Reactor Safety and Projects
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76012

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
SEISMIC QUALIFICATION OF HVAC SUPPORTS
SDAR: CP-85-54

Dear Mr. Johnson:

On December 20, 1985, we verbally notified your Mr. R. Hall of a deficiency involving discrepancies in supplier provided HVAC support documents which could invalidate the seismic qualification of the supports. This is an interim report of a potentially reportable item under the provisions of 10CFR50.55(e). We have submitted an interim report logged TXX-4668, dated January 20, 1986.

A program of field inspections and engineering verification has been initiated to determine the extent of this issue. As-built analyses of the support system in selected plant areas, in addition to the review of specific hardware concerns, will provide information to assess the unresolved support qualification issue. These efforts are currently scheduled for completion in late May, 1986.

We are continuing our evaluation and anticipate completion of our final report by June 19, 1986.

Very truly yours,

W. G. Council
W. G. Council

8603100645 860228
PDR ADOCK 05000445
S PDR

JCH/arm

c - NRC Region IV (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

1/0
IE27

86-222