

23A5841
REVISION 0
CLASS I
JULY 1988

23A5841 REV. 0

SUPPLEMENTAL RELOAD LICENSING SUBMITTAL
FOR

LA SALLE COUNTY STATION UNIT 2

RELOAD 2, CYCLE 3

Prepared by: P. A. Lambert
P. A. Lambert
Fuel Licensing

Verified by: P. E. Elliott
P. E. Elliott
Fuel Licensing

Approved by: J. S. Charnley
J. S. Charnley
Manager, Fuel Licensing

8809230081 880914
PDR ADOCK 05000374
P PNU



GE Nuclear Energy

17

00 72

IMPORTANT NOTICE REGARDING
CONTENTS OF THIS REPORT

PLEASE READ CAREFULLY

This report was prepared by General Electric solely for Commonwealth Edison Company (CECo) for CECo's use with the United States Nuclear Regulatory Commission (USNRC) for amending CECo's operating license of the La Salle County Station, Unit 2. The information contained in this report is believed by General Electric to be an accurate and true representation of the facts known, obtained or provided to General Electric at the time this report was prepared.

The only undertakings of the General Electric Company respecting information in this document are contained in the contract between Commonwealth Edison Company and General Electric Company for nuclear fuel and related services for the nuclear system for La Salle 2, and nothing contained in this document shall be construed as changing said contract. The use of this information except as defined by said contract, or for any purpose other than that for which it is intended, is not authorized; and with respect to any such unauthorized use, neither General Electric Company nor any of the contributors to this document makes any representation or warranty (express or implied) as to the completeness, accuracy or usefulness of the information contained in this document or that such use of such information may not infringe privately owned rights; nor do they assume any responsibility for liability or damage of any kind which may result from such use of such information.

00 73

ACKNOWLEDGEMENTS

The engineering and reload licensing analyses, which form the technical basis of this Supplemental Reload Licensing Submittal, were performed in the Nuclear Fuel and Engineering Services Department by F. T. Bolger.

00 74

1. PLANT-UNIQUE ITEMS (1.0)*

Transient Analysis Basis:

Appendix A

GETAB and Transient Analysis Initial Conditions:

Appendix B

2. RELOAD FUEL BUNDLES (1.0, 2.0, 3.3.1 AND 4.0)

<u>Fuel Type</u>	<u>Cycle Loaded</u>	<u>Number</u>
Irradiated		
8CRB176	1	40
8CRB219	1	260
BP8CRB299L	2	224
New		
BC320C	3	96
BC300D	3	144
Total		<hr/> 764

3. REFERENCE CORE LOADING PATTERN (3.3.1)

Nominal previous cycle core average exposure

at end of cycle:

17990 MWd/MT

Minimum previous cycle core average exposure

at end of cycle from cold shutdown considerations:

17714 MWd/MT

Assumed reload cycle core average exposure

at end of cycle:

19377 MWd/MT

Core loading pattern:

Figure 1

* () Refers to area of discussion in General Electric Standard Application for Reactor Fuel, NEDE-24011-P-A-8 (dated May 1986); a letter "S" preceding the number refers to the United States Supplement.

00 75

4. CALCULATED CORE EFFECTIVE MULTIPLICATION AND CONTROL SYSTEM WORTH- NO VOIDS, 20 DEG. C (3.3.2.1.1 AND 3.3.2.1.2)

Beginning of Cycle, k-effective

Uncontrolled	1.123
Fully Controlled	0.960
Strongest Control Rod Out	0.985
R, Maximum Increase in Cold Core Reactivity with Exposure into Cycle, Delta k	0.005

5. STANDBY LIQUID CONTROL SYSTEM SHUTDOWN CAPABILITY (3.3.2.1.3)

<u>DDM</u>	<u>Shutdown Margin (Delta k)</u> <u>(20 deg.C, Xenon Free)</u>
660	0.037

6. RELOAD-UNIQUE TRANSIENT ANALYSIS INPUT (3.3.2.1.5 AND S.2.2)

Values normally reported in this section are REDY inputs. There were no transients analyzed using REDY.

7. RELOAD-UNIQUE GETAB TRANSIENT ANALYSIS INITIAL CONDITION PARAMETERS (S.2.2)

Exposure: BOC3 TO EOC3

<u>Fuel Design</u>	<u>Peaking Factors</u>			<u>R-Factor</u>	<u>Bundle Power(MWT)</u>	<u>Bundle Flow (1000 lb/hr)</u>	<u>Initial MCPR</u>
	<u>Local</u>	<u>Radial</u>	<u>Axial</u>				
GE8x8EB*	1.20	1.57	1.40	1.051	6.681	114.9	1.21

*All fuel types are bounded by GE8x8EB.

00 76

8. SELECTED MARGIN IMPROVEMENT OPTIONS (S.2.2.2)

Transient Recategorization:	No
Recirculation Pump Trip:	Yes
Rod Withdrawal Limiter:	No
Thermal Power Monitor:	Yes
Improved Scram Time:	No
Exposure Dependent Limits:	No
Exposure Points Analyzed:	1

9. OPERATING FLEXIBILITY OPTIONS (S.2.2.3)

Single-Loop Operation:	Yes
Load Line Limit:	No
Extended Load Line Limit:	Yes
Increased Core Flow	Yes
Flow Point Analyzed:	105%
Feedwater Temperature Reduction:	Yes
ARTS Program:	No
Maximum Extended Operating Domain:	No

10. CORE-WIDE TRANSIENT ANALYSIS RESULTS (S.2.2.1)

Methods Used: GEMINI

<u>Transient</u>	<u>Flux (% NBR)</u>	<u>Q/A (% NBR)</u>	<u>Delta CPR GE8x8EB*</u>	<u>Figure</u>
Exposure Range: BOC3 to EOC3				
Load Rejection Without Bypass	383	115	0.14	2
Loss of Feedwater Heating	119	119	0.11	**
Feedwater Controller Failure	238	111	0.10	3
Exposure Range: BOC3 to EOC3 Extended Load Line Limit				
Load Rejection Without Bypass	328	113	0.12	4
Feedwater Controller Failure	211	109	0.08	5
Exposure Range: Extended EOC with Increased Core Flow				
Load Rejection Without Bypass	414	115	0.15	6
Feedwater Controller Failure	260	112	0.12	7
Exposure Range: Extended EOC with Increased Core Flow and Final Feedwater Temperature Reduction				
Load Rejection Without Bypass	374	114	0.14	8
Feedwater Controller Failure	276	117	0.16	9

*All fuel types are bounded by GE8x8EB.

**See Appendix A.

00 78

11. LOCAL ROD WITHDRAWAL ERROR (WITH LIMITING INSTRUMENT FAILURE)
TRANSIENT SUMMARY (S.2.2.1)

Limiting Rod Pattern: Figure 10

<u>Rod Block Reading %</u>	<u>Rod Position (Feet Withdrawn)</u>	<u>Delta CPR GE8x8EB*</u>	<u>MLHGR (kW/ft) GE8x8EB*</u>
104	4.0	0.15	18.84
105	4.5	0.18	18.84
106	5.0	0.19	18.84
107	6.5	0.22	18.84
108	12.0	0.23	18.84
109	12.0	0.23	18.84
110	12.0	0.23	18.84

Set Point Selected: 106

12. CYCLE MCPR VALUES (S.2.2)

Non-Pressurization Events

Exposure Range: BOC3 to EOC3

	<u>GE8x8EB*</u>
Loss of Feedwater Heating	1.18
Fuel Loading Error	**
Rod Withdrawal Error	1.26

Pressurization Events

Exposure Range: BOC3 to EOC3

	<u>Option A</u> <u>GE8x8EB*</u>	<u>Option B</u> <u>GE8x8EB*</u>
Load Rejection Without Bypass	1.26	1.22
Feedwater Controller Failure	1.20	1.18

*All fuel types are bounded by GE8x8EB.
 **Fuel Loading Error not applicable for C-Lattice plants.

00 79

Pressurization Events

Exposure Range: BOC3 to EOC3 Extended Load Line Limit

	<u>Option A</u> <u>GE8x8EB*</u>	<u>Option B</u> <u>GE8x8EB*</u>
Load Rejection Without Bypass	1.24	1.20
Feedwater Controller Failure	1.19	1.17

Exposure Range: Extended EOC with Increased Core Flow

	<u>Option A</u> <u>GE8x8EB*</u>	<u>Option B</u> <u>GE8x8EB*</u>
Load Rejection Without Bypass	1.27	1.23
Feedwater Controller Failure	1.22	1.20

Exposure Range: Extended EOC with Increased Core Flow and Final Feedwater Temperature Reduction

	<u>Option A</u> <u>GE8x8EB*</u>	<u>Option B</u> <u>GE8x8EB*</u>
Load Rejection Without Bypass	1.26	1.22
Feedwater Controller Failure	1.26	1.24

13. OVERPRESSURIZATION ANALYSIS SUMMARY (S.2.3)

<u>Transient</u>	<u>Steam Line Pressure (psig)</u>	<u>Vessel Pressure (psig)</u>	<u>Plant Response</u>
MSIV Closure (Flux Scram)	1227	1264	Figure 11

*All fuel types are bounded by GE8x8EB.

00 80

14. LOADING ERROR RESULTS (S.2.5.4)

Not applicable for C-Lattice plants.

15. CONTROL ROD DROP ANALYSIS RESULTS (S.2.5.1)

Control Rod Drop Accident Analysis is not required for banked position withdrawal sequence plants. NRC approval is documented in NEDE-24011-P-A-8-US, May 1986.

16. STABILITY ANALYSIS RESULTS (S.2.4)

GE SIL-380 recommendations have been included in the plant operating procedures and/or Technical Specifications; therefore, no stability analysis is required. NRC approval for deletion of a cycle-specific stability analysis is documented in NEDE-24011-P-A-8-US.

17. LOSS-OF-COOLANT ACCIDENT RESULTS (S.2.5.2)

LOCA Method Used: SAFER/GESTR-LOCA

La Salle County Station Units 1 and 2, "SAFER/GESTR-LOCA Loss-of-Coolant Accident Analysis," NEDC-31510P, December 1987 (as amended).

Technical Specification MAPLHGR Limits

Fuel Type: BC320C (GE8x8EB)


<u>Average Planar Exposure (GWd/ST)</u>	<u>MAPLHGR (KW/ft)</u>	
	<u>Most Limiting</u>	<u>Least Limiting</u>
0.0	11.6	11.6
3.0	--	12.2
4.0	12.2	12.4
6.0	12.6	12.8
8.0	12.9	13.1
10.0	13.1	--
12.5	13.0	13.0
15.0	12.7	12.7
35.0	10.2	10.2
45.0	8.5	8.6
50.0	6.1	6.1

17. LOSS-OF-COOLANT ACCIDENT RESULTS (S.2.5.2)(continued)

Technical Specification MAPLHGR Limits

Fuel Type: BC300D (GE8x8EB)

<u>Average Planar Exposure (Gwd/ST)</u>	<u>MAPLHGR (KW/ft)</u>
0.0	11.8
2.0	12.3
3.0	12.6
4.0	12.9
5.0	13.2
10.0	13.5
15.0	13.2
35.0	10.7
45.0	8.7
50.0	6.6



FUEL TYPE	
A = 8CRB176	D = BP8CRB299L
B = 8CRB219	E = BC300D
C = 8CRB219	F = BC320C

Figure 1. Reference Core Loading Pattern







Figure 2. Plant Response to Generator Load Rejection Without Bypass (BOC3 to EOC3)







Figure 3. Plant Response to Feedwater Controller Failure, (BOC3 to EOC3)







Figure 4. Plant Response to Generator Load Rejection Without Bypass (Extended Load Line 1)




Figure 5. Plant Response to Feedwater Controller Failure (Extended Load Line Limit)




Figure 6. . Plant Response to Generator Load Rejection Without Bypass (Increased Core Flow)







Figure 7. Plant Response to Feedwater Controller Failure (Increase Core Flow)




Figure 8. Plant Response to Generator Load Rejection Without Bypass (Increased Core Flow and Final Feedwater Temperature Reduction)




Figure 9. Plant Response to Feedwater Controller Failure (Increased Core Flow and Final Feedwater Temperature Reduction)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59					18		30		30		18				
55				14		8		8		8		14			
51			18		20		0		0		20		18		
47		14		8		30		30		30		8		14	
43	18		20		4		10		10		4		20		18
39		8		30		26		44		26		30		8	
35	30		0		10		0		0		10		0		30
31		8		30		44		16		44		30		8	
27	30		0		10		0		0		10		0		30
23		8		30		26		44		26		30		8	
19	18		20		4		10		10		4		20		18
15		14		8		30		30		30		8		14	
11			18		20		0		0		20		18		
7				14		8		8		8		14			
3					18		30		30		18				

NOTES:

- No. indicates number of notches withdrawn out of 48. Blank is a Withdrawn Rod.
- Error Rod is (26, 35).

Figure 10. Limiting Rod Pattern







Figure 11. Plant Response to MSIV Closure (Flux Scram)

APPENDIX A
TRANSIENT ANALYSIS BASIS

The Loss of Feedwater Heating event was analyzed using the BWR Simulator Code (Reference A-1). The use of this code is permitted in GESTAR II (Reference A-2).

The Loss of Feedwater Heating Event plot normally reported in Section 10 is not an output of the BWR Simulator Code; therefore, this plot is not included in this document.

REFERENCES

- A-1. "Three Dimensional BWR Core Simulator," NEDO-20953A, January 1977.
- A-2. "General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A-8, May 1986.

APPENDIX B
GETAB AND TRANSIENT ANALYSIS INITIAL CONDITIONS

The values used in the GETAB and Transient Analysis are given in Table B-1. The following values differ from the values reported in NEDE-24011-P-A-8-US, May 1986.

Table B-1
PLANT PARAMETER

<u>Parameter</u>	<u>Analysis Value</u>	<u>NEDE-24011 Value</u>
Thermal Power MWt	3323	3453
Rated Steamflow x 10 ⁶ lb/hr	14.30	14.97
Dome Pressure psig	1006	1020
Non-Fuel Power Fraction	0.038	0.04
Dual Mode Safety/Relief Valves (18)		
Relief Mode Low Setpoint psig	1087	1076
Safety Mode Low Setpoint psig	1162	1165

ADDITIONAL INFORMATION REGARDING THE SUPPLEMENTAL RELOAD LICENSING SUBMITTAL
FOR LA SALLE 2 RELOAD 2/CYCLE 3

Section 3. REFERENCE CORE LOADING PATTERN

Cycle N-1 Incremental Exposure	<u>8200 MWD/ST</u>
Cycle N Exposure Increment	<u>7450 MWD/ST</u>
Cycle N Full Power Capability (if different from above)	<u> </u>

Section 4. CALCULATED CORE EFFECTIVE MULTIPLICATION AND CONTROL SYSTEM
WORTH (NO VOIDS, 20°C)

Cycle Incremental Exposure Corresponding to Minimum Shutdown Margin R-Value	<u>6000 MWD/ST</u>
--	--------------------

Section 6. RELOAD-UNIQUE TRANSIENT ANALYSIS INPUT (REDY EVENTS)

EOC Void Fraction (Haling)	<u>REDY Not Used</u>
EOC Bypass Flow Fraction	<u>REDY Not Used</u>
Delayed Neutron Fraction (BOC/EOC)	<u>REDY Not Used</u>
Void Coefficient X 10 ³ (BOC/EOC)	<u>REDY Not Used</u>
[Units are (Δk/k)/(Δ% voids)]	

Section 10. CORE-WIDE TRANSIENT ANALYSIS RESULTS

<u>Limiting Exposure</u>	<u>Transient</u>	<u>Power (% NBR)</u>	<u>Flow (% NBR)</u>	<u>Flux (% NBR)</u>	<u>Q/A (% NBR)</u>	<u>PSL (psig)</u>	<u>PV (Dome) (psig)</u>	<u>PV (Bottom) (psig)</u>
<u>EOC</u>	<u>TTNBP</u>	<u>100</u>	<u>100</u>	<u>342.6</u>	<u>112.8</u>	<u>1141</u>	<u>1149</u>	<u>1177</u>
<u>EOC</u>	<u>LRNBP</u>	<u>100</u>	<u>100</u>	<u>382.9</u>	<u>114.7</u>	<u>1143</u>	<u>1150</u>	<u>1178</u>
<u>EOC</u>	<u>MSIVF</u>	<u>102</u>	<u>100</u>	<u>484.2</u>	<u>129.1</u>	<u>1227</u>	<u>1232</u>	<u>1264</u>
<u>Not Analyzed</u>	<u>MSIVD</u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
<u>(PANACEA)</u>	<u>LFWH</u>	<u>100</u>	<u>87</u>	<u>119.4</u>	<u>119.2</u>	<u>N/A</u>	<u>1006</u>	<u>1027 est</u>
<u>EOC</u>	<u>FWCF</u>	<u>100</u>	<u>100</u>	<u>238.1</u>	<u>111.1</u>	<u>1122</u>	<u>1128</u>	<u>1155</u>

ADDITIONAL INFORMATION REGARDING THE SUPPLEMENTAL RELOAD LICENSING SUBMITTAL
FOR LA SALLE 2 RELOAD 2/CYCLE 3

Section 10. CORE-WIDE TRANSIENT ANALYSIS REPORT (CONTINUED)

Were resolved OPL-3 values used for safety
and relief valve characteristics?

Yes

Assumed MSIV Closure Characteristics:

<u>Time (sec)</u>	<u>MSIV Area (per unit)</u>
0.0	1.0 (fully opened)
0.6	1.0
1.7	0.01
3.0	0.0 (fully closed)

Section 14. ROD BLOCK LINE EQUATION

$$RB \leq 0.58W + 50$$

Section 15. LOADING ERROR RESULTS

Bundle Type for Limiting Misorientation:

N/A

ADDITIONAL INFORMATION REGARDING THE SUPPLEMENTAL RELOAD LICENSING SUBMITTAL
FOR LA SALLE 2 RELOAD 2/CYCLE 3

Section 3. REFERENCE CORE LOADING PATTERN

Cycle N-1 Incremental Exposure _____
 Cycle N Exposure Increment _____
 Cycle N Full Power Capability (if different
 from above) _____

Section 4. CALCULATED CORE EFFECTIVE MULTIPLICATION AND CONTROL SYSTEM
WORTH (NO VOIDS, 20°C)

Cycle Incremental Exposure Corresponding to
 Minimum Shutdown Margin R-Value _____

Section 6. RELOAD-UNIQUE TRANSIENT ANALYSIS INPUT (REDY EVENTS)

(Provided unless generic LOFH is reported)

EOC Void Fraction (Haling) _____
 EOC Bypass Flow Fraction _____
 Delayed Neutron Fraction (BOC/EOC) _____
 Void Coefficient X 10³ (BOC/EOC) _____
 [Units are (Δk/k)/(Δ% voids)]

Section 10. CORE-WIDE TRANSIENT ANALYSIS RESULTS/ELLLA

Limiting Exposure	Transient	Power (% NBR)	Flow (% NBR)	Flux (% NBR)	Q/A (% NBR)	PSL (psig)	FV (Dome) (psig)	FV (Bottom) (psig)
EOC	TTNBP	100	87	290.6	110.8	1142	1150	1174
EOC	LRNBP	100	87	327.9	112.7	1142	1150	1174
EOC	MSIVF	102	87	458.7	122.4	1228	1232	1259
Not Analyzed	MSIVD	_____	_____	_____	_____	_____	_____	_____
Not Analyzed	LFWH	_____	_____	_____	_____	_____	_____	_____
EOC	FWCF	100	87	210.6	109.4	1122	1128	1152

ADDITIONAL INFORMATION REGARDING THE SUPPLEMENTAL RELOAD LICENSING SUBMITTAL
FOR LA SALLE 2 RELOAD 2/CYCLE 3

Section 3. REFERENCE CORE LOADING PATTERN

Cycle N-1 Incremental Exposure _____
 Cycle N Exposure Increment _____
 Cycle N Full Power Capability (if different
 from above) _____

Section 4. CALCULATED CORE EFFECTIVE MULTIPLICATION AND CONTROL SYSTEM
WORTH (NO VOIDS, 20°C)

Cycle Incremental Exposure Corresponding to
 Minimum Shutdown Margin R-Value _____

Section 6. RELOAD-UNIQUE TRANSIENT ANALYSIS INPUT (REDY EVENTS)

(Provided unless generic LOFH is reported)

EOC Void Fraction (Haling) _____
 EOC Bypass Flow Fraction _____
 Delayed Neutron Fraction (BOC/EOC) _____
 Void Coefficient X 10³ (BOC/EOC) _____
 [Units are (Δk/k)/(Δ% voids)]

Section 10. CORE-WIDE TRANSIENT ANALYSIS RESULTS/ICF

Limiting Exposure	Transient	Power (% NBR)	Flow (% NBR)	Flux (% NBR)	Q/A (% NBR)	PSL (psig)	PV (Dome) (psig)	PV (Bottom) (psig)
EOC+190 Mwd/ST	TTNBP	100	105	372.7	113.9	1141	1149	1178
EOC+190 Mwd/ST	LRNBP	100	105	413.9	115.3	1142	1150	1180
EOC+190 Mwd/ST	MSIVF	102	105	489.1	127.2	1228	1232	1267
Not Analyzed	MSIVD							
EOC+190 Mwd/ST	LPWH							
EOC+190 Mwd/ST	FWCF	100	105	259.7	112.3	1122	1128	1157

ADDITIONAL INFORMATION REGARDING THE SUPPLEMENTAL RELOAD LICENSING SUBMITTAL
FOR LA SALLE 2 RELOAD 2/CYCLE 3

Section 3. REFERENCE CORE LOADING PATTERN

Cycle N-1 Incremental Exposure _____
 Cycle N Exposure Increment _____
 Cycle N Full Power Capability (if different
 from above) _____

Section 4. CALCULATED CORE EFFECTIVE MULTIPLICATION AND CONTROL SYSTEM
WORTH (NO VOIDS, 20°C)

Cycle Incremental Exposure Corresponding to
 Minimum Shutdown Margin R-Value _____

Section 6. RELOAD-UNIQUE TRANSIENT ANALYSIS INPUT (REDY EVENTS)

(Provided unless generic LOFH is reported)
 EOC Void Fraction (Haling) _____
 EOC Bypass Flow Fraction _____
 Delayed Neutron Fraction (BOC/EOC) _____
 Void Coefficient X 10³ (BOC/EOC) _____
 [Units are (Δk/k)/(Δ% voids)]

Section 10. CORE-WIDE TRANSIENT ANALYSIS RESULTS/ICF+FFWTR

Limiting Exposure	Transient	Power (% NBR)	Flow (% NBR)	Flux (% NBR)	Q/A (% NBR)	PSL (psig)	PV (Dome) (psig)	PV (Bottom) (psig)
EOC+817 MWD/ST	TTNBP	100	105	341.4	112.5	1137	1145	1173
EOC+817 MWD/ST	LRNBP	100	105	373.6	114.3	1139	1146	1174
EOC+817 MWD/ST	MSIVF	102	105	412.0	125.4	1220	1225	1258
Not Analyzed	MSIVD							
Not Analyzed	LPWH							
EOC+817 MWD/ST	PWCF	100	105	276.2	116.8	1116	1121	1149

REFERENCES

1. Unit 1 Cycle 3 Reload Licensing Submittal and Technical Specification Changes, LOSR 87-74
2. GE Document NEDE-31455, "Extended Operating Domain and Equipment Out of Service for LaSalle County Nuclear Station Units 1 and 2", dated November 1987 with addendum in Attachment 6.
3. GE document NEDC-31510P, "LaSalle County Station Units 1 and 2 SAFER/GESTR-LOCA Loss-of-Coolant Accident Analyses," dated December 1987, Proprietary.

ATTACHMENT G

GE Document NEDC-31510P, "LaSalle County Station Units 1 and 2 SAFER/GESTR-LOCA Loss-of-Coolant Accident Analyses", Addendum Issued March, 1988, Proprietary.

This document will be sent under separate cover

ATTACHMENT H

GE STANDARD LICENSING STABILITY ANALYSIS RESULTS



August 9, 1988
REP:88-173

cc: W. F. Naughton

Mr. R. A. Roehl
Supervising Fuel Buyer
COMMONWEALTH EDISON COMPANY
Fuel Department, 234 E
P. O. Box 767
Chicago, IL 60690

SUBJECT: LaSalle Unit 2 Reload 2 Stability Analysis

REFERENCE: 1. "Contract between Commonwealth Edison Company and General Electric Company for Fuel Bundle Fabrication and Related Services for Quad Cities Nuclear Power Station and LaSalle County Station," dated January 6, 1986.

ATTACHMENT: LaSalle Unit 2 Reload 2 Standard Licensing Stability Analysis

Dear Mr. Roehl:

Attached are the results of the standard licensing stability analysis for LaSalle Unit 2, Cycle 3. These results are based on approved GESTAR-II models using approved procedures and were calculated in the same way as the Cycle 2 results. However, if LaSalle has a pump trip event similar to that experienced in Cycle 2, they should expect results similar to those observed in Cycle 2.

Very truly yours,

R. E. Parr
Senior Fuel Project Manager
Edison Projects
M/C 174; (408) 925-6526

REP:mg.3

ATTACHMENT 1

LaSalle 2/Cycle 3

The results of the standard licensing stability analysis are given below, consistent with the cycle 2 analysis approach. The results reflect the effects of the more negative C-3 void coefficients and the lower pressure drop GE-8 fuel.

DECAY RATIO AT THE INTERSECTION
OF NATURAL CIRCULATION AND

	<u>105% Rod Line</u>	<u>Extrap. APRM Rod Block</u>
Core Decay Ratio	.63	.72
Channel Decay Ratio		
P8x8R/8X8R	.47	.63
GE-8	.42	.56

The plot for this case is shown in Figure 1.




Figure 1. Reactor Core Decay Ratio vs Power