

SEMI-ANNUAL RADIOACTIVE EFFLUENT
RELEASE REPORT

July - December

1985

Public Service Company of Colorado

Fort St. Vrain
Nuclear Generating Station

February 1986

8603100683 851231
PDR ADOCK 05000267
R PDR

1025
1/1

1.0 Summary

This report summarizes the radiological effluent released from the Fort St. Vrain Nuclear Generating Station for the period July through December, 1985. In addition, Table 3.1 provides a general summary of the plant systems under radiological surveillance, and Table 4.1 summarizes the solid radioactive waste removed from the site during the aforementioned time period. This information is provided pursuant to the requirements of Section 7.5.1 e. of the Fort St. Vrain Technical Specifications.

Tritium activity continues to be the principal radionuclide released to the environment via the liquid pathway. A total of 10.99 curies of tritium was released during this reporting period. The principal radionuclide released via the gaseous pathway was xenon-133 with a total release value of 1.38 curies.

There were no unplanned gaseous or liquid radioactive releases from the site to the unrestricted area during this reporting period.

During the second half of 1985, one revision was made to the Offsite Dose Calculation Manual (SUSMAP-2) which more clearly delineated the sample site descriptions for our Radiological Environmental Surveillance Program. This revision also included one editorial change regarding lower allowable alarm setpoints.

No changes were made to the Process Control Program (SUSMAP-3) during the reporting period.

No license-initiated major changes to the radioactive waste systems were completed during this reporting period. Several design changes are in progress on both the gaseous and liquid waste systems and will be discussed as they are completed in future Semi-Annual Radioactive Effluent Reports.

As per previous Semi-Annual Radioactive Effluent Reports no meteorological data will be submitted. This data is available and will be reported separately upon request.

In accordance with the Fort St. Vrain Offsite Dose Calculation Manual (SUSMAP-2), the dose due to radioactive liquid and gaseous releases made in 1985 was as follows:

Liquid - 10CFR50

Whole Body	1.9E-1	mrem
Organ (Maximum)	2.2E-1	mrem

Gas - 10CFR50

Noble Gas Gamma	7.5E-5	mrad
Beta	1.3E-4	mrad

Iodine, Particulates, Tritium

Adult

Whole Body	4.5E-5	mrem
Organ (Maximum)	4.5E-5	mrem

Teen

Whole Body	4.9E-5	mrem
Organ (Maximum)	4.9E-5	mrem

Child

Whole Body	7.3E-5	mrem
Organ (Maximum)	7.3E-5	mrem

Infant

Whole Body	6.2E-5	mrem
Organ (Maximum)	6.2E-5	mrem

Gas - 10CFR20

Iodine, Particulates, Tritium	1.1E-1	mrem
----------------------------------	--------	------

As can be seen, the maximum whole body exposure and the maximum organ exposure to a member of the general public from Fort St. Vrain releases in 1985 were less than 1.0 mrem.

A total of six radioactive waste shipments were made during this reporting period. From a volume standpoint these shipments consisted mainly of dry active waste, de-watered resin, and absorbed oil. All containers used for these waste shipments were type A (L1-13 liners or 17-H drums certified as type A containers.). All oil was absorbed on Floor-dri Superfine, and oil-dri.

TABLE 1.1 - RADIOACTIVE LIQUID EFFLUENT RELEASES FOR 3rd QUARTER, 1985

	UNITS	JUL	AUG	SEP	QUARTERLY TOTAL	
1. Gross Beta Radioactivity						
a) Total Release	Curies	6.07E-05	6.24E-05	1.52E-04	2.75E-04	
b) Avg. Conc. before Dilution	µCi/ml	1.54E-06	8.47E-07	2.18E-06	1.47E-06 *	
Avg Conc. Released	µCi/ml					
c) after Dilution	above bkgd	6.40E-09	3.92E-09	5.64E-09	5.04E-09 *	
2. Tritium						
a) Total Release	Curies	1.14E+00	2.25E+00	1.52E+00	4.91E+00	
b) Avg. Conc. before Dilution	µCi/ml	2.97E-02	2.84E-02	2.21E-02	2.64E-02 *	
Avg Conc. Released	µCi/ml					
c) after Dilution	above bkgd	1.34E-04	1.39E-04	5.72E-05	1.09E-04 *	
3. Dissolved Noble Gases						
a) Total Release	Curies	NSA	2.11E-07	NSA	2.11E-07	
b) Avg. Conc. before Dilution	µCi/ml	NSA	2.84E-08	NSA	2.84E-08 *	
Avg Conc. Released	µCi/ml					
c) after Dilution	above bkgd	NSA	1.35E-10	NSA	1.35E-10 *	
4. Gross Alpha Radioactivity						
a) Total Release	Curies	1.20E-06	2.47E-06	2.53E-06	6.20E-06	
5. Total Volume of Liquid Released before Dilution						
	Liters	3.91E+04	7.51E+04	7.10E+04	1.85E+05	
6. Total Volume of Liquid Used for Dilution						
	Liters	9.21E+06	1.67E+07	2.39E+07	4.98E+07	
7. Estimated Total Radioactivity Released by Radioisotope above Background						
Nuclide	MPCw (µCi/ml)	Curies				
3H	3.00E-03		1.14E+00	2.25E+00	1.52E+00	4.91E+00
137Cs	2.00E-05		8.26E-06	6.13E-06	1.78E-05	3.22E-05
60Co	3.00E-05		8.96E-06	1.33E-05	1.24E-05	3.46E-05
133Xe	2.00E-04		NSA	2.11E-07	NSA	2.11E-07

*Represents a "weighted" average.

4.7E-05 = 4.7 x 10⁻⁵

5.2E+03 = 5.2 x 10⁺³

NSA means no significant activity.

TABLE 1.3: LIQUID EFFLUENT RELEASED VIA THE TURBINE BUILDING SUMP AND THE REACTOR BUILDING SUMP (CONTINUOUS RELEASE)

3rd QUARTER 1985

TURBINE BUILDING SUMP

	MONTH	JUL	AUG	SEP	QUARTERLY TOTAL
VOLUME	LITERS	1.27E+07	1.00E+07	4.64E+06	2.73E+07
TRITIUM	AVERAGE $\mu\text{Ci}/\text{m}^3$	1.16E-06	1.02E-06	8.92E-07	1.03E-06*
	TOTAL CURIES	1.48E-02	1.02E-02	4.14E-03	2.91E-02
GROSS $\beta\alpha$	AVERAGE $\mu\text{Ci}/\text{m}^3$	6.81E-08	7.12E-08	7.16E-08	7.03E-08*
	TOTAL CURIES	8.68E-04	7.12E-04	3.32E-04	1.91E-03
GROSS α	AVERAGE $\mu\text{Ci}/\text{m}^3$	3.51E-08	3.10E-08	3.15E-08	3.26E-08*
	TOTAL CURIES	4.48E-04	3.10E-04	1.46E-04	9.04E-04

REACTOR BUILDING SUMP

	MONTH	JUL	AUG	SEP	QUARTERLY TOTAL
VOLUME	LITERS	1.20E+06	3.80E+05	5.52E+05	2.13E+06
TRITIUM	AVERAGE $\mu\text{Ci}/\text{m}^3$	8.77E-06	4.11E-05	2.99E-05	2.54E-05*
	TOTAL CURIES	1.05E-02	1.56E-02	1.65E-02	4.26E-02
GROSS $\beta\alpha$	AVERAGE $\mu\text{Ci}/\text{m}^3$	7.13E-08	7.51E-08	7.34E-08	7.31E-08*
	TOTAL CURIES	8.52E-05	2.86E-05	4.05E-05	1.54E-04
GROSS α	AVERAGE $\mu\text{Ci}/\text{m}^3$	3.78E-08	3.42E-08	3.29E-08	3.51E-08*
	TOTAL CURIES	4.52E-05	1.30E-05	1.81E-05	7.63E-05

* Represents "weighted" average

SYSTEM	ALPHA	BETA	TRITIUM	
FARM POND				
	3.86E-08	7.88E-08	9.33E-06	MAXIMUM
	2.62E-08	6.44E-08	3.21E-07	MINIMUM
	3.28E-08 (9)	7.07E-08 (9)	2.91E-06 (9)	AVERAGE
COOLING TOWER B/D-DURING				
	1.63E-08	2.08E-08	5.26E-04	MAXIMUM
	4.08E-09	6.90E-09	3.65E-06	MINIMUM
	8.38E-09 (23)	1.24E-08 (23)	9.67E-05 (23)	AVERAGE
COOLING TOWER B/D-WEEKLY				
	1.67E-08	1.56E-08	5.82E-07	MAXIMUM
	4.35E-09	6.65E-09	3.11E-07	MINIMUM
	8.01E-09 (14)	9.68E-09 (14)	3.65E-07 (14)	AVERAGE
REACTOR BLDG. SUMP				
	1.07E-07	1.62E-07	2.12E-04	MAXIMUM
	2.10E-08	5.79E-08	3.64E-06	MINIMUM
	3.51E-08 (85)	7.31E-08 (85)	2.54E-05 (85)	AVERAGE
TURBINE BLDG. SUMP				
	4.51E-08	9.86E-08	4.03E-06	MAXIMUM
	2.05E-08	6.14E-08	3.19E-07	MINIMUM
	3.26E-08 (40)	7.03E-08 (40)	1.03E-06 (40)	AVERAGE
SYSTEM 21, LOOP 1				
	3.96E-08	7.60E-08	2.37E-06	MAXIMUM
	2.50E-08	6.54E-08	6.31E-07	MINIMUM
	3.38E-08 (8)	7.05E-08 (8)	1.45E-06 (8)	AVERAGE
SYSTEM 21, Loop 2				
	3.72E-08	7.72E-08	2.09E-06	MAXIMUM
	2.50E-08	6.78E-08	7.76E-07	MINIMUM
	3.36E-08 (7)	7.22E-08 (7)	1.35E-06 (7)	AVERAGE
SYSTEM 31				
	3.96E-08	7.02E-08	2.08E-06	MAXIMUM
	3.96E-08	7.02E-08	2.08E-06	MINIMUM
	3.96E-08 (1)	7.02E-08 (1)	2.08E-06 (1)	AVERAGE
SYSTEM 41				
	3.61E-08	7.58E-08	3.39E-07	MAXIMUM
	3.04E-08	6.15E-08	3.28E-07	MINIMUM
	3.29E-08 (3)	6.91E-08 (3)	3.32E-07 (3)	AVERAGE
SYSTEM 42				
	3.64E-08	7.53E-08	3.39E-07	MAXIMUM
	2.88E-08	6.16E-08	3.28E-07	MINIMUM
	3.19E-08 (3)	6.88E-08 (3)	3.35E-07 (3)	AVERAGE

- NOTES: 1. All activities expressed in units of $\mu\text{Ci/ml}$
2. () Represents the number of samples represented by the average value.

SYSTEM	ALPHA	BETA	TRITIUM	
SYSTEM 46, LOOP 1				
	3.72E-08	7.72E-08	2.09E-04	MAXIMUM
	1.68E-08	5.79E-08	2.40E-05	MINIMUM
	3.15E-08 (8)	7.05E-08 (8)	1.14E-04 (8)	AVERAGE
SYSTEM 46, LOOP 2				
	3.96E-08	7.60E-08	4.32E-06	MAXIMUM
	1.68E-08	5.79E-08	1.89E-06	MINIMUM
	3.28E-08 (8)	7.00E-08 (8)	3.14E-06 (8)	AVERAGE
SYSTEM 47, LOOP 1				
	3.71E-08	7.72E-08	1.80E-04	MAXIMUM
	2.50E-08	5.79E-08	3.11E-06	MINIMUM
	3.30E-08 (6)	6.98E-08 (6)	6.78E-05 (6)	AVERAGE
SYSTEM 47, LOOP 2				
	3.96E-08	7.61E-08	2.51E-04	MAXIMUM
	1.68E-08	6.92E-08	1.77E-05	MINIMUM
	3.05E-08 (4)	7.12E-08 (4)	7.97E-05 (4)	AVERAGE

- NOTES: 1. All activities expressed in units of $\mu\text{Ci/ml}$
 2. () Represents the number of samples represented by the average value.

TABLE 1.1 - RADIOACTIVE LIQUID EFFLUENT RELEASES FOR 4th QUARTER, 1985

	UNITS	OCT	NOV	DEC	QUARTERLY TOTAL
1. Gross Beta Radioactivity					
a) Total Release	Curies	3.81E-05	4.05E-05	2.30E-05	1.02E-04
b) Avg. Conc. before Dilution	µCi/ml	6.01E-07	4.57E-07	5.67E-07	5.38E-07 *
Avg Conc. Released	µCi/ml				
c) after Dilution	above bkgd	2.34E-09	1.76E-09	2.89E-09	2.25E-09 *
2. Tritium					
a) Total Release	Curies	1.17E+00	2.70E+00	2.21E+00	6.08E+00
b) Avg. Conc. before Dilution	µCi/ml	1.84E-02	3.08E-02	5.49E-02	3.18E-02 *
Avg Conc. Released	µCi/ml				
c) after Dilution	above bkgd	8.15E-05	1.22E-04	2.80E-04	1.44E-04 *
3. Dissolved Noble Gases					
a) Total Release	Curies	4.61E-05	2.27E-04	1.90E-05	2.92E-04
b) Avg. Conc. before Dilution	µCi/ml	3.09E-06	4.37E-06	7.73E-07	3.16E-06 *
Avg Conc. Released	µCi/ml				
c) after Dilution	above bkgd	1.20E-08	1.44E-08	4.36E-09	1.12E-08 *
4. Gross Alpha Radioactivity					
a) Total Release	Curies	2.09E-06	4.87E-06	1.15E-06	8.11E-06
5. Total Volume of Liquid Released before Dilution					
	Liters	6.44E+04	1.97E+05	4.01E+04	3.01E+05
6. Total Volume of Liquid Used for Dilution					
	Liters	1.56E+07	2.05E+07	9.53E+06	4.57E+07
7. Estimated Total Radioactivity Released by Radioisotope above Background					
Nuclide	MPCw (µCi/ml)	Curies			
3H	3.00E-03		1.17E+00	2.70E+00	2.21E+00
137Cs	2.00E-05		9.39E-06	5.36E-06	7.31E-07
60Co	3.00E-05		3.44E-06	2.34E-05	1.04E-06
133Xe	2.00E-04		4.61E-05	2.27E-04	1.90E-05

*Represents a "weighted" average.

4.7E-05 = 4.7 x 10⁻⁵

5.2E+03 = 5.2 x 10⁺³

NSA means no significant activity.

TABLE 1.3: LIQUID EFFLUENT RELEASED VIA THE TURBINE BUILDING SUMP AND THE REACTOR BUILDING SUMP (CONTINUOUS RELEASE)

4th QUARTER 1985

TURBINE BUILDING SUMP

	MONTH	OCT	NOV	DEC	QUARTERLY TOTAL
VOLUME	LITERS	6.62E+06	5.12E+06	2.64E+06	1.44E+07
TRITIUM	AVERAGE $\mu\text{Ci}/\text{ml}$	1.03E-06	1.31E-06	1.64E-06	1.11E-06*
	TOTAL CURIES	6.82E-03	6.71E-03	4.33E-03	1.79E-02
GROSS $\beta\gamma$	AVERAGE $\mu\text{Ci}/\text{ml}$	6.85E-08	6.67E-08	6.87E-08	7.03E-08*
	TOTAL CURIES	4.53E-04	3.42E-04	1.18E-04	9.13E-04
GROSS α	AVERAGE $\mu\text{Ci}/\text{ml}$	2.96E-08	2.35E-08	2.17E-08	2.38E-08*
	TOTAL CURIES	1.96E-04	1.20E-04	5.73E-05	3.73E-04

REACTOR BUILDING SUMP

	MONTH	OCT	NOV	DEC	QUARTERLY TOTAL
VOLUME	LITERS	3.67E+05	6.37E+05	8.18E+05	1.82E+06
TRITIUM	AVERAGE $\mu\text{Ci}/\text{ml}$	1.08E-05	7.26E-04	7.75E-04	1.33E-04*
	TOTAL CURIES	3.96E-03	4.62E-01	6.34E-01	1.10E+00
GROSS $\beta\gamma$	AVERAGE $\mu\text{Ci}/\text{ml}$	7.65E-08	7.41E-08	7.07E-08	7.28E-08*
	TOTAL CURIES	2.80E-05	4.72E-05	5.78E-05	1.33E-04
GROSS α	AVERAGE $\mu\text{Ci}/\text{ml}$	3.09E-08	2.64E-08	2.13E-08	2.44E-08*
	TOTAL CURIES	1.13E-05	1.68E-05	1.74E-05	4.55E-05

* Represents "weighted" average

TABLE 2.1 - RADIOACTIVE GASEOUS EFFLUENT RELEASES FOR 4th QUARTER, 1985

	UNITS	OCT	NOV	DEC	QUARTERLY TOTAL	
1a. Total Noble Gases	Curies	1.33E+00	5.46E-01	1.98E-02	1.90E+00	
1b. Total Tritium	Curies	6.55E-02	1.68E-02	9.81E-03	9.21E-02	
1c. Total Halogens	Curies	NSA	NSA	NSA	NSA	
1d. Total Particulate Gross (β,γ) Activity RT-7325	Curies	6.98E-08	5.24E-08	6.79E-08	1.90E-07	
1e. Total Particulate Gross Alpha Activity RT-7325	Curies	2.32E-08	2.10E-08	2.26E-08	6.68E-08	
2. Maximum Hourly Release Rate for Any One Hour Period	Ci/hr	1.58E-01	3.50E-02	1.76E-03	1.58E-01	
3. Estimated Total Radioac- tivity Released by Nu- clide						
Particulates	MPCa	Curies				
Halogens	MPCa(μCi/ml)	Curies				
Gases	MPCa(μCi/ml)	Curies				
3H	2.00E-07		6.55E-02	1.68E-02	9.81E-03	9.21E-02
85Krm	1.00E-07		3.43E-02	2.35E-02	NSA	5.78E-02
87Kr	2.00E-08		1.30E-03	1.07E-03	NSA	2.36E-03
88Kr	2.00E-08		2.69E-02	1.85E-02	NSA	4.54E-02
133Xe	3.00E-07		9.99E-01	3.38E-01	1.98E-02	1.36E+00
133Xem	3.00E-07		7.28E-03	NSA	NSA	7.28E-03
135Xe	1.00E-07		2.64E-01	1.65E-01	NSA	4.29E-01

4.7E-05 = 4.7 x 10⁻⁵

5.2E+03 = 5.2 x 10³

NSA means no significant activity.

SYSTEM	ALPHA	BETA	TRITIUM	
FARM POND	4.50E-08	7.58E-08	9.32E-06	MAXIMUM
	2.17E-08	6.12E-08	1.11E-06	MINIMUM
	3.08E-08 (11)	6.69E-08 (11)	5.80E-06 (11)	AVERAGE
COOLING TOWER B/D-DURING	1.96E-08	2.45E-08	4.80E-04	MAXIMUM
	3.25E-09	7.35E-09	4.69E-06	MINIMUM
	9.06E-09 (23)	1.45E-08 (23)	1.14E-04 (23)	AVERAGE
COOLING TOWER B/D-WEEKLY	1.53E-08	1.89E-08	5.70E-07	MAXIMUM
	4.18E-09	7.36E-09	3.34E-07	MINIMUM
	9.34E-09 (13)	1.26E-08 (13)	3.80E-07 (13)	AVERAGE
REACTOR BLDG. SUMP	5.00E-08	1.39E-07	5.14E-03	MAXIMUM
	1.23E-08	5.74E-08	3.61E-06	MINIMUM
	2.58E-08 (74)	7.36E-08 (74)	5.50E-04 (74)	AVERAGE
TURBINE BLDG. SUMP	3.85E-08	8.48E-08	5.96E-06	MAXIMUM
	1.29E-08	5.79E-08	3.38E-07	MINIMUM
	2.49E-08 (39)	6.80E-08 (39)	1.33E-06 (39)	AVERAGE
SYSTEM 21, LOOP 1	4.37E-08	7.89E-08	2.66E-06	MAXIMUM
	1.75E-08	5.85E-08	7.32E-07	MINIMUM
	2.68E-08 (7)	6.65E-08 (7)	1.53E-06 (7)	AVERAGE
SYSTEM 21, Loop 2	4.33E-08	7.94E-08	2.82E-06	MAXIMUM
	2.13E-08	6.08E-08	5.22E-07	MINIMUM
	3.21E-08 (7)	6.82E-08 (7)	1.58E-06 (7)	AVERAGE
SYSTEM 31	3.84E-08	1.11E-07	3.31E-06	MAXIMUM
	2.20E-08	6.31E-08	5.99E-07	MINIMUM
	3.01E-08 (7)	7.40E-08 (7)	1.44E-06 (7)	AVERAGE
SYSTEM 41	4.30E-08	7.75E-08	1.22E-06	MAXIMUM
	3.34E-08	6.58E-08	3.39E-07	MINIMUM
	3.89E-08 (3)	7.21E-08 (3)	6.36E-07 (3)	AVERAGE
SYSTEM 42	3.64E-08	7.66E-08	4.20E-07	MAXIMUM
	1.76E-08	6.54E-08	3.39E-07	MINIMUM
	3.00E-08 (3)	7.13E-08 (3)	3.69E-07 (3)	AVERAGE

- NOTES: 1. All activities expressed in units of $\mu\text{Ci/ml}$
2. () Represents the number of samples represented by the average value.

SYSTEM	ALPHA	BETA	TRITIUM	
SYSTEM 46, LOOP 1				
	3.38E-08	9.95E-08	2.38E-04	MAXIMUM
	1.75E-08	5.98E-08	1.64E-04	MINIMUM
	2.70E-08 (8)	7.02E-08 (8)	2.25E-04 (8)	AVERAGE
SYSTEM 46, LOOP 2				
	3.14E-08	8.33E-08	3.97E-06	MAXIMUM
	1.75E-08	6.09E-08	3.08E-06	MINIMUM
	2.60E-08 (9)	6.84E-08 (9)	3.51E-06 (9)	AVERAGE
SYSTEM 47, LOOP 1				
	3.14E-08	8.01E-08	2.23E-04	MAXIMUM
	1.75E-08	5.85E-08	1.74E-04	MINIMUM
	2.63E-08 (7)	6.65E-08 (7)	1.89E-04 (7)	AVERAGE
SYSTEM 47, LOOP 2				
	3.38E-08	6.70E-08	2.27E-04	MAXIMUM
	1.75E-08	5.95E-08	1.78E-04	MINIMUM
	2.44E-08 (7)	6.31E-08 (7)	1.97E-04 (7)	AVERAGE

- NOTES: 1. All activities expressed in units of $\mu\text{Ci/ml}$
2. () Represents the number of samples represented by the average value.

TABLE 4.1 - SOLID WASTE SHIPMENTS FOR 1985

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not Irradiated Fuel)

1. Type of Waste	Unit	6-Month Period	Estimated Total Error %
	Cubic Meters	6.61E+01	
a. Process Waste	Curies	1.78E+01	Error= 5.66E-01 %
	Cubic Meters	4.31E+01	
b. Dry Active Waste	Curies	2.46E+00	Error= 6.94E-01 %
	Cubic Meters	7.36E-01	
c. Irradiated Comp.	Curies	3.99E+02	Error= 4.75E+00 %


2. Estimate of Major Nuclide Composition (By Type of Waste)				
Major Nuclides for				
a. Process Waste	H3	Curies= 6.71E+00	+/- 3.16E-01	%
	C14	Curies= 6.02E+00	+/- 3.24E-01	%
	FE55	Curies= 3.48E+00	+/- 2.71E+00	%
	S35	Curies= 8.10E-01	+/- 7.21E-01	%
	N163	Curies= 7.19E-01	+/- 2.70E+00	%
Major Nuclides for				
b. Process Waste	FE55	Curies= 1.46E+00	+/- 1.05E+00	%
	S35	Curies= 7.35E-01	+/- 1.03E+00	%
	H3	Curies= 7.80E-02	+/- 1.20E+00	%
	AG110M	Curies= 3.81E-02	+/- 1.03E+00	%
	754	Curies= 2.54E-02	+/- 1.03E+00	%
Major Nuclides for				
c. Irradiated Comp.	FE55	Curies= 2.04E+02	+/- 6.76E+00	%
	C060	Curies= 1.88E+02	+/- 6.92E+00	%
	N163	Curies= 6.35E+00	+/- 6.97E+00	%
	MN54	Curies= 7.60E-01	+/- 6.81E+00	%
	CS137	Curies= 2.39E-02	+/- 7.07E+00	%

3. Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
1	Truck	Barnwell Waste Management Facility
5	Truck	U. S. Ecology, Inc. (Washington

B. Irradiated Fuel Shipments

Number of Shipments	Mode of Transportation	Destination
0	N/A	N/A




Public Service
Company of Colorado

16805 WCR 19 1/2, Platteville, Colorado 80651-9298

February 27, 1986
Fort St. Vrain
Unit #1
P-86172

Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Attn: Mr. J. E. Gagliardo, Chief
Reactor Projects Branch



Docket No. 50-267

SUBJECT: Semi-Annual Radioactive Effluent
Release Report

Dear Mr. Gagliardo:

Attached please find the Semi-Annual Radioactive Effluent Release Report for the Fort St. Vrain Nuclear Generating Station.

This report covers the period July 1, 1985 through December 31, 1985, and is submitted pursuant to Section 7.5.1 e. of the Fort St. Vrain Technical Specifications.

Please contact Mr. Mike Holmes at (303) 480-6960 if you have any questions regarding this report.

Sincerely,

J.W. Gahm by

J. W. Gahm
Manager, Nuclear Production
Fort St. Vrain Nuclear
Generating Station

JWG:VJM/skd

Attachments

86-228

IE 24
IE 25
11

cc w/attachments:

Dottie Sherman, ANI Library
American Nuclear Insurers
The Exchange Suite, 270 Farmington Avenue
Farmington, Connecticut 06032

Mr. Albert J. Hazle, Director
Radiation Control Division
Colorado Department of Health
4210 E. 11th Ave.
Denver, CO 80220

Mr. Mike Dolphin, Site Manager
General Atomic Company
P.O. Box 426
Platteville, CO 80651

Mr. Paul B. Smith
Regional Representative, Radiation Program
U.S. Environmental Protection Agency
Region VIII
Suite 900, 1860 Lincoln St.
Denver, CO 80203

Mr. Frank Rozich, Director
Water Pollution Control Division
Colorado Department of Health
4210 East 11th Ave.
Denver, CO 80220

Mr. George Campbell
Environmental Science Division
Rockwell International
123 Building
P. O. Box 464
Golden, CO 80401

Dr. James E. Johnson
Radiology & Radiation Biology Dept.
Colorado State University
Fort Collins, CO 80523

Mr. Robert Farrell
Senior NRC Resident Inspector
Fort St. Vrain Station