

June 5, 1973

Mr. B. J. Youngblood
Chief, Environmental Projects
Branch No. 3
Directorate of Licensing
U.S. Atomic Energy Commission
Washington, D.C. 20545

Dear Mr. Youngblood:

CONTROL OF POTENTIAL RADIOIODINE RELEASES
NEWBOLD ISLAND GENERATING STATION
DOCKET NOS. 50-354 AND 50-355

The Newbold Island Environmental Statement discussed the control of radioiodine releases to the environment such that the staff's projected annual exposure to the 2-gram thyroid organ of a child will not exceed 5 millirems. Public Service Electric and Gas Company provided a detailed discussion of the staff's concern on this subject in our Additional Responses to Comments, etc. transmitted to you by letter dated May 2, 1973. Recent discussions with the staff indicate that clarification of that discussion would be helpful. To that end we provide the following information.

The control of releases of radioiodines to the environment such that the calculated potential annual exposure to the 2-gram thyroid organ of a child will not exceed 5 millirems is a design objective of Newbold Island Generating Station. To meet this objective, the potentially radioactive portion of the turbine building ventilation system exhaust will be treated by charcoal filters before release to the environment. In addition, the design will provide for minimizing steam leakage from valves 2-1/2 inches and larger installed in systems which are potentially radioactive. The detailed design of these systems (or an equally effective alternative) will be provided to the staff for review when it is developed.

BB05270103 BB051e
PDR ADOCK 05000354
P PDR

6/5/73

Our previous submittal included a description of a possible alternate system as well as a discussion of the assumptions used by the staff in their exposure calculation. In view of the ultraconservative nature of those assumptions and the fact that on-site meteorological data is not yet available, all or parts of these systems will be deleted from the final design if it is demonstrated that they are unnecessary to meet the limits of future regulations.


Very truly yours,



F. W. Schneider
Manager of Engineering
Electric Engineering Department



JCR:jcm



PSEG

The Energy People

DBL/PSB

RESPONSE TO REQUIREMENTS OF
APPENDIX I TO 10CFR50
FOR HOPE CREEK GENERATING
STATION *Rev 1*
DOCKET NOS. 50-354
50-355

ENCLOSURE ONE

8-30-76

Food & ~~Ammonia~~ data

Gaspar & Sodhop output

HOPE CREEK NUCLEAR GENERATING STATION

50 - 354

50 - 355

INFORMATION SUPPLIED
IN RESPONSE TO ENCLOSURE
1 OF NRC LETTER DATED
FEBRUARY 19, 1976 (GUIDANCE
FOR MEETING THE REQUIREMENTS
OF APPENDIX I TO 10 CFR 50)

TABLE OF CONTENTS

Information Request	1
Item 1	1.0
Item 2	2.0
Item 3	3.0
Item 4	4.0
Additional Information Air Pathway	A.1
<i>Complete derivations of food data</i>	
Additional Information Liquid Pathway	A.2
Item 5	5.0
Item 6	6.0

ENCLOSURE 1 OF FEBRUARY LETTER
GUIDANCE TO MEET THE REQUIREMENTS
OF APPENDIX I TO 10 CFR 50

1. PROVIDE AN EVALUATION SHOWING CAPABILITY TO MEET SECTIONS II.A
B, C AND D.
2. RADIOACTIVE SOURCE TERMS-CONSISTENT WITH THE METHODOLOGY IN REGULATORY
GUIDE 1.112 (DRAFT REGULATORY GUIDES 1.BB AND 1.CC)
3. METEOROLOGY/HYDROLOGY-CONSISTENT WITH METHODOLOGY IN REGULATORY
GUIDES 1.111 AND 1.113 (DRAFT REGULATORY GUIDES 1.DD AND 1.EE)
4. DOSE CALCULATIONS-CONSISTENT WITH METHODOLOGY IN REGULATORY GUIDE
1.109 (DRAFT REGULATORY GUIDE 1.AA)
5. EFFLUENT RELEASE DATA-
 - A. EXCLUDE FIRST YEAR OF OPERATION
 - B. TABULATE BY EFFLUENT RELEASE POINT, MONTH, MODE OF OPERATION
(E.G., FULL POWER OPERATION, REFUELING, SHUTDOWN)
6. COST-BENEFIT ANALYSIS (IF USED)-CONSISTENT WITH METHODOLOGY IN
REGULATORY GUIDE 1.110 (DRAFT REGULATORY GUIDE 1.FF)

Item 1

Provide an evaluation showing capability to meet Section II.A, B, C and D.

Response

A summation showing the capability of the Hope Creek Generating Station ability to meet 10CFR50 Appendix I, section II A, II B, II C, and II D is provided in table 1.1.

Supporting information and an explanation of the values are given as responses to questions 2,3,4 and 6.

TABLE 1.1

SUMMARY SHOWING THE HOPE CREEK GENERATING STATION'S
ABILITY TO MEET SECTION II. OF APPENDIX I

			REGULATORY LIMIT	CALCULATED EXPOSURE
SEC II.A	LIQUID EFFLUENTS	(TOTAL BODY)	3 MREM/REACTOR	5.35E-2 mrem/reactor
		(ANY ORGAN)	10 MREM/REACTOR	4.35E-1 mrem/reactor
SEC II.B.1	GASEOUS EFFLUENTS	(AIR DOSE-GAMMA)	10 MRAD/REACTOR	9.30E-1 mrad/reactor ⁽³⁾
		(AIR DOSE-BETA)	20 MRAD/REACTOR	6.25E-1 mrad/reactor ⁽³⁾
	OR			
SEC II.B.2	GASEOUS EFFLUENTS ⁽²⁾	(TOTAL BODY)	5 MREM/REACTOR	3.71E-2 mrem/reactor ⁽⁴⁾
		(SKIN)	15 MREM/REACTOR	5.74E-2 mrem/reactor ⁽⁴⁾
SEC II.C	IODINE AND PARTICULATES	(ANY ORGAN)	15 MREM/REACTOR	1.67E-1 mrem/reactor ⁽⁵⁾
SEC II.D	50 MILE RADIUS INTEGRATED POPULATION EXPOSURE	(TOTAL BODY)	\$1000/MAN-REM total man-rem	2.46 man-rem ⁽¹⁾
		(THYROID)	\$1000/MAN-REM total man-thyroid- rem	6.36 man-thyroid-rem ⁽¹⁾

(1) SEE PAGE 6.0

(2) HIGHER QUANTITIES MAY BE PERMITTED IF ASSURED THAT DOSES TO ANY INDIVIDUAL IN AN UNRESTRICTED AREA WILL BE LESS THAN THESE VALUES.

(3) EVALUATED AT SITE BOUNDARY OF 800 METERS NORTH OF THE HOPE CREEK UNIT 2 REACTOR BUILDING.

(4) EVALUATED AT LOCATION OF RESIDENCE 3.5 MILES ENE OF SITE.

(5) EVALUATED AT LOCATION OF NEAREST MILK COW, 4.8 MILES WNE OF SITE.

Item 2

Radioactive source term - consistent with the methodology in Regulatory 1,CC.

Response

Radioactive source terms were calculated using the BWR-GALE Code. This is consistent with the recommendations of USNRC Regulatory Guide 1.112.

Source terms were calculated for four cases. These are as follows:

- Case 1 Base Case - Table 2.1
- Case 2 Base Case with Augment to include leakoff collection for valves 2.5 inches and larger - Table 2.2
- Case 3 Base Case with Augment to include charcoal and HEPA Filters in potentially radioactive areas of the Turbine Building Ventilation system - Table 2.3
- Case 4 Base Case with Augment to include both the leakoff collection system and charcoal and HEPA filters in the Turbine Building (combination of Cases 2 and 3).

A thorough discussion of these equipment deletions is provided in response to Item 6 (Cost Benefit) of this report.

HOPE CREEK GENERATING STATION

THERMAL POWER LEVEL (MWt)	BWR	3440.00000
PLANT CAPACITY FACTOR		0.80
TOTAL STEAM FLOW (10**6 LBS/HR)		14.00000
MASS CF COOLANT IN REACTOR (M-LB)		0.60000
CLEAN-UP DEMIN FLOW (MIL-LBS/HR)		0.13000
COND DEMIN REGENERATION TIME (D)		42.00000
FRAC FEEDWATER THRU COND DEMIN		1.00000
RADWASTE DILUT FLOW (THOU GPM)		24.00000

CASE 1

LIQUID WASTE INPUTS

STREAM	FLOW RATE (GAL/DAY)	FRACTION OF PCA	FRACTION DISCHARGED	COLLECTION TIME (DAYS)	DECAY TIME (DAYS)	DECONTAMINATION FACTORS		
						I	CS	OTHERS
HIGH PURITY WASTE	1.21E+05	0.090	0.0	0.148	0.177	1.00E+02	1.00E+01	1.00E+02
LOW PURITY WASTE	2.01E+04	0.000	0.500	0.500	0.177	1.00E+02	2.00E+00	1.00E+02
CHEMICAL WASTES	5.04E+02	0.160	1.000	8.000	0.555	1.00E+02	1.00E+02	1.00E+02
REGENERANT SOLS	1.00E+04		0.0	0.167	0.433	1.00E+03	1.00E+04	1.00E+04

GASEOUS WASTE INPUTS

GLAND SEAL STEAM FLOW (THOU-LB/H)	0.0
MASS OF STEAM IN REACTOR (MI-LB)	0.02000
GLAND SEAL HOLD-UP TIME (HRS)	0.0
AIR-EJECTOR OFF-GAS HOLD-UP (HR)	0.50000
CONTAINMENT BLDG IODINE RELEASE FRACTION	1.00000
PARTICULATE RELEASE FRACTION	0.01000
TURBINE BUILDING IODINE RELEASE FRACTION	1.00000
PARTICULATE RELEASE FRACTION	1.00000
RELEASE FRACT.-SPECIAL DES. FEATURES	1.00000
GLAND SEAL VENT IODINE PF	1.00000
AIR-EJECTOR OFF-GAS IODINE PF	0.10000
AUXILLARY BLDG IODINE RELEASE FRACTION	0.10000
PARTICULATE RELEASE FRACTION	0.01000
RADWASTE BLDG IODINE RELEASE FRACTION	0.10000
PARTICULATE RELEASE FRACTION	0.01000
THERE IS A CRYOGENIC DISTILLATION COLUMN	
IODINE AND XENON DECONTAMINATION FACTOR	10000.
KRYPTON DECONTAMINATION FACTOR	4000.
KRYPTON AND XENON HOLDUP TIME (DAYS)	90.

AIRBORNE PARTICULATE RELEASE RATE

(CURIES PER YEAR)

ISOTOPE	AIRBORNE PARTICULATE RELEASE RATE (CURIES PER YEAR)					TOTAL
	CONTAINMENT BLDG.	TURBINE BLDG.	AUXILIARY BLDG.	RADWASTE BLDG.	MECH VAC. PUMP	
Cs-137	3.0E-06	1.3E-02	3.0E-06	9.0E-05	0.0	1.3E-02
Co-60	3.0E-05	6.0E-04	3.0E-05	3.0E-04	0.0	9.6E-04
Fe-59	4.0E-06	5.0E-04	4.0E-04	1.5E-04	0.0	6.6E-04
Co-58	6.0E-06	6.0E-04	6.0E-06	4.5E-05	0.0	6.6E-04
Co-60	1.0E-04	2.0E-03	1.0E-04	9.0E-04	0.0	3.1E-03
Zn-65	2.0E-05	2.0E-04	2.3E-05	1.5E-05	0.0	2.5E-04
Se-75	9.0E-07	6.0E-03	9.0E-07	4.5E-06	0.0	6.0E-03
Sr-90	5.0E-08	2.0E-05	5.0E-08	3.0E-06	0.0	2.3E-05
Zn-65	4.0E-06	1.0E-04	4.0E-06	5.0E-07	0.0	1.1E-04
Co-60	2.0E-06	3.0E-04	2.0E-06	5.0E-07	0.0	3.0E-04
Co-134	4.0E-05	3.0E-04	4.0E-05	4.5E-05	3.0E-06	4.3E-04
Co-136	3.0E-06	5.0E-05	3.0E-06	4.5E-06	2.0E-06	6.2E-05
Co-137	5.5E-05	6.0E-04	5.5E-05	9.0E-05	1.0E-05	8.1E-04
Co-140	4.0E-06	1.1E-02	4.0E-06	1.0E-06	1.1E-05	1.1E-02
Co-57	1.0E-06	6.0E-04	1.0E-06	2.6E-05	0.0	6.3E-04

TABLE 2.1

GASEOUS RELEASE RATE
(CURIES PER YEAR)

JUCELL ID	COOLANT CONC. (MICROCURIES/G)	CONTAINMENT BLDG.	TURBINE ELD.G.	AUXILIARY BLDG.	RADWASTE BLDG.	GLAND SEAL	AIR EJECTOR	MECH VAC PUMP	TOTAL
KC-03H	1.100E-03	0.0	0.0	0.0	0.0	0.0	1.0E+01	0.0	1.0E+01
KC-05H	1.900E-03	3.0E+00	6.8E+01	3.0E+00	0.0	0.0	2.0E+01	0.0	9.4E+01
KC-05	6.000E-06	0.0	0.0	0.0	0.0	0.0	2.6E+02	0.0	2.6E+02
KC-07	6.600E-03	3.0E+00	1.3E+02	3.0E+00	0.0	0.0	5.6E+01	0.0	1.9E+02
KC-08	6.600E-03	3.0E+00	2.3E+02	3.0E+00	0.0	0.0	6.5E+01	0.0	3.0E+02
KC-09	4.100E-02	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
KC-10M	4.700E-06	0.0	0.0	0.0	0.0	0.0	1.0E+00	0.0	1.0E+00
KC-10H	9.000E-05	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
KC-11J	2.600E-03	6.6E+01	2.5E+02	6.6E+01	1.0E+01	0.0	1.2E+01	2.3E+03	2.7E+03
KC-13H	8.400E-04	4.6E+01	6.5E+02	4.6E+01	0.0	0.0	0.0	0.0	7.4E+02
KC-13J	7.200E-03	3.4E+01	6.3E+02	3.4E+01	4.5E+01	0.0	3.1E+01	3.5E+02	1.1E+03
KC-13I	4.700E-02	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
KC-13B	2.800E-02	7.0E+00	1.4E+03	7.0E+00	0.0	0.0	3.7E+01	0.0	1.5E+03
TOTAL NUBLE GASES			43 CURIES/YP						6.9E+03
I-131	3.292E-03	1.7E-01	1.9E-01	1.7E-02	5.0E-03	0.0	2.6E-04	3.0E-02	4.1E-01
I-133	1.416E-02	6.8E-01	7.6E-01	6.8E-02	1.8E-02	0.0	2.1E-04	0.0	1.5E+00
TOTAL GASEOUS RELEASE									

0.0 APPEARING IN THE TABLE INDICATES RELEASE IS LESS THAN 1.0 CI/YR FOR NUBLE GAS, 0.0001 CI/YR FOR I

HOPE CREEK GENERATING STATION LIQUID EFFLUENTS

Case 1

CONCENTRATION IN PRIMARY ANNUAL RELEASES TO DISCHARGE CA

NUCLIDE HALF-LIFE (DAYS)	CORROSION AND ACTIVATION PRODUCTS	CONCENTRATION IN PRIMARY				ANNUAL RELEASES TO DISCHARGE CA			TOTAL (CI/YR)
		COOLANT (MICRO CI/ML)	HIGH PURITY (CURIES)	LOW PURITY (CURIES)	CHEMICAL (CURIES)	TOTAL LWS (CURIES)	ADJUSTED TOTAL (CI/YR)	DETERGENT WASTES (CI/YR)	
NA 24	6.25E-01	8.57E-03	0.0	0.00008	0.00058	0.00066	0.00486	0.00490	
P 32	1.43E+01	2.03E-04	0.0	0.00000	0.00018	0.00019	0.00137	0.00140	
CR 51	2.78E-01	5.08E-03	0.0	0.00007	0.00507	0.00514	0.03803	0.03800	
MN 54	3.03E+02	6.11E-05	0.0	0.00000	0.00007	0.00008	0.00051	0.00150	
MN 56	1.07E-01	4.05E-02	0.0	0.00005	0.00002	0.00008	0.00058	0.00058	
FE 55	9.50E+02	1.02E-03	0.0	0.00001	0.00113	0.00115	0.00848	0.00850	
FE 59	4.50E-05	3.05E-05	0.0	0.00000	0.00003	0.00003	0.00024	0.00024	
CO 58	7.13E+01	2.04E-04	0.0	0.00000	0.00022	0.00022	0.00163	0.00560	
CO 60	1.92E+03	4.07E-04	0.0	0.00001	0.00045	0.00046	0.00340	0.01200	
CY 64	5.33E-01	2.83E-02	0.0	0.00023	0.00147	0.00170	0.01261	0.01300	
ZN 65	2.45E+02	2.04E-04	0.0	0.00000	0.00022	0.00023	0.00168	0.00170	
ZN 69M	5.75E-01	1.89E-03	0.0	0.00002	0.00011	0.00013	0.00095	0.00095	
Zn 69	3.90E-02	0.0	0.0	0.00002	0.00012	0.00014	0.00102	0.00100	
W187	9.96E-01	2.92E-04	0.0	0.00000	0.00004	0.00004	0.00032	0.00032	
NP239	2.33E+00	6.99E-03	0.0	0.00009	0.00254	0.00262	0.01942	0.01900	

FISSION PRODUCTS	CONCENTRATION IN PRIMARY				ANNUAL RELEASES TO DISCHARGE CA			TOTAL (CI/YR)
	COOLANT (MICRO CI/ML)	HIGH PURITY (CURIES)	LOW PURITY (CURIES)	CHEMICAL (CURIES)	TOTAL LWS (CURIES)	ADJUSTED TOTAL (CI/YR)	DETERGENT WASTES (CI/YR)	
BR 83	1.00E-01	2.26E-03	0.0	0.00000	0.00000	0.00000	0.00003	0.00003
SR 89	5.20E+01	1.02E-04	0.0	0.00000	0.00011	0.00011	0.00081	0.00081
SR 93	1.33E+04	6.11E-06	0.0	0.00000	0.00000	0.00000	0.00005	0.00005
Y 90	2.67E+00	0.0	0.0	0.00000	0.00000	0.00000	0.00003	0.00003
SR 91	4.03E-01	3.70E-03	0.0	0.00003	0.00012	0.00014	0.00104	0.00100
Y 91M	3.47E-02	0.0	0.0	0.00002	0.00007	0.00009	0.00067	0.00067
Y 91	5.88E+01	4.07E-05	0.0	0.00000	0.00007	0.00007	0.00052	0.00052
SR 92	1.13E-01	8.14E-03	0.0	0.00001	0.00001	0.00002	0.00013	0.00013
Y 92	1.47E-01	5.03E-03	0.0	0.00003	0.00005	0.00008	0.00062	0.00062
Y 93	4.25E-01	3.71E-03	0.0	0.00003	0.00013	0.00015	0.00114	0.00110
ZR 95	6.50E+01	7.13E-06	0.0	0.00000	0.00001	0.00001	0.00006	0.00006
MB 95	3.50E+01	7.12E-06	0.0	0.00000	0.00001	0.00001	0.00006	0.00006
MD 99	2.79E+00	2.00E-03	0.0	0.00003	0.00084	0.00087	0.00644	0.00640
TC 99M	2.53E-01	1.77E-02	0.0	0.00010	0.00398	0.003108	0.00798	0.00800
RU103	3.96E+01	2.03E-05	0.0	0.00000	0.00002	0.00002	0.00016	0.00030
RH103M	3.96E-02	0.0	0.0	0.00000	0.00002	0.00002	0.00016	0.00016
RU105	1.85E-01	1.72E-03	0.0	0.00001	0.00001	0.00001	0.00010	0.00010
RH105M	5.21E-04	0.0	0.0	0.00001	0.00001	0.00001	0.00010	0.00010
RH105	1.53E+03	0.0	0.0	0.00000	0.00005	0.00005	0.00040	0.00040
RU106	3.47E+02	3.06E-06	0.0	0.00000	0.00000	0.00000	0.00003	0.00240
TE129M	3.40E+01	4.07E-05	0.0	0.00000	0.00004	0.00004	0.00031	0.00031
TE129	4.79E-02	0.0	0.0	0.00000	0.00003	0.00003	0.00020	0.00020
TE131M	1.25E+00	9.82E-05	0.0	0.00000	0.00002	0.00002	0.00014	0.00014
TE131	1.74E-02	0.0	0.0	0.00000	0.00000	0.00000	0.00003	0.00003
TE131	8.05E+00	5.04E-03	0.0	0.00000	0.00000	0.00000	0.00006	0.00006
TE132	3.25E+03	1.03E-05	0.0	0.00000	0.00000	0.00000	0.00004	0.00004
TE132	9.58E-02	2.25E-02	0.0	0.00000	0.00001	0.00001	0.00027	0.00027
TE133	8.75E-01	1.87E-02	0.0	0.00010	0.00212	0.00231	0.01708	0.01700
TE134	3.67E-02	4.84E-02	0.0	0.00000	0.00000	0.00000	0.00002	0.00002
CS134	7.49E+02	3.06E-05	0.0	0.00002	0.00003	0.00006	0.00041	0.01300
TE135	2.79E-01	1.69E-02	0.0	0.00009	0.00024	0.00032	0.00241	0.00240
CS136	1.30E+01	2.02E-05	0.0	0.00001	0.00002	0.00003	0.00023	0.00023
CS137	1.10E+04	7.13E-05	0.0	0.00005	0.00008	0.00013	0.00095	0.02500

TABLE 2.1
4 of 5

HOPE CREEK GENERATING STATION LIQUID EFFLUENTS (CONTINUED)

NUCLIDE	HALF-LIFE (DAYS)	CONCENTRATION IN PRIMARY COOLANT		ANNUAL RELEASES TO DISCHARGE CANAL				TOTAL LMS (CURIES)	ADJUSTED TOTAL (CI/YR)	DETERGENT WASTES (CI/YR)	TOTAL (CI/YR)
		(MICRO CI/ML)	HIGH PURITY (CURIES)	LOW PURITY (CURIES)	CHEMICAL (CURIES)	TOTAL LMS (CURIES)					
BA137M	1.77E+03	3.0	0.0	0.00005	0.00007	0.00012	0.00089	0.0	0.00089	0.0	0.00089
BA139	5.76E+02	7.55E-03	0.0	0.00000	0.00000	0.00000	0.00002	0.0	0.00002	0.0	0.00002
BA140	1.26E+01	4.06E-04	0.0	0.00001	0.00036	0.00036	0.00268	0.0	0.00268	0.0	0.00270
LA143	1.67E+03	0.0	0.0	0.00000	0.00029	0.00029	0.00215	0.0	0.00215	0.0	0.00220
LA141	1.62E+01	0.0	0.0	0.00000	0.00000	0.00000	0.00002	0.0	0.00002	0.0	0.00002
CE141	3.24E+01	3.05E-05	0.0	0.00000	0.00003	0.00003	0.00025	0.0	0.00025	0.0	0.00025
LA142	6.39E+02	3.81E-03	0.0	0.00000	0.00000	0.00000	0.00001	0.0	0.00001	0.0	0.00001
CE143	1.38E+00	2.96E-05	0.0	0.00000	0.00001	0.00001	0.00005	0.0	0.00005	0.0	0.00005
PR143	1.37E+01	4.06E-05	0.0	0.00000	0.00004	0.00004	0.00029	0.0	0.00029	0.0	0.00029
CE144	2.84E+02	3.06E-06	0.0	0.00000	0.00000	0.00000	0.00003	0.0	0.00003	0.0	0.00003
PS144	1.20E+02	0.0	0.0	0.00000	0.00000	0.00000	0.00000	0.0	0.00000	0.0	0.00000
ND147	1.11E+01	3.04E-06	3.0	0.00000	0.00000	0.00000	0.00002	0.0	0.00002	0.0	0.00002
ALL OTHERS		1.43E-01	0.0	0.00000	0.00000	0.00000	0.00004	0.0	0.00004	0.0	0.00004
TOTAL											
EXCEPT TRITIUM		4.05E-01	0.0	0.00135	0.02207	0.02342	0.17342	0.06234	0.17342	0.06234	0.23000
TRITIUM RELEASE			43	CURIES PER YEAR							

HOPE CREEK GENERATING STATION

BWR

THERMAL POWER LEVEL (MW)	3443.3000
PLANT CAPACITY FACTOR	0.80
TOTAL STEAM FLOW (10**6 LBS/HR)	14.3333
MASS OF COOLANT IN REACTOR (M-LB)	0.6000
FISSION PRODUCT CARRY-OVER FRACTION	0.0010
HALOGEN CARRY-OVER FRACTION	0.0200
CLEAN-UP DEMIN FLOW (MIL-LBS/HR)	0.1300
COND DEMIN REGENERATION TIME (D)	42.3333
FRAC FEEDWATER THRU COND (LMIN)	1.0000
RADWASTE DILUT FLOW (THOU GPM)	24.0000

CASE 2

LIQUID WASTE INPUTS

STREAM	FLOW RATE (GAL/DAY)	FRACTION OF PCA	FRACTION DISCHARGED	COLLECTION TIME (DAYS)	DECA: TIME (DAYS)	DECONTAMINATION FACTORS		
						I	CS	OTHERS
HIGH PURITY WASTE	1.21E+05	3.393	0.0	0.148	3.177	1.33E+02	1.33E+31	1.33E+32
LOW PURITY WASTE	2.01E+04	0.0001	0.500	0.500	0.177	1.00E+02	2.00E+30	1.00E+02
CHEMICAL WASTES	5.04E+02	0.160	1.000	8.000	0.555	1.00E+02	1.00E+32	1.33E+32
REGULANT SOLS	1.33E+34		0.0	0.167	0.433	1.00E+03	1.00E+04	1.00E+04

GASEOUS WASTE INPUTS

GLAND SEAL STEAM FLOW (THOU-LB/H)	0.0
MASS OF STEAM IN REACTOR (MT-LB)	3.3233
GLAND SEAL HOLD-UP TIME (HRS)	0.0
AIR-EJECTOR OFF-GAS HOLD-UP (HR)	0.5000
CONTAINMENT BLDG IODINE RELEASE FRACTION	1.00000
PARTICULATE RELEASE FRACTION	0.01000
TURBINE BUILDING IODINE RELEASE FRACTION	1.33333
PARTICULATE RELEASE FRACTION	1.00000
RELEASE FRACT.-SPECIAL DES. FEATURES	0.20000
GLAND SEAL VENT IODINE PF	1.0000
AIR-EJECTOR OFF-GAS IODINE PF	0.1000
AUXILIARY BLDG IODINE RELEASE FRACTION	3.13333
PARTICULATE RELEASE FRACTION	0.01000
RADWASTE BLDG IODINE RELEASE FRACTION	0.13333
PARTICULATE RELEASE FRACTION	0.01000
THERE IS A CRYOGENIC DISTILLATION COLUMN	
IODINE AND XENON DECONTAMINATION FACTOR	13333.
KRYPTON DECONTAMINATION FACTOR	4000.
KRYPTON AND XENON HOLDUP TIME (DAYS)	92.

GASEOUS RELEASE RATE
(CURIES PER YEAR)

NUCLIDE	COOLANT CONC. (MICROCURI/ES/G)	CONTAINMENT BLDG.	TURBINE PLDG.	AUXILIARY BLDG.	RADWASTE BLDG.	GLAND SEAL	AIR EJECTOR	MECH VAC PUMP	TOTAL
KR-83M	1.100E-03	0.0	0.0	0.0	0.0	0.0	1.0E+01	0.0	1.0E+01
KR-85M	1.900E-03	3.0E+00	1.4E+01	3.0E+00	0.0	0.0	2.0E+01	0.0	4.0E+01
KR-85	6.000E-06	0.0	0.0	0.0	0.0	0.0	2.6E+02	0.0	2.6E+02
KR-87	6.600E-03	3.0E+00	2.6E+01	3.0E+00	0.0	0.0	5.6E+01	0.0	8.8E+01
KR-88	6.600E-03	3.0E+00	4.6E+01	3.0E+00	0.0	0.0	6.5E+01	0.0	1.2E+02
KR-89	4.100E-02	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
KE-131M	4.700E-06	0.0	0.0	0.0	0.0	0.0	1.0E+00	0.0	1.0E+00
KE-133M	9.000E-05	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
KE-133	2.600E-03	6.6E+01	5.0E+01	6.6E+01	1.0E+01	0.0	1.2E+01	2.3E+03	2.5E+03
KE-135M	8.400E-04	4.6E+01	1.3E+02	4.6E+01	0.0	0.0	0.0	0.0	2.2E+02
KE-135	7.200E-03	3.4E+01	1.3E+02	3.4E+01	4.5E+01	0.0	3.1E+01	3.5E+02	6.2E+02
KE-137	4.700E-02	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
KE-138	2.800E-02	7.0E+00	2.9E+02	7.0E+00	0.0	0.0	3.7E+01	0.0	3.4E+02
TOTAL NOBLE GASES									
I-131	3.252E-03	1.7E-01	3.8E-02	1.7E-02	5.0E-03	0.0	2.6E-04	3.0E-02	2.6E-01
I-133	1.416E-02	6.8E-01	1.5E-01	6.8E-02	1.8E-02	0.0	2.1E-04	0.0	9.2E-01
TRITIUM GASEOUS RELEASE 43 CURIES/YR									

0.0 APPEARING IN THE TABLE INDICATES RELEASE IS LESS THAN 1.0 CI/YR FOR NOBLE GAS, 0.0001 CI/YR FOR I

AIRBORNE PARTICULATE RELEASE RATE

(CURIES PER YEAR)

NUCLIDE	CONTAINMENT BLDG.	TURBINE BLDG.	AUXILIARY BLDG.	RADWASTE BLDG.	MECH VAC. PUMP	TOTAL
CR-91	3.0E-06	2.6E-03	3.0E-06	9.0E-05	0.0	2.7E-03
MN-54	3.0E-05	1.2E-04	3.0E-05	3.0E-04	0.0	4.8E-04
FE-59	4.0E-06	1.0E-04	4.0E-06	1.5E-04	0.0	2.6E-04
CO-58	6.0E-06	1.2E-04	6.0E-06	4.5E-05	0.0	1.8E-04
CU-60	1.0E-04	4.0E-04	1.0E-04	9.0E-04	0.0	1.5E-03
ZN-65	2.0E-05	4.0E-05	2.0E-05	1.5E-05	0.0	9.5E-05
SR-89	9.0E-07	1.2E-03	9.0E-07	4.5E-06	0.0	1.2E-03
SR-90	5.0E-08	4.0E-06	5.0E-08	3.0E-06	0.0	7.1E-06
ZR-95	4.0E-06	2.0E-05	4.0E-06	5.0E-07	0.0	2.8E-05
SB-124	2.0E-06	6.0E-05	2.0E-06	5.0E-07	0.0	6.4E-05
CS-134	4.0E-05	6.0E-05	4.0E-05	4.5E-05	3.0E-06	1.9E-04
CS-136	3.0E-06	1.0E-05	3.0E-06	4.5E-06	2.0E-06	2.2E-05
CS-137	5.5E-05	1.2E-04	5.5E-05	9.0E-05	1.0E-05	3.3E-04
BA-140	4.0E-06	2.2E-03	4.0E-06	1.0E-06	1.1E-05	2.2E-03
CE-141	1.0E-06	1.2E-04	1.0E-06	2.6E-05	0.0	1.5E-04

CONCENTRATION ANNUAL RELEASES TO DISCHARGE

NUCLIDE	HALF-LIFE (DAYS)	CONCENTRATION IN PRIMARY COOLANT (MICRO CI/ML)	HIGH PURITY LOW PURITY (CURIES)	CHEMICAL (CURIES)	TOTAL (CURIES)	ADJUSTED TOTAL (CI/YR)	DETERGENT WASTES (CI/YR)	TOTAL (CI/YR)
NA 24	6.25E-01	0.27E-03	0.0	0.00008	0.00058	0.00066	0.0	0.00066
P 32	1.43E+01	2.03E-04	0.0	0.00009	0.00018	0.00019	0.0	0.00019
CR 51	2.78E+01	5.08E-03	0.0	0.00007	0.00517	0.00524	0.0	0.00524
MN 54	2.33E+22	6.11E-22	2.2	2.33333	2.33337	2.33337	0.00100	0.00100
MN 56	1.07E-01	4.05E-02	0.0	0.00005	0.00002	0.00007	0.0	0.00007
FE 55	5.50E+02	1.02E-03	6.0	0.00001	0.00113	0.00114	0.0	0.00114
FE 59	4.50E+01	3.05E-05	0.0	0.00000	0.00000	0.00000	0.0	0.00000
CU 64	7.13E+01	2.04E-04	0.0	0.00000	0.00002	0.00002	0.00403	0.00403
CU 63	1.92E+23	4.37E-24	0.0	0.00000	0.00000	0.00000	0.00000	0.00000
CU 65	5.33E-01	2.33E-02	0.0	0.00000	0.00151	0.00151	0.00087	0.00087
ZN 65	2.45E+02	2.04E-04	0.0	0.00000	0.00000	0.00000	0.0	0.00000
ZN 69M	5.75E-01	1.89E-03	0.0	0.00002	0.00011	0.00013	0.0	0.00013
ZN 69	3.96E-02	0.0	0.0	0.00002	0.00012	0.00014	0.0	0.00014
Ni 67	9.96E-21	2.92E-24	0.0	0.00000	0.00000	0.00000	0.0	0.00000
Ni 259	2.25E+00	6.99E-03	0.0	0.00000	0.00025	0.00025	0.0	0.00025

FUSION PRODUCTS

BF 10	1.00E-01	2.26E-03	0.0	0.00000	0.00000	0.00000	0.0	0.00000
SR 89	5.20E+01	1.02E-04	0.0	0.00000	0.00011	0.00011	0.0	0.00011
SF 93	1.33E+24	6.11E-26	0.0	0.00000	0.00001	0.00001	0.0	0.00001
Y 90	2.67E+00	0.0	0.0	0.00000	0.00000	0.00000	0.0	0.00000
SR 91	4.23E-21	3.73E-23	0.0	0.00000	0.00000	0.00000	0.0	0.00000
Y 91	3.07E-02	0.0	0.0	0.00000	0.00000	0.00000	0.0	0.00000
Y 91	5.08E+21	4.37E-25	0.0	0.00000	0.00000	0.00000	0.0	0.00000
SF 92	1.13E-01	8.14E-03	0.0	0.00001	0.00001	0.00002	0.0	0.00002
Y 92	1.77E-01	5.02E-03	0.0	0.00000	0.00000	0.00000	0.0	0.00000
Y 93	4.25E-24	3.73E-23	0.0	0.00000	0.00000	0.00000	0.0	0.00000
ZR 95	6.20E+01	7.13E-06	0.0	0.00000	0.00000	0.00000	0.0	0.00000
MO 95	2.52E+21	7.13E-26	0.0	0.00000	0.00000	0.00000	0.0	0.00000
MO 99	2.79E+00	2.04E-03	0.0	0.00000	0.00000	0.00000	0.0	0.00000
TC 99M	4.50E-01	1.77E-02	0.0	0.00010	0.00000	0.00010	0.0	0.00010
RU103	3.55E+01	2.04E-05	0.0	0.00000	0.00000	0.00000	0.00016	0.00016
RU103M	3.96E-02	0.0	0.0	0.00000	0.00000	0.00000	0.0	0.00000
RU135	1.85E-21	1.73E-23	0.0	0.00000	0.00000	0.00000	0.0	0.00000
RU105M	5.21E-04	0.0	0.0	0.00001	0.00001	0.00002	0.0	0.00002
RU105	1.50E+00	0.0	0.0	0.00000	0.00000	0.00000	0.0	0.00000
RU106	3.67E+02	3.06E-06	0.0	0.00000	0.00000	0.00000	0.00240	0.00240
RU106	3.97E-04	0.0	0.0	0.00000	0.00000	0.00000	0.0	0.00000
TE125M	2.52E+21	4.37E-25	0.0	0.00000	0.00000	0.00000	0.0	0.00000
TE129	4.75E-02	0.0	0.0	0.00000	0.00000	0.00000	0.0	0.00000
TE134M	1.25E+00	9.82E-25	0.0	0.00000	0.00000	0.00000	0.0	0.00000
TE134	1.74E-02	0.0	0.0	0.00000	0.00000	0.00000	0.0	0.00000
TE134	6.05E+00	5.04E-03	0.0	0.00000	0.00000	0.00000	0.0	0.00000
TE132	3.25E+23	1.33E-25	0.0	0.00000	0.00000	0.00000	0.0	0.00000
TE132	9.96E-02	2.29E-02	0.0	0.00002	0.00001	0.00003	0.0	0.00003
TE133	6.75E-21	4.37E-22	0.0	0.00000	0.00000	0.00000	0.0	0.00000
TE134	3.67E-02	4.04E-02	0.0	0.00000	0.00000	0.00000	0.0	0.00000
CS134	7.99E+02	5.04E-05	0.0	0.00000	0.00000	0.00000	0.0	0.00000
TE135	2.75E-21	4.04E-02	0.0	0.00000	0.00000	0.00000	0.0	0.00000
CS136	1.30E+01	2.92E-05	0.0	0.00001	0.00002	0.00003	0.0	0.00003
CS137	1.13E+24	7.13E-25	0.0	0.00000	0.00000	0.00000	0.00240	0.00240

WQCLID	HAZ-LIFE (DAYS)	CONCENTRATION IN PRIMARY EFFLUENT		ANNUAL RELEASES TO DISCHARGE					ADJUSTED TOTAL (CI/YR)	DETERGENT WASTES (CI/YR)	TOTAL (CI/YR)
		ML/ML	MG/L	HIGH PRIORITY (CURIES)	LOW PRIORITY (CURIES)	CHEMICALS (CURIES)	TOTAL LADS (CURIES)				
B41374	4.77E-03	0.0	0.0	0.0	0.00005	0.00007	0.00012	0.00009	0.0	0.00089	
B4139	5.76E-22	7.55E-23	0.0	0.0	3.33333	3.33000	0.00000	0.00002	0.0	0.00002	
B4140	1.06E+01	4.06E-04	0.0	0.0	0.00001	0.00006	0.00006	0.00000	0.0	0.00010	
B4140	1.07E+00	0.0	0.0	0.0	3.33333	3.33329	3.33329	3.33215	3.3	0.33223	
B4141	1.07E-01	0.0	0.0	0.0	0.00000	0.00000	0.00000	0.00000	0.0	0.00000	
B4141	2.09E+01	3.05E-05	0.0	0.0	0.00000	0.00000	0.00000	0.00000	0.0	0.00000	
B4142	6.59E-24	3.81E-23	0.0	0.0	0.00000	0.00000	0.00000	0.00000	0.0	0.00000	
B4143	1.30E+00	2.96E-05	0.0	0.0	0.00000	0.00001	0.00001	0.00005	0.0	0.00005	
B4143	1.57E+01	4.36E-25	0.0	0.0	3.33333	3.33334	3.33334	3.33329	3.3	0.33329	
B4144	2.06E+02	3.06E-06	0.0	0.0	0.00000	0.00000	0.00000	0.00000	0.00520	0.00520	
B4145	1.00E-04	0.0	0.0	0.0	0.00000	0.00000	0.00000	0.00000	0.0	0.00000	
B4147	1.11E+21	3.34E-26	0.0	0.0	0.00000	0.00000	0.00000	0.00002	0.0	0.00002	
ALL OTHERS	1.93E-01	0.0	0.0	0.0	0.00000	0.00000	0.00001	0.00004	0.0	0.00004	
TOTAL				0.0	0.00135	3.32237	3.32342	3.17342	3.36234	3.23333	

TRITIUM RELEASE 0.0 CURIES PER YEAR

HOPE CREEK GENERATING STATION		BWR
THERMAL POWER LEVEL (MWt)		3440.0000
PLANT CAPACITY FACTOR		0.80
TOTAL STEAM FLOW (10 ⁶ LBS/HR)		15.2222
MASS OF COOLANT IN REACTOR (M-LB)		0.6000
FISSION PRODUCT CARRY-OVER FRACTION		0.0010
HALOGEN CARRY-OVER FRACTION		0.0200
CLEAN-UP DEMIN FLOW (M-LB/HR)		0.1300
COND DEMIN REGENERATION TIME (D)		42.3333
FRAC FLOW WATER THRU COND DEMIN		1.0000
RADWASTE DILUT FLOW (THOU GPM)		24.0000

CASE 3

LIQUID WASTE INPUTS

STREAM	FLOW RATE (GAL/DAY)	FRACTION OF PCA	FRACTION DISCHARGED	COLLECTION TIME (DAYS)	DECAY TIME (DAYS)	DECONTAMINATION FACTORS		
						I	CS	OTHERS
HIGH PURITY WASTE	1.21E+05	0.393	0.3	0.148	3.177	1.33E+02	1.00E+01	1.00E+02
LOW PURITY WASTE	2.01E+04	0.0001	0.500	0.500	0.177	1.00E+02	2.00E+00	1.00E+02
CHEMICAL WASTES	5.04E+02	0.160	1.000	0.333	3.555	1.33E+02	1.33E+02	1.33E+02
REVENUE/PAID SOLS	1.00E+04	0.0	0.0	0.167	0.533	1.00E+03	1.00E+04	1.00E+04

GASEOUS WASTE INPUTS

GLAND SEAL STEAM FLOW (THOU-LB/H)	0.0
MASS OF STEAM IN REACTOR (M-LB)	0.0200
GLAND SEAL HOLD-UP TIME (HRS)	0.0
AIR-EJECTOR OFF-GAS HOLD-UP (HR)	0.5000
CONTAINMENT BLDG IODINE RELEASE FRACTION	1.3333
PARTICULATE RELEASE FRACTION	0.01000
TURBINE BUILDING IODINE RELEASE FRACTION	0.10000
PARTICULATE RELEASE FRACTION	0.01000
RELEASE FRACT.-SPECIAL DES. FEATURES	1.00000
GLAND SEAL VENT IODINE PF	1.3333
AIR-EJECTOR OFF-GAS IODINE PF	0.1000
AUXILIARY BLDG IODINE RELEASE FRACTION	0.10000
PARTICULATE RELEASE FRACTION	0.01000
RADWASTE BLDG IODINE RELEASE FRACTION	0.10000
PARTICULATE RELEASE FRACTION	0.01000
THERE IS A CRYOGENIC DISTILLATION COLUMN	
IODINE AND XENON DECONTAMINATION FACTOR	10000.
KRYPTON DECONTAMINATION FACTOR	4000.
KRYPTON AND XENON HOLDUP TIME (DAYS)	90.

GASEOUS RELEASE RATE
(CURIES PER YEAR)

NUCLIDE	COOLANT CONC. (MICROCURIES/G)	CONTAINMENT BLDG.	TURBINE BLDG.	AUXILIARY BLDG.	RADWASTE BLDG.	GLAND SEAL	AIR EJECTOR	MECH VAC PUMP	TOTAL
KR-B3M	1.100E-03	0.0	0.0	0.0	0.0	0.0	1.0E+01	0.0	1.0E+01
KR-B5M	1.900E-03	3.0E+00	6.8E+01	3.0E+00	0.0	0.0	2.0E+01	0.0	9.9E+01
KR-B5	6.00E-06	0.0	0.0	0.0	0.0	0.0	2.6E+02	0.0	2.6E+02
KR-B7	5.600E-03	3.0E+00	1.3E+02	3.0E+00	0.0	0.0	5.6E+01	0.0	1.5E+02
KR-B8	6.600E-03	3.0E+00	2.3E+02	3.0E+00	0.0	0.0	6.5E+01	0.0	3.9E+02
KR-B9	4.100E-02	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
XE-131M	4.700E-06	0.0	0.0	0.0	0.0	0.0	1.0E+00	0.0	1.0E+00
XE-133M	9.000E-05	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
XE-133	2.600E-03	6.6E+01	2.5E+02	6.6E+01	1.0E+01	0.0	1.2E+01	2.3E+03	2.7E+03
XE-135M	8.400E-04	4.6E+01	6.5E+02	4.6E+01	0.0	0.0	0.0	0.0	7.4E+02
XE-135	7.200E-03	3.4E+01	6.3E+02	3.4E+01	4.5E+01	0.0	3.1E+01	3.5E+02	1.1E+03
XE-137	4.700E-02	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
XE-138	2.800E-02	7.0E+00	1.4E+03	7.0E+00	0.0	0.0	3.7E+01	0.0	1.5E+03
TOTAL PUZZLE GASES									6.5E+03
I-131	3.292E-03	1.7E-01	1.9E-02	1.7E-02	5.0E-03	0.0	2.6E-04	3.0E-02	2.4E-01
I-133	1.416E-02	6.8E-01	7.6E-02	6.8E-02	1.8E-02	0.0	2.1E-04	0.0	0.7E-01
INITIUM GASEOUS RELEASE 43 CURIES/YR									

0.0 APPEARING IN THE TABLE INDICATES RELEASE IS LESS THAN 1.0 CI/YR FOR NOBLE GAS, 0.0001 CI/YR FOR I

AIRBORNE PARTICULATE RELEASE RATE

(CURIES PER YEAR)

NUCLIDE	AIRBORNE PARTICULATE RELEASE RATE (CURIES PER YEAR)							TOTAL
	CONTAINMENT BLDG.	TURBINE BLDG.	AUXILIARY BLDG.	RADWASTE BLDG.	MECH VAC. PUMP			
CR-51	3.0E-06	1.3E-04	3.0E-06	9.0E-05	0.0			2.4E-04
MN-54	3.0E-05	6.0E-05	3.0E-05	3.0E-04	0.0			3.7E-04
FE-59	4.0E-06	5.0E-06	4.0E-06	1.5E-04	0.0			1.6E-04
CO-58	6.0E-06	6.0E-06	6.0E-04	4.5E-05	0.0			6.3E-05
CO-60	1.0E-04	2.0E-05	1.0E-04	9.0E-04	0.0			1.1E-03
ZN-65	2.0E-05	2.0E-06	2.0E-05	1.5E-05	0.0			5.7E-05
SR-89	9.0E-07	6.0E-05	9.0E-07	4.5E-06	0.0			6.6E-05
SR-90	5.0E-03	2.0E-07	5.0E-03	3.0E-06	0.0			3.3E-06
Zr-95	4.0E-06	1.0E-06	4.0E-06	5.0E-07	0.0			9.5E-06
SB-124	2.0E-06	3.0E-06	2.0E-06	5.0E-07	0.0			7.5E-06
CS-134	4.0E-05	3.0E-06	4.0E-05	4.5E-05	3.0E-06			1.3E-04
CS-136	3.0E-06	5.0E-07	3.0E-06	4.5E-06	2.0E-06			1.3E-05
CS-137	5.5E-05	6.0E-06	5.5E-05	9.0E-05	1.0E-05			2.2E-04
BA-140	4.0E-06	1.1E-04	4.0E-06	1.0E-06	1.1E-02			1.3E-04
CE-141	1.0E-06	6.0E-06	1.0E-06	2.6E-05	0.0			3.6E-05

CONCENTRATION IN PRIMARY ANNUAL RELEASES TO DISCHARGE TOTAL

NUCLIDE HALF-LIFE (DAYS)	MICRO C/ML	HIGH PURITY LOW PURITY (CURIES)	CHEMICAL (CURIES)	TOTAL LBS (CURIES)	ADJUSTED		TOTAL (CI/YR)
					TOTAL (CI/YR)	DETERGENT WASTES (CI/YR)	

CORROSION AND ACTIVATION PRODUCTS

Co 54	6.25E+01	8.57E-33	3.3338	3.3336	3.33486	3.3	0.33490
Cr 52	1.43E+01	2.03E-04	0.0000	0.0019	0.00137	0.0	0.00140
C	2.78E+01	5.08E-03	0.0007	0.00514	0.03803	0.0	0.03833
Mn	2.23E+02	6.11E-25	0.0200	0.00027	0.00021	0.00100	0.00150
Fe 56	1.07E-01	4.05E-02	0.0005	0.00002	0.00058	0.0	0.00058
Fe 59	4.50E+01	1.32E-33	0.0000	3.3331	3.3348	3.3	0.33850
Co 58	7.13E+01	2.04E-04	0.0000	0.0003	0.00024	0.0	0.00024
Co 60	1.42E+03	4.37E-04	0.0001	0.0022	0.03163	3.33433	3.33563
Co 64	2.23E-01	2.83E-02	0.0023	0.0045	0.00340	0.00870	0.01200
Zn 65	2.45E+02	2.34E-34	3.3333	3.3322	3.3348	3.0	0.00170
Zn 69M	5.75E-01	1.85E-03	0.0002	0.0011	0.0005	9.0	0.00095
Zn 69	3.96E-02	0.0	0.0002	3.3314	3.3312	3.3	0.33133
Ni 63	9.96E-01	2.92E-04	0.0000	0.0004	0.00032	0.0	0.00032
Ni 64	2.35E+00	6.59E-03	0.0000	0.00254	0.01942	0.0	0.01900

FISSTON PRODUCTS

BR 83	1.00E-01	2.26E-03	0.0000	0.0000	0.00003	0.0	0.00003
SR 89	5.20E+01	1.02E-04	3.3333	3.3311	3.3381	3.3	0.33381
SF 90	1.03E+04	6.11E-06	0.0000	0.0001	0.00005	0.0	0.00005
Y 90	2.07E+00	0.0	0.0000	0.0000	0.00003	0.0	0.00003
Y 91	4.23E-01	3.73E-23	2.2323	0.0012	0.0014	0.0	0.00140
Y 91M	3.47E-02	0.0	0.0002	0.0007	0.00067	0.0	0.00067
Y 91	5.88E+01	4.07E-05	0.2323	3.3337	3.3352	3.3	3.3352
SR 92	1.13E-01	6.44E-03	0.0001	0.0001	0.00013	0.0	0.00013
Y 92	1.47E-01	5.03E-03	0.0003	0.0005	0.00062	0.0	0.00062
Y 93	4.25E-01	3.71E-03	0.0003	0.0013	0.0014	0.0	0.00140
Zr 95	5.20E+01	7.13E-06	0.0000	0.0000	0.00006	0.0	0.00006
Nb 95	3.50E+01	7.12E-06	0.0003	3.3331	3.3336	3.3	0.33336
MU 99	2.79E+00	2.03E-03	0.0000	0.0004	0.00044	0.0	0.00044
TC 99M	2.50E+01	1.77E-02	0.0010	0.00098	0.00108	3.3	0.33333
RU 103	3.56E+01	2.33E-05	0.0000	0.0002	0.00016	0.0	0.00016
RH 103M	3.96E-02	0.0	0.0000	0.0002	0.00016	0.0	0.00016
RU 105	1.85E-01	1.74E-03	0.3321	3.3321	3.3321	3.3	3.33210
RH 105M	5.21E-04	0.0	0.0001	0.0001	0.00010	0.0	0.00010
RH 105	1.50E+00	0.0	0.0000	0.0005	0.00044	3.3	0.33343
RU 106	3.47E+02	3.06E-06	0.0000	0.0000	0.00003	0.0	0.00003
RH 106	3.47E-04	0.0	0.0000	0.0000	0.00003	0.0	0.00003
TE 129M	3.45E+01	4.37E-05	3.3333	3.3324	3.3324	3.3	3.33240
TE 129	4.79E-02	0.0	0.0000	0.0000	0.00003	0.0	0.00003
TE 124M	1.25E+00	9.82E-05	0.0000	3.3332	3.3332	3.3	3.33320
TE 131	1.74E-02	0.0	0.0000	0.0000	0.00003	0.0	0.00003
I 131	6.05E+00	5.04E-03	0.0007	0.0000	0.00003	0.0	0.00003
TE 132	3.25E+03	1.33E-05	3.3333	3.3333	3.3333	3.3	3.33330
I 132	5.58E-02	2.25E-02	0.0002	0.0001	0.00004	0.0	0.00004
I 132	8.12E-01	1.87E-02	3.3319	3.3321	3.3321	3.3	3.33210
I 134	3.07E-02	4.84E-02	0.0000	0.0000	0.00003	0.0	0.00003
CS 135	7.99E+02	3.06E-05	0.0002	0.0003	0.00006	0.0	0.00006
I 135	2.79E-01	1.69E-02	3.3339	0.00024	0.00032	0.0	0.00032
CS 136	1.30E+01	2.02E-05	0.0001	0.00002	0.00003	0.0	0.00003
CS 137	1.10E+04	7.13E-05	3.3335	3.3338	3.3338	3.3	3.33380

HOPE CREEK GENERATING STATION LIQUID EFFLUENTS (CONTINUED)

CAS

MOLLUSC HALF-LIFE (DAYS)	CONCENTRATION IN PRIMARY COOLANT		ANNUAL RELEASES TO DISCHARGE CANAL		ADJUSTED TOTAL		DETERGENT WASTES (CI/YR)	TOTAL (CI/YR)
	(MICRO CI/ML)	HIGH PURITY LOG PURITY (CURIES)	CHEMICAL (CURIES)	TOTAL LWS (CURIES)	(CI/YR)	(CI/YR)		
BA137M	1.77E-03	0.0	0.0005	0.00012	0.00089	0.0	0.00089	0.00089
BA139	5.76E-02	7.55E-33	0.3333	3.3333	3.3332	3.3	0.00002	0.00002
BA140	1.28E+01	5.06E-04	0.0001	0.00036	0.00265	0.0	0.00270	0.00270
LA140	1.67E+00	0.0	0.0000	0.00029	3.3215	0.0	0.3323	0.3323
LA141	1.62E-21	0.0	0.0000	0.0000	0.00002	0.0	0.00002	0.00002
CI141	3.24E+01	3.35E-05	0.0000	0.00003	0.00025	0.0	0.00025	0.00025
LA142	6.39E-32	3.81E-33	3.3333	3.3333	3.3331	0.0	0.00001	0.00001
CE143	1.38E+00	2.96E-05	0.0000	0.00001	0.00005	0.0	0.00005	0.00005
PA143	1.37E+01	5.06E-05	0.0000	0.00004	0.3329	3.3	0.3329	0.3329
CE144	4.84E+02	3.06E-06	0.0000	0.0000	0.00003	0.0	0.00003	0.00003
PR144	1.20E-02	0.0	0.0000	0.0000	0.00002	0.0	0.00002	0.00002
NO147	1.11E+31	3.34E-36	3.3333	3.3333	0.00002	0.0	0.00002	0.00002
ALL OTHERS			0.0	0.0000	0.00004	0.0	0.00004	0.00004
TOTAL					0.17342	0.06234	0.23576	0.23576
EXCEPT TRITIUM	4.02E-01	0.0	0.00135	0.02207	0.02342			
TRITIUM RELEASE								

93 CURIES PER YEAR

HOPE CREEK GENERATING STATIO		BWR
THERMAL POWER LEVEL (MWT)		3440.0000
PLANT CAPACITY FACTOR		0.80
TOTAL STEAM FLOW (10**6 LBS/HR)		14.0000
MASS OF COOLANT IN REACTOR(M-LB)		0.6000
FISSION PRODUCT CARRY-OVER FRACTION		0.0010
HALOGEN CARRY-OVER FRACTION		0.0200
CLEAN-UP DEMIN FLOW(MIL-LBS/HR)		0.1200
COND DEMIN REGENERATION TIME(D)		42.0000
FRAC FEEDWATER THRU COND DEMIN		1.0000
RADWASTE DILUT FLW (THOU GPM)		24.0000

CASE 4

LIQUID WASTE INPUTS

STREAM	FLOW RATE (GAL/DAY)	FRACTION OF PCA	FRACTION DISCHARGED	COLLECTION TIME (DAYS)	DECAY TIME (DAYS)	DECONTAMINATION FACTORS		
						I	CS	OTHERS
HIGH PURITY WASTE	1.21E+05	0.090	0.0	0.146	0.177	1.00E+02	1.00E+01	1.00E+02
LOW PURITY WASTE	2.01E+04	0.0001	0.500	0.500	0.177	1.00E+02	2.00E+00	1.00E+02
CHEMICAL WASTES	5.04E+02	0.160	1.000	8.000	0.555	1.00E+02	1.00E+02	1.00E+02
REGENERANT SOLS	1.00E+04		0.0	0.167	0.433	1.00E+03	1.00E+04	1.00E+04

GASEOUS WASTE INPUTS

GLAND SEAL STEAM FLOW(THOU-LB/H)	0.0
MASS OF STEAM IN REACTOR(MI-LB)	0.0200
GLAND SEAL HOLD-UP TIME (HRS)	0.0
AIR-EJECTOR OFF-GAS HOLD-UP(HR)	0.5000
CONTAINMENT BLDGIODINE RELEASE FRACTION	1.00000
PARTICULATE RELEASE FRACTION	0.01000
TURBINE BUILDING IODINE RELEASE FRACTION	0.10000
PARTICULATE RELEASE FRACTION	0.01000
RELEASE FRACT.-SPECIAL DES. FEATURES	0.20000
GLAND SEAL VENT IODINE PF	1.0000
AIR-EJECTOR OFF-GAS IODINE PF	0.1000
AUXILLARY BLDG IODINE RELEASE FRACTION	0.10000
PARTICULATE RELEASE FRACTION	0.01000
RADWASTE BLDG IODINE RELEASE FRACTION	0.10000
PARTICULATE RELEASE FRACTION	0.01000
THERE IS A CRYOGENIC DISTILLATION COLUMN	
IODINE AND XENON DECONTAMINATION FACTOR	10000.
KRYPTON DECONTAMINATION FACTOR	4000.
KRYPTON AND XENON HOLDUP TIME (DAYS)	90.

GASEOUS RELEASE RATE

(CURIES PER YEAR)

NUCLIDE	COOLANT CONC. (MICROCURIES/G)	CONTAINMENT BLDG.	TURBINE BLDG.	AUXILIARY BLDG.	RADWASTE BLDG.	GLAND SEAL	AIR EJECTOR	MECH VAC PUMP	TOTAL
KR-83M	1.100E-03	0.0	0.0	0.0	0.0	0.0	1.0E+01	0.0	1.0E+01
KR-85M	1.900E-03	3.0E+00	1.4E+01	3.0E+00	0.0	0.0	2.0E+01	0.0	4.0E+01
KR-85	6.000E-06	0.0	0.0	0.0	0.0	0.0	2.6E+02	0.0	2.6E+02
KR-87	6.600E-03	3.0E+00	2.6E+01	3.0E+00	0.0	0.0	5.6E+01	0.0	8.8E+01
KR-88	6.600E-03	3.0E+00	4.6E+01	3.0E+00	0.0	0.0	6.5E+01	0.0	1.2E+02
KR-89	4.100E-02	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
XE-131M	4.700E-06	0.0	0.0	0.0	0.0	0.0	1.0E+00	0.0	1.0E+00
XE-133M	9.000E-05	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
XE-133	2.600E-03	6.6E+01	5.0E+01	6.6E+01	1.0E+01	0.0	1.2E+01	2.3E+03	2.5E+03
XE-135M	8.400E-04	4.6E+01	1.3E+02	4.6E+01	0.0	0.0	0.0	0.0	2.2E+02
XE-135	7.200E-01	3.4E+01	1.3E+02	3.4E+01	4.5E+01	0.0	3.1E+01	3.5E+02	6.2E+02
XE-137	4.700E-02	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
XE-138	2.800E-02	7.0E+00	2.9E+02	7.0E+00	0.0	0.0	3.7E+01	0.0	3.4E+02
TOTAL NOBLE GASES									4.2E+03
I-131	3.292E-03	1.7E-01	3.8E-03	1.7E-02	5.0E-03	0.0	2.6E-04	3.0E-02	2.3E-01
I-133	1.416E-02	6.8E-01	1.5E-02	6.8E-02	1.8E-02	0.0	2.1E-04	0.0	7.8E-01
TRITIUM GASEOUS RELEASE									4.3 CURIES/YR

0.0 APPEARING IN THE TABLE INDICATES RELEASE IS LESS THAN 1.0 CI/YR FOR NOBLE GAS, 0.0001 CI/YR FOR I

AIRBORNE PARTICULATE RELEASE RATE

(CURIES PER YEAR)

NUCLIDE	CONTAINMENT BLDG.	TURBINE BLDG.	AUXILIARY BLDG.	RADWASTE BLDG.	MECH VAC. PUMP	TOTAL
CR-51	3.0E-06	2.6E-05	3.0E-06	9.0E-05	0.0	1.2E-04
MN-54	3.0E-05	1.2E-06	3.0E-05	3.0E-04	0.0	3.6E-04
FE-59	4.0E-06	1.0E-06	4.0E-06	1.5E-04	0.0	1.6E-04
CO-58	6.0E-06	1.2E-06	6.0E-06	4.5E-05	0.0	5.8E-05
CO-60	1.0E-04	4.0E-06	1.0E-04	9.0E-04	0.0	1.1E-03
ZN-65	2.0E-05	4.0E-07	2.0E-05	1.5E-05	0.0	5.5E-05
SR-89	9.0E-07	1.2E-05	9.0E-07	4.5E-06	0.0	1.8E-05
SR-90	5.0E-08	4.0E-08	5.0E-08	3.0E-06	0.0	3.1E-06
ZR-95	4.0E-06	2.0E-07	4.0E-06	5.0E-07	0.0	8.7E-06
SB-124	2.0E-06	6.0E-07	2.0E-06	5.0E-07	0.0	5.1E-06
CS-134	4.0E-05	6.0E-07	4.0E-05	4.5E-05	3.0E-06	1.3E-04
CS-136	3.0E-06	1.0E-07	3.0E-06	4.5E-06	2.0E-06	1.3E-05
CS-137	5.5E-05	1.2E-06	5.5E-05	9.0E-05	1.0E-05	2.1E-04
BA-140	4.0E-06	2.2E-05	4.0E-06	1.0E-06	1.1E-05	4.2E-05
CE-141	1.0E-06	1.2E-06	1.0E-06	2.6E-05	0.0	2.9E-05

ISOTOPE	CONCENTRATION IN PRIMARY COOLANT (DAYS)	ANNUAL RELEASES TO DISCHARGE CANAL (MICRO CI/ML)	ANNUAL RELEASES TO DISCHARGE CANAL			ADJUSTED TOTAL (CI/YR)	DETERGENT WASTES (CI/YR)	TOTAL (CI/YR)	
			HIGH PURITY (CURIES)	LOW PURITY (CURIES)	CHEMICAL (CURIES)				TOTAL (CURIES)
A137M	1.77E-03	0.0	0.0	0.00005	0.00007	0.00012	0.00089	0.00089	
A139	5.76E-02	7.55E-03	0.0	0.00000	0.00000	0.00000	0.00002	0.00002	
A140	1.28E+01	4.06E-04	0.0	0.00001	0.00036	0.00036	0.00268	0.00270	
A140	1.07E+00	0.0	0.0	0.00000	0.00029	0.00029	0.00215	0.00220	
A141	1.02E-01	0.0	0.0	0.00000	0.00000	0.00000	0.00002	0.00002	
E141	3.24E+01	3.05E-05	0.0	0.00000	0.00003	0.00003	0.00025	0.00025	
A142	6.39E-02	3.81E-03	0.0	0.00000	0.00000	0.00000	0.00001	0.00001	
E143	1.38E+00	2.96E-05	0.0	0.00000	0.00001	0.00001	0.00005	0.00005	
R143	1.37E+01	4.06E-05	0.0	0.00000	0.00004	0.00004	0.00029	0.00029	
E144	2.84E+02	3.06E-06	0.0	0.00000	0.00000	0.00000	0.00003	0.00002	
R144	1.20E-02	0.0	0.0	0.00000	0.00000	0.00000	0.00003	0.00002	
D147	1.11E+01	3.04E-06	0.0	0.00000	0.00000	0.00000	0.00002	0.00002	
ALL OTHERS		1.43E-01	0.0	0.00000	0.00000	0.00001	0.00004	0.00004	
TOTAL EXCEPT TRITIUM		4.05E-01	0.0	0.00135	0.02207	0.02342	0.17342	0.06234	0.23000

CASE 4

TRITIUM RELEASE 43 CURIES PER YEAR

Item 3

Meteorology/hydrology - consistent with methodology in Regulatory Guide 1.111 and 1.113 (Draft Regulatory Guides 1.DD and 1.EE).

Response

The meteorological and hydrological models used in this evaluation differ somewhat from those recommended by Regulatory Guide (R.G.) 1.111 and 1.113.

An explanation of the methodology used in developing X/Q's and D/Q's was provided in response to questions in the Enclosure 2 submittal (NRC February 19 letter). Furthermore, it is stated in Section C of R.G. 1.111 "Models proposed by the applicant and accepted by the NRC Staff will be used by the staff in determining Environmental Technical Specifications."

The hydrology model was based upon Regulatory Guide 1.EE since Regulatory Guide 1.113 was not available at the time calculations were performed.

Item 4

Dose calculations consistent with methodology in Regulatory Guide 1.109 (Draft Regulatory Guide 1.AA).

Response

A minor variation of the GASPAR dose code, as explained below, was used to calculate doses from gaseous effluents. Computational models used to calculate doses from gaseous effluents conforms to those referenced in Regulatory Guide 1.109. Site specific data was used as recommended by the guide. To obtain more realistic doses, noble gases were corrected for decay during transit. Each isotope's respective half life was used instead of applying a single conservative half life. For the vegetation pathway, 54 days was used for the average decay time after harvest. The source terms for the dose calculations were generated by the GALE code.

In order to demonstrate the impact of the entire station the computer printout sheets are based upon a two unit site. This was done by simply using the multiplier factor of two which is provided as part of the GALE code. Any value produced in the computer printout sheets is actually based upon the source term which would be produced by two units. However any value referenced in this report, other than the computer printout sheets, was adjusted to reflect a single unit contribution to the radiation dose in the environs.

RESULTS OF THE COMPUTER CALCULATIONS

I. Liquid Effluents - Aquatic Dose

The total body dose to an individual was calculated to be $5.35E-2^{(1)}$ mrem/yr to an adult (The adult is the critical age group for liquid effluents). This value is well below the 10CFR50 'limit' of 3 mrem/year/unit to the total body of any individual. Contributions to the dose from fish, invertebrate ingestion, shoreline buildup, swimming and boating were included in the calculations. The relative contributions of the different pathways are tabulated and presented in this report. The two units shall share common discharge pipes. The dilution flow of 24,000 GPM is a minimum value which is independent of the number of units in operation. Since the computer printout sheets are based upon a two unit site, it is necessary to divide the values presented in the computer printout sheets by a factor of two to reflect a single unit contribution to the radiation dose in the environs.

The maximum organ dose is calculated to be $4.35E-1^{(1)}$ mrem/year to the bones of an adult. The calculated dose is well below the 10 mrem/year/reactor to any organ specified in Appendix I to 10CFR50.

II. Gaseous Effluents - Air Dose

The air dose calculated at the nearest land site boundary of 800 meters North of the Hope Creek Unit No. 2 Reactor Building is $9.30E-1$ mrad/year/reactor (gamma rays) and $6.25E-1$ mrad/year/reactor (beta rays). These values are well below the respective Appendix I limits of 10 mrad/year/reactor (gamma rays) and 20 mrad/yr/reactor (beta rays). Doses indicated in the computer printouts should be divided by two to reflect a single unit source term.

1. See table 4.9e

Caseous Effluents - Individual

In calculating the maximum expected exposures to an individual both nearby residences and nearby dairy farms were considered.

Table 4.1 is a tabulation of the total body exposures to different age group categories at the two locations.

Table 4.2 is a tabulation of the total body exposures to different age group categories at the closest dairy farm located within five miles of the site.

The maximum calculated total body dose to an individual is $3.71E-2$ mrem/year/reactor to a child at the residence 3.5 miles ENE of the site. This is well below the 5 mrem/year/reactor total body dose in Appendix I.

Table 4.3 and 4.4 present similar tabulations for the skin dose at the locations of nearby residences and dairy farms, respectively. The maximum calculated skin dose to an individual is $5.74E-2$ mrem/year/reactor to a child at the residence 3.5 miles ENE of the site. This is well below the 15 mrem/year/reactor skin dose in Appendix I.

Iodine and Particulates - Individual

If it is conservatively assumed that the calculated doses to an individual (any organ) are only due to iodines and particulates, then the computer dose tabulations at the nearby residences and dairy farms may be referred to in order to demonstrate compliance with the 15 mrem/year/reactor limit of Appendix I.

Based on the tabulation of doses to the various organs, the thyroid is the most critical. Tables 4.5 and 4.6 tabulates the thyroid exposures at the nearby residences and dairy farms, respectively. As tabulated in these tables, the maximum thyroid dose is $1.67E-1$ mrem/year/reactor (at dairy farm 4.8 miles NNE) to an infant. This is well below the 15 mrem/year/reactor value set forth in Appendix I.

TABLE 4.1

Total Body DOSE(mrem/yr/unit) at Nearby Residences

LOCATION: 3.5 miles ENE

	ADULT	TEENAGER	CHILD	INFANT
PLUME	2.13E-2	2.13E-2	2.13E-2	2.13E-2
GROUND	5.05E-4	5.05E-4	5.05E-4	5.05E-4
VEGETABLES	2.24E-3	3.28E-3	7.75E-3	(b)
MEAT	1.21E-3	9.30E-4	1.75E-3	(b)
MILK(cow)	1.44E-3	2.39E-3	5.75E-3	1.21E-2
MILK(goat)	a	a	a	a
INHALATION	9.35E-5	5.85E-5	6.60E-5	7.70E-5
TOTAL	2.68E-2	2.85E-2	3.71E-2	3.40E-2

a) No goat milk at this location

b) Not considered a feasible pathway for this age category

TABLE 4.2

Total Body DOSE(mrem/yr/unit) at Nearby Dairy Farms

LOCATION: 4.8 miles NNE

	ADULT	TEENAGER	CHILD	INFANT
PLUME	9.30E-3	9.30E-3	9.30E-3	9.30E-3
GROUND	2.78E-4	2.78E-4	2.78E-4	2.78E-4
VEGETABLES	1.15E-3	.169E-3	3.98E-3	(b)
MEAT	6.15E-4	4.78E-4	8.95E-4	(b)
MILK(cow)	7.40E-4	1.23E-3	2.96E-3	6.20E-3
MILK(goat)	(a)	(a)	(a)	(a)
INHALATION	4.82E-5	3.02E-5	3.41E-5	3.97E-5
TOTAL	1.21E-2	1.30E-2	1.74E-2	1.58E-2

LOCATION: 5.0 miles W

	ADULT	TEENAGER	CHILD	INFANT
PLUME	7.10E-3	7.10E-3	7.10E-3	7.10E-3
GROUND	1.55E-4	1.55E-4	1.55E-4	1.55E-4
VEGETABLES	9.30E-4	1.37E-3	3.24E-3	(b)
MEAT	5.05E-4	3.91E-4	7.30E-4	(b)
MILK (cow)	5.95E-4	9.90E-4	2.39E-3	5.00E-3
MILK (goat)	(a)	(a)	(a)	(a)
INHALATION	3.88E-5	2.42E-5	2.71E-5	3.14E-5
TOTAL	9.32E-3	1.00E-2	1.36E-2	1.23E-2

- a) No milk animals of this type at this location
 b) Not considered a feasible pathway for this age category

TABLE 4.3

Skin DOSE(mrem/yr/unit) at Nearby Residence

LOCATION: 3.50 miles ENE

	ADULT	TEENAGER	CHILD	INFANT
PLUME	4.20E-2	4.20E-2	4.20E-2	4.20E-2
GROUND	5.90E-4	5.90E-4	5.90E-4	5.90E-4
VEGETABLES	2.14E-3	3.18E-3	7.60E-4	(b)
MEAT	1.20E-3	9.25E-4	1.74E-3	(b)
MILK(cow)	1.35E-3	2.25E-3	5.50E-3	1.16E-2
MILK(goat)	(a)	(a)	(a)	(a)
INHALATION	7.65E-5	4.23E-5	4.29E-5	4.56E-5
TOTAL	4.73E-2	4.89E-2	5.74E-2	5.42E-2

- a) No milk animals of this type at this location
 b) Not considered a feasible pathway for this age category

TABLE 4.4

____ Skin DOSE(mrem/yr/unit) at Nearby Dairy Farms _____

LOCATION: 4.8 miles NNE

	ADULT	TEENAGER	CHILD	INFANT
PLUME	1.86E-2	1.86E-2	1.86E-2	1.86E-2
GROUND	3.28E-4	3.28E-4	3.28E-4	3.28E-4
VEGETABLES	1.10E-4	1.63E-3	3.90E-3	(b)
MEAT	6.15E-4	4.75E-4	8.90E-4	(b)
MILK(cow)	6.90E-4	1.16E-3	2.81E-3	5.95E-3
MILK(goat)	(a)	(a)	(a)	(a)
INHALATION	3.92E-5	2.17E-5	2.20E-5	2.34E-5
TOTAL	2.14E-2	2.22E-2	2.65E-2	2.49E-2

LOCATION: 5.0 miles W

	ADULT	TEENAGER	CHILD	INFANT
PLUME	1.43E-2	1.43E-2	1.43E-2	1.43E-2
GROUND	1.82E-4	1.82E-4	1.82E-4	1.82E-4
VEGETABLES	8.95E-4	1.33E-3	3.19E-3	(b)
MEAT	5.00E-4	3.89E-4	7.30E-4	(b)
MILK (cow)	5.65E-4	9.45E-4	2.31E-3	4.87E-3
MILK (goat)	(a)	(a)	(a)	(a)
INHALATION	3.21E-5	1.78E-5	1.80E-5	1.92E-5
TOTAL	1.64E-2	1.71E-2	2.07E-2	1.93E-2

- a) No milk animals of this type at this location
 b) Not considered a feasible pathway for this age category

TABLE 4.5

Thyroid DOSE(mrem/yr/unit) at Nearest Residence

LOCATION: 3.5 miles ENE

	ADULT	TEENAGER	CHILD	INFANT
PLUME	2.13E-2	2.13E-2	2.13E-2	2.13E-2
GROUND	5.05E-4	5.05E-4	5.05E-4	5.05E-4
VEGETABLES	2.67E-2	2.28E-2	3.78E-2	(b)
MEAT	2.43E-3	1.78E-3	3.02E-3	(b)
MILK(cow)	3.65E-2	5.05E-2	1.11E-1	2.66E-1
MILK(goat)	(a)	(a)	(a)	(a)
INHALATION	1.03E-2	8.80E-3	1.22E-2	2.09E-2
TOTAL	9.76E-2	1.10E-1	1.85E-1	3.08E-1

- a) No milk animals of this type at this location
 b) Not considered a feasible pathway for this age category

TABLE 4.6

Thyroid DOSE(mrem/yr/unit) at Nearby Dairy Farms

LOCATION: 4.8 miles NNE

	ADULT	TEENAGER	CHILD	INFANT
PLUME	9.30E-3	9.30E-3	9.30E-3	9.30E-3
GROUND	2.78E-4	2.78E-4	2.78E-4	2.78E-4
VEGETABLES	1.47E-2	1.25E-2	2.06E-2	(b)
MEAT	1.30E-2	9.45E-4	1.60E-3	(b)
MILK(cow)	2.01E-2	3.04E-2	6.10E-2	1.47E-1
MILK(goat)	(a)	(a)	(a)	(a)
INHALATION	5.35E-3	4.61E-3	6.35E-3	1.09E-2
TOTAL	5.10E-2	5.80E-2	9.91E-2	1.67E-1

LOCATION: 5.0 miles W

	ADULT	TEENAGER	CHILD	INFANT
PLUME	7.10E-3	7.10E-3	1.10E-3	7.10E-3
GROUND	1.55E-4	1.55E-4	1.55E-4	1.55E-4
VEGETABLES	8.45E-3	7.35E-3	1.25E-2	(b)
MEAT	8.80E-4	6.50E-4	1.13E-3	(b)
MILK (cow)	1.14E-2	1.72E-2	3.47E-2	8.30E-2
MILK (goat)	(a)	(a)	(a)	(a)
INHALATION	4.03E-3	3.47E-3	4.79E-3	8.20E-3
TOTAL	3.20E-2	3.59E-2	6.03E-2	9.85E-2

a) No milk animals of this type at this location

b) Not considered a feasible pathway for this age category

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION

JC = 0 1 0 0 0 0 0 0 0 0
FV=0.50 FP=0.66 FG=0.50 FPF=0.33 HUMIDITY=8.00
HCGS TWO UNIT SOURCE TERM CASE RUN 7 (NO,NO,NO)
UML = 2.00E+00 JC1 = 0 JC2 = 0

NUCLIDE CI/YR

36KR 83M	2.00E+01
36KR 85M	1.88E+02
36KR 85	5.20E+02
36KR 87	3.80E+02
36KR 88	6.00E+02
54XE131M	2.00E+00
54XE133	5.40E+03
54XE135M	1.48E+03
54XE135	2.20E+03
54XE138	3.00E+03
53I 131	8.20E-01
53I 133	3.00E+00
6C 14	1.90E+01
18AR 41	5.00E+01
1H 3	8.60E+01
24CR 51	2.60E-02
25MN 54	1.92E-03
26FE 59	1.32E-03
27CU 58	1.32E-03
27CO 60	6.20E-03
30ZN 65	5.00E-04
38SK 89	1.20E-02
38SR 90	4.60E-05
40ZR 92	2.20E-04
51SB124	6.00E-04
55CS134	8.60E-04
55CS136	1.24E-04
55CS137	1.62E-03
56BA140	2.20E-02
58CE141	1.26E-03
30	6.97442969E+03

GASPAR

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
 SPECIAL LOCATION # 1 DAIRY FARM #1
 AT 4.80 MILES 2

ANNUAL BETA AIR DOSE = 2.19E-02 MILLRADS
 ANNUAL GAMMA AIR DOSE = 2.80E-02 MILLRADS

PATHWAY	T.BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
PLUME	1.86E-02	1.86E-02	1.86E-02	1.85E-02	1.86E-02	1.86E-02	1.88E-02	3.72E-02
GROUND	5.56E-04	5.56E-04	5.56E-04	5.56E-04	5.56E-04	5.56E-04	5.56E-04	6.55E-04
VEGET ADULT	2.30E-03	2.32E-03	1.06E-02	2.33E-03	2.36E-03	2.93E-02	2.20E-03	2.19E-03
TEEN	3.37E-03	3.37E-03	3.70E-03	3.41E-03	2.64E-03	2.49E-02	3.26E-03	3.25E-03
CHILD	7.96E-03	7.88E-03	8.85E-03	8.03E-03	2.13E-03	4.12E-02	7.80E-03	7.79E-03
MEAT ADULT	1.23E-03	1.25E-03	5.96E-03	1.24E-03	1.23E-03	2.59E-03	1.23E-03	1.23E-03
TEEN	9.56E-04	9.60E-04	9.43E-04	9.59E-04	7.30E-04	1.89E-03	9.51E-04	9.50E-04
CHILD	1.79E-03	1.79E-03	1.78E-03	1.79E-03	4.60E-04	3.20E-03	1.78E-03	1.78E-03
COW MILK ADULT	1.48E-03	1.43E-03	6.62E-03	1.55E-03	1.60E-03	4.02E-02	1.38E-03	1.38E-03
TEEN	2.46E-03	2.36E-03	2.45E-03	2.59E-03	2.07E-03	6.08E-02	2.32E-03	2.31E-03
CHILD	5.92E-03	5.67E-03	6.04E-03	6.11E-03	1.71E-03	1.22E-01	5.64E-03	5.62E-03
INFANT	1.24E-02	1.19E-02	1.28E-02	1.31E-02	1.71E-03	2.93E-01	1.19E-02	1.19E-02
GOAT MILK ADULT	1.85E-03	1.61E-03	7.00E-03	2.10E-03	2.28E-03	1.42E-01	1.48E-03	1.46E-03
TEEN	2.97E-03	2.58E-03	3.12E-03	3.48E-03	2.94E-03	2.15E-01	2.43E-03	2.39E-03
CHILD	6.84E-03	5.91E-03	7.64E-03	7.63E-03	2.43E-03	4.29E-01	5.82E-03	5.76E-03
INFANT	1.40E-02	1.23E-02	1.62E-02	1.66E-02	2.43E-03	1.03E+00	1.22E-02	1.21E-02
INHAL ADULT	9.64E-05	9.98E-05	2.97E-05	1.32E-04	1.52E-04	1.07E-02	1.05E-04	7.84E-05
TEEN	6.04E-05	5.88E-05	2.64E-05	9.17E-05	1.06E-04	9.21E-03	7.18E-05	4.33E-05
CHILD	6.82E-05	5.33E-05	4.10E-05	9.39E-05	5.63E-05	1.27E-02	7.09E-05	4.39E-05
INFANT	7.93E-05	5.39E-05	6.08E-05	1.30E-04	3.96E-05	2.18E-02	9.17E-05	4.67E-05

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
 SPECIAL LOCATION # 2 DAIRY FARM #2
 AT 5.00 MILES 13

ANNUAL BETA AIR DOSE = 1.72E-02 MILLRADS
 ANNUAL GAMMA AIR DOSE = 2.14E-02 MILLRADS

PATHWAY	T.BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
PLUME	1.42E-02	1.42E-02	1.42E-02	1.42E-02	1.42E-02	1.42E-02	1.44E-02	2.85E-02
GROUND	3.09E-04	3.09E-04	3.09E-04	3.09E-04	3.09E-04	3.09E-04	3.09E-04	3.64E-04
VEGET								
ADULT	1.86E-03	1.87E-03	8.57E-03	1.97E-03	1.89E-03	1.69E-02	1.80E-03	1.79E-03
TEEN	2.73E-03	2.73E-03	2.88E-03	2.75E-03	2.13E-03	1.47E-02	2.67E-03	2.66E-03
CHILD	6.48E-03	6.43E-03	6.92E-03	6.51E-03	1.72E-03	2.50E-02	6.39E-03	6.38E-03
MEAT								
ADULT	1.01E-03	1.02E-03	4.88E-03	1.01E-03	1.01E-03	1.76E-03	1.00E-03	1.00E-03
TEEN	7.81E-04	7.84E-04	7.71E-04	7.83E-04	5.96E-04	1.30E-03	7.79E-04	7.78E-04
CHILD	1.46E-03	1.46E-03	1.45E-03	1.47E-03	3.76E-04	2.25E-03	1.46E-03	1.46E-03
COW MILK								
ADULT	1.19E-03	1.16E-03	5.39E-03	1.22E-03	1.25E-03	2.27E-02	1.13E-03	1.13E-03
TEEN	1.98E-03	1.92E-03	1.95E-03	2.05E-03	1.62E-03	3.44E-02	1.89E-03	1.89E-03
CHILD	4.77E-03	4.63E-03	4.81E-03	4.88E-03	1.34E-03	6.93E-02	4.62E-03	4.61E-03
INFANT	1.00E-02	9.77E-03	1.02E-02	1.04E-02	1.34E-03	1.66E-01	9.76E-03	9.74E-03
GOATMILK								
ADULT	1.41E-03	1.28E-03	5.60E-03	1.55E-03	1.65E-03	7.96E-02	1.21E-03	1.20E-03
TEEN	2.28E-03	2.06E-03	2.32E-03	2.56E-03	2.13E-03	1.20E-01	1.98E-03	1.96E-03
CHILD	5.32E-03	4.80E-03	5.70E-03	5.76E-03	1.76E-03	2.40E-01	4.75E-03	4.72E-03
INFANT	1.10E-02	1.00E-02	1.21E-02	1.24E-02	1.76E-03	5.77E-01	9.99E-03	9.91E-03
INHAL								
ADULT	7.76E-05	7.97E-05	2.17E-05	1.02E-04	1.20E-04	8.05E-03	7.92E-05	6.42E-05
TEEN	4.83E-05	4.68E-05	1.97E-05	7.02E-05	8.35E-05	6.93E-03	5.13E-05	3.55E-05
CHILD	5.42E-05	4.29E-05	3.06E-05	7.27E-05	4.42E-05	9.58E-03	5.10E-05	3.60E-05
INFANT	6.28E-05	4.36E-05	4.54E-05	9.94E-05	3.11E-05	1.64E-02	6.33E-05	3.83E-05

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
 SPECIAL LOCATION # 3 VEG PLOT #1
 AT 4.40 MILES 16

ANNUAL BETA AIR DOSE = 3.72E-02 MILLRADS
 ANNUAL GAMMA AIR DOSE = 4.85E-02 MILLRADS

PATHWAY	T.BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
PLUME	3.22E-02	3.22E-02	3.22E-02	3.22E-02	3.22E-02	3.22E-02	3.26E-02	6.40E-02
GROUND	9.07E-04	9.07E-04	9.07E-04	9.07E-04	9.07E-04	9.07E-04	9.07E-04	1.07E-03
VEGET								
ADULT	3.78E-03	3.81E-03	1.74E-02	3.83E-03	3.87E-03	4.78E-02	3.61E-03	3.60E-03
TEEN	5.54E-03	5.54E-03	6.08E-03	5.61E-03	4.34E-03	4.07E-02	5.36E-03	5.35E-03
CHILD	1.31E-02	1.30E-02	1.45E-02	1.32E-02	3.50E-03	6.72E-02	1.28E-02	1.28E-02
MEAT								
ADULT	2.03E-03	2.05E-03	9.80E-03	2.03E-03	2.03E-03	4.24E-03	2.02E-03	2.01E-03
TEEN	1.57E-03	1.58E-03	1.55E-03	1.58E-03	1.20E-03	3.09E-03	1.56E-03	1.56E-03
CHILD	2.94E-03	2.94E-03	2.93E-03	2.95E-03	7.57E-04	5.24E-03	2.93E-03	2.93E-03
COW MILK								
ADULT	2.43E-03	2.34E-03	1.09E-02	2.54E-03	2.63E-03	6.55E-02	2.27E-03	2.27E-03
TEEN	4.04E-03	3.89E-03	4.03E-03	4.25E-03	3.40E-03	9.92E-02	3.81E-03	3.79E-03
CHILD	9.73E-03	9.32E-03	9.92E-03	1.00E-02	2.80E-03	1.99E-01	9.27E-03	9.25E-03
INFANT	2.04E-02	1.96E-02	2.11E-02	2.15E-02	2.80E-03	4.77E-01	1.96E-02	1.96E-02
GOATMILK								
ADULT	3.04E-03	2.64E-03	1.15E-02	3.44E-03	3.74E-03	2.32E-01	2.44E-03	2.40E-03
TEEN	4.87E-03	4.24E-03	5.12E-03	5.70E-03	4.83E-03	3.51E-01	4.00E-03	3.93E-03
CHILD	1.12E-02	9.72E-03	1.25E-02	1.25E-02	3.98E-03	6.99E-01	9.57E-03	9.46E-03
INFANT	2.31E-02	2.02E-02	2.65E-02	2.72E-02	3.98E-03	1.68E+00	2.01E-02	1.99E-02
INHAL								
ADULT	1.58E-04	1.64E-04	4.87E-05	2.17E-04	2.50E-04	1.76E-02	1.73E-04	1.29E-04
TEEN	9.92E-05	9.66E-05	4.33E-05	1.50E-04	1.75E-04	1.51E-02	1.18E-04	7.12E-05
CHILD	1.12E-04	8.76E-05	6.72E-05	1.54E-04	9.24E-05	2.09E-02	1.16E-04	7.22E-05
INFANT	1.30E-04	8.86E-05	9.97E-05	2.13E-04	6.50E-05	3.58E-02	1.50E-04	7.68E-05

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
 SPECIAL LOCATION # 4 HC FENCE POST
 AT 0.50 MILES 1

ANNUAL BETA AIR DOSE = 1.25E+00 MILLRADS
 ANNUAL GAMMA AIR DOSE = 1.85E+00 MILLRADS

PATHWAY	T.BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
PLUME	1.24E+00	1.24E+00	1.24E+00	1.24E+00	1.24E+00	1.24E+00	1.25E+00	2.38E+00
GROUND	4.13E-02	4.13E-02	4.13E-02	4.13E-02	4.13E-02	4.13E-02	4.13E-02	4.86E-02
VEGET								
ADULT	9.96E-02	1.01E-01	4.54E-01	1.02E-01	1.04E-01	2.11E+00	9.18E-02	9.13E-02
TEEN	1.44E-01	1.44E-01	1.74E-01	1.48E-01	1.14E-01	1.75E+00	1.36E-01	1.36E-01
CHILD	3.38E-01	3.32E-01	4.10E-01	3.43E-01	9.14E-02	2.80E+00	3.26E-01	3.25E-01
MEAT								
ADULT	5.18E-02	5.26E-02	2.49E-01	5.20E-02	5.18E-02	1.52E-01	5.12E-02	5.11E-02
TEEN	4.00E-02	4.04E-02	3.96E-02	4.03E-02	3.06E-02	1.09E-01	3.97E-02	3.96E-02
CHILD	7.49E-02	7.48E-02	7.48E-02	7.52E-02	1.93E-02	1.79E-01	7.44E-02	7.44E-02
COW MILK								
ADULT	6.50E-02	6.10E-02	2.80E-01	6.99E-02	7.42E-02	2.94E+00	5.79E-02	5.75E-02
TEEN	1.08E-01	1.00E-01	1.10E-01	1.17E-01	9.57E-02	4.44E+00	9.69E-02	9.62E-02
CHILD	2.56E-01	2.38E-01	2.70E-01	2.71E-01	7.90E-02	8.87E+00	2.36E-01	2.35E-01
INFANT	5.36E-01	5.00E-01	5.72E-01	5.83E-01	7.50E-02	2.13E+01	4.99E-01	4.96E-01
GOATMILK								
ADULT	9.00E-02	7.20E-02	3.09E-01	1.08E-01	1.22E-01	1.05E+01	6.25E-02	6.09E-02
TEEN	1.43E-01	1.14E-01	1.59E-01	1.80E-01	1.57E-01	1.59E+01	1.03E-01	9.97E-02
CHILD	3.20E-01	2.52E-01	3.88E-01	3.79E-01	1.30E-01	3.16E+01	2.45E-01	2.40E-01
INFANT	6.49E-01	5.17E-01	8.21E-01	8.40E-01	1.30E-01	7.63E+01	5.16E-01	5.04E-01
INHAL								
ADULT	4.18E-03	4.43E-03	1.56E-03	6.24E-03	6.97E-03	5.36E-01	5.26E-03	3.27E-03
TEEN	2.67E-03	2.62E-03	1.34E-03	4.42E-03	4.87E-03	4.61E-01	3.92E-03	1.81E-03
CHILD	3.05E-03	2.32E-03	2.07E-03	4.45E-03	2.58E-03	6.38E-01	3.84E-03	1.83E-03
INFANT	3.59E-03	2.32E-03	3.07E-03	6.19E-03	1.81E-03	1.09E+00	5.29E-03	1.95E-03


POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
 SPECIAL LOCATION # 5 HC NEAR RESID
 AT 3.50 MILES 4

CASE 1

ANNUAL BETA AIR DOSE = 4.74E-02 MILLRADS
 ANNUAL GAMMA AIR DOSE = 6.41E-02 MILLRADS

PATHWAY	T.BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
PLUME	4.26E-02	4.26E-02	4.26E-02	4.26E-02	4.26E-02	4.26E-02	4.31E-02	8.39E-02
GROUND	1.01E-03	1.01E-03	1.01E-03	1.01E-03	1.01E-03	1.01E-03	1.01E-03	1.18E-03
VEGET								
ADULT	4.47E-03	4.51E-03	2.06E-02	4.53E-03	4.57E-03	5.34E-02	4.28E-03	4.27E-03
TEEN	6.56E-03	6.56E-03	7.15E-03	6.64E-03	5.14E-03	4.56E-02	6.36E-03	6.35E-03
CHILD	1.55E-02	1.54E-02	1.71E-02	1.56E-02	4.14E-03	7.56E-02	1.52E-02	1.52E-02
MEAT								
ADULT	2.41E-03	2.43E-03	1.16E-02	2.41E-03	2.41E-03	4.86E-03	2.39E-03	2.39E-03
TEEN	1.86E-03	1.87E-03	1.84E-03	1.87E-03	1.42E-03	3.55E-03	1.86E-03	1.85E-03
CHILD	3.49E-03	3.49E-03	3.47E-03	3.50E-03	8.98E-04	6.04E-03	3.43E-03	3.48E-03
COW MILK								
ADULT	2.87E-03	2.78E-03	1.29E-02	2.99E-03	3.10E-03	7.29E-02	2.70E-03	2.69E-03
TEEN	4.78E-03	4.61E-03	4.76E-03	5.01E-03	4.00E-03	1.10E-01	4.52E-03	4.50E-03
CHILD	1.15E-02	1.11E-02	1.17E-02	1.19E-02	3.30E-03	2.21E-01	1.10E-02	1.10E-02
INFANT	2.42E-02	2.33E-02	2.49E-02	2.53E-02	3.30E-03	5.31E-01	2.33E-02	2.32E-02
GOATMILK								
ADULT	3.56E-03	3.12E-03	1.36E-02	4.00E-03	4.34E-03	2.58E-01	2.89E-03	2.85E-03
TEEN	5.71E-03	5.00E-03	5.96E-03	6.63E-03	5.60E-03	3.89E-01	4.74E-03	4.66E-03
CHILD	1.32E-02	1.15E-02	1.46E-02	1.46E-02	4.62E-03	7.76E-01	1.14E-02	1.12E-02
INFANT	2.71E-02	2.35E-02	3.09E-02	3.18E-02	4.62E-03	1.87E+00	2.39E-02	2.36E-02
INHAL								
ADULT	1.87E-04	1.94E-04	5.66E-05	2.55E-04	2.94E-04	2.05E-02	2.02E-04	1.53E-04
TEEN	1.17E-04	1.14E-04	5.05E-05	1.76E-04	2.05E-04	1.76E-02	1.36E-04	8.45E-05
CHILD	1.32E-04	1.04E-04	7.84E-05	1.81E-04	1.09E-04	2.44E-02	1.35E-04	8.57E-05
INFANT	1.54E-04	1.05E-04	1.16E-04	2.50E-04	7.65E-05	4.18E-02	1.72E-04	9.12E-05

LIQUID EFFLUENTS AND THEIR DOSES



TABLES 4.9a through 4.9z CONTAINS INFORMATION ON THE
IMPACT FROM LIQUID EFFLUENTS FROM THE HOPE CREEK GENERATING STATION

INDIVIDUAL DOSES TO ADULTS ARE ON TABLE 4.9e

POPULATION DOSES ARE ON TABLES 4.9y and 4.9z

HOPE CREEK GENERATING STATION - LIQUID DOSE CALCULATIONS

DISCHARGE=0.54E+02 CFS

SOURCE TERM MULTIPLIER=0.29E+01

SALTWATER SITE

HOPE CREEK LIQUID SOURCE TERM RUN 7 (NO,NO,NO)

GRIEF RH103M 1.60E-04
 GRIEF RH105M 1.00E-04
 GRIEF RH106 2.00E-05
 GRIEF BA137M 8.90E-04

UML-2

LADTAP

NO RECONCENTRATION OF NUCLIDES

NUCLIDE	CURIE/YEAR	INGESTION DOSE FACTORS										SHORELINE	
		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI	SKIN	TOTAL BODY	RECON		
11NA 24	9.80E-03	2.26E-06	2.26E-06	2.26E-06	2.26E-06	2.26E-06	2.26E-06	2.26E-06	2.26E-06	2.90E-08	2.50E-08	1.00E+00	
15P 32	2.80E-03	1.93E-04	1.21E-05	7.47E-06	0.0	0.0	0.0	2.17E-05	0.0	0.0	0.0	1.00E+00	
24CR 51	7.60E-02	0.0	0.0	2.66E-09	1.59E-09	5.87E-10	3.53E-09	6.69E-07	2.60E-10	2.20E-10	2.20E-10	1.00E+00	
25MN 54	3.00E-03	0.0	4.57E-06	8.73E-07	0.0	1.36E-06	0.0	1.40E-05	6.80E-09	5.80E-09	1.00E+00	1.00E+00	
25MN 56	1.16E-03	0.0	1.15E-07	2.05E-08	0.0	1.46E-07	0.0	3.67E-06	1.30E-08	1.10E-08	1.00E+00	1.00E+00	
26FE 55	1.70E-02	6.20E-06	2.79E-05	7.33E-06	0.0	0.0	3.23E-05	1.09E-05	0.0	0.0	0.0	1.00E+00	
26FE 59	4.80E-04	4.34E-06	1.03E-05	3.92E-06	0.0	0.0	2.86E-06	3.40E-05	9.40E-09	8.00E-09	1.00E+00	1.00E+00	
27CO 58	1.12E-02	0.0	7.46E-07	1.67E-06	0.0	0.0	0.0	1.51E-05	8.20E-09	7.00E-09	1.00E+00	1.00E+00	
27CO 60	2.40E-02	0.0	2.15E-06	4.72E-06	0.0	0.0	0.0	4.02E-05	2.00E-08	1.70E-08	1.00E+00	1.00E+00	
29CU 64	2.60E-02	0.0	8.34E-08	3.92E-08	0.0	2.10E-07	0.0	7.10E-06	1.70E-09	1.50E-09	1.00E+00	1.00E+00	
30ZN 65	3.40E-03	4.85E-06	1.54E-05	6.97E-06	0.0	1.03E-05	0.0	9.70E-06	4.60E-09	4.00E-09	1.00E+00	1.00E+00	
30ZN 69M	1.90E-03	1.70E-07	4.09E-07	3.73E-08	0.0	2.48E-07	0.0	2.49E-05	3.40E-09	2.90E-09	1.00E+00	1.00E+00	
30ZN 69	2.00E-03	1.03E-08	1.98E-08	1.37E-09	0.0	1.28E-08	0.0	2.96E-09	0.0	0.0	1.00E+00	1.00E+00	
74W 187	6.40E-04	1.03E-07	8.62E-08	3.02E-08	0.0	0.0	0.0	2.82E-05	3.60E-09	3.10E-09	1.00E+00	1.00E+00	
93NP 239	3.80E-02	1.20E-09	1.18E-10	6.46E-11	0.0	3.65E-10	0.0	2.40E-05	1.10E-09	9.50E-10	1.00E+00	1.00E+00	
35BR 83	6.00E-05	0.0	0.0	4.02E-08	0.0	0.0	0.0	5.79E-08	9.30E-11	6.40E-11	1.00E+00	1.00E+00	
38SR 89	1.62E-03	3.09E-04	0.0	8.85E-06	0.0	0.0	0.0	4.94E-05	6.50E-13	5.60E-13	1.00E+00	1.00E+00	
38SR 90	1.00E-04	7.61E-03	0.0	1.86E-03	0.0	0.0	0.0	1.02E-04	0.0	0.0	1.00E+00	1.00E+00	
39Y 90	6.00E-05	9.63E-09	0.0	2.58E-10	0.0	0.0	0.0	1.02E-04	2.60E-12	2.20E-12	1.00E+00	1.00E+00	
38SR 91	2.00E-03	5.82E-06	0.0	2.56E-07	0.0	0.0	0.0	2.93E-05	8.30E-09	7.10E-09	1.00E+00	1.00E+00	
39Y 91M	1.34E-03	9.10E-11	0.0	3.53E-12	0.0	0.0	0.0	2.67E-10	4.40E-09	3.80E-09	1.00E+00	1.00E+00	
39Y 91	1.04E-03	1.41E-07	0.0	3.78E-09	0.0	0.0	0.0	7.76E-05	2.70E-11	2.40E-11	1.00E+00	1.00E+00	
38SR 92	2.60E-04	2.16E-06	0.0	9.31E-08	0.0	0.0	0.0	4.26E-05	1.00E-08	9.00E-09	1.00E+00	1.00E+00	
39Y 92	1.24E-03	8.46E-10	0.0	2.47E-11	0.0	0.0	0.0	1.48E-05	1.90E-09	1.60E-09	1.00E+00	1.00E+00	
39Y 93	2.20E-03	2.68E-09	0.0	7.40E-11	0.0	0.0	0.0	8.50E-05	7.80E-10	5.70E-10	1.00E+00	1.00E+00	
40ZR 95	1.20E-04	3.04E-08	9.76E-09	6.61E-09	0.0	1.54E-08	0.0	3.03E-05	5.80E-09	5.00E-09	1.00E+00	1.00E+00	
41NB 95	1.20E-04	6.23E-09	3.46E-09	1.36E-09	0.0	3.43E-09	0.0	2.10E-05	6.00E-09	5.10E-09	1.00E+00	1.00E+00	
42MO 99	1.28E-02	0.0	4.31E-06	8.20E-07	0.0	9.77E-06	0.0	9.99E-06	2.20E-09	1.90E-09	1.00E+00	1.00E+00	
43TC 99M	1.60E-02	2.47E-10	6.98E-10	8.90E-09	0.0	1.06E-08	3.42E-10	4.13E-07	1.10E-09	9.60E-10	1.00E+00	1.00E+00	
44RU 103	6.00E-04	1.85E-07	0.0	7.98E-08	0.0	7.07E-07	0.0	2.16E-05	4.20E-09	3.60E-09	1.00E+00	1.00E+00	
44RU 105	2.00E-04	1.54E-08	0.0	6.08E-09	0.0	1.99E-07	0.0	9.42E-06	5.10E-09	4.50E-09	1.00E+00	1.00E+00	
45RH 105	8.00E-04	1.22E-07	8.86E-08	5.83E-08	0.0	3.76E-07	0.0	1.41E-05	7.70E-10	6.60E-10	1.00E+00	1.00E+00	
44RU 106	4.80E-03	2.75E-06	0.0	3.48E-07	0.0	5.32E-06	0.0	1.78E-04	1.80E-09	1.50E-09	1.00E+00	1.00E+00	
52TE 129M	6.20E-04	1.15E-05	4.30E-06	1.82E-06	3.95E-06	4.80E-05	0.0	5.79E-05	9.00E-10	7.70E-10	1.00E+00	1.00E+00	
52TE 129	4.00E-04	3.15E-08	1.19E-08	7.66E-09	2.41E-08	1.32E-07	0.0	2.37E-08	8.40E-10	7.10E-10	1.00E+00	1.00E+00	
52TE 131M	2.80E-04	1.74E-06	8.47E-07	7.06E-07	1.34E-06	8.58E-06	0.0	8.40E-05	9.90E-09	8.40E-09	1.00E+00	1.00E+00	
52TE 131	6.00E-05	1.97E-08	8.24E-09	6.22E-09	1.62E-08	8.64E-08	0.0	2.95E-09	2.60E-06	2.20E-09	1.00E+00	1.00E+00	
53I 131	5.80E-02	4.16E-06	5.96E-06	3.41E-06	1.95E-03	1.02E-05	0.0	1.57E-06	3.40E-09	2.80E-09	1.00E+00	1.00E+00	
52TE 132	8.00E-05	2.53E-05	1.64E-06	1.53E-06	1.80E-06	1.58E-05	0.0	7.71E-05	2.00E-09	1.70E-09	1.00E+00	1.00E+00	
53I 132	5.40E-04	2.03E-07	5.43E-07	1.93E-07	7.15E-05	8.66E-07	0.0	1.02E-07	2.00E-08	1.70E-08	1.00E+00	1.00E+00	
53I 133	3.40E-02	1.43E-06	2.48E-06	7.57E-07	4.77E-04	4.33E-06	0.0	2.18E-06	4.50E-09	3.70E-09	1.00E+00	1.00E+00	
53I 134	4.00E-05	1.06E-07	2.88E-07	1.03E-07	3.74E-05	4.59E-07	0.0	2.51E-10	1.90E-08	1.60E-08	1.00E+00	1.00E+00	
55CS 134	2.60E-02	6.22E-05	1.48E-04	1.21E-04	0.0	4.80E-05	1.59E-05	2.59E-06	1.40E-08	1.20E-08	1.00E+00	1.00E+00	
53I 135	4.80E-03	4.43E-07	1.17E-06	4.29E-07	1.53E-04	1.86E-06	0.0	1.31E-06	1.40E-08	1.20E-08	1.00E+00	1.00E+00	
55CS 136	4.60E-04	6.51E-06	2.57E-05	1.85E-05	0.0	1.43E-05	1.96E-06	2.92E-06	1.70E-08	1.50E-08	1.00E+00	1.00E+00	
55CS 137	5.00E-02	7.98E-05	1.09E-04	7.15E-05	0.0	3.71E-05	1.23E-05	2.10E-06	4.90E-09	4.20E-09	1.00E+00	1.00E+00	

CASE 1

57LA 140	4.40E-03	2.50E-09	1.26E-09	3.34E-10	0.0	8.28E-09	1.46E-08	4.18E-05	2.40E-09	2.10E-09	1.00E+00
57LA 141	4.00E-05	3.19E-10	9.91E-11	1.62E-11	0.0	0.0	0.0	9.25E-05	1.70E-08	1.50E-08	1.00E+00
58CE 141	5.00E-04	9.37E-09	6.34E-09	7.18E-10	0.0	0.0	0.0	1.18E-05	2.80E-10	2.50E-10	1.00E+00
57LA 142	2.00E-05	1.20E-10	5.82E-11	1.45E-11	0.0	2.9E-09	0.0	2.42E-05	6.20E-10	5.50E-10	1.00E+00
58CE 143	1.00E-04	1.65E-09	1.22E-06	1.35E-10	0.0	0.0	0.0	4.25E-07	1.80E-08	1.50E-08	1.00E+00
59PR 143	5.80E-04	9.21E-09	3.70E-09	4.57E-10	0.0	5.38E-10	0.0	4.56E-05	2.50E-09	2.20E-09	1.00E+00
58CE 144	1.04E-02	4.89E-07	2.04E-07	2.62E-08	0.0	2.13E-09	0.0	4.03E-05	0.0	0.0	1.00E+00
59PR 144	4.03E-05	3.02E-11	1.25E-11	1.53E-12	0.0	1.21E-07	0.0	1.65E-04	3.70E-10	3.20E-10	1.00E+00
60ND 147	4.00E-05	6.30E-09	7.28E-09	4.35E-10	0.0	7.06E-12	0.0	4.33E-18	2.30E-10	2.00E-10	1.00E+00
1H 3	8.60E+01	0.0	1.34E-07	1.34E-07	1.34E-07	4.25E-09	0.0	3.49E-05	1.20E-09	1.00E-09	1.00E+00
											1.00E+00

* * * TEENAGER DOSE FACTORS * * *

NUCLIDE	CURIE/YEAR	INGESTION DOSE FACTORS (MREM/PCI INTAKE)							SHORELINE (MREM/HR)/(PCI/M**2)		
		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI	SKIN	TOTAL BODY	RECON
27CO 58	1.12E-02	0.0	9.92E-07	2.26E-06	0.0	0.0	0.0	1.34E-05			
27CO 60	2.40E-02	0.0	2.76E-06	6.30E-06	0.0	0.0	0.0	3.31E-05			
38SR 89	1.62E-03	4.60E-04	0.0	1.32E-05	0.0	0.0	0.0	4.99E-05			
38SR 90	1.00E-04	1.04E-02	0.0	2.57E-03	0.0	0.0	0.0	2.20E-04			
39Y 90	6.00E-05	3.30E-08	0.0	8.87E-10	0.0	0.0	3.75E-05	1.09E-04			
39Y 91	1.04E-03	1.96E-07	0.0	5.23E-09	0.0	0.0	0.0	7.53E-05			
40ZR 95	1.20E-04	3.72E-08	1.24E-08	8.66E-09	0.0	1.54E-08	0.0	2.68E-05			
41NB 95	1.20E-04	7.24E-09	4.36E-09	2.46E-09	0.0	3.43E-09	0.0	1.78E-05			
44RU 103	6.00E-04	2.37E-07	0.0	1.06E-07	0.0	7.07E-07	0.0	1.85E-05			
44RU 106	4.80E-03	4.00E-06	0.0	5.03E-07	0.0	5.32E-06	0.0	1.81E-04			
52TE 129M	6.20E-04	1.66E-05	6.15E-06	2.61E-06	5.30E-06	4.80E-05	0.0	5.80E-05			
53I 131	5.80E-02	5.57E-06	7.87E-06	4.69E-06	2.27E-03	1.02E-05	0.0	1.49E-06			
52TE 132	8.00E-05	3.55E-06	2.22E-06	2.10E-06	2.36E-06	1.58E-05	0.0	8.00E-05			
53I 133	3.40E-02	2.03E-06	3.44E-06	1.06E-06	6.25E-04	4.33E-06	0.0	2.50E-06			
55CS 134	2.60E-02	8.05E-05	1.94E-04	9.06E-05	0.0	4.80E-05	2.35E-05	2.24E-06			
55CS 137	5.00E-02	1.07E-04	1.44E-04	5.05E-05	0.0	3.71E-05	1.91E-05	1.92E-06			
56BA 140	5.40E-03	2.83E-05	3.48E-08	1.82E-06	0.0	8.68E-09	2.33E-08	4.14E-06			
57LA 140	4.40E-03	3.48E-09	1.72E-09	4.55E-10	0.0	0.0	0.0	9.48E-05			
58CE 141	5.00E-04	1.26E-08	8.46E-09	9.70E-10	0.0	2.94E-09	0.0	2.29E-05			
58CE 144	1.04E-02	7.22E-07	2.96E-07	3.83E-08	0.0	1.21E-07	0.0	1.70E-04			
IH 3	8.60E+01	0.0	1.06E-07	1.06E-07	1.06E-07	1.34E-07	1.06E-07	1.06E-07			

* * * CHILD DOSE FACTORS * * *

NUCLIDE	CURIE/YEAR	INGESTION DOSE FACTORS (MREM/PCI INTAKE)							SHORELINE (MREM/HR)/(PCI/M**2)		
		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI	SKIN	TOTAL BODY	RECON
27CO 58	1.12E-02	0.0	1.85E-06	5.58E-06	0.0	0.0	0.0	1.10E-05			
27CO 60	2.40E-02	0.0	5.17E-06	1.55E-05	0.0	0.0	0.0	2.86E-05			
38SR 89	1.62E-03	1.38E-03	0.0	3.95E-05	0.0	0.0	0.0	5.15E-05			
38SR 90	1.00E-04	1.72E-02	0.0	4.36E-03	0.0	0.0	0.0	2.29E-04			
39Y 90	6.00E-05	4.21E-08	0.0	1.13E-09	0.0	0.0	0.0	1.20E-04			
39Y 91	1.04E-03	5.85E-07	0.0	1.56E-08	0.0	0.0	0.0	7.77E-05			
40ZR 95	1.20E-04	1.04E-07	2.42E-08	2.20E-08	0.0	1.54E-08	0.0	2.50E-05			
41NB 95	1.20E-04	1.95E-08	8.32E-09	6.11E-09	0.0	3.43E-09	0.0	1.44E-05			
44RU 103	6.00E-04	6.78E-07	0.0	2.74E-07	0.0	7.07E-07	0.0	1.78E-05			
44RU 106	4.80E-03	1.19E-05	0.0	1.48E-06	0.0	5.32E-06	0.0	1.85E-04			
52TE 129M	6.20E-04	4.95E-05	1.38E-05	7.65E-06	1.58E-05	4.80E-05	0.0	5.96E-05			
53I 131	5.80E-02	1.63E-05	1.67E-05	1.26E-05	5.43E-03	1.02E-05	0.0	1.43E-06			
52TE 132	8.00E-05	1.02E-05	4.50E-06	5.42E-06	6.62E-06	1.58E-05	0.0	7.89E-05			
53I 133	3.40E-02	5.98E-06	7.38E-06	2.90E-06	1.78E-03	4.33E-06	0.0	2.99E-06			
55CS 134	2.60E-02	2.24E-04	3.77E-04	8.02E-05	0.0	4.80E-05	4.19E-05	2.04E-06			
55CS 137	5.00E-02	3.12E-04	3.02E-04	4.50E-05	0.0	3.71E-05	3.54E-05	1.84E-06			
56BA 140	5.40E-03	8.26E-05	7.25E-08	4.85E-06	0.0	8.68E-09	4.32E-08	4.21E-06			
57LA 140	4.40E-03	1.01E-08	3.52E-09	1.19E-09	0.0	0.0	0.0	1.00E-04			
58CE 141	5.00E-04	3.76E-08	1.88E-08	2.80E-09	0.0	2.94E-09	0.0	2.36E-05			
58CE 144	1.04E-02	2.14E-06	6.70E-07	1.14E-07	0.0	1.21E-07	0.0	1.74E-04			
IH 3	8.60E+01	0.0	2.03E-07	2.03E-07	2.03E-07	1.34E-07	2.03E-07	2.03E-07			

* * * INFANT DOSE FACTORS * * *

NUCLIDE	CURIE/YEAR	INGESTION DOSE FACTORS (MREM/PCI INTAKE)							SHORELINE (MREM/HR)/(PCI/M**2)		
		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI	SKIN	TOTAL BODY	RECON
27CO 58	1.12E-02	0.0	3.78E-06	9.26E-06	0.0	0.0	0.0	9.79E-06			
27CO 60	2.40E-02	0.0	1.07E-05	2.56E-05	0.0	0.0	0.0	2.64E-05			
38SR 89	1.62E-03	2.93E-03	0.0	8.42E-05	0.0	0.0	0.0	5.48E-05			
38SR 90	1.00E-04	2.51E-02	0.0	6.40E-03	0.0	0.0	0.0	2.43E-04			

HC65

Table 4.9c

39Y	90	6.00E-05	8.97E-08	0.0	2.41E-09	0.0	0.0	0.0	1.29E-04
39Y	91	1.04E-03	1.25E-06	0.0	3.33E-08	0.0	0.0	0.0	8.27E-05
40ZR	95	1.20E-04	2.11E-07	5.32E-08	3.78E-04	0.0	1.54E-05	0.0	2.38E-05
41NB	95	1.20E-04	3.89E-08	1.75E-08	1.03E-08	0.0	3.43E-09	0.0	1.40E-05
44RU	103	6.00E-04	1.41E-06	0.0	4.85E-07	0.0	7.07E-07	0.0	1.76E-05
44RU	106	4.80E-03	2.54E-05	0.0	3.12E-06	0.0	5.32E-06	0.0	1.97E-04
52TE	129M	6.20E-04	1.05E-04	3.61E-05	1.60E-05	3.95E-05	4.80E-05	0.0	6.33E-05
53I	131	5.80E-02	3.42E-05	4.07E-05	2.38E-05	1.31E-02	1.02E-05	0.0	1.53E-06
52TE	132	8.00E-05	2.13E-05	1.05E-05	9.76E-06	1.55E-05	1.58E-05	0.0	8.08E-05
53I	133	3.40E-02	1.26E-05	1.84E-05	5.58E-06	2.35E-03	4.33E-06	0.0	3.27E-06
55CS	134	2.60E-02	4.58E-04	8.24E-04	6.97E-05	0.0	4.80E-05	9.42E-05	1.96E-06
55CS	137	5.00E-02	6.53E-04	7.31E-04	4.20E-05	0.0	3.71E-05	8.81E-05	1.89E-06
56BA	140	5.40E-03	1.74E-04	1.75E-07	8.99E-06	0.0	8.68E-09	1.07E-07	4.43E-06
57LA	140	4.40E-03	2.12E-08	8.37E-09	2.16E-09	0.0	0.0	0.0	1.04E-04
58CE	141	5.00E-04	8.00E-08	4.91E-08	5.75E-09	0.0	2.94E-09	0.0	2.38E-05
58CE	144	1.04E-02	4.49E-06	1.77E-06	2.42E-07	0.0	1.21E-07	0.0	1.85E-04
IH	3	8.60E+01	0.0	3.07E-07	3.07E-07	3.07E-07	1.34E-07	3.07E-07	3.07E-07

CASE 1

TOTAL NUMBER IN SOURCE TERM IS 58 TOTAL RELEASE IS 8.6460E+01

ADULT DOSES

DOSE (MREM PER YEAR INTAKE)

PATHWAY	SKIN	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
FISH		6.68E-01	1.26E-01	5.66E-02	4.67E-02	9.42E-03	7.47E-02	1.16E-01
INVERTEBRATE		2.01E-01	1.44E-01	4.97E-02	5.80E-02	5.22E-02	1.15E-01	1.72E-01
SHORELINE	9.26E-04	7.91E-04	7.91E-04	7.91E-04	7.91E-04	7.91E-04	7.91E-04	7.91E-04
SWIMMING	0.0	1.10E-04	1.10E-04	1.10E-04	1.10E-04	1.10E-04	1.10E-04	1.10E-04
BOATING	0.0	2.38E-05	2.38E-05	2.38E-05	2.38E-05	2.38E-05	2.38E-05	2.38E-05
TOTAL	9.26E-04	8.70E-01	2.70E-01	1.07E-01	1.06E-01	6.25E-02	1.91E-01	2.88E-01

USAGE (KG/YR, HR/YR)

FISH	21.0
INVERTEBRATE	5.0
SHORELINE	12.0
SWIMMING	120.0
BOATING	52.0

DILUTION

TIME (HR)

10.0	34.00
10.0	34.00
10.0	10.00
10.0	10.00
10.0	10.00

SHOREWIDTH FACTOR = 0.2

0.5

ISOTOPE CONTRIBUTION

PATHWAY	SKIN	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
FISH	P 32 96%	P 32 32%	P 32 43%	I 131 94%	MN 54 1%	FE 55 96%	P 32 62%	
	FE 55 2%	FE 55 49%	FE 55 28%	I 133 4%	ZN 65 32%	CS 137 1%	FE 55 21%	
	CS 137 1%	ZN 65 3%	ZN 65 3%	CS 134 9%	I 131 2%	CS 134 23%	FE 59 1%	
		CS 134 5%	CS 134 9%	CS 137 34%	CS 134 23%	CS 137 34%	CO 60 3%	
		CS 137 7%	CS 137 11%	H 3 4%		ZN 65 2%	NB 95 2%	
INVERTEBRATE	P 32 78%	P 32 6%	P 32 12%	TE 129M 4%	ZN 65 34%	FE 55 99%	P 32 10%	
	FE 55 10%	FE 55 68%	FE 55 52%	I 131 90%	TE 129M 57%		FE 55 22%	
	ZN 65 4%	ZN 65 18%	CO 60 2%	I 133 4%	TE 131M 2%		FE 59 1%	
	TE 129M 3%	TE 129M 1%	ZN 65 2%		TE 132 1%		CO 58 1%	
			TE 129M 2%				CO 60 5%	
			CS 134 1%				ZN 65 10%	
		CS 137 1%				ZN 69M 2%		
						RU 1 6 5%		
						TE 129M 21%		
						TE 131M 6%		
						TE 132 2%		
						LA 140 1%		
						CE 144 6%		
SHORELINE	CO 60 42%	CO 60 42%						
	CS 134 14%	CS 134 14%						
	CS 137 41%	CS 137 42%						
SWIM	NA 24 11%							
	MN 54 1%							
	CO 58 4%							
	CO 60 25%							
	CU 64 1%							
	NP 239 1%							
	MO 99 1%							
	I 131 9%							

HCQS

Table 4.9e

I 133 5X
CS 134 17X
I 135 1X
CS 137 11X
LA 140 3X

TEENAGER DOSES

DOSE (MPREM PER YEAR INTAKE)

PATHWAY	SKIN	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
FISH		5.12E-01	9.96E-02	4.08E-02	4.16E-02	7.18E-03	5.76E-02	8.71E-02
INVERTEBRATE		1.54E-01	1.11E-01	3.82E-02	5.19E-02	3.97E-02	8.78E-02	1.29E-01
SHORELINE	5.17E-03	4.41E-03	4.41E-03	4.41E-03	4.41E-03	4.41E-03	4.41E-03	4.41E-03
SWIMMING	0.0	2.20E-04	2.20E-04	2.20E-04	2.20E-04	2.20E-04	2.20E-04	2.20E-04
BOATING	0.0	2.38E-05	2.38E-05	2.38E-05	2.38E-05	2.38E-05	2.38E-05	2.38E-05
TOTAL	5.17E-03	6.71E-01	2.15E-01	8.36E-02	9.81E-02	5.15E-02	1.50E-01	2.21E-01

	USAGE (KG/YR,HR/YR)	DILUTION	TIME(HR)	SHOREWIDTH FACTOR=0.2
FISH	16.0	10.0	34.00	
INVERTEBRATE	3.8	10.0	34.00	
SHORELINE	67.0	10.0	10.00	
SWIMMING	240.0	10.0	10.00	
BOATING	52.0	10.0	10.00	

* * * ISOTOPE CONTRIBUTION * * *

PATHWAY	SKIN	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
FISH	P 32 95%	P 32 95%	P 32 30%	P 32 46%	I 131 93%	MN 54 1%	FE 55 95%	P 32 63%
	FE 55 2%	FE 55 2%	FE 55 47%	FE 55 30%	I 131 5%	ZN 65 32%	CS 134 1%	FE 55 21%
	CS 137 1%	CS 137 1%	ZN 65 3%	CO 60 1%	I 131 2%	I 131 2%	CS 137 2%	FE 59 1%
			CS 134 6%	ZN 65 3%	CS 134 23%	CS 134 23%	CS 137 2%	CO 60 3%
INVERTEBRATE			CS 137 9%	CS 134 7%	CS 137 8%	H 3 4%		ZN 65 2%
								NB 95 2%
	P 32 77%	P 32 77%	P 32 6%	P 32 12%	TE 129M 4%	ZN 65 34%	FE 55 99%	P 32 10%
	FE 55 10%	FE 55 10%	FE 55 67%	FE 55 51%	I 131 89%	TE 129M 57%		FE 55 22%
	ZN 65 4%	ZN 65 4%	ZN 65 18%	CO 60 3%	I 133 5%	TE 131M 2%		FE 59 1%
	TE 129M 5%	TE 129M 5%	TE 129M 2%	ZN 65 24%		TE 132 1%		CO 60 4%
			CS 137 1%	TE 129M 3%				ZN 65 10%
				CS 134 1%				ZN 69M 2%
				CS 137 1%				RU 1 6 5%
								TE 129M 21%
							TE 131M 6%	
							TE 132 2%	
							LA 140 1%	
							CE 144 6%	

SHORELINE	CO 60 42%	CO 60 42%
	CS 134 14%	CS 134 14%
	CS 137 41%	CS 137 42%

SWIM	NA 24 11%
	MN 54 1%
	CO 58 4%
	CO 60 25%
	CU 64 1%
	N ² 39 1%
	MO 99 1%
	I 131 9%
	I 133 5%

SKIN	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI_LLI
SWIM (con't)	Cs 134		17%				
	I 135		1%				
	Cs 137		11%				
	La 140		3%				

CHILD DOSES

DOSE (MREM PER YEAR INTAKE)

PATHWAY	SKIN	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
FISH		2.29E-01	5.05E-02	1.78E-02	4.33E-02	3.09E-03	2.57E-02	3.73E-02
INVERTEBRATE		7.80E-02	5.28E-02	1.92E-02	5.67E-02	1.77E-02	3.94E-02	5.80E-02
SHORELINE	1.08E-03	9.22E-04	9.22E-04	9.22E-04	9.22E-04	9.22E-04	9.22E-04	9.22E-04
SWIMMING	0.0	1.10E-04	1.10E-04	1.10E-04	1.10E-04	1.10E-04	1.10E-04	1.10E-04
BOATING	0.0	1.33E-05	1.33E-05	1.33E-05	1.33E-05	1.33E-05	1.33E-05	1.33E-05
TOTAL	1.08E-03	3.08E-01	1.04E-01	3.81E-02	1.01E-01	2.19E-02	6.62E-02	9.63E-02

PATHWAY	USAGE (KG/YR,HR/YR)	DILUTION	TIME (HR)	SHOREWIDTH FACTOR=0.2
FISH	6.9	10.0	34.00	
INVERTEBRATE	1.7	10.0	34.00	
SHORELINE	14.0	10.0	10.00	
SWIMMING	120.0	10.0	10.00	
BOATING	29.0	10.0	10.00	

* * * ISOTOPE CONTRIBUTION * * *

PATHWAY	SKIN	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
FISH	P 32 92%	P 32 26%	P 32 45%	I 131 92%	MN 54 1%	FE 55 92%	P 32 63%	
	FE 55 1%	FE 55 40%	FE 55 30%	I 133 6%	ZN 65 32%	CS 134 2%	FE 55 21%	
	CS 134 1%	ZN 65 2%	CO 60 3%	I 131 2%	CS 137 3%	FE 59 1%		
	CS 137 3%	CS 134 11%	ZN 65 3%	CS 134 23%	CS 137 34%	CO 60 2%		
		CS 137 17%	CS 134 6%	CS 137 34%	H 3 4%	ZN 65 2%		
			H 3 1%			NB 95 1%		

INVERTEBRATE	P 32 68%	P 32 6%	P 32 10%	TE 129M 5%	ZN 65 34%	FE 55 98%	P 32 10%
	FE 55 9%	FE 55 63%	FE 55 46%	I 131 87%	TE 129M 57%		FE 55 22%
	ZN 65 3%	ZN 65 17%	CO 58 1%	I 133 6%	TE 131M 2%		FE 59 1%
	TE 129M 13%	TE 129M 5%	CO 60 6%		TE 132 1%		CO 60 4%
	CS 137 1%	CS 134 1%	ZN 65 21%				ZN 65 10%
		CS 137 2%	TE 129M 8%				ZN 69M 2%

SHORELINE	CO 60 42%	CO 60 42%
	CS 134 14%	CS 134 14%
	CS 137 41%	CS 137 42%

SWIM	NA 24 11%
	MN 54 1%
	CO 58 4%
	CO 60 25%
	CU 64 1%
	NP 239 1%
	MO 99 1%
	I 131 9%

Swim (cont)

I 133 54
CS 134 174
I 135 14
CS 137 114
LA 140 34

1

SPORTFISH HARVEST

DOSE(MAN-REM)

PATHWAY	AGE GROUP	USAGE	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
FISH	ADULT	2.12E+05	1.47E+00	3.47E-01	1.51E-01	7.40E-02	2.81E-02	2.29E-01	2.80E-01
FISH	TEENAGER	3.38E+04	2.36E-01	5.81E-02	2.26E-02	1.37E-02	4.50E-03	3.70E-02	4.41E-02
FISH	CHILD	2.05E+04	1.50E-01	4.19E-02	1.38E-02	1.97E-02	2.72E-03	2.31E-02	2.65E-02
FISH	TOTAL	2.66E+05	1.86E+00	4.47E-01	1.87E-01	1.07E-01	3.53E-02	2.89E-01	3.51E-01

DILUTION	CATCH	TIME(HR)	INCLUDES FOOD PROCESSING TIME OF 1.68E+02 HR	POPULATION=4.65E+04
0.44E+05	0.19E+04	0.37E+03	370-1680	200
0.19E+03	0.35E+04	0.33E+03	230	160
0.13E+03	0.45E+04	0.29E+03		122
0.14E+02	0.61E+04	0.23E+03		60
0.51E+01	0.93E+04	0.19E+03		20
0.45E+01	0.12E+05	0.18E+03		10
0.78E+01	0.20E+05	0.22E+03		50
0.96E+02	0.46E+05	0.27E+03		100
0.30E+03	0.78E+05	0.33E+03		160
0.15E+04	0.85E+05	0.40E+03		230

AVERAGE INDIVIDUAL CONSUMPTION (KG/YR) ADULT=6.90E+00 TEEN=5.20E+00 CHILD=2.20E+00

* * * ISOTOPE CONTRIBUTION * * *

AGE GROUP	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
ADULT	P 32 94%	P 32 25%	P 32 35%	I 131 98%	MN 54 1%	FE 55 96%	P 32 55%
	FE 55 2%	FE 55 55%	FE 55 33%	H 3 1%	ZN 65 32%	CS 137 1%	MN 54 1%
	CS 137 1%	ZN 65 3%	CO 60 1%		I 131 1%		FE 55 26%
		CS 134 5%	ZN 65 4%		CS 134 23%		FE 59 2%
		CS 137 8%	CS 134 11%		CS 137 35%		CO 60 4%
			CS 137 12%		H 3 4%		ZN 65 3%
							NB 95 3%
TEENAGER	P 32 94%	P 32 23%	P 32 38%	I 131 98%	MN 54 1%	FE 55 95%	P 32 56%
	FE 55 2%	FE 55 52%	FE 55 35%	H 3 1%	ZN 65 32%	CS 134 1%	MN 54 1%
	CS 137 1%	ZN 65 3%	CO 60 1%		I 131 1%	CS 137 2%	FE 55 27%
		CS 134 7%	ZN 65 4%		CS 134 23%		FE 59 2%
		CS 137 10%	CS 134 8%		CS 137 35%		CO 60 3%
			CS 137 9%		H 3 4%		ZN 65 3%
							NB 95 2%
CHILD	P 32 89%	P 32 20%	P 32 37%	I 131 98%	MN 54 1%	FE 55 92%	P 32 57%
	FE 55 2%	FE 55 44%	FE 55 35%	H 3 1%	ZN 65 32%	CS 134 2%	MN 54 1%
	CS 134 2%	ZN 65 3%	CO 60 3%		I 131 1%	CS 137 3%	FE 55 27%
	CS 137 5%	CS 134 12%	ZN 65 4%		CS 134 23%		FE 59 2%
		CS 137 18%	CS 134 7%		CS 137 35%		CO 60 3%
			CS 137 8%		H 3 4%		ZN 65 3%
			H 3 1%				NB 95 2%

COMMERCIAL HARVEST

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
FISH	ADULT	3.14E+07	2.28E-01	5.97E-02	2.55E-02	1.02E-02	4.97E-03	4.07E-02	4.59E-02
FISH	TEENAGER	5.02E+06	3.68E-02	9.99E-03	3.81E-03	1.89E-03	7.95E-04	6.58E-03	7.22E-03
FISH	CHILD	3.04E+06	2.35E-02	7.25E-03	2.33E-03	2.72E-03	4.81E-04	4.11E-03	4.33E-03
FISH	TOTAL	3.95E+07	2.88E-01	7.69E-02	3.16E-02	1.48E-02	6.25E-03	5.14E-02	5.75E-02

DILUTION CATCH TIME (HR) - INCLUDES FOOD PROCESSING TIME OF 2.40E+02 HR POPULATION=6.90E+06

0.44E+05	0.55E+04	0.45E+03	280
0.19E+03	0.10E+05	0.40E+03	450
0.13E+03	0.13E+05	0.36E+03	210
0.14E+02	0.18E+05	0.31E+03	170
0.51E+01	0.28E+05	0.26E+03	120
0.45E+01	0.35E+05	0.26E+03	90
0.78E+01	0.59E+05	0.29E+03	170
0.96E+02	0.14E+06	0.34E+03	230
0.30E+03	0.23E+06	0.40E+03	300
0.15E+04	0.25E+06	0.47E+03	

AVERAGE INDIVIDUAL CONSUMPTION (KG/YR): ADULT=6.90E+00 TEEN=5.20E+00 CHILD=2.20E+00

ISOTOPE CONTRIBUTION

AGE GROUP	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
ADULT	P 32 93%	P 32 22%	P 32 32%	I 131 97%	MN 54 1%	FE 55 96%	P 32 52%
	FE 55 3%	FE 55 56%	FE 55 35%	H 3 2%	ZN 65 32%	CS 137 1%	MN 54 1%
	CS 137 1%	ZN 65 4%	CO 60 1%	I 131 1%	CS 134 23%		FE 55 28%
		CS 134 6%	ZN 65 4%	CS 137 35%			FE 59 2%
		CS 137 8%	CS 134 11%				CO 60 5%
			CS 137 13%		H 3 5%		ZN 65 3%
							NB 95 3%
TEENAGER	P 32 93%	P 32 21%	P 32 34%	I 131 98%	MN 54 1%	FE 55 95%	P 32 53%
	FE 55 3%	FE 55 54%	FE 55 37%	H 3 1%	ZN 65 32%	CS 134 1%	MN 54 1%
	CS 137 2%	ZN 65 3%	CO 60 1%	I 131 1%	CS 137 2%		FE 55 29%
		CS 134 7%	ZN 65 4%	CS 134 23%			FE 59 2%
		CS 137 11%	CS 134 9%	CS 137 35%			CO 60 4%
			CS 137 10%		H 3 5%		ZN 65 3%
							NB 95 2%
CHILD	P 32 87%	P 32 17%	P 32 34%	I 131 98%	MN 54 1%	FE 55 92%	P 32 53%
	FE 55 3%	FE 55 45%	FE 55 37%	H 3 1%	ZN 65 32%	CS 134 2%	MN 54 1%
	CS 134 2%	ZN 65 3%	CO 60 3%	I 131 1%	CS 137 4%		FE 55 29%
	CS 137 6%	CS 134 12%	ZN 65 4%	CS 134 23%			FE 59 2%
		CS 137 19%	CS 134 8%	CS 137 35%			CO 60 3%
			CS 137 8%		H 3 5%		ZN 65 3%
			H 3 1%				NB 95 2%

NEPA DOSES

ORTFISH HARVEST

Table 4.9a

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
INVER	ADULT	3.10E+04	2.85E-01	2.63E-01	8.89E-02	5.74E-02	8.59E-02	2.17E-01	2.59E-01
INVER	TEENAGER	4.93E+03	4.62E-02	4.24E-02	1.43E-02	1.07E-02	1.37E-02	3.46E-02	4.08E-02
INVER	CHILD	3.10E+03	3.34E-02	2.82E-02	1.00E-02	1.65E-02	8.59E-03	2.18E-02	2.56E-02
INVER	TOTAL	3.90E+04	3.64E-01	3.33E-01	1.13E-01	8.46E-02	1.08E-01	2.73E-01	3.26E-01

DILUTION CATCH TIME (HR) - INCLUDES FOOD PROCESSING TIME OF 1.68E+02 HR POPULATION=4.69E+04

0.44E+05	0.27E+03	0.37E+03	200
0.19E+03	0.51E+03	0.33E+03	160
0.13E+03	0.66E+03	0.29E+03	120
0.14E+02	0.90E+03	0.23E+03	60
0.51E+01	0.14E+04	0.19E+03	30
0.45E+01	0.17E+04	0.18E+03	30
0.78E+01	0.29E+04	0.22E+03	30
0.96E+02	0.68E+04	0.27E+03	100
0.30E+03	0.11E+05	0.33E+03	160
0.15E+04	0.12E+05	0.40E+03	230

Invest - spot OK
1/20/70

AVERAGE INDIVIDUAL CONSUMPTION (KG/YR) ADULT=1.00E+00 TEEN=7.50E-01 CHILD=3.30E-01

ISOTOPE CONTRIBUTION

Table 4.9b

AGE GROUP	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
ADULT	P 32 73%	P 32 5%	P 32 9%	TE 129M 7%	ZN 65 39%	FE 55 99%	P 32 9%
	FE 55 14%	FE 55 71%	FE 55 55%	I 131 92%	TE 129M 57%		FE 55 28%
	ZN 65 5%	ZN 65 19%	CO 60 2%		CS 137 1%		FE 59 2%
	TE 129M 4%	TE 129M 1%	ZN 65 25%				CO 58 1%
		CS 137 1%	TE 129M 2%				CO 60 7%
			CS 134 1%				ZN 65 12%
			CS 137 1%				RU 1 6 6%
							TE 129M 22%
							CE 144 7%
TEENAGER	P 32 72%	P 32 4%	P 32 9%	TE 129M 8%	ZN 65 39%	FE 55 99%	P 32 9%
	FE 55 14%	FE 55 70%	FE 55 54%	I 131 91%	TE 129M 57%		FE 55 28%
	ZN 65 5%	ZN 65 18%	CO 60 3%		CS 137 1%		FE 59 2%
	TE 129M 5%	TE 129M 2%	ZN 65 25%				CO 58 1%
		CS 137 1%	TE 129M 2%				CO 60 6%
			CS 134 1%				ZN 65 12%
			CS 137 1%				RU 1 6 6%
							TE 129M 23%
							CE 144 8%
CHILD	P 32 63%	P 32 4%	P 32 8%	TE 129M 9%	ZN 65 39%	FE 55 98%	P 32 9%
	FE 55 12%	FE 55 66%	FE 55 48%	I 131 89%	TE 129M 57%		FE 55 28%
	ZN 65 4%	ZN 65 17%	CO 58 1%		CS 137 1%		FE 59 2%
	TE 129M 15%	TE 129M 5%	CO 60 7%				CO 60 5%
	CS 137 2%	CS 134 1%	ZN 65 22%				ZN 65 12%
		CS 137 2%	TE 129M 7%				RU 1 6 6%
			CS 134 1%				TE 129M 23%
			CS 137 1%				CE 144 8%

COMMERCIAL HARVEST

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
INVER	ADULT	4.55E+06	1.46E-01	1.49E-01	5.01E-02	2.58E-02	4.73E-02	1.24E-01	1.43E-01
INVER	TEENAGER	7.24E+05	2.38E-02	2.40E-02	8.04E-03	4.84E-03	7.52E-03	1.98E-02	2.25E-02
INVER	CHILD	4.55E+05	1.73E-02	1.60E-02	5.63E-03	7.44E-03	4.73E-03	1.25E-02	1.41E-02
INVER	TOTAL	5.73E+06	1.87E-01	1.89E-01	6.37E-02	3.81E-02	5.95E-02	1.57E-01	1.80E-01

DILUTION CATCH TIME (HR) - INCLUDES FOOD PROCESSING TIME OF 2.40E+02 HR POPULATION = 6.90E+06

0.44E+05	0.11E+05	0.45E+03
0.19E+03	0.21E+05	0.40E+03
0.13E+03	0.27E+05	0.36E+03
0.14E+02	0.37E+05	0.31E+03
0.51E+01	0.56E+05	0.26E+03
0.45E+01	0.70E+05	0.26E+03
0.78E+01	0.12E+06	0.29E+03
0.96E+02	0.28E+06	0.34E+03
0.30E+03	0.47E+06	0.40E+03
0.15E+04	0.51E+06	0.47E+03

Handwritten notes: 250, 250, 1400, 900, 1700, 2300, 3000. A large arrow points downwards.

Commercial harvest

AVERAGE INDIVIDUAL CONSUMPTION (KG/YR) ADULT=1.00E+00 TEEN=7.50E-01 CHILD=3.30E-01

* * * ISOTOPE CONTRIBUTION * * *

AGE GROUP	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
ADULT	P 32 71% FE 55 16% ZN 65 6% TE 129M 4%	P 32 4% FE 55 71% ZN 65 19% TE 129M 1% CS 137 1%	P 32 8% FE 55 56% CO 60 2% ZN 65 25% TE 129M 2% CS 134 1% CS 137 2%	TE 129M 8% I 131 91%	ZN 65 40% TE 129M 56% CS 137 1%	FE 55 99%	P 32 8% FE 55 29% FE 59 2% CO 58 1% CO 60 7% ZN 65 12% RU 1 6 6% TE 129M 22% CE 144 7%
TEENAGER	P 32 69% FE 55 15% ZN 65 6% TE 129M 6% CS 137 1%	P 32 4% FE 55 70% ZN 65 19% TE 129M 2% CS 137 1%	P 32 7% FE 55 55% CO 60 3% ZN 65 25% TE 129M 2% CS 134 1% CS 137 1%	TE 129M 9% I 131 89%	ZN 65 40% TE 129M 56% CS 137 1%	FE 55 99%	P 32 8% FE 55 29% FE 59 2% CO 58 1% CO 60 6% ZN 65 12% RU 1 6 6% TE 129M 22% CE 144 8%
CHILD	P 32 60% FE 55 13% ZN 65 5% TE 129M 15% CS 137 2%	P 32 4% FE 55 66% ZN 65 17% TE 129M 4% CS 134 1% CS 137 2%	P 32 7% FE 55 49% CO 58 1% CO 60 7% ZN 65 23% TE 129M 7% CS 134 1%	TE 129M 11% I 131 87%	ZN 65 40% TE 129M 56% CS 137 1%	FE 55 98%	P 32 8% FE 55 29% FE 59 2% CO 60 5% ZN 65 12% RU 1 6 6% TE 129M 2%

NEPA DOSES

Table 4.9q

CASE 1

NOTE TOTAL NEPA DOSE MUST INCLUDE SPORT CATCH

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
INVER	ADULT	1.27E+06	1.05E+01	1.06E+01	3.58E+00	1.85E+00	3.38E+00	8.89E+00	1.02E+01
INVER	TEENAGER	2.02E+05	1.70E+00	1.72E+00	5.75E-01	3.46E-01	5.38E-01	1.42E+00	1.61E+00
INVER	CHILD	1.27E+05	1.24E+00	1.14E+00	4.03E-01	5.32E-01	3.38E-01	8.93E-01	1.01E+00
INVER	TOTAL	1.60E+06	1.34E+01	1.35E+01	4.56E+00	2.73E+00	4.26E+00	1.12E+01	1.29E+01

DILUTION	CATCH	TIME(HR)	INCLUDES FOOD PROCESSING TIME OF 2.40E+02 HR	POPULATION=1.93E+06
0.44E+05	0.11E+05	0.45E+03	220	
0.19E+03	0.21E+05	0.40E+03	230	
0.13E+03	0.27E+05	0.36E+03	180	
0.14E+02	0.37E+05	0.31E+03	170	
0.51E+01	0.56E+05	0.26E+03	100	
0.45E+01	0.70E+05	0.26E+03	100	
0.78E+01	0.12E+06	0.29E+03	120	
0.96E+02	0.28E+06	0.34E+03	70	
0.30E+03	0.47E+06	0.40E+03	230	
0.15E+04	0.51E+06	0.47E+03	300	

NEPA Invert

AVERAGE INDIVIDUAL CONSUMPTION (KG/YR) ADULT=1.0GE+00 TEEN=7.50E-01 CHILD=3.30E-01

Table 4.9r

* * * POPULATION WATER CONSUMPTION DOSES * * *

HYDROSPHERE TRITIUM DOSE

CASE 1

PATHWAY	AGE GROUP	USAGE	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
WATER	TOTAL	2.20E+00	2.82E-10	2.82E-10					

----- DOSE (MAN-REM) -----

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SHORELINE	TOTAL POPUL	3.68E+05	6.41E-06	5.48E-06	5.48E-06

LOCATION- REGION U5

DILUTION=0.44E+05 TRANSIT TIME=0.21E+03 HR SWF=0.2

* * * ISOTOPE CONTRIBUTION * * *

AGE GROUP	SKIN	TOTAL BODY
-----------	------	------------

ADULT

CO 60	42%	CO 60	42%
CS 134	14%	CS 134	14%
CS 137	42%	CS 137	42%

----- DOSE (MAN-REM) -----

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SHORELINE	TOTAL POPUL	3.40E+05	1.36E-03	1.16E-03	1.16E-03

LOCATION- REGION U4

DILUTION=0.19E+03 *1900* TRANSIT TIME=0.16E+03 HR SWF=0.2 *0.5*

----- DOSE (MAN-REM) -----

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SHORELINE	TOTAL POPUL	3.68E+05	2.15E-03	1.83E-03	1.83E-03

LOCATION- REGION U3

DILUTION=0.13E+03 *1300* TRANSIT TIME=0.12E+03 HR SWF=0.2

----- DOSE (MAN-REM) -----

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SHORELINE	TOTAL POPUL	3.68E+05	1.97E-02	1.68E-02	1.68E-02

LOCATION- REGION U2

DILUTION=0.14E+02 *140* TRANSIT TIME=0.67E+02 HR SWF=0.2

----- DOSE (MAN-REM) -----

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SHORELINE	TOTAL POPUL	4.00E+05	6.05E-02	5.17E-02	5.17E-02

LOCATION- REGION U1

DILUTION=0.51E+01 *5.1* TRANSIT TIME=0.22E+02 HR SWF=0.2

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SHORELINE	TOTAL POPUL	3.40E+05	5.83E-02	4.98E-02	4.98E-02

CASE 1

LOCATION- REGION D1
 DILUTION=0.45E+01 TRANSIT TIME=0.17E+02 HR SWF=0.2

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SHORELINE	TOTAL POPUL	4.60E+05	4.55E-02	3.88E-02	3.88E-02

LOCATION- REGION D2
 DILUTION=0.78E+01 TRANSIT TIME=0.47E+02 HR SWF=0.2

7.8

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SHORELINE	TOTAL POPUL	3.64E+05	2.92E-03	2.49E-03	2.49E-03

LOCATION- REGION D3
 DILUTION=0.96E+02 TRANSIT TIME=0.10E+03 HR SWF=0.2

96

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SHORELINE	TOTAL POPUL	4.36E+05	1.13E-03	9.64E-04	9.64E-04

LOCATION- REGION D4
 DILUTION=0.30E+03 TRANSIT TIME=0.16E+03 HR SWF=0.2

3000

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SHORELINE	TOTAL POPUL	5.56E+05	2.79E-04	2.38E-04	2.38E-04

LOCATION- REGION D5
 DILUTION=0.15E+04 TRANSIT TIME=0.23E+03 HR SWF=0.2

15000

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SWIMMING	TOTAL POPUL	2.02E+05	0.0	2.84E-08	2.84E-08

LOCATION- 0.2 RE
 DILUTION=0.44E+05 TRANSIT TIME=0.21E+03 HR

44000

• • • ISOTOPE CONTRIBUTION • • •

Table 4.9t

HCGS

AGE GROUP SKIN TOTAL BODY

ADULT

CR 51 1%
 MN 54 1%
 CO 58 6%
 CO 60 37%
 ZN 65 1%
 I 13i 7%
 CS 134 25%
 CS 137 16%

CASE 1

DOSE (MAN-REM)

PATHWAY AGE GROUP USAGE SKIN TOTAL BODY THYROID
 SWIMMING TOTAL POPUL 1.87E+05 0.0 6.16E-06 6.16E-06
 LOCATION- 0.2 RE
 DILUTION=0.19E+03 TRANSIT TIME=0.16E+03 HR
 190

DOSE (MAN-REM)

PATHWAY AGE GROUP USAGE SKIN TOTAL BODY THYROID
 SWIMMING TOTAL POPUL 2.02E+05 0.0 9.94E-06 9.94E-06
 LOCATION- 0.2 RE
 DILUTION=0.13E+03 TRANSIT TIME=0.12E+03 HR
 130

DOSE (MAN-REM)

PATHWAY AGE GROUP USAGE SKIN TOTAL BODY THYROID
 SWIMMING TOTAL POPUL 2.02E+05 0.0 9.75E-05 9.75E-05
 LOCATION- 0.2 RE
 DILUTION=0.14E+02 TRANSIT TIME=0.67E+02 HR
 14

DOSE (MAN-REM)

PATHWAY AGE GROUP USAGE SKIN TOTAL BODY THYROID
 SWIMMING TOTAL POPUL 2.20E+05 0.0 3.54E-04 3.54E-04
 LOCATION- 0.2 RE
 DILUTION=0.51E+01 TRANSIT TIME=0.22E+02 HR
 5.1

DOSE (MAN-REM)

PATHWAY AGE GROUP USAGE SKIN TOTAL BODY THYROID
 SWIMMING TOTAL POPUL 1.87E+05 0.0 3.56E-04 3.56E-04
 LOCATION- 0.2 RE
 DILUTION=0.45E+01 TRANSIT TIME=0.17E+02 HR
 4.5

Table 4.9u

HCGS

(MAN-REM)

CASE 1

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SWIMMING	TOTAL POPUL	2.53E+05	0.0	2.36E-04	2.36E-04

LOCATION- 0.2 RE

DILUTION=0.78E+01 TRANSIT TIME=0.47E+02 HR

7.8

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SWIMMING	TOTAL POPUL	2.02E+05	0.0	1.39E-05	1.39E-05

LOCATION- 0.2 RE

DILUTION=0.96E+02 TRANSIT TIME=0.10E+03 HR

96

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SWIMMING	TOTAL POPUL	2.40E+05	0.0	5.10E-06	5.10E-06

LOCATION- 0.2 RE

DILUTION=0.30E+03 TRANSIT TIME=0.16E+03 HR

300

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
SWIMMING	TOTAL POPUL	3.06E+05	0.0	1.22E-06	1.22E-06

LOCATION- 0.2 RE

DILUTION=0.15E+04 TRANSIT TIME=0.23E+03 HR

1500

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
BOATING	TOTAL POPUL	6.72E+03	0.0	4.71E-10	4.71E-10

LOCATION- 0.2 RE

DILUTION=0.44E+05 TRANSIT TIME=0.21E+03 HR

DOSE (MAN-REM)

PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
BOATING	TOTAL POPUL	1.25E+04	0.0	2.06E-07	2.06E-07

LOCATION- 0.2 RE

DILUTION=0.19E+03 TRANSIT TIME=0.15E+03 HR

Table 4.9v

HCGS

DOSE (MAN-REM)

PATHWAY AGE GROUP USAGE SKIN TOTAL BODY THYROID
 BOATING TOTAL POPUL 1.63E+04 0.0 4.01E-07 4.01E-07

LOCATION- 0.2 RE

DILUTION=0.13E+03 TRANSIT TIME=0.12E+03 HR

DOSE (MAN-REM)

PATHWAY AGE GROUP USAGE SKIN TOTAL BODY THYROID
 BOATING TOTAL POPUL 2.21E+04 0.0 5.32E-06 5.32E-06

LOCATION- 0.2 RE

DILUTION=0.14E+02 TRANSIT TIME=0.67E+02 HR

DOSE (MAN-REM)

PATHWAY AGE GROUP USAGE SKIN TOTAL BODY THYROID
 BOATING TOTAL POPUL 3.36E+04 0.0 2.70E-05 2.70E-05

LOCATION- 0.2 RE

DILUTION=0.51E+01 TRANSIT TIME=0.22E+02 HR

DOSE (MAN-REM)

PATHWAY AGE GROUP USAGE SKIN TOTAL BODY THYROID
 BOATING TOTAL POPUL 4.22E+04 0.0 4.02E-05 4.02E-05

LOCATION- 0.2 RE

DILUTION=0.45E+01 TRANSIT TIME=0.17E+02 HR

DOSE (MAN-REM)

PATHWAY AGE GROUP USAGE SKIN TOTAL BODY THYROID
 BOATING TOTAL POPUL 7.20E+04 0.0 3.36E-05 3.36E-05

LOCATION- 0.2 RE

DILUTION=0.78E+01 TRANSIT TIME=0.47E+02 HR

DOSE (MAN-REM)

PATHWAY AGE GROUP USAGE SKIN TOTAL BODY THYROID
 BOATING TOTAL POPUL 1.67E+05 0.0 5.75E-06 5.75E-06

LOCATION- 0.2 RE

DILUTION=0.96E+02 TRANSIT TIME=0.10E+03 HR

DOSE (MAN-REM)

PATHWAY AGE GROUP USAGE SKIN TOTAL BODY THYROID

BCGS

Table 4.9a

BOATING TOTAL POPUL 2.81E+05 0.0 2.99E-06

SE 1

LOCATION- 0.2 RE

DILUTION=0.30E+03 TRANSIT TIME=0.16E+03 HR

DOSE (MAN-REM)


PATHWAY	AGE GROUP	USAGE	SKIN	TOTAL BODY	THYROID
BOATING	TOTAL POPUL	3.06E+05	0.0	6.11E-07	6.11E-07

LOCATION- 0.2 RE


DILUTION=0.15E+04 TRANSIT TIME=0.23E+03 HR

TI
APERTURE
CARD

Also Available On
Aperture Card



Measured from centroid of 2 units of Hope Creek
NNE



PUBLIC SERVICE ELECTRIC AND GAS COMPANY	INTAKE & DISCHARGE LOCATION
HOPE CREEK GEN. STATION	AMENDMENT 6 FIG 6.3-2

8805270103-01

NUCLIDE	RELEASE CI/YR	MAN-REM DOSE		MAN-REM PER CURIE	
		TOTAL BODY	THYROID	TOTAL BODY	THYROID
11NA 24	9.80E-03	6.65E-05	6.65E-05	6.79E-03	6.79E-03
15P 32	2.80E-03	9.34E-02	4.78E-08	3.33E+01	1.71E-05
24CR 51	7.60E-02	8.19E-05	7.18E-05	1.38E-03	9.44E-04
25MN 54	3.00E-03	8.89E-04	5.66E-04	2.96E-01	1.89E-01
25MN 56	1.16E-03	4.32E-08	4.32E-08	3.72E-05	3.72E-05
26FE 55	1.70E-02	1.71E-01	3.11E-09	1.01E+01	1.83E-07
26FE 59	4.80E-04	2.27E-03	2.01E-05	4.72E+00	4.18E-02
27CO 58	1.12E-02	1.86E-03	6.23E-04	1.66E-01	5.56E-02
27CO 60	2.40E-02	7.75E-02	6.94E-02	3.23E+00	2.89E+00
29CU 64	2.60E-02	6.94E-06	6.93E-06	2.67E-04	2.67E-04
30ZN 65	3.40E-03	5.47E-02	3.46E-04	1.61E+01	1.02E-01
30ZN 69M	1.90E-03	1.15E-06	1.14E-06	6.05E-04	6.01E-04
30ZN 69	2.00E-03	1.23E-14	1.23E-14	6.14E-12	6.14E-12
74W 187	6.40E-04	7.36E-07	7.35E-07	1.15E-03	1.15E-03
93NP 239	3.80E-02	2.34E-05	2.34E-05	6.15E-04	6.15E-04
35BR 83	6.00E-05	8.27E-12	8.27E-12	1.38E-07	1.38E-07
38SR 89	1.62E-03	1.99E-05	2.55E-08	1.23E-02	1.57E-05
38SR 90	1.00E-04	2.54E-04	1.55E-10	2.54E+00	1.55E-06
39Y 90	6.00E-05	1.69E-09	1.60E-09	2.82E-05	2.66E-05
38SR 91	2.00E-03	1.81E-06	1.81E-06	9.06E-04	9.06E-04
39Y 91M	1.34E-03	8.77E-13	8.77E-13	6.55E-10	6.55E-10
39Y 91	1.04E-03	3.67E-07	1.66E-07	3.53E-04	1.60E-04
38SR 92	2.60E-04	9.93E-09	9.93E-09	3.82E-05	3.82E-05
39Y 92	1.24E-03	2.51E-08	2.51E-08	2.03E-05	2.03E-05
39Y 93	2.20E-03	2.20E-07	2.20E-07	1.00E-04	1.00E-04
40ZR 95	1.20E-04	4.52E-04	4.48E-06	3.76E-02	3.73E-02
41NB 95	1.20E-04	3.72E-06	2.60E-06	3.10E-02	2.16E-02
42MO 99	1.28E-02	1.97E-05	1.71E-05	1.54E-03	1.33E-03
43TC 99M	1.60E-02	7.86E-07	7.86E-07	4.91E-05	4.91E-05
44RU 103	6.00E-04	1.20E-05	1.00E-05	2.00E-02	1.67E-02
44RU 105	2.00E-04	2.23E-08	2.23E-08	1.12E-04	1.12E-04
45RH 105	8.00E-04	3.10E-07	2.57E-07	3.83E-04	3.21E-04
44RU 106	4.80E-03	3.62E-04	2.77E-04	7.55E-02	5.76E-02
52TE 129M	6.20E-04	4.73E-03	1.00E-02	7.63E+00	1.62E+01
52TE 129	4.00E-04	3.03E-12	3.03E-12	7.57E-09	7.57E-09
52TE 131M	2.80E-04	6.27E-06	1.10E-05	2.24E-02	3.92E-02
52TE 131	6.00E-05	4.71E-23	4.71E-23	7.84E-19	7.84E-19
53I 131	5.80E-02	6.73E-04	2.32E-01	1.16E-02	4.01E+00
52TE 132	8.00E-05	8.00E-05	9.44E-05	1.00E+00	1.18E+00
53I 132	5.40E-04	1.50E-08	1.50E-08	2.78E-05	2.78E-05
53I 133	3.40E-02	4.03E-05	1.22E-04	1.18E-03	3.58E-03
53I 134	4.00E-05	2.29E-13	2.29E-13	5.73E-09	5.73E-09
55CS 134	2.60E-02	5.04E-02	2.40E-02	1.94E+00	9.21E-01
53I 135	4.80E-03	3.91E-06	3.91E-06	8.15E-04	8.15E-04
55CS 136	4.60E-04	6.04E-05	1.35E-05	1.31E-01	2.93E-02
55CS 137	5.00E-02	9.90E-02	6.90E-02	1.98E+00	1.38E+00
56BA 139	4.00E-05	6.47E-13	6.47E-13	1.62E-08	1.62E-08
56BA 140	5.40E-03	5.27E-05	2.07E-05	9.75E-03	3.83E-03
57LA 140	4.40E-03	3.68E-05	3.68E-05	8.36E-03	8.36E-03
57LA 141	4.00E-05	1.24E-10	1.24E-10	3.10E-06	3.10E-06
58CE 141	5.00E-04	1.07E-06	1.07E-06	2.15E-03	2.13E-03
57LA 142	2.00E-05	4.28E-11	4.28E-11	2.14E-06	2.14E-06
58CE 143	1.00E-04	1.02E-07	1.02E-07	1.02E-03	1.02E-03
59PR 143	5.80E-04	9.61E-09	2.46E-09	1.66E-05	4.25E-06
58CE 144	1.04E-02	1.08E-04	9.87E-05	1.04E-02	9.49E-03
59PR 144	4.00E-05	6.27E-30	6.27E-30	1.57E-25	1.57E-25
60ND 147	4.00E-05	7.02E-08	7.02E-08	1.77E-03	1.76E-03
1H 3	8.60E+01	2.53E-03	2.53E-03	2.94E-05	2.94E-05

Table 4.9z
TOTAL INTEGRATED MAN REM DOSE (LIQUIDS)

Total Body

Thyroid

5.61E-01

4.10E-01

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION

RECORD #	CAVIARPS INVENTORY	AND ANNUAL PATHWAY INVENTORIES-CI	LOCATED ON CASE	EMITTER	GROUP	VEGETATION	MILK	MEAT
AP 008	3.00E+01	6.10E-03	0.0	0.0	0.0	0.0	0.0	0.0
AP 009	3.00E+01	1.36E-01	0.0	0.0	0.0	0.0	0.0	0.0
AP 010	3.00E+01	4.99E+03	0.0	0.0	0.0	0.0	0.0	0.0
AP 011	3.00E+01	7.92E-02	0.0	0.0	0.0	0.0	0.0	0.0
AP 012	3.00E+01	2.76E-01	0.0	0.0	0.0	0.0	0.0	0.0
AP 013	3.00E+01	1.13E+02	0.0	0.0	0.0	0.0	0.0	0.0
AP 014	3.00E+01	1.13E+02	0.0	0.0	0.0	0.0	0.0	0.0
AP 015	3.00E+01	3.74E+03	0.0	0.0	0.0	0.0	0.0	0.0
AP 016	3.00E+01	1.60E-01	0.0	0.0	0.0	0.0	0.0	0.0
AP 017	3.00E+01	2.02E-02	2.85E-03	2.86E-07	1.07E-06	2.14E-09		
AP 018	3.00E+01	1.03E-02	9.60E-04	3.34E-24	3.60E-08	7.83E-15		
AP 019	3.00E+01	2.65E+02	0.0	1.26E-03	2.65E-04	1.09E-09		
AP 020	3.00E+01	1.51E-02	0.0	0.0	0.0	0.0	0.0	0.0
AP 021	3.00E+01	0.72E+02	0.0	3.89E-04	6.93E-05	1.33E-05		
AP 022	3.00E+01	2.82E-03	5.26E-04	1.78E-07	1.31E-08	1.57E-04		
AP 023	3.00E+01	2.37E-03	4.45E-04	6.42E-08	3.14E-10	1.59E-13		
AP 024	3.00E+01	2.32E-04	5.37E-05	1.71E-08	4.98E-10	2.12E-09		
AP 025	3.00E+01	3.76E-04	7.02E-05	2.56E-08	5.64E-10	9.93E-10		
AP 026	3.00E+01	4.06E-02	7.62E-03	2.41E-07	4.65E-05	9.56E-03		
AP 027	3.00E+01	4.85E-04	9.10E-05	2.06E-08	1.97E-06	1.79E-09		
AP 028	3.00E+01	2.59E-03	4.49E-04	1.70E-07	3.26E-05	3.22E-10		
AP 029	3.00E+01	5.00E-04	1.09E-04	2.04E-09	3.39E-11	3.40E-12		
AP 030	3.00E+01	5.72E-05	1.07E-05	4.01E-09	4.33E-13	4.09E-13		
AP 031	3.00E+01	1.43E-04	2.69E-05	1.63E-08	3.39E-10	1.23E-13		
AP 032	3.00E+01	2.53E-03	4.76E-04	3.14E-08	7.36E-05	3.97E-10		
AP 033	3.00E+01	6.37E-06	1.40E-06	1.35E-10	1.97E-10	4.52E-12		
AP 034	3.00E+01	2.05E-02	3.80E-03	6.75E-08	1.50E-08	8.52E-13		
AP 035	3.00E+01	1.14E-03	2.05E-04	2.25E-08	1.15E-09	6.32E-10		
AP 036	3.00E+01	1.62E-04	3.04E-05	1.10E-08	1.93E-10	4.50E-11		

GASPAR

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION

SITE POPULATION DATA

Hancock Bridge

DIR	0.0-1.	1.-2.	2.-3.	3.-4.	4.-5.	5.-10.	10.-20.	20.-30.	30.-40.	40.-50.	TOTAL
N	0.0	0.0	0.0	0.0	0.0	0.0	1.506E+05	2.088E+05	1.927E+05	2.255E+05	7.777E+05
NNE	0.0	0.0	0.0	0.0	6.400E+01	1.215E+04	2.386E+04	1.448E+05	1.267E+06	1.594E+06	3.042E+06
NE	0.0	0.0	1.100E+01	5.200E+01	6.980E+02	2.993E+03	1.012E+04	7.912E+04	5.032E+05	5.273E+05	1.123E+06
ENE	0.0	0.0	0.0	6.900E+01	2.120E+02	1.641E+03	9.230E+03	4.442E+04	8.304E+04	8.501E+04	2.236E+05
E	0.0	0.0	0.0	4.000E+01	0.0	1.001E+03	3.425E+04	7.690E+04	5.577E+04	2.970E+04	1.977E+05
ESE	0.0	0.0	0.0	0.0	2.300E+01	2.817E+02	1.725E+04	2.103E+04	9.572E+03	3.903E+04	8.718E+04
SE	0.0	0.0	0.0	0.0	0.0	6.100E+01	3.185E+03	1.192E+03	3.870E+02	2.761E+04	3.244E+04
SSE	0.0	0.0	0.0	0.0	0.0	9.810E+02	3.470E+02	1.351E+03	6.090E+03	8.216E+03	1.699E+04
S	0.0	0.0	0.0	0.0	3.560E+02	1.783E+03	1.907E+04	6.787E+04	1.606E+04	1.458E+04	1.107E+05
SSW	0.0	0.0	0.0	2.840E+02	5.000E+01	5.460E+03	2.038E+04	9.398E+03	1.020E+04	1.283E+04	5.861E+04
SW	0.0	0.0	0.0	0.0	4.550E+02	6.665E+03	8.849E+03	6.320E+03	7.471E+03	1.147E+04	4.123E+04
WSW	0.0	0.0	5.000E+01	5.000E+01	4.550E+02	1.582E+04	5.867E+03	3.583E+03	1.655E+04	5.867E+04	1.010E+05
W	0.0	0.0	5.000E+01	2.530E+02	5.050E+02	3.183E+04	7.307E+03	8.151E+03	1.063E+05	2.036E+05	3.580E+05
WNW	0.0	0.0	0.0	2.021E+03	4.040E+02	7.578E+03	2.382E+04	3.458E+04	5.877E+04	3.776E+04	1.649E+05
W	0.0	0.0	0.0	1.263E+03	1.865E+03	1.006E+03	9.383E+04	3.849E+04	2.085E+04	2.856E+04	1.859E+05
NW	0.0	0.0	0.0	1.010E+02	1.720E+03	1.824E+03	1.638E+05	8.800E+04	6.375E+04	3.544E+04	3.546E+05
TOTAL	0.0	0.0	1.110E+02	4.133E+03	6.805E+03	9.108E+04	5.918E+05	8.340E+05	2.418E+06	2.939E+06	6.885E+06

DENSITY1 /M**21 = 3.44E-04

Bayview Beach

Adams

50 mi tot

SITE VEGETATION PRODUCTION, KGR (INCLUDES FRUITS & VEGETABLES)

Needs adjustment for humans

DIR	0.0-1.	1.-2.	2.-3.	3.-4.	4.-5.	5.-10.	10.-20.	20.-30.	30.-40.	40.-50.	TOTAL
N	0.0	0.0	0.0	0.0	0.0	1.450E+06	1.300E+07	2.870E+05	1.690E+06	0.0	1.643E+07
NNE	0.0	0.0	0.0	0.0	1.640E+05	1.160E+07	4.070E+07	4.340E+07	1.450E+06	0.0	9.735E+07
NE	0.0	0.0	0.0	0.0	9.110E+03	1.160E+07	3.640E+07	0.0	1.580E+07	2.460E+07	8.841E+07
ENE	0.0	0.0	0.0	0.0	0.0	8.750E+06	2.760E+07	4.160E+07	1.530E+07	2.200E+07	1.152E+08
E	0.0	0.0	0.0	0.0	0.0	4.673E+06	5.440E+07	4.730E+07	2.310E+07	7.780E+06	1.372E+08
ESE	0.0	0.0	0.0	0.0	0.0	8.750E+06	6.130E+07	0.0	1.040E+07	9.610E+06	9.006E+07
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.120E+06	1.510E+07	1.622E+07
SSE	0.0	0.0	0.0	0.0	0.0	0.0	1.380E+07	1.760E+07	1.950E+07	1.290E+07	6.380E+07
S	0.0	0.0	0.0	0.0	1.820E+03	1.093E+06	3.530E+06	6.890E+06	9.400E+06	2.390E+06	2.830E+07
SSW	0.0	0.0	0.0	1.280E+03	0.0	1.320E+06	3.070E+06	7.220E+05	6.210E+06	1.330E+07	2.462E+07
SW	0.0	0.0	0.0	0.0	1.930E+04	1.540E+06	3.140E+06	5.220E+06	4.260E+06	4.500E+06	1.868E+07
WSW	0.0	0.0	0.0	0.0	4.540E+03	1.220E+07	4.510E+06	7.860E+06	1.280E+07	6.060E+06	4.343E+07
W	0.0	0.0	0.0	0.0	4.540E+03	1.540E+06	4.960E+06	2.620E+06	2.620E+06	8.310E+06	1.945E+07
WNW	0.0	0.0	0.0	0.0	5.500E+03	1.320E+06	4.880E+06	3.440E+06	9.100E+06	8.460E+06	2.721E+07
NW	0.0	0.0	0.0	1.720E+03	4.820E+03	2.200E+05	4.510E+06	6.280E+06	3.920E+06	6.550E+06	2.149E+07
ENE	0.0	0.0	0.0	0.0	9.080E+02	0.0	0.0	2.090E+06	1.210E+06	6.090E+06	1.139E+07
TOTAL	0.0	0.0	0.0	3.000E+03	2.145E+05	6.603E+07	2.808E+08	1.847E+08	1.399E+08	1.476E+08	8.193E+08

DENSITY1 /M**21 = 4.10E-02

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION

SITE		MILK PRODUCTION, LITERS									
DIR	0.0-1.	1.-2.	2.-3.	3.-4.	4.-5.	5.-10.	10.-20.	20.-30.	30.-40.	40.-50.	TOTAL
N	0.0	0.0	0.0	0.0	0.0	3.270E+05	2.940E+06	3.480E+05	2.030E+06	6.420E+06	1.207E+07
NNE	0.0	0.0	0.0	0.0	1.360E+05	2.620E+06	2.940E+06	3.480E+06	2.030E+06	6.420E+06	1.763E+07
NE	0.0	0.0	0.0	0.0	0.0	2.620E+06	9.150E+06	1.810E+06	6.250E+06	0.0	1.364E+07
ENE	0.0	0.0	0.0	0.0	0.0	1.960E+06	8.180E+06	0.0	2.490E+05	1.040E+07	2.079E+07
E	0.0	0.0	0.0	0.0	0.0	7.130E+05	1.770E+06	2.560E+06	3.530E+05	0.0	5.396E+06
ESE	0.0	0.0	0.0	0.0	0.0	2.850E+05	2.000E+06	0.0	2.850E+05	9.150E+05	3.485E+06
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.970E+05	1.320E+06	1.617E+06
SSE	0.0	0.0	0.0	0.0	0.0	0.0	2.990E+06	3.820E+06	5.280E+06	3.730E+06	1.582E+07
S	0.0	0.0	0.0	0.0	0.0	1.300E+06	2.700E+06	1.490E+06	2.160E+06	4.970E+05	8.147E+06
SSW	0.0	0.0	0.0	0.0	0.0	1.560E+06	2.150E+06	6.730E+05	0.0	0.0	4.383E+06
SW	0.0	0.0	0.0	0.0	0.0	1.820E+06	3.240E+06	6.950E+06	7.170E+06	6.690E+06	2.587E+07
WSW	0.0	0.0	0.0	0.0	0.0	1.820E+06	5.540E+06	7.740E+06	1.110E+07	5.150E+06	3.135E+07
W	0.0	0.0	0.0	0.0	2.890E+05	1.820E+06	7.350E+06	3.480E+06	7.520E+06	1.700E+07	3.746E+07
WNW	0.0	0.0	0.0	0.0	0.0	1.560E+06	6.860E+06	1.360E+07	4.030E+07	4.840E+07	1.107E+08
NW	0.0	0.0	0.0	0.0	0.0	2.600E+06	5.630E+06	2.020E+07	2.770E+07	4.800E+07	1.041E+08
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.490E+06	2.270E+07	4.060E+07	6.579E+07
TOTAL	0.0	0.0	0.0	0.0	4.250E+05	2.100E+07	6.344E+07	6.864E+07	1.292E+08	1.955E+08	4.783E+08

DENSITY /M**21 = 2.39E-02

SITE		MEAT PRODUCTION, KGR (CORN-POULTRY)									
DIR	0.0-1.	1.-2.	2.-3.	3.-4.	4.-5.	5.-10.	10.-20.	20.-30.	30.-40.	40.-50.	TOTAL
N	0.0	0.0	0.0	0.0	0.0	3.796E+04	3.403E+05	1.660E+05	9.685E+05	1.738E+06	3.251E+06
NNE	0.0	0.0	0.0	0.0	7.800E+03	3.027E+05	1.055E+06	4.562E+06	1.572E+05	0.0	6.085E+06
NE	0.0	0.0	0.0	0.0	1.140E+04	3.027E+05	9.448E+05	0.0	7.740E+05	2.664E+06	4.690E+06
ENE	0.0	0.0	0.0	0.0	0.0	2.271E+05	7.180E+05	3.687E+06	1.022E+06	3.574E+05	6.012E+06
E	0.0	0.0	0.0	0.0	0.0	8.603E+04	3.291E+05	1.573E+06	5.446E+05	1.042E+05	2.637E+06
ESE	0.0	0.0	0.0	0.0	0.0	5.295E+04	3.715E+05	0.0	1.959E+05	8.952E+05	1.515E+06
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.041E+05	1.981E+06	2.185E+06
SSE	0.0	0.0	0.0	0.0	0.0	0.0	1.060E+06	1.355E+06	1.971E+06	2.998E+06	7.384E+06
S	0.0	0.0	0.0	0.0	0.0	1.016E+05	6.703E+05	5.300E+05	7.662E+05	1.766E+05	2.245E+06
SSW	0.0	0.0	0.0	0.0	0.0	1.219E+05	2.599E+05	2.605E+05	7.150E+05	1.544E+06	2.901E+06
SW	0.0	0.0	0.0	0.0	0.0	1.417E+05	3.605E+05	1.980E+06	2.378E+06	2.080E+06	6.941E+06
WSW	0.0	0.0	0.0	0.0	3.720E+03	1.417E+05	6.587E+05	1.192E+06	2.003E+06	9.116E+05	4.911E+06
W	0.0	0.0	0.0	0.0	1.860E+04	1.417E+05	7.451E+05	3.972E+05	9.155E+05	2.815E+06	5.033E+06
WNW	0.0	0.0	0.0	0.0	1.320E+03	1.219E+05	6.618E+05	1.823E+06	6.977E+06	1.144E+07	2.103E+07
NW	0.0	0.0	0.0	2.400E+02	0.0	2.021E+04	4.738E+05	2.543E+06	3.911E+06	8.501E+06	1.545E+07
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.562E+05	3.208E+06	7.756E+06	1.122E+07
TOTAL	0.0	0.0	0.0	2.400E+02	4.284E+04	1.809E+06	8.649E+06	2.032E+07	2.671E+07	4.596E+07	1.035E+08

DENSITY /M**21 = 5.17E-03

TABLE 2.5-6 (continued)

Map Location	Name of Owner	Mailing Address	Distance from site (miles-direction)	Number of Young Cows	Number of Milk Cows	Total Milk Production (lbs/yr.)	
45	Bob Kux	Box 35 Port Penn	4.1 - NW	47	45	454,500	27
46	Ed Deporti	St. Georges	8.8 - NW	60	60	606,000	
47	Wills Passmore	R.D. #1 Box 64 Townsend	6 - SW	55	55	555,500	
48	T. Alkinson	R.D. #1 Townsend	6.2 - SW	50	50	505,000	
49	Carton Blendt Jr.	R.D. #1 Townsend	6.1 - SW	50	50	505,000	
50	Loyd & David Sheats	R.D. #2 Middletown	5.7 - WSW	125	125	1,262,500	15
51	David Reed	R.D. #2 Middletown	5.9 - WNW	55	55	555,500	
52	Phillips	R.D. #2 Middletown	4.4 - W	30	0	-	27
53	NA	NA	6 - SW	0	4	40,400	
54	NA	NA	6.2 - SW	0	2	20,200	
55	McNatt - Moore	Port Penn	4.5 - NNW	9	0	-	27
56	Steller	Townson	4.3 - SW	1	1	10,100	
57	Voss	R.D. #2 Middletown	5.0 - W	25	0	-	
58	W. David	Townson	5.1 - SSW	0	1	10,100	

NA - Not Available

- Notes:
- 1) Total milk production based on an average of 10,100 lbs/yr. per cow.
 - 2) Dairy information for New Castle County, Delaware, was given in total number of cows, therefore an approximate number of milk cows was obtained.
 - 3) Herds 53-54 were obtained after making a site visit to Delaware; no names or addresses were available.
 - 4) Information on dairy cows in a five mile radius of site updated in summer, 1973.

TABLE 2.5-6 (continued)

Map Location	Name of Owner	Mailing Address	Distance from site (Miles-direction)	Number of Young Cows	Number of Milk Cows	Total Milk production (lbs/yr.)
Cumberland Co., New Jersey						
30	Albert S. Fogg	R.D. #3 Bridgeton	9.9 - E	40	70	707,000
New Castle Co., Delaware						
31	George Baxter	R #1 Middletown	6.6 - NW	40	40	404,000
32	W. E. Bullen	R #1 Middletown	6.6 - WNW	50	50	505,000
33	R. Chambers	R #1 Middletown	5.2 - NW	60	60	606,000
34	W. Cleaver	R #1 Middletown	8.8 - W	60	60	606,000
35	J. Coverdale	R #1 Middletown	7.6 WNW	55	55	555,500
36	S. Coverdale	R #1 Middletown	7.8 - WNW	55	55	555,500
37	Raymond Burriss	R.D. #2 Middletown	8.6 - W	50	50	505,000
38	Samuel Deats	R #1 Middletown	10 - WNW	60	60	606,000
39	Robert Emerson	R.D. #2 Middletown	8.2 - WNW	60	60	606,000
40	J. Fennimore	Box 161 Middletown	8.3 - W	50	50	505,000
41	Claude D. Hamman	R.D. #2 Middletown	4.9 - W	50	75	575,700
42	Harvey Voshell	R #1 Middletown	10.2 - NW	60	60	606,000
43	Edger Wooleyham	R.D. #2 Middletown	9.3 - NW	50	50	505,000
44	Leroy Deporti	Odessa	6.7 - WSW	50	50	505,000

Table 2.5-6
 (Sheet 3 of 4)

Amendment 27

TABLE 2.5-6 (continued)

Map Location	Name of Owner	Mailing Address	Distance from site (miles-direction)	Number of Young Cows	Number of Milk Cows	Total Milk Production (lbs/yr.)
15	F. Sowers	R.D. #3 Salem	4.4 - NNE	1	2	20,200
16	Norman Johnson	R.D. #2 Salem	8 - ENE	170	0	0
17	Ar. Peterson	Box 15 Alloway	9.5 - ENE	45	57	575,700
18	Albert M. Bell	R.D. #2 Salem	7.7 - NE	20	40	404,000
19	Walt Bradway	R.D. #2 Salem	7 - E	0	7	70,700
20	Norman Counseller	R.D. #2 Salem	6.5 - E	11	28	232,800
21	W. Deldon	R.D. #2 Salem	11 - E	34	52	525,200
22	Howard Henderson, Jr.	R.D. #2 Salem	5.2 - E	10	16	161,600
23	Richard Keen	R.D. #2 Salem	8.2 - NE	20	45	454,500
24	Ross Peterson	Howard Ave.	8 - NE	25	0	0
25	Vicent Retman	R.D. #1 Salem	9 - NNE	10	6	60,600
26	Bob Ridgway	R.D. #3 Salem	6.6 - NE	25	45	454,500
27	Edgar Stoms	R.D. #1 Salem	9 - NNE	20	45	454,500
28	W.K. Thomaski	R.D. #2 Salem	8.3 - ENE	50	0	0
29	A. Weigel	R.D. #1 Salem	9.2 - NNE	8	30	303,000

TABLE 2.5-6

Dairy Farms Within 10 Miles of the Site

Map Location	Name of Owner	Mailing Address	Distance from site (miles-direction)	Number of Young Cows	Number of Milk Cows	Total Milk Production (lbs/yr.)
Salem Co., N.J.						
1	Dr. Webster	R.D. #3 Salem	5.6 - NNE	NA	50	505,000
2	A. Farnkaopf	R.D. #3 Salem	5.1 - NNE	10	60	60,600
3	L. Richie	30 S. Tillury Rd.	7.3 - NNE	10	28	282,800
4	B. Haynes, Jr.	R.D. #3 Salem	6.3 - NNE	25	73	737,300
5	F. Schrier	R.D. #3 Salem	10 - NNE	1	34	343,400
6	L. Fogg	R.D. #2 Salem	6 E	50	50	505,000
7	W. Dixon	R.D. #2 Salem	5.5 - E	11	21	212,100
8	F. Smith	R.D. #2 Salem	7 - E	3	31	313,100
9	J.H. Griscom	R.D. #1 Salem	9.3 - NNE	25	74	747,400
10	Ar. Griscom, Jr.	R.D. #1 Salem	11 - NE	65	80	808,000
11	Waldac Farms, Inc.	R.D. #1 Salem	12 - NE	107	100	1,010,000
12	Charles Harris	R.D. #2 Salem	5.2 - NE	0	15	151,500
13	W. Gaunt	R.D. #2 Salem	8.5 - ENE	23	35	353,500
14	Horrace Stoms	R.D. #2 Salem	7.4 - NE	35	70	707,000

27

15

1:1120m

Salem

Rehyd dist
N 1315 - 1280
1520 1430
1690



300' met tower stacked
 700 Acres - Reactor in SW corner (Pg. 12.3-35)
 Bdy = 1375 m ~~east~~ north (Pg. 12.3-36)
 Applicants LP2 = 5 mi

AERIAL PHOTOGRAPH OF SITE




Figure 2. - Map of Artificial Island and the location of the Salem Nuclear Generating Station, Salem County, New Jersey. Note locations of Hope and Hope Alloway Halfway creeks.

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION

AGRICULTURAL PRODUCTIVITY

PRODUCT	CAP USE	PRODUCTION	EXPORT	T. POP. SERVED
VEGETATION	1.99E+02	8.19E+09	0.0	4.12E+06
MILK	1.35E+02	4.78E+08	0.0	3.55E+06
MEAT	7.84E+01	1.03E+08	0.0	1.32E+06

0.20 0.14 0.66

200.00 240.00 190.00

170.00 200.00 110.00

57.00 59.00 95.00

Table 4.11a

CASE 1

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION

ID	SPECIAL LOCATION	DIR	MILES	X/Q	X/QIDEC	X/QIDEP	DEPOSIT	PL	CO	VT	MT	CM	GM	IN
1	Dairy Farm #1		2	4.00	2.94E-08	2.94E-08	1.02E-08	1.02E-10	0	0	0	0	0	0
1	Dairy Farm #2		13	5.00	2.41E-08	2.41E-08	5.69E-09	5.69E-11	0	0	0	0	0	0
*	M.C. Pond #1		16	4.40	4.83E-08	4.83E-08	1.67E-08	1.67E-10	0	0	0	0	0	0
1	High School		1	0.50	1.23E-06	1.23E-06	7.59E-07	7.59E-09	0	0	0	0	0	0
1	High School #510		4	3.50	5.74E-08	5.74E-08	1.85E-08	1.85E-10	0	0	0	0	0	0

S.B.
Pub

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION

SITE ANNUAL ~~DEPOSITION~~ DEPLETED X/O DATA, SEC/M3

DATE	0.-1.	1.-2.	2.-3.	3.-4.	4.-5.	5.-10.	10.-20.	20.-30.	30.-40.	40.-50.
1	7.587E-07	1.552E-07	5.266E-08	2.765E-08	1.695E-08	6.187E-09	1.578E-09	6.469E-10	3.573E-10	2.112E-10
10E	5.049E-07	9.135E-08	3.577E-08	1.855E-08	1.159E-08	4.253E-09	1.102E-09	4.789E-10	2.728E-10	1.606E-10
10E	5.499E-07	1.017E-07	3.985E-08	2.094E-08	1.284E-08	4.672E-09	1.189E-09	5.041E-10	2.834E-10	1.660E-10
10E	4.099E-07	9.029E-08	3.533E-08	1.848E-08	1.127E-08	4.042E-09	1.008E-09	4.325E-10	2.448E-10	1.417E-10
10E	7.099E-07	1.266E-07	4.913E-08	2.568E-08	1.569E-08	5.678E-09	1.433E-09	5.903E-10	3.272E-10	1.925E-10
10E	5.099E-07	1.000E-07	3.882E-08	2.040E-08	1.253E-08	4.603E-09	1.196E-09	5.166E-10	2.935E-10	1.739E-10
10E	6.099E-07	1.315E-07	5.063E-08	2.652E-08	1.626E-08	5.961E-09	1.541E-09	6.418E-10	3.581E-10	2.134E-10
10E	5.019E-07	9.312E-08	3.593E-08	1.881E-08	1.153E-08	4.216E-09	1.094E-09	4.779E-10	2.734E-10	1.616E-10
10E	5.021E-07	1.033E-07	3.986E-08	2.076E-08	1.265E-08	4.552E-09	1.146E-09	4.863E-10	2.740E-10	1.603E-10
10E	5.099E-07	7.587E-08	2.933E-08	1.520E-08	9.211E-09	3.264E-09	8.094E-10	3.619E-10	2.095E-10	1.208E-10
10E	4.009E-07	7.425E-08	2.873E-08	1.497E-08	9.121E-09	3.278E-09	8.315E-10	3.751E-10	2.180E-10	1.267E-10
10E	4.009E-07	4.899E-08	1.872E-08	9.674E-09	5.855E-09	2.076E-09	5.295E-10	2.673E-10	1.634E-10	9.399E-11
10E	4.009E-07	5.820E-08	2.231E-08	1.156E-08	7.018E-09	2.509E-09	6.421E-10	3.089E-10	1.850E-10	1.072E-10
10E	4.019E-07	3.983E-08	1.536E-08	7.935E-09	4.752E-09	1.684E-09	3.961E-10	1.346E-10	6.591E-11	3.864E-11
10E	4.019E-07	8.283E-08	3.277E-08	1.723E-08	1.054E-08	3.802E-09	9.544E-10	4.141E-10	2.355E-10	1.360E-10
10E	6.099E-07	1.235E-07	4.907E-08	2.593E-08	1.595E-08	5.823E-09	1.474E-09	6.023E-10	3.314E-10	1.939E-10

SITE ANNUAL DEPOSITION DATA, M-2

DATE	0.-1.	1.-2.	2.-3.	3.-4.	4.-5.	5.-10.	10.-20.	20.-30.	30.-40.	40.-50.
1	7.587E-09	1.352E-09	5.266E-10	2.765E-10	1.695E-10	6.187E-11	1.578E-11	6.469E-12	3.573E-12	2.112E-12
10E	5.049E-09	9.135E-10	3.577E-10	1.855E-10	1.159E-10	4.253E-11	1.102E-11	4.789E-12	2.728E-12	1.606E-12
10E	5.499E-09	1.017E-09	3.985E-10	2.094E-10	1.284E-10	4.672E-11	1.189E-11	5.041E-12	2.834E-12	1.660E-12
10E	4.099E-09	9.029E-10	3.533E-10	1.848E-10	1.127E-10	4.042E-11	1.008E-11	4.325E-12	2.448E-12	1.417E-12
10E	7.099E-09	1.266E-09	4.913E-10	2.568E-10	1.569E-10	5.678E-11	1.433E-11	5.903E-12	3.272E-12	1.925E-12
10E	5.099E-09	1.000E-09	3.882E-10	2.040E-10	1.253E-10	4.603E-11	1.196E-11	5.166E-12	2.935E-12	1.739E-12
10E	6.099E-09	1.315E-09	5.063E-10	2.652E-10	1.626E-10	5.961E-11	1.541E-11	6.418E-12	3.581E-12	2.134E-12
10E	5.019E-09	9.312E-10	3.593E-10	1.881E-10	1.153E-10	4.216E-11	1.094E-11	4.779E-12	2.734E-12	1.616E-12
10E	5.021E-09	1.033E-09	3.986E-10	2.076E-10	1.265E-10	4.552E-11	1.146E-11	4.863E-12	2.740E-12	1.603E-12
10E	5.099E-09	7.587E-10	2.933E-10	1.520E-10	9.211E-11	3.264E-11	8.094E-12	3.619E-12	2.095E-12	1.208E-12
10E	4.009E-09	7.425E-10	2.873E-10	1.497E-10	9.121E-11	3.278E-11	8.315E-12	3.751E-12	2.180E-12	1.267E-12
10E	4.009E-09	4.899E-10	1.872E-10	9.674E-11	5.855E-11	2.076E-11	5.295E-12	2.673E-12	1.634E-12	9.399E-13
10E	4.009E-09	5.820E-10	2.231E-10	1.156E-10	7.018E-11	2.509E-11	6.421E-12	3.089E-12	1.850E-12	1.072E-12
10E	4.019E-09	3.983E-10	1.536E-10	7.935E-11	4.752E-11	1.684E-11	3.961E-12	1.346E-12	6.591E-13	3.864E-13
10E	4.019E-09	8.283E-10	3.277E-10	1.723E-10	1.054E-10	3.802E-11	9.544E-12	4.141E-12	2.355E-12	1.360E-12
10E	6.099E-09	1.235E-09	4.907E-10	2.593E-10	1.595E-10	5.823E-11	1.474E-11	6.023E-12	3.314E-12	1.939E-12

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CESEK GENERATING STATION

SITE ANNUAL X/R DATA, SEC/M3

DIR	0.-1.	1.-2.	2.-3.	3.-4.	4.-5.	5.-10.	10.-20.	20.-30.	30.-40.	40.-50.
E	1.226E-06	3.024E-07	1.345E-07	7.693E-08	5.038E-08	2.105E-08	6.400E-09	2.742E-09	1.604E-09	1.078E-09
NE	7.990E-07	1.972E-07	8.762E-08	5.013E-08	3.279E-08	1.369E-08	4.171E-09	1.821E-09	1.089E-09	7.451E-10
SE	6.079E-07	2.265E-07	1.012E-07	5.806E-08	3.804E-08	1.592E-08	4.859E-09	2.108E-09	1.251E-09	8.503E-10
SW	3.024E-07	2.202E-07	9.952E-08	5.736E-08	3.769E-08	1.585E-08	4.862E-09	2.116E-09	1.257E-09	8.557E-10
S	1.170E-06	2.975E-07	1.329E-07	7.625E-08	4.996E-08	2.091E-08	6.371E-09	2.734E-09	1.600E-09	1.077E-09
SSW	0.790E-07	2.002E-07	9.159E-08	5.216E-08	3.403E-08	1.414E-08	4.283E-09	1.861E-09	1.109E-09	7.570E-10
SE	1.243E-06	2.834E-07	1.245E-07	7.089E-08	4.624E-08	1.922E-08	5.810E-09	2.489E-09	1.460E-09	9.835E-10
SSE	8.659E-07	1.963E-07	8.712E-08	5.207E-08	3.233E-08	1.342E-08	4.063E-09	2.521E-09	1.058E-09	7.237E-10
S	7.047E-07	2.502E-07	1.117E-07	6.405E-08	4.195E-08	1.755E-08	5.347E-09	2.309E-09	1.362E-09	9.225E-10
SSW	7.902E-07	2.131E-07	9.674E-08	5.587E-08	3.676E-08	1.549E-08	4.762E-09	2.078E-09	1.237E-09	8.428E-10
SW	7.117E-07	1.872E-07	8.418E-08	4.844E-08	3.180E-08	1.336E-08	4.099E-09	1.798E-09	1.079E-09	7.400E-10
WSW	4.937E-07	1.326E-07	5.976E-08	3.437E-08	2.255E-08	9.459E-09	2.904E-09	1.301E-09	8.003E-10	5.589E-10
S	6.243E-07	1.682E-07	7.592E-08	4.375E-08	2.875E-08	1.210E-08	3.720E-09	1.643E-09	9.929E-10	6.843E-10
WSW	4.225E-07	1.245E-07	5.711E-08	3.310E-08	2.183E-08	9.238E-09	2.835E-09	1.182E-09	6.637E-10	4.312E-10
SW	7.153E-07	2.063E-07	9.394E-08	5.434E-08	3.579E-08	1.512E-08	4.660E-09	2.039E-09	1.216E-09	8.300E-10
WSW	1.000E-06	2.725E-07	1.229E-07	7.082E-08	4.653E-08	1.957E-08	5.992E-09	2.585E-09	1.520E-09	1.026E-09

SITE ANNUAL X/R DATA, SEC/M3

DIR	0.-1.	1.-2.	2.-3.	3.-4.	4.-5.	5.-10.	10.-20.	20.-30.	30.-40.	40.-50.
E	1.226E-06	3.024E-07	1.345E-07	7.693E-08	5.038E-08	2.105E-08	6.400E-09	2.742E-09	1.604E-09	1.078E-09
NE	7.990E-07	1.972E-07	8.762E-08	5.013E-08	3.279E-08	1.369E-08	4.171E-09	1.821E-09	1.089E-09	7.451E-10
SE	6.079E-07	2.265E-07	1.012E-07	5.806E-08	3.804E-08	1.592E-08	4.859E-09	2.108E-09	1.251E-09	8.503E-10
SW	3.024E-07	2.202E-07	9.952E-08	5.736E-08	3.769E-08	1.585E-08	4.862E-09	2.116E-09	1.257E-09	8.557E-10
S	1.170E-06	2.975E-07	1.329E-07	7.625E-08	4.996E-08	2.091E-08	6.371E-09	2.734E-09	1.600E-09	1.077E-09
SSW	0.790E-07	2.002E-07	9.159E-08	5.216E-08	3.403E-08	1.414E-08	4.283E-09	1.861E-09	1.109E-09	7.570E-10
SE	1.243E-06	2.834E-07	1.245E-07	7.089E-08	4.624E-08	1.922E-08	5.810E-09	2.489E-09	1.460E-09	9.835E-10
SSE	8.659E-07	1.963E-07	8.712E-08	5.207E-08	3.233E-08	1.342E-08	4.063E-09	2.521E-09	1.058E-09	7.237E-10
S	7.047E-07	2.502E-07	1.117E-07	6.405E-08	4.195E-08	1.755E-08	5.347E-09	2.309E-09	1.362E-09	9.225E-10
SSW	7.902E-07	2.131E-07	9.674E-08	5.587E-08	3.676E-08	1.549E-08	4.762E-09	2.078E-09	1.237E-09	8.428E-10
SW	7.117E-07	1.872E-07	8.418E-08	4.844E-08	3.180E-08	1.336E-08	4.099E-09	1.798E-09	1.079E-09	7.400E-10
WSW	4.937E-07	1.326E-07	5.976E-08	3.437E-08	2.255E-08	9.459E-09	2.904E-09	1.301E-09	8.003E-10	5.589E-10
S	6.243E-07	1.682E-07	7.592E-08	4.375E-08	2.875E-08	1.210E-08	3.720E-09	1.643E-09	9.929E-10	6.843E-10
WSW	4.225E-07	1.245E-07	5.711E-08	3.310E-08	2.183E-08	9.238E-09	2.835E-09	1.182E-09	6.637E-10	4.312E-10
SW	7.153E-07	2.063E-07	9.394E-08	5.434E-08	3.579E-08	1.512E-08	4.660E-09	2.039E-09	1.216E-09	8.300E-10
WSW	1.000E-06	2.725E-07	1.229E-07	7.082E-08	4.653E-08	1.957E-08	5.992E-09	2.585E-09	1.520E-09	1.026E-09

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
 ALASKA ANNUAL INTEGRATED POPULATION DOSE SUMMARY (MANREM)
 PATHWAY = MEAT

CASE 1

ALARA
 Pop classes
 (meat)

2527

NUCLIDE	T. BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
I 131	9.44E-05 0.11%	3.31E-05 0.04%	1.17E-04 0.04%	1.54E-04 0.18%	2.18E-04 0.34%	4.95E-02 37.23%	0.0	0.0
I 133	7.81E-12 0.0%	1.80E-11 0.0%	1.51E-11 0.0%	2.40E-11 0.0%	3.41E-11 0.0%	4.85E-09 0.0%	0.0	0.0
C 14	0.16E-02 97.51%	8.16E-02 97.17%	2.80E-01 99.84%	8.16E-02 97.37%	6.20E-02 96.83%	8.16E-02 61.42%	8.16E-02 97.82%	8.16E-02 97.85%
H 3	1.79E-03 2.14%	1.79E-03 2.13%	0.0	1.79E-03 2.14%	1.75E-03 2.72%	1.79E-03 1.35%	1.79E-03 2.15%	1.79E-03 2.15%
CH 51	4.18E-09 0.0%	1.05E-06 0.0%	0.0	0.0	9.22E-10 0.0%	2.50E-09 0.0%	5.55E-09 0.0%	0.0
MN 54	1.39E-07 0.0%	2.23E-06 0.0%	0.0	7.28E-07 0.0%	2.17E-07 0.0%	0.0	0.0	0.0
FE 59	0.33E-06 0.0%	7.22E-05 0.09%	9.22E-06 0.0%	2.19E-05 0.03%	0.0	0.0	6.08E-06 0.0%	0.0
CU 58	2.09E-06 0.0%	1.45E-05 0.02%	0.0	8.72E-07 0.0%	0.0	0.0	0.0	0.0
CO 60	5.88E-05 0.07%	3.82E-04 0.45%	0.0	2.49E-05 0.03%	0.0	0.0	0.0	0.0
ZN 65	1.24E-05 0.01%	1.72E-05 0.02%	8.61E-06 0.0%	2.73E-05 0.03%	1.83E-05 0.03%	0.0	0.0	0.0
SR 89	3.94E-06 0.0%	1.60E-05 0.02%	1.37E-04 0.05%	0.0	0.0	0.0	0.0	0.0
SR 90	8.25E-06 0.0%	4.80E-07 0.0%	3.35E-05 0.01%	0.0	0.0	0.0	0.0	0.0
ZR 95	2.70E-09 0.0%	1.24E-05 0.01%	1.24E-08 0.0%	3.99E-09 0.0%	6.29E-09 0.0%	0.0	0.0	0.0
SO124	1.37E-07 0.0%	9.82E-06 0.01%	3.47E-07 0.0%	6.54E-05 0.0%	0.0	8.38E-10	2.69E-07	0.0
CS134	4.53E-05 0.05%	9.94E-07 0.0%	3.15E-05 0.01%	6.93E-05 0.08%	1.91E-05 0.03%	0.0	7.61E-06	0.0
CS136	8.48E-08 0.0%	1.34E-03 0.0%	2.98E-08 0.0%	1.16E-07 0.0%	6.56E-08 0.0%	0.0	8.99E-09	0.0
CS137	5.69E-05 0.07%	1.75E-06 0.0%	8.91E-05 0.03%	1.12E-04 0.13%	3.16E-05 0.05%	0.0	1.29E-05	0.0
BA140	1.09E-06 0.0%	2.17E-05 0.03%	1.71E-05 0.0%	1.55E-08 0.0%	5.49E-09 0.0%	0.0	1.15E-08	0.0
Cc144	4.23E-11	1.08E-06	5.57E-10	3.48E-10	1.32E-10	0.0	0.0	0.0

Table 4.11d

HCGS

SE 1

	0.0 %	0.0 %	0.0 %	0.0 %	0.0 %	0.0 %	0.0 %	0.0 %	0.0 %
*TOTAL	8.37E-02	8.40E-02	2.80E-01	8.38E-02	6.41E-02	1.33E-01	8.34E-02	8.34E-02	0.0 %

Table 4.11c

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GRADING STATION
 ALASKA ANNUAL INTEGRATED POPULATION DOSE SUMMARY (MANREM)
 PATHWAY = COW MILK

HCGS

NUCLIDE	T. BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
I 131	6.42E-03 2.33%	1.63E-03 0.60%	8.05E-03 1.40%	9.71E-03 3.45%	1.09E-02 6.72%	3.10E+00 91.25%	0.0 0.0	0.0 0.0%
I 133	4.90E-05 0.02%	8.82E-05 0.03%	9.73E-05 0.02%	1.41E-04 0.05%	1.56E-04 0.10%	3.01E-02 0.89%	0.0 0.0%	0.0 0.0%
C 14	2.58E-01 93.54%	2.58E-01 95.67%	5.63E-01 97.64%	2.58E-01 91.61%	1.42E-01 87.23%	2.58E-01 7.58%	2.58E-01 96.33%	2.58E-01 96.51%
H 1	9.32E-03 3.38%	9.32E-03 3.46%	0.0 0.0%	9.32E-03 3.32%	8.58E-03 5.28%	9.32E-03 0.27%	9.32E-03 3.49%	9.32E-03 3.49%
CR 51	3.48E-08 0.0%	8.75E-06 0.0%	0.0 0.0%	0.0 0.0%	7.68E-09 0.0%	2.08E-08 0.0%	4.62E-08 0.0%	0.0 0.0%
MN 54	2.74E-07 0.0%	4.40E-06 0.0%	0.0 0.0%	1.44E-06 0.0%	4.27E-07 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%
FE 59	1.95E-06 0.0%	1.69E-05 0.0%	2.16E-06 0.0%	5.13E-06 0.0%	0.0 0.0%	0.0 0.0%	1.42E-06 0.0%	0.0 0.0%
CO 58	1.51E-06 0.0%	7.46E-06 0.0%	0.0 0.0%	5.85E-07 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%
CO 60	3.64E-05 0.01%	1.68E-04 0.06%	0.0 0.0%	1.43E-05 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%
ZN 65	1.02E-04 0.04%	1.43E-04 0.05%	7.13E-05 0.01%	2.26E-04 0.08%	1.51E-04 0.09%	0.0 0.0%	0.0 0.0%	0.0 0.0%
SR 89	5.71E-05 0.02%	1.63E-04 0.06%	1.99E-03 0.35%	0.0 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%
SR 90	8.15E-05 0.03%	4.90E-06 0.0%	3.28E-04 0.06%	0.0 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%
ZR 95	2.86E-12 0.0%	1.31E-08 0.0%	1.32E-11 0.0%	4.23E-12 0.0%	6.67E-12 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%
SB124	3.76E-07 0.0%	2.69E-05 0.0%	5.52E-07 0.0%	1.80E-08 0.0%	0.0 0.0%	2.30E-09 0.0%	7.36E-07 0.0%	0.0 0.0%
CS134	7.68E-04 0.28%	1.35E-05 0.0%	7.87E-04 0.14%	1.59E-03 0.56%	3.53E-04 0.22%	0.0 0.0%	1.77E-04 0.07%	0.0 0.0%
CS136	3.64E-06 0.0%	5.74E-07 0.0%	1.28E-06 0.0%	5.05E-06 0.0%	2.81E-06 0.0%	0.0 0.0%	3.85E-07 0.0%	0.0 0.0%
CS137	9.41E-04 0.34%	3.11E-05 0.01%	2.24E-03 0.39%	2.57E-03 0.91%	5.78E-04 0.36%	0.0 0.0%	3.04E-04 0.11%	0.0 0.0%
BA140	2.87E-06 0.0%	2.81E-05 0.01%	4.32E-05 0.0%	4.51E-08 0.0%	5.95E-09 0.0%	0.0 0.0%	2.71E-08 0.0%	0.0 0.0%
CE141	2.50E-10 0.0%	4.58E-06 0.0%	3.31E-09 0.0%	1.91E-09 0.0%	5.66E-10 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%

Table 4.11f

	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
TOTAL	2.75E-01	2.69E-01	5.76E-01	2.81E-01	1.62E-01	3.40E+00	2.67E-01	2.67E-01	2.67E-01	2.67E-01

FILE 4119

NOV

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
 ALASKA ANNUAL INTEGRATED POPULATION DOSE SUMMARY (MAIREM)
 PATHWAY = VEGETATION

NUCLIDE	T. BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
I 131	1.58E-03 0.13%	4.40E-04 0.03%	1.97E-03 0.06%	2.43E-03 0.19%	2.94E-03 0.38%	7.78E-01 38.57%	0.0 0.0%	0.0 0.0%
I 135	4.14E-21 0.0%	8.00E-21 0.0%	8.17E-21 0.0%	1.21E-20 0.0%	1.45E-20 0.0%	2.55E-18 0.0%	0.0 0.0%	0.0 0.0%
C 14	1.18E+00 94.06%	1.18E+00 93.81%	2.99E+00 95.77%	1.18E+00 93.95%	7.16E-01 92.35%	1.18E+00 58.67%	1.18E+00 95.36%	1.18E+00 95.51%
H 3	5.56E-02 4.42%	5.56E-02 4.41%	0.0 0.0%	5.56E-02 4.41%	5.21E-02 6.71%	5.56E-02 2.76%	5.56E-02 4.48%	5.56E-02 4.49%
CR 51	4.74E-07 0.0%	1.15E-04 0.0%	0.0 0.0%	0.0 0.0%	1.05E-07 0.0%	2.63E-07 0.0%	6.29E-07 0.0%	0.0 0.0%
MN 54	5.61E-05 0.0%	8.99E-04 0.07%	0.0 0.0%	2.94E-04 0.02%	8.74E-05 0.01%	0.0 0.0%	0.0 0.0%	0.0 0.0%
FE 59	6.68E-05 0.0%	5.80E-04 0.05%	7.40E-05 0.0%	1.76E-04 0.01%	0.0 0.0%	0.0 0.0%	4.88E-05 0.0%	0.0 0.0%
CU 58	6.53E-05 0.0%	3.58E-04 0.03%	0.0 0.0%	2.50E-05 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%
CG 60	1.72E-03 0.14%	8.84E-03 0.70%	0.0 0.0%	6.90E-04 0.05%	0.0 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%
ZN 65	1.44E-04 0.01%	2.00E-04 0.02%	9.99E-05 0.0%	3.17E-04 0.03%	2.12E-04 0.03%	0.0 0.0%	0.0 0.0%	0.0 0.0%
SR 89	2.77E-03 0.22%	8.78E-03 0.70%	9.68E-02 3.10%	0.0 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%
SR 90	5.06E-03 0.40%	3.00E-04 0.02%	2.04E-02 0.65%	0.0 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%
ZR 95	2.65E-08 0.0%	1.21E-04 0.0%	1.22E-07 0.0%	3.91E-08 0.0%	6.17E-08 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%
SB124	1.14E-05 0.0%	8.15E-04 0.06%	2.88E-05 0.0%	5.44E-07 0.0%	0.0 0.0%	6.96E-08 0.0%	2.24E-05 0.0%	0.0 0.0%
CS134	3.38E-03 0.27%	7.59E-05 0.0%	3.07E-03 0.10%	6.35E-03 0.50%	1.51E-03 0.19%	0.0 0.0%	7.03E-04 0.06%	0.0 0.0%
CS136	2.49E-06 0.0%	3.94E-07 0.0%	8.78E-07 0.0%	3.46E-06 0.0%	1.93E-06 0.0%	0.0 0.0%	2.64E-07 0.0%	0.0 0.0%
CS137	4.23E-03 0.34%	1.36E-04 0.01%	8.85E-03 0.28%	1.04E-02 0.82%	2.50E-03 0.32%	0.0 0.0%	1.22E-03 0.10%	0.0 0.0%
BA140	4.79E-05 0.0%	6.28E-04 0.05%	7.69E-04 0.0%	6.22E-07 0.0%	1.95E-07 0.0%	0.0 0.0%	4.91E-07 0.0%	0.0 0.0%
CE141	1.30E-08 0.0%	2.63E-04 0.0%	1.72E-07 0.0%	1.01E-07 0.0%	3.24E-08 0.0%	0.0 0.0%	0.0 0.0%	0.0 0.0%

CASH 1

	0.0 %	0.0 %	0.0 %	0.0 %	0.0 %	0.0 %	0.0 %	0.0 %	0.0 %
TOTAL	1.26E+00	1.26E+00	3.12E+00	1.26E+00	7.76E-	2.02E+00	1.24E+00	1.24E+00	0.0 %

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
 ALARA ANNUAL INTEGRATED POPULATION DOSE SUMMARY (MANREM)
 PATHWAY = INHAL

NUCLIDE	T.BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
I 131	3.79E-03 11.16%	8.93E-04 2.67%	4.72E-03 41.39%	6.17E-03 13.64%	8.85E-03 18.76%	2.03E+00 50.32%	0.0 0.0%	0.0 0.0%
I 133	3.11E-03 9.15%	4.83E-03 14.47%	6.08E-03 53.37%	9.58E-03 21.18%	1.37E-02 27.99%	1.97E+00 49.01%	0.0 0.0%	0.0 0.0%
H 3	2.70E-02 79.35%	2.70E-02 80.71%	0.0 0.0%	2.70E-02 59.55%	2.64E-02 53.86%	2.70E-02 0.67%	2.70E-02 78.89%	2.70E-02 100.00%
CR 51	1.70E-07 0.0%	5.65E-06 0.02%	0.0 0.0%	0.0 0.0%	3.88E-03 0.0%	1.04E-07 0.0%	2.45E-05 0.07%	0.0 0.0%
MN 54	7.91E-07 0.0%	9.72E-06 0.03%	0.0 0.0%	4.97E-06 0.01%	1.24E-06 0.0%	0.0 0.0%	1.76E-04 0.51%	0.0 0.0%
FL 59	9.12E-07 0.0%	1.62E-05 0.05%	1.02E-06 0.0%	2.40E-03 5.30%	0.0 0.0%	0.0 0.0%	8.77E-05 0.26%	0.0 0.0%
CG 58	1.49E-07 0.0%	8.86E-06 0.03%	0.0 0.0%	1.13E-07 0.0%	0.0 0.0%	0.0 0.0%	9.61E-05 0.28%	0.0 0.0%
CC 60	4.99E-06 0.01%	1.10E-04 0.33%	0.0 0.0%	3.85E-06 0.0%	0.0 0.0%	0.0 0.0%	2.87E-03 8.40%	0.0 0.0%
ZK 65	1.52E-06 0.0%	1.75E-06 0.0%	1.06E-06 0.0%	3.38E-06 0.0%	2.26E-06 0.0%	0.0 0.0%	2.85E-05 0.08%	0.0 0.0%
SR 89	5.77E-06 0.02%	2.76E-04 0.83%	2.01E-04 1.76%	0.0 0.0%	0.0 0.0%	0.0 0.0%	1.44E-03 4.22%	0.0 0.0%
SR 90	1.54E-05 0.05%	2.18E-06 0.0%	2.51E-04 2.20%	0.0 0.0%	0.0 0.0%	0.0 0.0%	3.73E-05 0.11%	0.0 0.0%
ZK 95	3.35E-07 0.0%	2.16E-06 0.0%	1.54E-06 0.01%	4.95E-07 0.0%	7.79E-07 0.0%	0.0 0.0%	2.56E-05 0.07%	0.0 0.0%
SB124	4.87E-07 0.0%	1.59E-05 0.05%	1.22E-06 0.01%	2.31E-08 0.0%	0.0 0.0%	2.96E-09 0.0%	9.73E-05 0.28%	0.0 0.0%
CS134	3.85E-05 0.11%	5.64E-07 0.0%	2.66E-05 0.23%	5.59E-05 0.12%	1.62E-05 0.03%	0.0 0.0%	6.59E-06 0.02%	0.0 0.0%
CS136	9.02E-07 0.0%	9.47E-08 0.0%	3.17E-07 0.0%	1.19E-06 0.0%	6.94E-07 0.0%	0.0 0.0%	9.73E-08 0.0%	0.0 0.0%
CS137	4.24E-05 0.12%	8.71E-07 0.0%	6.59E-05 0.58%	7.88E-05 0.17%	2.36E-05 0.05%	0.0 0.0%	9.84E-06 0.03%	0.0 0.0%
BA140	3.11E-06 0.0%	2.56E-04 0.77%	4.74E-05 0.42%	5.81E-08 0.0%	2.41E-03 0.0%	0.0 0.0%	2.27E-03 6.66%	0.0 0.0%
CE141	1.05E-07 0.0%	9.81E-06 0.03%	1.37E-06 0.01%	9.24E-07 0.0%	5.16E-07 0.0%	0.0 0.0%	3.74E-05 0.11%	0.0 0.0%
TOTAL	3.40E-02	3.34E-02	1.14E-02	4.53E-02	4.90E-02	4.03E+00	3.42E-02	2.70E-02

T. J. ...

L. J. ...

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
 ALASKA ANNUAL INTEGRATED POPULATION DOSE SUMMARY (MANREM)
 PATHWAY = GROUND

NUCLIDE	T.BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
I 131	4.35E-03 4.11%	4.35E-03 4.11%	4.35E-03 4.11%	4.35E-03 4.11%	4.35E-03 4.11%	4.35E-03 4.11%	4.35E-03 4.11%	5.28E-03 4.24%
I 135	2.26E-03 2.14%	2.26E-03 2.14%	2.26E-03 2.14%	2.26E-03 2.14%	2.26E-03 2.14%	2.26E-03 2.14%	2.26E-03 2.14%	2.75E-03 2.21%
CR 51	7.47E-05 0.07%	7.47E-05 0.07%	7.47E-05 0.07%	7.47E-05 0.07%	7.47E-05 0.07%	7.47E-05 0.07%	7.47E-05 0.07%	8.83E-05 0.07%
MN 54	1.64E-03 1.55%	1.64E-03 1.55%	1.64E-03 1.55%	1.64E-03 1.55%	1.64E-03 1.55%	1.64E-03 1.55%	1.64E-03 1.55%	1.92E-03 1.54%
FE 59	2.21E-04 0.21%	2.21E-04 0.21%	2.21E-04 0.21%	2.21E-04 0.21%	2.21E-04 0.21%	2.21E-04 0.21%	2.21E-04 0.21%	2.60E-04 0.21%
CO 58	3.11E-04 0.29%	3.11E-04 0.29%	3.11E-04 0.29%	3.11E-04 0.29%	3.11E-04 0.29%	3.11E-04 0.29%	3.11E-04 0.29%	3.65E-04 0.29%
CO 60	8.21E-02 77.73%	8.21E-02 77.73%	8.21E-02 77.73%	8.21E-02 77.73%	8.21E-02 77.73%	8.21E-02 77.73%	8.21E-02 77.73%	9.66E-02 77.68%
ZN 65	2.31E-04 0.22%	2.31E-04 0.22%	2.31E-04 0.22%	2.31E-04 0.22%	2.31E-04 0.22%	2.31E-04 0.22%	2.31E-04 0.22%	2.65E-04 0.21%
SR 89	1.59E-07 0.0%	1.59E-07 0.0%	1.59E-07 0.0%	1.59E-07 0.0%	1.59E-07 0.0%	1.59E-07 0.0%	1.59E-07 0.0%	1.85E-07 0.0%
ZR 95	3.40E-05 0.03%	3.40E-05 0.03%	3.40E-05 0.03%	3.40E-05 0.03%	3.40E-05 0.03%	3.40E-05 0.03%	3.40E-05 0.03%	3.95E-05 0.03%
SB124	2.21E-04 0.21%	2.21E-04 0.21%	2.21E-04 0.21%	2.21E-04 0.21%	2.21E-04 0.21%	2.21E-04 0.21%	2.21E-04 0.21%	2.55E-04 0.21%
CS134	3.62E-03 3.42%	3.62E-03 3.42%	3.62E-03 3.42%	3.62E-03 3.42%	3.62E-03 3.42%	3.62E-03 3.42%	3.62E-03 3.42%	4.22E-03 3.39%
CS136	1.14E-05 0.01%	1.14E-05 0.01%	1.14E-05 0.01%	1.14E-05 0.01%	1.14E-05 0.01%	1.14E-05 0.01%	1.14E-05 0.01%	1.29E-05 0.01%
CS137	1.03E-02 9.72%	1.03E-02 9.72%	1.03E-02 9.72%	1.03E-02 9.72%	1.03E-02 9.72%	1.03E-02 9.72%	1.03E-02 9.72%	1.20E-02 9.63%
BA140	2.78E-04 0.26%	2.78E-04 0.26%	2.78E-04 0.26%	2.78E-04 0.26%	2.78E-04 0.26%	2.78E-04 0.26%	2.78E-04 0.26%	3.17E-04 0.26%
CE141	1.06E-05 0.01%	1.06E-05 0.01%	1.06E-05 0.01%	1.06E-05 0.01%	1.06E-05 0.01%	1.06E-05 0.01%	1.06E-05 0.01%	1.19E-05 0.0%
TOTAL	1.06E-01	1.06E-01	1.06E-01	1.06E-01	1.06E-01	1.06E-01	1.06E-01	1.24E-01

HCCS

Table 4.11k

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
 ALASKA ANNUAL INTEGRATED POPULATION DOSE SUMMARY (MANF 4)
 PATHWAY = PLUME

CASE 1

NUCLIDE	T. BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
KR 83M	1.47E-07 0.0%	1.47E-07 0.0%	1.47E-07 0.0%	1.47E-07 0.0%	1.47E-07 0.0%	1.47E-07 0.0%	1.15E-05 0.0%	4.17E-05 0.0%
KR 85M	3.09E-02 1.18%	3.09E-02 1.18%	3.09E-02 1.18%	3.09E-02 1.18%	3.09E-02 1.18%	3.09E-02 1.18%	3.19E-02 1.20%	1.13E-01 1.71%
KR 85	1.58E-03 0.06%	1.58E-03 0.06%	1.53E-03 0.06%	1.58E-03 0.06%	1.58E-03 0.06%	1.58E-03 0.06%	5.25E-03 0.20%	2.65E-01 4.01%
KR 87	1.68E-01 6.47%	1.68E-01 6.47%	1.68E-01 6.47%	1.68E-01 6.47%	1.68E-01 6.47%	1.68E-01 6.47%	1.74E-01 6.54%	7.49E-01 11.35%
KR 88	1.06E+00 40.57%	1.06E+00 40.57%	1.06E+00 40.57%	1.06E+00 40.57%	1.06E+00 40.57%	1.06E+00 40.57%	1.06E+00 39.85%	1.55E+00 23.54%
XE131M	3.43E-05 0.0%	3.43E-05 0.0%	3.43E-05 0.0%	3.43E-05 0.0%	3.43E-05 0.0%	3.43E-05 0.0%	4.26E-05 0.0%	4.22E-04 0.0%
XL133	2.96E-01 11.37%	2.96E-01 11.37%	2.96E-01 11.37%	2.96E-01 11.37%	2.96E-01 11.37%	2.96E-01 11.37%	3.17E-01 11.92%	1.01E+00 15.33%
XE133M	4.67E-02 1.79%	4.67E-02 1.79%	4.67E-02 1.79%	4.67E-02 1.79%	4.67E-02 1.79%	4.67E-02 1.79%	4.70E-02 1.76%	7.71E-02 1.17%
XE133	6.50E-01 24.95%	6.50E-01 24.95%	6.50E-01 24.95%	6.50E-01 24.95%	6.50E-01 24.95%	6.50E-01 24.95%	6.68E-01 25.07%	2.10E+00 31.84%
XE138	3.12E-01 11.97%	3.12E-01 11.97%	3.12E-01 11.97%	3.12E-01 11.97%	3.12E-01 11.97%	3.12E-01 11.97%	3.15E-01 11.84%	6.53E-01 9.89%
AR 41	4.27E-02 1.64%	4.27E-02 1.64%	4.27E-02 1.64%	4.27E-02 1.64%	4.27E-02 1.64%	4.27E-02 1.64%	4.27E-02 1.60%	7.59E-02 1.15%
TOTAL	2.61E+00	2.61E+00	2.61E+00	2.61E+00	2.61E+00	2.61E+00	2.66E+00	6.60E+00

HCS

Table 4.11L

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
 ALARA ANNUAL INTEGRATED POPULATION DOSE SUMMARY (HANREN)
 PATHWAY = *TGTAL*

HCOS

NUCLIDE	T.BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
KR 83A	1.47E-07 0.0%	1.47E-07 0.0%	1.47E-07 0.0%	1.47E-07 0.0%	1.47E-07 0.0%	1.47E-07 0.0%	1.15E-05 0.0%	4.17E-05 0.0%
KR 85M	3.09E-02 0.71%	3.09E-02 0.71%	3.09E-02 0.46%	3.09E-02 0.70%	3.09E-02 0.82%	3.09E-02 0.25%	3.19E-02 0.73%	1.13E-01 1.36%
KR 85	1.58E-03 0.04%	1.58E-03 0.04%	1.58E-03 0.02%	1.58E-03 0.04%	1.58E-03 0.04%	1.58E-03 0.01%	5.25E-03 0.12%	2.65E-01 3.17%
KR 87	1.68E-01 3.86%	1.68E-01 3.86%	1.68E-01 2.52%	1.68E-01 3.85%	1.68E-01 4.48%	1.68E-01 1.37%	1.74E-01 3.96%	7.49E-01 8.98%
KR 88	1.06E+00 24.22%	1.06E+00 24.24%	1.06E+00 15.76%	1.06E+00 24.12%	1.06E+00 28.09%	1.06E+00 8.60%	1.06E+00 24.15%	1.55E+00 18.63%
XE131M	3.43E-05 0.0%	3.43E-05 0.0%	3.43E-05 0.0%	3.43E-05 0.0%	3.43E-05 0.0%	3.43E-05 0.0%	4.26E-05 0.0%	4.22E-04 0.0%
XE133	2.96E-01 6.79%	2.96E-01 6.80%	2.96E-01 4.42%	2.96E-01 6.76%	2.96E-01 7.87%	2.96E-01 2.41%	3.17E-01 7.22%	1.01E+00 12.13%
XE135M	4.67E-02 1.07%	4.67E-02 1.07%	4.67E-02 0.70%	4.67E-02 1.07%	4.67E-02 1.24%	4.67E-02 0.38%	4.70E-02 1.07%	7.71E-02 0.92%
XE135	6.50E-01 14.90%	6.50E-01 14.91%	6.50E-01 9.71%	6.50E-01 14.84%	6.50E-01 17.28%	6.50E-01 5.29%	6.68E-01 15.19%	2.10E+00 25.19%
XE138	3.12E-01 7.15%	3.12E-01 7.15%	3.12E-01 4.66%	3.12E-01 7.12%	3.12E-01 8.29%	3.12E-01 2.54%	3.15E-01 7.17%	6.53E-01 7.83%
I 131	1.62E-02 0.37%	7.34E-03 0.17%	1.92E-02 0.29%	2.28E-02 0.52%	2.73E-02 0.72%	5.96E+00 48.50%	4.35E-03 0.10%	5.28E-03 0.06%
I 133	5.42E-03 0.12%	7.19E-03 0.16%	8.44E-03 0.13%	1.20E-02 0.27%	1.61E-02 0.43%	2.01E+00 16.33%	2.26E-03 0.05%	2.75E-03 0.03%
C 14	1.52E+00 34.91%	1.52E+00 34.94%	3.83E+00 57.17%	1.52E+00 34.76%	9.20E-01 24.46%	1.52E+00 12.40%	1.52E+00 34.65%	1.52E+00 18.26%
AR 41	4.27E-02 0.98%	4.27E-02 0.98%	4.27E-02 0.64%	4.27E-02 0.98%	4.27E-02 1.14%	4.27E-02 0.35%	4.27E-02 0.97%	7.59E-02 0.91%
H 3	9.37E-02 2.15%	9.37E-02 2.15%	0.0 0.0%	9.37E-02 2.14%	8.88E-02 2.36%	9.37E-02 0.76%	9.37E-02 2.13%	9.37E-02 1.12%
CR 51	7.54E-05 0.0%	2.09E-04 0.0%	7.47E-05 0.0%	7.47E-05 0.0%	7.43E-05 0.0%	7.51E-05 0.0%	9.99E-05 0.0%	8.83E-05 0.0%
MR 59	1.69E-03 0.04%	2.55E-03 0.06%	1.64E-03 0.02%	1.94E-03 0.04%	1.72E-03 0.05%	1.64E-03 0.01%	1.81E-03 0.04%	1.92E-03 0.02%
FE 59	2.99E-04 0.0%	9.07E-04 0.02%	3.08E-04 0.0%	2.82E-03 0.06%	2.21E-04 0.0%	2.21E-04 0.0%	3.65E-04 0.0%	2.60E-04 0.0%
CO 58	3.80E-04	7.00E-04	3.11E-04	3.59E-04	3.11E-04	3.11E-04	4.07E-04	3.65E-04

Alara Tot

Table 4.11m

Table 4.11m

CO 60	0.39E-02	9.16E-02	8.21E-02	8.28E-02	6.71E-02	8.21E-02	8.50E-02	9.66E-02	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	1.52E	2.10E	1.23E	1.69E	2.18E	0.67E	1.53E	1.16E												
ZN 67	7.91E-04	5.92E-04	4.12E-04	8.05E-04	7.15E-04	2.31E-04	2.59E-04	2.65E-04	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	0.01E	0.01E	0.0%	0.02E	0.02E	0.0%	0.0%	0.0%												
SK 89	2.84E-03	9.24E-03	9.91E-02	1.59E-07	1.59E-07	1.59E-07	1.44E-03	1.85E-07	0.0%	0.0%	0.0%	0.03E	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	0.07E	0.21E	1.48E	0.0%	0.0%	0.0%	0.03E	0.0%												
SK 90	7.16E-03	3.08E-04	2.10E-02	0.0	0.0	0.0	3.73E-05	0.0	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	0.12E	0.0%	0.31E	0.0%	0.0%	0.0%	0.0%	0.0%												
ZK 95	3.44E-05	1.70E-04	3.57E-05	3.46E-05	3.99E-05	3.40E-05	5.96E-05	3.95E-05	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%												
SB124	2.34E-04	1.09E-03	2.53E-04	2.22E-04	2.21E-04	2.21E-04	3.42E-04	2.55E-04	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	0.0%	0.02E	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%												
CS134	7.84E-03	3.71E-03	7.53E-03	1.17E-02	5.51E-03	3.62E-03	4.51E-03	4.22E-03	0.0%	0.0%	0.03E	0.10E	0.05E	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	0.18E	0.09E	0.11E	0.27E	0.15E	0.03E	0.10E	0.05E												
CS136	1.85E-05	1.25E-05	1.39E-05	2.12E-05	1.69E-05	1.14E-05	1.21E-05	1.29E-05	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%												
CS137	1.55E-02	1.04E-02	2.15E-02	2.34E-02	1.34E-02	1.03E-02	1.18E-02	1.20E-02	0.0%	0.0%	0.0%	0.27E	0.14E	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	0.36E	0.24E	0.32E	0.53E	0.39E	0.09E	0.27E	0.14E												
BA140	3.32E-04	1.21E-03	1.15E-03	2.79E-04	2.78E-04	2.78E-04	2.55E-03	3.17E-04	0.0%	0.0%	0.0%	0.06E	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	0.0%	0.03E	0.0%	0.0%	0.0%	0.0%	0.06E	0.0%												
CE141	1.07E-05	2.89E-04	1.21E-05	1.16E-05	1.11E-05	1.06E-05	4.80E-05	1.19E-05	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%												
TOTAL	4.36E+00	4.36E+00	6.70E+00	4.38E+00	3.76E+00	4.23E+01	4.40E+00	8.34E+00	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%

Table 4.11n

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOFF CREEK GENERATING STATION
 ALASKA ANNUAL INTEGRATED POPULATION DOSE SUMMARY (MARREM)

PATHWAY	L. BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
PLUKE	2.61E+00	2.61E+00	2.61E+00	2.61E+00	2.61E+00	2.61E+00	2.66E+00	6.63E+00
	59.72%	55.76%	38.91%	59.46%	69.25%	21.20%	60.59%	79.12%
GRASS	1.06E-01	1.06E-01	1.06E-01	1.06E-01	1.06E-01	1.06E-01	1.06E-01	1.24E-01
	2.42%	2.42%	1.58%	2.41%	2.81%	0.86%	2.40%	1.49%
LABOR	3.63E-02	3.34E-02	1.14E-02	4.53E-02	4.99E-02	4.03E+00	3.42E-02	2.70E-02
	3.78%	0.77%	0.17%	1.65%	1.30%	32.78%	0.78%	0.32%
VEGET	1.26E+00	1.26E+00	3.12E+00	1.26E+00	7.76E-01	2.02E+00	1.24E+00	1.24E+00
	28.85%	28.95%	46.56%	28.76%	20.62%	16.42%	28.24%	14.36%
COW MILK	2.75E-01	2.69E-01	5.76E-01	2.81E-01	1.62E-01	3.40E+00	2.67E-01	2.67E-01
	6.31%	6.18%	3.61%	6.42%	4.32%	27.65%	6.09%	3.20%
FEED	6.37E-02	6.40E-02	2.80E-01	8.56E-02	6.41E-02	1.33E-01	8.34E-02	8.34E-02
	1.92%	1.93%	4.18%	1.91%	1.70%	1.08%	1.90%	1.00%
TOTAL*	4.50E+00	4.34E+00	6.70E+00	4.23E+00	2.76E+00	1.23E+01	4.40E+00	8.34E+00

ADDITIONAL INFORMATION

Supplied In Response To Item 4

Section A 1 Air Pathways

Section A 2 Liquid Pathways

AIR PATHWAYS

Agricultural and Farming Practices within 50 Miles of Artificial Island.

The available data on farm production and agricultural practices within 50 miles of Artificial Island was collected and condensed to provide input parameters for radiological dose assessment. A detailed survey was conducted for the area within five miles of the Artificial Island site to obtain specific information within the immediate site environs. This survey data was current through 1975, having last been updated in February and March of 1976.

Thirty-one farms are located, at least partially, within five miles of Artificial Island as shown in Figure A 1.1 and Table A 1.1. Most of these farms are relatively small and often the products are used entirely by the individual farmers. Data collected for this part of the study was obtained by direct contact with the individual farmers and landowners. All farms and potential vegetable gardens (≥ 500 sq. ft.) located at least partially within five miles of Artificial Island were located by visual surveillance and their locations marked on USGS topographic maps. Farmers were interviewed and data collected on a standard survey sheet by trained personnel familiar with the area. The 31 farms within the five-mile radius of Artificial Island produce 217 metric tons of fruits and vegetables and 1,360 metric tons of field crops per year. Apples, peaches, sweet corn, potatoes and tomatoes make up the majority of human food production. Corn (for grain or silage) and alfalfa are the prevalent field crops grown.

Only two dairy farms are located with five miles of Artificial Island. These farms and the nearest vegetable garden in each sector are listed in Table A 1.3. Annual milk production from these two farms is 4.2×10^5 liters.

Other major animal products produced are beef and chickens. The total annual beef and poultry production is 46 metric tons.

The data on agricultural practices within 50 miles of Artificial Island was extracted from the U. S. Department of Commerce Census of Agriculture (USDCCOA) publications for the states of Delaware, Maryland, New Jersey and Pennsylvania, and from the Department of Agriculture Crop Reporting Service (CRS) publications for the respective states. In general, USDCCOA data was reported for 1969 and CRS data was available for 1974. The latter also includes summaries of the prior few years. The data showed a decrease in acreage in production over the past decade probably due to higher land costs, and suburban expansion and development. This has been offset to some extent by increases in yield, such that the total production figures have remained stable for the past several years. It was assumed that the 1969 through 1975 data could be combined without significantly affecting the applicability of the data.

Agricultural production has been divided into five areas: livestock, dairy, fruits, vegetables and field crops. County production data was apportioned into the sixteen $22 \frac{1}{2}$ degree sectors and appropriate radial intervals by assuming that production was uniform throughout the arable county land area. After subtracting urban and forested

areas, the area of the county in the sector segment of interest was determined and converted to a fraction of the county's total agricultural land. This fraction was used to calculate the fractions of each type of country agricultural production in the area of interest. For distances beyond five miles, "o" entry in the distribution tables indicates that all land within the sector was urban or forested as far as could be determined from the USGS maps used for the apportionment. Where two or more counties intersected within a segment, their respective productions were summed.

The annual meat and poultry production within 50 miles of Artificial Island is given in Table A 1.4 for the areas of interest. Table A 1.5 gives the annual production figures of beef only for the same areas. Meat and poultry production within 50 miles of Artificial Island is summarized in Table A 1.6.

Annual milk production within 50 miles of Artificial Island is given in Table A 1.7. The contributions of the two individual farms within five miles can be easily seen. The distribution of this milk is summarized in Table A 1.8.

Annual production of fruits and vegetables within 50 miles of Artificial Island are given in Tables A 1.9 and A 1.10 respectively. This data is summarized by crop type in Table A 1.13. The distribution of the truck farming produce is summarized in Table A 1.11. Annual field crop production is given in Table A 1.12 and summarized by crop type in Table A 1.14.

Information on grazing season, feeding regimes and milk production was gathered from site area field surveys. From this data, pasture grass density estimates were arrived at by an application of a bovine energy conversion model. The field survey also provided yield statistics for harvested crops for beef and dairy cattle feeding, as summarized in Table A 1.14.


In a survey of 78 dairy farms with a 50-mile radius of Artificial Island, pasture areas ranged from 4 to 130 acres with an average pasturage of 31 acres. The number of dairy cattle ranged from a single cow to as many as 300 cows on a farm. The average number of cows per farm was 61. Thus, approximately two cows per acre grazed in the sample area. The average milk production was about 30 pounds per cow per day (14 kg/cow/day).

The majority of farms reported grazing from April-May through November. Most of the dairy herds were reported to be pastured 24 hours a day during these months. Based on a 30-day removal for green crop, typical of Mid-Atlantic States farms, the pasture consumption was computed to range from a minimum of 1.8 kg/cow/day to a maximum of 74 kg/cow/day, averaging around 6 kg/cow/day. An average grazing area was computed to be $2,375\text{m}^2/\text{cow/day}$. The pasture density so derived ranged from 0.05 kg/m^2 to 1.7 kg/m^2 with an average of 0.23 kg/m^2 , so derived ranged from 0.05 kg/m^2 to 1.7 kg/m^2 with an average of 0.23 kg/m^2 .

SUMMARY OF HIGHEST ELEVATIONS (FEET) WITHIN 50-MILES OF ARTIFICIAL ISLAND

DISTANCE RANGE (MILES)

DIRECTION	0-1	1-2	2-3	3-4	4-5	5-10	10-20	20-30	30-40	40-50
N	10	20	20	River & Marsh	River & Marsh	20	100	450	600	600
NNE	10	Marsh & Mud	Marsh & River	Marsh	20	50	100	100	350	258
NE	10	River & Marsh	River & Marsh	10	20	50	200	200	250	164
ENE	10	10	Marsh & River	15	12	50	140	135	150	200
E	20	10	River & Marsh	15	10	100	117	106	120	200
ESE	20	6	Marsh & River	10	10	38	200	100	65	100
SE	20	River	River	River	River	10	10	9	11	22
SSE	20	River	River	River	River	10	10	10	9	15
S	20	River	River	17	20	10	50	53	56	52
SSW	20	River	River & Marsh	25	12	50	100	75	70	63
SW	20	River	River & Marsh	12	22	100	75	75	75	75
WSW	20	River	River & Marsh	16	30	100	69	100	70	50
W	20	River	20	30	60	100	85	84	350	457
WNW	20	River	River	24	31	67	71	445	600	750
NW	10	River	River	23	30	100	500	500	573	828
NNW	10	10	River	10	30	100	500	450	662	1,000



FARMS WITHIN 5 MILES OF THE SITE

Fig. A.1.1

IDENTIFICATION KEY FOR FIGURE A 1.1
FARMS WITHIN A FIVE MILE RADIUS OF ARTIFICIAL ISLAND

Map Location	Farm Name	Direction & Distance (miles) from Artificial Island	
1	Dukes	SSW	3.8
2	L. Voss	W	3.8
3	Cleaver	W	3.9
4	Alexander	WNW	4.0
5	Kux	NW	3.9
6	Sowers	NNE	4.2
7	Farnkoph	NNE	4.8
8	Hinchman	NE	4.0
9	Farrell	NE	4.4
10	R. Davis	NE	4.7
11	McLain	S	4.2
12	Spicer	SSW	5.0
13	Steller	SW	4.4
14	Sheltzer	SW	5.0
15	Dickinson	SW	5.0
16	Cleaver	WSW	4.4
17	Bolton	WSW	4.4
18	Hammond	WSW	4.7
19	Phillips	W	4.4
20	Yoss	W	4.6
21	Coleman	W	4.7
22	Hanan	W	5.0
23	Armstrong	WNW	4.0
24	Currey	WNW	4.0
25	Betts	WNW	4.4
26	Woolleyhan	WNW	4.7
27	Willoughby	NW	4.2
28	Lesser	NNW	4.4
29	Meyer	NNW	4.6
30	W. Davis	SSW	5.1
31	L. Davis	SSW	5.2

Nearest Milk Producing Animals and Vegetable Gardens

(>500 ft²) within 5 miles of Artificial Island

Direction	Nearest Milk Animals		Nearest Vegetable Gardens	
	Map* Location	(Miles)	Map Location	(Miles)
N		---		---
NNE	7	4.8	6	4.2
NE		---	8	4.0
ENE		---		---
E		---		---
ESE		---		---
SE		---		---
SSE		---		---
S		---	11	4.2
SSW		---	1	3.8
SW		---	13	4.4
WSW		---	16	4.4
W	22	5.0	2	3.8
WNW		---	4	4.0
NW		---	5	3.9
NNW		---	28	4.4

*Map location on Figure A 1.1

Annual Meat and Poultry Production within 50 miles of Artificial Island
(kg/year)

Direction	Distance Range in Miles										Total
	0-1	1-2	2-3	3-4	4-5	5-10 ⁵	10-20 ⁶	20-30 ⁶	30-40 ⁶	40-50	
N	0	0	0	0	0	3.83 E 4	3.43 E 5	1.66 E 5	9.71 E 5	1.81 E 6	3.33 E 6
NNE	0	0	0	0	7.85 E 3	3.05 E 5	1.06 E 6	4.61 E 6	1.59 E 5	0	6.14 E 6
NE	0	0	0	0	1.15 E 4	3.05 E 5	9.53 E 5	0	7.81 E 5	2.66 E 6	4.71 E 6
ENE	0	0	0	0	0	2.23 E 5	7.24 E 5	3.72 E 6	1.06 E 6	4.11 E 5	6.14 E 6
E	0	0	0	0	0	8.74 E 4	3.51 E 5	1.60 E 6	6.07 E 5	1.36 E 5	2.78 E 6
ESE	0	0	0	0	0	5.65 E 4	3.96 E 5	0	1.99 E 5	1.71 E 6	2.36 E 6
SE	0	0	0	0	0	0	0	0	2.34 E 6	-1.10 E 7	-1.33 E 7
SSE	0	0	0	0	0	0	2.07 E 6	2.65 E 6	5.80 E 6	-3.89 E 7	-4.94 E 7
S	0	0	0	0	0	3.35 E 5	1.26 E 6	1.04 E 6	1.50 E 6	3.46 E 5	4.28 E 6
SSW	0	0	0	0	0	1.62 E 5	4.20 E 5	7.24 E 5	8.36 E 6	-1.80 E 7	-2.77 E 7
SW	0	0	0	0	0	1.89 E 5	4.22 E 5	2.44 E 6	3.03 E 6	2.61 E 6	8.69 E 6
WSW	0	0	0	0	0	3.72 E 3	1.89 E 5	7.33 E 5	1.25 E 6	2.14 E 6	9.44 E 5
W	0	0	0	0	0	1.86 E 4	1.83 E 5	8.58 E 5	4.31 E 5	9.16 E 5	3.07 E 6
WNW	0	0	0	0	0	1.34 E 3	1.62 E 5	7.82 E 5	2.05 E 6	9.35 E 6	-1.65 E 7
NA	0	0	0	0	0	2.40 E 2	2.69 E 4	5.04 E 5	2.87 E 6	4.45 E 6	-1.10 E 7
NNW	0	0	0	0	0	0	0	4.10 E 5	3.65 E 6	8.48 E 6	-1.25 E 7
Total	0	0	0	2.84 E 3	4.30 E 4	2.07 E 6	1.10 E 7	2.40 E 7	4.53 E 7	1.18 E 8	2.00 E 8

Meat & Poultry = Total Production

Annual Beef Production within 50 Miles of Artificial Island
(kg/year)

Direction	Distance Range in Miles										Total
	0-1	1-2	2-3	3-4	4-5	5-10	10-20	20-30	30-40	40-50	
N	0				3.00 E 4	2.70 E 5	3.60 E 4	2.10 E 5	6.41 E 5	1.19 E 6	
NNE	7.80 E 3	2.40 E 5	8.39 E 5	1.88 E 5	6.48 E 3	0				1.28 E 6	
NE	1.15 E 4	2.40 E 5	7.49 E 5	0	3.24 E 4	8.65 E 5				1.50 E 6	
ENE	0	1.80 E 5	5.69 E 5	3.22 E 5	4.18 E 4	3.58 E 4				1.15 E 6	
E	0	6.67 E 4	2.10 E 5	2.70 E 5	4.69 E 4	3.72 E 3				5.98 E 5	
ESE	0	3.38 E 4	2.37 E 5	0	3.55 E 4	1.14 E 5				4.20 E 5	
SE	0	0	0	0	3.29 E 4	1.51 E 5				1.84 E 5	
SSE	0	0	3.85 E 5	4.91 E 5	6.73 E 5	3.88 E 5				1.94 E 6	
S	0	7.18 E 4	2.71 E 5	1.92 E 5	2.78 E 5	6.41 E 4				8.76 E 5	
SSW	0	9.60 E 4	1.43 E 5	8.18 E 4	2.43 E 5	5.25 E 5				1.08 E 6	
SW	0	1.00 E 5	2.04 E 5	6.61 E 5	7.35 E 5	6.64 E 5				2.36 E 6	
WSW	3.72 E 3	1.00 E 5	4.38 E 5	6.33 E 5	8.70 E 5	4.22 E 5				2.47 E 6	
W	1.86 E 4	1.00 E 5	5.94 E 5	3.30 E 5	7.20 E 5	1.74 E 6				3.50 E 6	
WNW	1.32 E 3	3.60 E 4	5.17 E 5	1.29 E 6	4.04 E 6	5.18 E 6				1.11 E 7	
Wd	2.40 E 2	0	1.44 E 4	3.48 E 5	1.81 E 6	4.75 E 6				9.55 E 6	
WNW	0	0	0	0	1.57 E 5	2.16 E 6				6.22 E 6	
Total	0	0	0	2.40 E 2	4.28 E 4	1.35 E 6	5.77 E 6	6.46 E 6	1.28 E 7	1.94 E 7	4.58 E 7

Beef

SUMMARY OF MEAT AND POULTRY PRODUCTION
WITHIN 50 MILES OF ARTIFICIAL ISLAND

Livestock	Number of Animals	Meat Production (kg/year)	Production (% of Total)
Cattle	3.82 E 5	4.58 E 7	24
Sheep	1.54 E 4	5.70 E 5	--
Hogs	1.52 E 5	5.64 E 7	28
Broilers	5.06 E 7	9.62 E 7	48

Beef + Poultry 4.58
 9.62
 14.20

Hogs 5.64
 19.84
 .06

Salmon Hope Creek Vegetation

DATA from Applicants

NAME: Tables A - 1.9, 1.10, 1.12, 1.14

DEPARTURE FROM STATE (GALLONS)

	1-1	1-2	2-3	3-4	4-5	5-6	6-7	7-8	8-9	9-10	10-20	20-30	30-40	40-50	TOTAL
N				6.883	0.044	0.180	1.333	6.040	0.235	0.196					
ANE				7.60	16.43	1.89	4.17	4.37	0.150						
NE					0.911		3.72		1.58	2.60					
ENE						0.894	2.77	4.20	1.53	2.21					
E						0.543	5.44	4.76	2.32	0.778					
ESE						0.914	6.15		1.01	0.995					
SE									0.126	1.58					
SSE								1.89	2.13	1.48					
S					0.252	0.134	6.921	0.739	1.01	0.256					
SSW				3.12	0.278	0.160	0.332	0.095	0.642	1.47					
SW					2.514	0.178	0.353	0.702	0.483	0.572					
WSW					0.602	1.24	0.526	0.916	1.50	0.735					
W				0.233	0.594	0.178	0.577	0.239	0.338	0.969					
WNW				1.20	0.571	0.153	0.569	0.512	1.43	1.21					
NW				1.792	0.660	0.025	0.523	0.877	0.756	0.824					
NNW					0.091			0.249	0.617	1.21					

Total of 1.9, 1.10, & part of 1-12

Salmon Hope Creek Vegetation (Appl. Tables A - 1.9, 1.10, 1.12)
 Milk (" " Table A - 1.7)
 Meat (" " " A - 1.4)

0-5-10

Annual Milk Production within 50 Miles of Artificial Island
(1/yr.)

Distance Range in Miles

Direction	0-1	1-2	2-3	3-4	4-5	5-10	10-20	20-30	30-40	40-50	Total
N	0					3.27 E 6	2.94 E 6	3.48 E 6	2.03 E 6	6.42 E 6	1.21 E 7
NNE	1.36 E 5					2.52 E 6	9.15 E 6	1.81 E 6	6.25 E 4	0	1.37 E 7
NE	0					2.52 E 6	8.18 E 6	0	2.49 E 5	-1.04 E 7	2.14 E 7
ENE	0					1.36 E 6	6.20 E 6	3.34 E 6	3.74 E 5	2.96 E 5	1.22 E 7
E	0					7.13 E 5	1.77 E 6	2.56 E 6	3.53 E 5	0	5.34 E 6
ESE	0					2.85 E 5	2.00 E 6	0	2.85 E 5	9.15 E 5	3.48 E 6
SE	0					0	0	0	2.97 E 5	1.32 E 6	1.62 E 6
SSE	0					0	2.99 E 6	3.82 E 6	5.28 E 6	3.73 E 6	1.58 E 7
S	0					1.30 E 6	2.70 E 6	1.49 E 6	2.16 E 6	4.97 E 5	8.14 E 6
SSW	0					1.56 E 6	2.15 E 6	6.73 E 5	0	0	4.38 E 6
SW	0					1.32 E 6	3.24 E 6	6.95 E 6	7.17 E 6	6.69 E 6	2.59 E 7
WSW	0					1.32 E 6	5.54 E 6	7.74 E 6	1.11 E 7	5.15 E 6	3.14 E 7
W	2.39 E 5					1.82 E 6	7.35 E 6	3.48 E 6	7.52 E 6	-1.70 E 7	3.74 E 7
WNW	0					1.56 E 6	6.86 E 6	1.36 E 7	-4.03 E 7	-4.84 E 7	1.11 E 8
WW	0					2.60 E 5	5.63 E 6	2.02 E 7	2.7 E 7	-4.80 E 7	1.02 E 8
WNW	0					0	0	2.49 E 6	2.27 E 7	-4.06 E 7	6.53 E 7
Total	0	0	0	0	4.25 E 5	1.87 E 7	6.67 E 7	6.84 E 7	1.28 E 8	1.89 E 8	4.71 E 8

milk

SUMMARY OF MILK DISTRIBUTION
WITHIN 50 MILES OF ARTIFICIAL ISLAND*

<u>State</u>	<u>New Jersey</u>		<u>Pennsylvania</u>	
Total Utilization %	Fresh 67	Processed 33	Fresh 75	Processed 25
Make-up of Processed:				
Ice Cream & Frozen Products		27		12
Creamery Butter				5
Cheese & other		6		8

*No data available for Delaware and Maryland; however, the distribution is assumed to be similar to that shown for New Jersey and Pennsylvania.

Relative milk production from New Jersey, Maryland, Delaware and Pennsylvania Counties within 50 miles of Artificial Island:

<u>Production</u> %	<u>New Jersey</u>	<u>Maryland</u>	<u>Delaware</u>	<u>Pennsylvania</u>
	10	21	6	63

Annual Truck Farming Production - Fruit, within 50 Miles of Artificial Island
(kg/year)

Direction	Distance Range in Miles										Total
	0-1	1-2	2-3	3-4	4-5	5-10	10-20	20-30	30-40	40-50	
N						2.49 E 3	1.92 E 4	6.97 E 3	4.07 E 4	1.34 E 4	8.27 E 4
NNE					3.00 E 2	1.59 E 4	6.98 E 4	1.13 E 7	3.89 E 5	0	1.17 E 7
NE					2.40 E 3	1.59 E 4	6.24 E 4	0	6.96 E 6	6.77 E 6	1.38 E 7
ENE						1.49 E 4	4.73 E 4	8.56 E 6	4.27 E 6	8.50 E 6	2.14 E 7
E						1.22 E 5	3.16 E 6	2.71 E 6	3.90 E 6	1.98 E 6	1.19 E 7
ESE						5.08 E 5	3.56 E 6	0	4.74 E 5	9.32 E 5	5.47 E 6
SE						0	0	0	6.52 E 4	1.27 E 5	1.92 E 5
SSE						0	8.67 E 5	1.11 E 6	1.50 E 6	7.24 E 5	4.19 E 6
S						7.58 E 3	4.88 E 5	4.33 E 5	8.04 E 4	2.42 E 5	1.25 E 6
SSW				1.28 E 3		9.10 E 3	1.07 E 5	2.27 E 3	5.28 E 3	1.14 E 4	1.37 E 5
SW					1.08 E 3	1.06 E 4	1.29 E 4	1.45 E 4	2.13 E 4	1.78 E 4	7.82 E 4
WSW						1.06 E 4	1.54 E 5	1.30 E 5	8.59 E 3	3.72 E 5	6.76 E 5
W						1.04 E 4	2.86 E 5	1.99 E 5	3.40 E 5	6.49 E 5	1.48 E 6
WNW					4.65 E 2	9.10 E 3	2.18 E 5	2.22 E 5	6.40 E 5	5.55 E 5	1.64 E 6
NW				4.85 E 2	1.19 E 3	1.52 E 3	8.15 E 4	3.86 E 5	6.50 E 4	1.08 E 5	6.44 E 5
NNW						0	0	2.02 E 4	5.31 E 4	9.31 E 4	1.66 E 5
Total				1.76 E 3	5.44 E 3	7.47 E 5	9.37 E 6	2.74 E 7	2.12 E 7	2.16 E 7	8.03 E 7

Truck → Fruit

Annual Truck Farming Production - Vegetables, within 50 Miles of Artificial Island
(kg/year)

Direction	Distance Range in Miles										
	0-1	1-2	2-3	3-4	4-5	5-10	10-20	20-30	30-40	40-50	Total
N					0	1.45 E 6	1.30 E 7	2.80 E 5	1.65 E 6	1.20 E 6	1.76 E 7
N.E					1.64 E 5	1.16 E 7	4.07 E 7	3.21 E 7	1.10 E 6	0	8.57 E 7
NE					6.71 E 3	1.16 E 7	3.63 E 7	0	8.79 E 6	1.78 E 7	7.45 E 7
E.NE					0	8.72 E 6	2.76 E 7	3.30 E 7	1.10 E 7	1.35 E 7	9.38 E 7
E					0	4.55 E 6	5.12 E 7	4.46 E 7	1.92 E 7	5.80 E 6	1.25 E 8
ESE					0	8.24 E 6	5.77 E 7	0	9.97 E 6	8.69 E 6	8.46 E 7
SE					0	0	0	0	1.06 E 6	1.50 E 7	1.61 E 7
SSE					0	0	1.29 E 7	1.65 E 7	1.80 E 7	1.22 E 7	5.96 E 7
S					1.82 E 3	1.09 E 6	8.04 E 6	6.46 E 6	9.32 E 6	2.15 E 6	2.71 E 7
SSW					0	1.31 E 6	2.96 E 6	7.20 E 5	6.16 E 6	1.33 E 7	2.44 E 7
SW					1.82 E 4	1.53 E 6	3.13 E 6	5.21 E 6	4.24 E 6	4.43 E 6	1.86 E 7
WSW					4.54 E 3	1.22 E 7	4.36 E 6	7.73 E 6	1.28 E 7	6.03 E 6	4.31 E 7
W					4.54 E 3	1.53 E 6	4.67 E 6	1.82 E 6	2.28 E 6	7.66 E 6	1.80 E 7
WNW					5.14 E 3	1.31 E 6	4.66 E 6	3.22 E 6	8.46 E 6	7.90 E 6	2.56 E 7
N.W			1.23 E 3		3.63 E 3	2.18 E 5	4.43 E 6	5.89 E 6	3.86 E 6	6.44 E 6	2.08 E 7
W.W					9.08 E 2	0	0	2.07 E 6	3.16 E 6	6.00 E 6	1.12 E 7
Total			1.23 E 3		2.09 E 5	6.53 E 7	2.72 E 8	1.60 E 8	1.21 E 8	1.28 E 8	7.46 E 8

Truck - Veg kg/yr

SUMMARY OF TRUCK FARMING DISTRIBUTION - FRUITS AND VEGETABLES
WITHIN 50 MILES OF ARTIFICIAL ISLAND*

State:	<u>New Jersey</u>		<u>Maryland</u>		<u>Delaware</u>		<u>Pennsylvania</u>	
Utilization %	Fresh-Processed		Fresh-Processed		Fresh-Processed		Fresh-Processed	
<u>FRUIT</u>								
Apples	55 ⁷⁰	45 ⁷⁰	--	--	--	--	37	63
Peaches	99	1	--	--	--	--	89	11
<u>VEGETABLES</u>								
Beans, snap	100	--	20	80	--	100	10	90
Corn, sweet	100	--	--	--	--	100	--	--
Tomatoes	11	89	35	65	--	100	11	89

Relative Fruit and Vegetable Production by State within 50 Miles of Artificial Island:

	<u>New Jersey</u>	<u>Maryland</u>	<u>Delaware</u>	<u>Pennsylvania</u>
Fruits	60 ⁷⁰	10 ⁷⁰	15	15
Vegetables	67	20	8	5

*Based on state data and counties within the 50-mile area.

Table A-1.12 for Humant

NAME:

DATA

DISTANCE FROM SITE (METERS)

	0-1	1-2	2-3	3-4	4-5	5-10	10-20	20-30	30-40	40-50	TOTAL
N					3.490	0.340	3.06 ¹⁵	0.1216	0.656 ¹⁶	0.743 ¹⁶	
NNE				6.813		2.71	9.59 ¹⁵	0.288	0.010		
NE				7.60		2.71	8.27		0.061	1.46	
ENE						2.04	0.76	3.422	0.062	0.058	
E						0.760	2.41	0.329	0.658	0.004	
ESE						0.387	2.72		0.043	0.330	
SE									0.135	0.628	
SSE									1.78	1.86	
S											
SSW				1.74	0.701	1.71	6.84	0.495	0.712	0.165	
SW					1.50	2.05	3.22	0.223	0.255	1.39	
WSW					5.86	2.38	3.94	1.78	0.590	1.22	
W					1.48		7.50	1.30	2.21	0.949	
WNW				0.233	1.40		8.16	0.366	0.760	1.38	
NW				0.077	1.78	0.105	8.09	1.68	5.20	1.64	
NNW							7.15	2.49	3.63	1.69	
								0.405	2.96	5.16	

Table A-1.12 adjusted by
A-1.14

Direction	Distance Range in Miles										
	0-1	1-2	2-3	3-4	4-5	5-10	10-20	20-30	30-40	40-50	Total
N					0	1.45 E 6	1.30 E 7	2.80 E 5	1.65 E 6	1.20 E 6	1.76 E 7
NNE					1.64 E 5	1.16 E 7	4.07 E 7	3.21 E 7	1.10 E 6	0	8.57 E 7
NE					6.71 E 3	1.16 E 7	3.63 E 7	0	8.79 E 6	1.78 E 7	7.45 E 7
ENE					0	5.72 E 6	2.76 E 7	3.30 E 7	1.10 E 7	1.35 E 7	9.38 E 7
E					0	4.55 E 6	5.12 E 7	4.46 E 7	1.92 E 7	5.80 E 6	1.25 E 8
ESE					0	8.24 E 6	5.77 E 7	0	9.97 E 6	8.69 E 6	8.46 E 7
SE					0	0	0	0	1.06 E 6	1.50 E 7	1.61 E 7
SSE					0	0	1.29 E 7	1.65 E 7	1.80 E 7	1.22 E 7	5.96 E 7
S					1.82 E 3	1.09 E 6	8.04 E 6	6.46 E 6	9.32 E 6	2.15 E 6	2.71 E 7
SSW					0	1.31 E 6	2.96 E 6	7.20 E 5	6.16 E 6	1.33 E 7	2.44 E 7
SW					1.82 E 4	1.53 E 6	3.13 E 6	5.21 E 6	4.24 E 6	4.48 E 6	1.86 E 7
WSW					4.54 E 3	1.22 E 7	4.36 E 6	7.73 E 6	1.28 E 7	6.03 E 6	4.31 E 7
W					4.54 E 3	1.53 E 6	4.67 E 6	1.82 E 6	2.28 E 6	7.66 E 6	1.80 E 7
WNW					5.14 E 3	1.31 E 6	4.66 E 6	3.22 E 6	8.46 E 6	7.90 E 6	2.56 E 7
WW				1.23 E 3	3.63 E 3	2.18 E 5	4.43 E 6	5.89 E 6	3.86 E 6	6.44 E 6	2.09 E 7
WWW					9.08 E 2	0	0	2.07 E 6	3.16 E 6	6.00 E 6	1.12 E 7
Total				1.23 E 3	2.09 E 5	6.53 E 7	2.72 E 8	1.60 E 8	1.21 E 8	1.28 E 8	7.46 E 8

Truck - Veg ^{Kg/yr}

Direction	0-1	1-2	2-3	3-4	4-5	5-10	10-20	20-30	30-40	40-50	Total
N						2.49 E 3	1.92 E 4	6.97 E 3	4.07 E 4	1.34 E 4	8.27 E 4
NNE					3.00 E 2	1.59 E 4	6.98 E 4	1.13 E 7	3.89 E 5	0	1.17 E 7
NE					2.40 E 3	1.59 E 4	6.24 E 4	0	6.96 E 6	6.77 E 6	1.38 E 7
ENE						1.49 E 4	4.73 E 4	8.56 E 6	4.27 E 6	8.50 E 6	2.14 E 7
E						1.22 E 5	3.16 E 6	2.71 E 6	3.90 E 6	1.98 E 6	1.19 E 7
ESE						5.08 E 5	3.56 E 6	0	4.74 E 5	9.32 E 5	5.47 E 6
SE						0	0	0	6.52 E 4	1.27 E 5	1.32 E 5
SSE						0	8.67 E 5	1.11 E 6	1.50 E 6	7.24 E 5	4.19 E 6
S						7.58 E 3	4.88 E 5	4.33 E 5	8.04 E 4	2.42 E 5	1.25 E 6
SSW			1.28 E 3			9.10 E 3	1.07 E 5	2.27 E 3	5.28 E 3	1.14 E 4	1.37 E 5
SW				1.08 E 3		1.06 E 4	1.29 E 4	1.45 E 4	2.13 E 4	1.78 E 4	7.82 E 4
WSW						1.06 E 4	1.54 E 5	1.30 E 5	8.59 E 3	3.72 E 5	6.76 E 5
W						1.04 E 4	2.86 E 5	1.99 E 5	3.40 E 5	6.49 E 5	1.48 E 6
WNW					4.65 E 2	9.10 E 3	2.18 E 5	2.22 E 5	6.40 E 5	5.55 E 5	1.64 E 6
TW			4.85 E 2	1.19 E 3		1.52 E 3	8.15 E 4	3.86 E 5	6.50 E 4	1.08 E 5	6.44 E 5
SNW						0	0	2.02 E 4	5.31 E 4	9.31 E 4	1.66 E 5
Total			1.76 E 3	5.44 E 3		7.47 E 5	9.37 E 6	2.74 E 7	2.12 E 7	2.16 E 7	8.03 E 7

Truck → Fruit

HCGS

TABLE A 1.9

Annual Field Crop Production within 50 Miles of Artificial Island
(kg/year)

Direction	Distance Range in Miles										Total
	0-1	1-2	2-3	3-4	4-5	5-10	10-20	20-30	30-40	40-50	
N				0	1.26 E 5	9.76 E 5	8.78 E 6	3.26 E 6	1.88 E 7	2.13 E 7	5.32 E 7
NNE				1.95 E 5	0	7.78 E 6	2.75 E 7	8.27 E 6	2.85 E 5	0	4.40 E 7
NE				2.18 E 5	0	7.78 E 6	2.37 E 7	0	1.76 E 6	4.18 E 7	7.52 E 7
ENE				0	0	5.86 E 6	2.18 E 6	1.21 E 7	1.79 E 6	1.67 E 6	2.36 E 7
E				0	0	2.18 E 6	6.90 E 6	9.43 E 6	1.66 E 6	1.11 E 5	2.03 E 7
ESE				0	0	1.11 E 6	7.79 E 6	0	1.23 E 6	9.45 E 6	1.96 E 7
SE				0	0	0	0	0	3.88 E 6	1.80 E 7	2.19 E 7
SSE				0	0	0	2.83 E 7	3.62 E 7	5.11 E 7	5.33 E 7	1.69 E 8
S				0	2.01 E 4	4.89 E 6	1.96 E 7	1.42 E 7	2.04 E 7	4.72 E 6	6.39 E 7
SSW				4.98 E 4	4.31 E 4	5.87 E 6	7.22 E 6	6.38 E 6	7.32 E 6	3.99 E 7	6.63 E 7
SW				0	1.68 E 5	6.82 E 6	1.13 E 7	5.09 E 7	1.69 E 7	3.50 E 7	1.21 E 8
WSW				0	4.24 E 4	6.82 E 6	2.15 E 7	3.72 E 7	6.33 E 7	2.72 E 7	1.56 E 8
W				6.67 E 3	4.02 E 5	6.82 E 6	2.34 E 7	1.05 E 7	2.18 E 7	3.95 E 7	1.02 E 8
WNW				3.45 E 4	3.02 E 3	5.87 E 6	2.32 E 7	4.82 E 7	1.49 E 8	4.69 E 7	2.73 E 8
WW				2.22 E 3	5.11 E 4	9.79 E 5	2.05 E 7	7.13 E 7	1.04 E 8	4.84 E 7	2.45 E 8
WNW				0	0	0	0	3.16 E 7	8.49 E 7	1.48 E 8	2.45 E 8
Total	0	0	0	5.06 E 5	8.55 E 5	6.39 E 7	2.55 E 8	3.20 E 8	6.00 E 8	4.62 E 8	1.70 E 9

Total Field Crops (includes Hay & Silage)

SUMMARY OF TRUCK FARMING PRODUCTION - FRUITS AND VEGETABLES
WITHIN 50 MILES OF ARTIFICIAL ISLAND

<u>FRUIT</u>	<u>0 - 5 Miles</u>		<u>0 - 50 Miles</u>	
	Kgx10 ³	%	Kgx10 ⁶	%
Apples	4.22	59	39.9	50
Cherries	0.02	--	0.1	--
Grapes	0.85	12	0.4	1
Peaches	0.98	14	36.5	45
Pears	0.29	4	0.5	1
Plums	0.06	--	0.1	--
Strawberries	0.78	11	2.8	3

<u>VEGETABLES</u>			<u>0 - 50 Miles</u>	
			Kgx10 ⁶	%
Snap Beans			40	5
Cabbage, Lettuce, Spinach			87	12
Sweet Corn			81	11
Tomatoes			271	36
Potatoes			171	23
Others			98	13

SUMMARY OF FIELD CROP PRODUCTION WITHIN 50 MILES

OF ARTIFICIAL ISLAND

<u>TYPE</u>	<u>AREA</u> (10^6 m^2)	<u>QUANTITY</u> (10^6 kg)	<u>YIELD</u> (kg/m^2)	<u>PRODUCTION</u> (% of total)
Corn Silage	256	892	3.48	39
<u>Grain Corn</u>	1360	890	0.65	38
Alfalfa	323	223	0.69	10
Other Hay	271	119	0.44	5
Wheat	321	90	0.28	4
Barley	220	68.2	0.31	3
Oats	53	12.7	0.24	1

1 Bushel = 60 lb = 27 Kg
 RAB Memo gives 6.4 kg/bw. wheat
 + 0.57 kg/bw Corn

Wheat, etc = $(6.4/27) \times 170.9 \text{ Kg} = 40.5 \times 10^6$
 Corn = $(0.57/27) \times 890 \text{ Kg} = 18.8$

For humans \rightarrow Tot grain = $5.93 \times 10^7 \text{ Kg/yr}$
 Ratio this to total production in
 Table A1.12 ^(1.7×10^8) to get correct amounts
 for humans. Then add to
 Fruit & Veg Tables for
 Total Vegetation production,
 & input to Gaspar.

LIQUID PATHWAYS

Surface Water

Information on water usage in the region of interest was obtained from the concerned federal, state and other public agencies, from available statistical publications and in some cases by direct survey of its users.

South of Philadelphia there are no private or municipal utilities which use the Delaware River or Bay as a potable water source, due to the saline content of the water.¹

Industrial use, assumed to be for cooling and processing, is shown in Table A 2.2. Facilities for recreational use of the river and bay are presented in Table A 2.1⁽¹⁾

Information on marinas was obtained in two ways. A search of the telephone directories for the areas involved resulted in information obtained directly from the marinas themselves. The second source was "the Boating Almanac"² for the Delaware River and Bay area. Total capacity is nearly 1700 boats; boat rentals and charter and party boats total 100 or more. Over half of these marinas are located in New Jersey along the Cohansey River, the Maurice River, and the coast inbetween.


Estimates of current and projected recreational users are presented in Tables A 2,3 & 4 for Delaware and Tables A 2,5 & 6 for New Jersey.³

An impressive number of Wildlife Refuges and Fish and Wildlife Management Areas are located along the river and bay. These are open to the public primarily for wildlife observation and nature study, but hunting and fishing are allowed, and in some cases boating. Information on acreage, attendance and activities was obtained from the Refuge Managers and from the United States Department of the Interior, Fish and Wildlife Service.

(1) Location of facilities listed on Table A 2.1 are identified on Figure A 2.1.

References

1. Personal communication, Greene A. Jones, Director, Water Programs Division, United States Environmental Protection Agency, Region III, Philadelphia, PA.
2. "The Boating Almanac", Volume #3, 1974, Boating Almanac Co., Inc., Green Village, NJ.
3. Personal communication, John Rattie, Delaware River Basin Commission, West Trenton, NJ.



WATER USERS WITHIN 50 MILES OF THE SITE

Fig A. 2.1

TABLE A 2.1

 IDENTIFICATION KEY FOR Figure 2 A.1
 WATER USERS WITHIN 50 MILES OF ARTIFICIAL ISLAND

Map Location	Facility	Direction & Distance from Artificial Island		Acres	Water Related Activity					Capacity		Attendance
			miles		swimming	boating	fishing	hunting (waterfowl)	fishing-commercial		(boats for hire)	
1A	Artificial Island Wildlife Refuge	N	2.3				x	x				
1	Fort Mott State Park	N	9.5	1229	x							232,042
2	Marina	NNE	2.3		x					50		
3	Marina	NNE	7.9		x					77		
4	Various ramps	NNE	8.4		x							
5	Marina	NNE	8.7		x					86		
6	Mad Horse Creek Fish & Wildlife Management Area	ESE	2.9									
7	Woodland Beach & Wildlife Refuge	SSE	9.6	3542.9	x	x	x					1000 hunter
7A	Chesapeake & Delaware Wildlife Refuge	NW	8.4									2000 hunter
8	Reedy Island	NNW	3.6	50	x	x		x				
9	Augustine Beach & Wildlife Refuge	NNW	3.8	190.7		x	x					
10	Marina	NNW	8.4			x			x	70		
11	Fort Delaware	NNW	9.0									13,021
12	Killcohook National Wildlife Refuge	N	10.6	704								
13	Pennsville Public Launching Ramp	N	14.0		x							
14	Marina				x					30		
15	Marina	N	18.6		x					10		
16	Marina	ESE	11.6		x				x	50		
17	Marina	ESE	11.9		x					125		
18	Marina	ESE	17.0		x					100		
19	Marina	SE	11.9		x					125		
20	Dix Fish & Wildlife Management Area	SE	13.7									
21	Marina	SE	19.8		x				x	40		
22	Bombay Hook National Wildlife Refuge	SSE	13.5	15,110			x	x				59,404
23	Marina	NNE	21.2				x					
24	Marina	NNE	25.0				x					
25	Marina	NNE	25.6				x					
26	Nantuxent Fish & Wildlife Management Area	SE	20.8									
27	Marina	SE	20.8		x					70	20	
28	Marina	SE	22.1		x					80	15	
29	Marina	SE	22.3		x				x	100	15	

Map Location	Facility	TABLE A 2.1 (cont.) Direction & Distance from Artificial Island		Miles	Water Related Activity				Capacity		Attendance
			miles		swimming	boating	fishing	hunting (waterfowl) fishing--commercial	(boats for hire)		
30	Boat Rental	SE	22.8		x				20		
31	Fortescue Fish & Wildlife Management Area	SE	25.0								
32	Marina	SE	25.6		x				20	1	
33	Marina	SE	26.0		x						
34	Marina	SE	26.2		x				20	18	
35	Egg Island Fish & Wildlife Management Area	SE	27.9								
36	Marina	SSE	30.6					x		2	
37	Bowers Beach	SSE	30.9	13.1	x	x	x				
38	Marina	ESE	31.7		x				62	1	
39	Marina	ESE	32.5		x				100	1	
40	Marina	ESE	32.7		x				35	1	
41	Marina	ESE	32.9		x				90		
42	Marina	ESE	32.9		x	x			200	6	
43	Marina	ESE	32.9		x				16		
44	Marina	ESE	33.2		x						
45	Marina	ESE	33.2		x				26		
46	Heislerville Fish & Wildlife Management Area	ESE	33.8								
47	Boat Rental				x						
48	Marina	SSE	37.8		x				100		
49	Marina	SSE	38.6						30		
50	Dennis Creek Fish & Wildlife Management Area	ESE	41.3								
51	Fowler Beach	SSE	42.5	2			x				
52	Prime Hook National Wildlife Refuge	SSE	44.5								
53	Lewes Recreational Area	SSE	52.7	1.7		x	x				
54	Boat rental	SSE	53.0					x		1	
55	Cape Henlopen State Park	SSE	53.5	1641	x	x	x				1,294,994

TABLE A 2.1 2 of 2

DELAWARE RIVER SURFACE WATER WITHDRAWALS BELOW
PHILADELPHIA TO AND INCLUDING DELAWARE BAY

	Average Use 1970 mgd*	Location and Remarks
Philadelphia Electric Co.	193.0	Chester Station, Pa.
Allied Chemical Corp.	1.5	Marcus Hook, Pa.
F. M. C. Corporation	4.4	Marcus Hook, Pa.
Philadelphia Electric Co.	2.7	Tilghman St. Gas Plant - Chester, Pa.
Philadelphia Electric Co.	552.2	Eddystone Station, Pa.
B.P. Oil Co.	130.1	Marcus Hook, Pa.
Union Carbide	30.2	Essington, Pa.
Sun Oil Co.	121.7	Marcus Hook, Pa.
Westinghouse Electric Co.	17.8	Lester, Pa.
Scott Paper Co.	20.5	Chester, Pa.
E. I. duPont	6.7	Gibbstown, N. J.
Texaco, Inc.	2.9	West Deptford Township, N. J.
Olin Corporation	16.8	Paulsboro Borough, N. J.
Mobil Oil Corp.	30.2	Paulsboro Borough, N. J.
Heinz Co.	0.1	Salem Creek - brackish
E. I. duPont	126.0	Deepwater, N. J.
Atlantic City Electric	336.0	Deepwater Station - Pennsgrove, N. J.
Allied Chemical Corp.	35.7	New Castle, Delaware
Atlas Chemical Ind. Inc.	10.9	New Castle, Delaware
Delmarva Power & Light Co.	354.0	Edge Moor Power Station, Wilmington, Del.
E. I. duPont	0.9	Pigments Dept. Christina River (brackish)
E. I. duPont	22.4	Edge Moor
Getty Oil Co.	317.3	Delaware City
Phoenix Steel Corp.	8.2	Claymont
Ludlow Corp.	0.1	New Castle, Delaware
Bancroft Co.	88.8	Lewes, Delaware
Fish Products Co.	3.0	Lewes, Delaware

*mgd = million gallons per day.

Ref.: personal communication, John Rattie, Delaware River Basin Commission - West Trenton, N. J.

Assumed & Projected Daily Recreation for State of Delaware

<u>per day</u>	<u>Visitors</u>	<u>Year</u>
9,000		1966
12,700		1980
18,000		2000

Summary of Daily Capacities (1967)

Number of Persons

boating	7,900
swimming (bay)	21,592
fishing	20,171

Projected User Days - 1980:

	<u>Del. Resident</u>	<u>Non-Resident</u>
fishing	1,673,000	35,000
boating	2,238,000	40,000
swimming (bay)	600,000	10,000

Projected User Days - 2000:

	<u>Del. Resident</u>	<u>Non-Resident</u>
fishing	2,340,000	40,000
boating	3,130,000	55,000
swimming (bay)	800,000	15,000

SOURCE: Lesser, C. Marine Fisheries Survey, 1968. Compiled for Div. of Fish and Wildlife, Department of Natural Resources & Env. Control, State of Delaware, Dover, Del.

Recreational Use of Delaware River & Bay

<u>Delaware River & tributaries</u>	<u>person-days</u>
fishing-private	11,591
cruising	3,369
<u>Delaware Bay</u>	
fishing-private	67,234
fishing - party boat	30,319
cruising	6,179
sailing	462

SOURCE: Lesser, C. Marine Fisheries Survey, 1968. Compiled for Div. of Fish & Wildlife, Department of Natural Resources & Env. Control, State of Delaware, Dover, Del.

Recreation Demand for State of New Jersey - Delaware Bay

Average Weekend Day during Peak Season - 1970

	<u>Resident</u>	<u>Non-Resident</u>
Swimming	7,300	11,700
Sightseeing	2,400	3,500
Fishing	800	3,800
Boating	1,500	2,400
Hunting	500	800
Water Skiing	500	400
Canoeing	100	100
Sailing	100	200

SOURCE: Outdoor Recreation in New Jersey, New Jersey Statewide Comprehensive Outdoor Recreation Plan, State of New Jersey, Department of Environmental Protection, Office of Environmental Review, 1973.

DELAWARE BAY PRESENT AND FUTURE RECREATIONAL FACILITY NEEDS

RECREATION	CAPACITY (person)	ESTIMATED DEMANDS (person)		
		1970	1980	2000
Swimming	60,557	19,000	27,100	39,200
Boating	6,373	3,900	5,700	8,200
Fishing	28,219	4,700	5,700	7,600

SOURCE: Outdoor Recreation in New Jersey, New Jersey Statewide Comprehensive Outdoor Recreation Plan, State of New Jersey, Department of Environmental Protection, Office of Environmental Review, 1973.

Commercial/Recreational Fish & Shellfish Catch From the Delaware River Bay

The present commercial fish and shellfish catch for New Jersey and Delaware is tabulated in Table A 2.7. The species selected from Cape May County statistics were only those identified by Ichthyological Associates as indigenous to the Delaware Bay. (1) Catch statistics for Delaware were not obtainable by species but it is not unreasonable to correlate them to New Jersey species by relative amounts.

Projected values were not readily available but past and present river conditions indicate that these values will not increase in the future. This is primarily due to extensive industrial and municipal waste discharge into the estuary which has resulted in poor water quality. (2)

The principal fishing ports in Delaware are Lewes and Little Creek for finfish (mostly striped bass) and Port Mahon, Flemings Landing, and Collins Beach for shellfish (mostly blue crab). (3) The principal fishing ports in New Jersey are located at Stow Creek, Greenwich, and Newport for shellfish (oyster and blue crab). (4) All marinas contacted which have dockage for commercial boats are identified in Figure A 2.1.

Since the commercial catch is limited (4.9×10^6 lbs. finfish, 4.8×10^6 lbs. blue crab, and 1×10^6 lbs. oysters), it is not unduly conservative to estimate that the entire catch is consumed locally (within 50 miles).

Statistics on recreational catch were very limited. Table A 2.8 lists some estimates for finfish and shellfish catch from 1968. Figure A 2.1 provides information on recreational areas where fishing as an activity is common. Projected values for recreational fishing in the area would not indicate any increase in numbers mainly because the best fishing is too far from population centers. (5)

There are approximately 21,000 acres of tidal marsh in New Jersey and 18,000 acres in Delaware where waterfowl can be found. Waterfowl hunting is quite popular here, in areas where this activity is allowed.

Estimates from Delaware indicate about 11,000 hunters spent 93,000 days hunting waterfowl in 1969. (6) Statistics on the number caught were unavailable, but should conform with local hunting regulations.

The only other major use of the marshes is muskrat trapping. While this activity is chiefly for the pelts, it must be assumed that the flesh is eaten. Statistics were available for 1969 with an estimate that 45,000 muskrats were caught within the study area.

REFERENCES

1. Schuler, V. J., An Ecological Study of the Delaware River in the Vicinity of Artificial Island, Ichthyological Associates, Inc., Ithaca, N. Y., 1974.
2. U.S.E.P.A., Delaware Estuary Comprehensive Study - Preliminary Report and Findings, Department of Interior, Phila., Pa. 1966.
3. The Coastal Zone of Delaware, The Governor's Task Force on Marine and Coastal Affairs, July, 1972.
4. Op. cit., ref 1.
5. Op. cit., ref 2
6. Files of Division of Fish and Wildlife, Department of Natural Resources & Environmental Control, Dover, Del.

U

COMMERCIAL FISH/SHELLFISH CATCH FOR NEW JERSEY & DELAWARE
WITH EMPHASIS ON DELAWARE RIVER-BAY
(pounds per year)

New Jersey Counties 1974 (a)

<u>Species</u>	<u>Cape May</u>	<u>Cumberland</u>
Sea trout (<i>Cynoscion arenarius</i>)	1,790,000	123,000
Butterfish (<i>Selenotoca papuensis</i>)	774,000	300
Menhaden (<i>Brevoortia tyrannus</i>)	377,000	100,000
Bluefish (<i>Pomatomus saltatrix</i>)	294,000	18,500
Striped bass (<i>Morone saxatilis</i>)	266,000	19,700
American eel (<i>Anguilla rostrata</i>)	23,900	39,600
American shad (<i>Dorosoma cepedianum</i>)	11,500	7,730
White perch (<i>Morone americana</i>)	5,790	12,100
Atlantic sturgeon (<i>Acipenserida</i>)	8,540	-----
Spot (<i>Leiostomus xanthurus</i>)	4,980	2,980
Alewife (<i>Pomolobus pseudoharengus</i>)	2,600	-----
Carp (<i>Cyprinus carpio</i>)	-----	47,700
Catfish (<i>Ictalurus furcatus</i>)	-----	6,860
<u>Finfish totals</u>	<u>3,560,000</u>	<u>378,000</u>
Blue crab (<i>Callinectes sapidus</i>)		
hard shell	130,000	1,740,000
peeler	8,260	113,000
Oyster (<i>Crassostrea virginica</i>)	-----	985,000
Clam (<i>Spisula solidissima</i>)	20,600	-----
Turtle, snapper (<i>Chelydra serpentina</i>)	-----	5,750

Delaware Counties - 1974 (b)

	<u>Kent</u>	<u>Newcastle</u>	<u>Sussex</u>
(mostly blue crab)	1,800,000	878,000	1,460,000

Delaware Statewide Catch - 1968 (c)

food fish	161,000
oyster meat	43,000
clam meat	242,000
blue crab	223,000

(fish)
3,560
378
161

4,099,000 lb
756,000 kg used in calc

(a) SOURCE: New Jersey Landings, Annual Summary 1974, National Marine Fisheries Service, Wash., D. C.

(b) SOURCE: Personal communication, National Marine Fisheries Service, 1976

(c) SOURCE: The Coastal Zone at Delaware - The Governor's Task Force on Marine and Coastal Affairs - July, '72

Recreational Fish/Shellfish Catch for Delaware River-Bay (1968)

Finfish*

Pounds Caught

Delaware River and Canal	
net	26,400
private boat	11,300
bridge & bank	90,900
Delaware Bay	
net	25,100
party boat	448,000
private boat	550,000
shore & jetty	23,400

*The catch is estimated at 6 fish/person-day; 65% of the total is trout, flounder, and bluefish.

Shellfish

<u>Crabbing</u>	<u>Person-Days</u>	<u>Number Caught</u>
Bowers	33	--
Lewes	2,300	15,600
<u>Clamming</u>		
inland bays	56,025	1,680,000

SOURCE: Lesser, Chas. Marine Fisheries Survey, 1968 - Compiled for Division of Fish and Wildlife, (Department of Natural Resources & Env. Control) State of Delaware.

Item 5

Effluent Release Data

- A. Exclude first year of operation
- B. Tabulate by effluent release point, month, mode of operation, refueling, shutdown

Response

Hope Creek Generating Station is under construction. Item 5 does not apply.

Item 6

Cost Benefit Analysis (if used) consistent with methodology in Regulatory Guide 1.110 (Draft Regulatory Guide 1.FF).

Response

The computer printouts indicate that the total body man-rem is 2.18 man-rem⁽¹⁾ (one unit basis) from gaseous effluents and 0.28 man-rem⁽²⁾ from liquid effluents (one unit basis) for a total of 2.46 man-rem to the total body.

Similarly, the thyroid man-rem from gaseous effluents is 6.15 man-rem⁽¹⁾ and .21 man-rem⁽²⁾ from liquid effluents for a total of 6.36 man-rem to the thyroid.

The base plant as represented by parameters listed in response to Question 1 of Enclosure 2 was then evaluated with various "augment" to the gaseous radioactive waste treatment systems.

An evaluation of the cost vs the benefit of three different "augment" to the gaseous radwaste system was considered. The proposed "augment" were as follows:

<u>No.</u>	<u>AUGMENT *</u> <u>Description</u>	<u>Corresponding Source</u> <u>Term Case No.</u> <u>(From Item 2)</u>
1)	Base case (no augments)	1
2)	Steam valves ≥ 2.5 inches leak-off collection	2
3)	Charcoal and HEPA filters installed in potentially radioactive areas of the turbine building ventilation system.	3
4)	Containment prepurge clean-up system	- a,b
5)	Combination of all three augments (2,3&4)	4 a,c

These augment were analyzed with the results presented on pages 6.1 through 6.9

As the total man-rem exposure from liquid effluents are very small it is evident that no augments could be added to the liquid radwaste system for a favorable cost benefit return.

1) See table 4.11n

6.0

2) See table 4.9z

- a) No provision in BWR-GALE Code for prepurge internal clean-up of drywell.
- b) Source term from case 1 adjusted to reflect prepurge clean-up.
- c) Source term from case 4 adjusted to reflect total of all augments.

* These "augment" were originally included in the Hope Creek design. The cost-benefit analysis which follows analyzes the cost effectiveness of the originally proposed "augment".

Augment: Turbine Building Charcoal/HEPA Filters

- 1) The cumulative population man-rem exposures are given in Table 1.1.
- 2) The computer code calculates the thyroid dose to be 6.15 man-thyroid-rem^{*} without the augment and 4.44^{**} man-thyroid-rem^s with the augment. The dose reduction of this augment is 1.71 man-thyroid-rem.
- 3) Dose calculation models used are described on page 4.1. Detail work sheets with the basis for cost estimates are given on Table 6.1.
- 4) The cost benefit analysis format conforms with Regulatory Guide 1.10.

A. Direct Cost

- i) The direct cost of equipment and materials is 109,600 dollars.
- ii) The direct labor cost is estimated to be 19,500 dollars.
- iii) The total direct costs are 129,100 dollars

B. Indirect Cost

The indirect cost factor is 1.625 which is the adjustment factor for multi-unit sites with generally unitized radwaste systems.

C. Total Capital Cost

The total capital cost is 209,788 dollars

D. Recovery Factor

The capital recovery factor which reflects the costs of borrowed money is 0.1150.

E. Annual Fixed Cost

The annual fixed costs are 24,126 dollars.

F. Operating Cost

The annual operating cost is 27,400 dollars.

G. Total Annual Cost

The total annual cost of this augment is 51,526 dollars

Augment: Turbine Building Charcoal/HEPA Filter (Cont'd.)

5) Benefit of the augment

The "benefit" of the augment arrived at by multiplying the dose reduction factor calculated in Item 2 by \$1000 per man-thyroid-rem is 1710 dollars.

6) The cost of the augment (51,526 dollars) far exceeds the benefit of this augment (1710 dollars) therefore, the augment is deemed not to be cost effective.

*Table 6.4

**Table 6.6

TOTAL DIRECT COST ESTIMATE SHEET OF RADWASTE TREATMENT SYSTEM
FOR LIGHT-WATER-COOLED NUCLEAR REACTORS

Description of Augment TURBINE BUILDING CHARCOAL/HEPA FILTERS*

DIRECT COST (1975 \$1000)

ITEM	DIRECT COST (1975 \$1000)			BASIS FOR COST ESTIMATE
	LABOR	EQUIPMENT/MATERIALS	TOTAL	
1. PROCESS EQUIPMENT	17	95.3	112.3	Cost of filters including internal components. Costs also include larger capacity fan Labor based on 1975 dollars.
2. BUILDING ASSIGNMENT				
3. ASSOCIATED PIPING SYSTEMS				
4. INSTRUMENTATION AND CONTROLS				
5. ELECTRICAL SERVICE				
6. SPARE PARTS				
SUBTOTAL	17	95.3	112.3	
7. CONTINGENCY	2.5	14.3	16.8	15%
8. TOTAL DIRECT COSTS	19.5	109.6	129.1	

* Filters for contaminated areas of turbine building only. Flow is estimated to be 30,000CFM (ref. Pg. G-10 suppl. ER)

Table 6.1
1 of 2

ANNUAL OPERATING AND MAINTENANCE COST ESTIMATE SHEET OF RADWASTE TREATMENT
SYSTEM FOR LIGHT-WATER-COOLED NUCLEAR REACTORS

Description of Augment

TURBINE BUILDING CHARCOAL/HEPA FILTERS *

COST (1975 \$1000)

ITEM	LABOR	OTHER	TOTAL	BASIS FOR COST ESTIMATE
1. OPERATING LABOR, SUPERVISION, AND OVERHEAD			3.8	15 min/shift + 40 hr annual test
2. MAINTENANCE MATERIAL AND LABOR			18.0	60 HEPA or high efficiency filters @150 each & 30 charcoal filters @900 each every two years
3. CONSUMABLES, CHEMICALS, AND SUPPLIES			-	In items 2 and 4
4. UTILITIES AND SERVICES				
Waste Disposal			3.0	\$50/HEPA or high efficiency filter, \$100/charcoal filter
Water				
Steam				
Electricity			2.6	16kw additional fan HP for filter @ 0.018 \$/kw-hr
Building Services				
Other				
5. TOTAL O AND M ANNUAL COST			27.4	

* Filters for contaminated areas of turbine building only. Flow is estimated to be 30,000 CFM.

Augment: Steam Valve Leak-off Collection System

1. The cumulative population man-rem exposures are given in Table 1.1.
2. The computer code calculates the thyroid dose to be 3.98 *man-thyroid-rem with the augment and 6.15**man-thyroid-rem without the augment. The dose reduction factor is therefore 2.17man-thyroid-rem.
3. Dose calculation models used are described on page 4.1. Detailed worksheets with the basis for cost estimates are given on Table 6.2.
4. The cost benefit analysis format conforms with that given in Regulatory Guide 1.10.

A. Direct Cost

- i) The direct cost of equipment and materials is 82,000 dollars
- ii) The direct labor cost is estimated to be 155,000 dollars
- iii) The total direct cost is 237,000 dollars

B. Indirect Cost

The indirect cost factor is 1.625.

C. Total Capitol Cost

The total capitol cost is 385,130 dollars

D. Recovery Factor

The capitol recovery factor which reflects the costs of borrowed money is 0.1150.

E. Annual Fixed Cost

The annual fixed cost is 44,290 dollars

F. Operating Cost

The annual operating cost is considered to be nominal considering the passive nature of the system.

G. Annual Cost

The total annual cost of this equipment is therefore 44,290 dollars dollars.

5. Benefit of the Augment:

The benefit of the augment is calculated to be 2170 dollars. (2.17 man-rem dose reduction times \$1000/man-rem).

6. Cost Benefit Analysis:

The cost of the augment (44,290 dollars) far exceeds its potential benefit (2,170 dollars) Therefore the augment is deemed not to be cost effective.

* See table 6.5

** See table 6.4

TOTAL DIRECT COST ESTIMATE SHEET OF RADWASTE TREATMENT SYSTEM
FOR LIGHT-WATER-COOLED NUCLEAR REACTORS

Description of Augment STEAM VALVE LEAK-OFF COLLECTION SYSTEM

ITEM	DIRECT COST (1975 \$1000)			BASIS FOR COST ESTIMATE
	LABOR	EQUIPMENT/MATERIALS	TOTAL	
1. PROCESS EQUIPMENT				
2. BUILDING ASSIGNMENT				
3. ASSOCIATED PIPING SYSTEMS	133	71	204	2,000 feet of 1 inch pipe; 1 2 inch pipe. Estimate of pip based on 1975 dollars
4. INSTRUMENTATION AND CONTROLS			-	
5. ELECTRICAL SERVICE	1.8	.2	2	Motorized single shutoff val to the main condenser
6. SPARE PARTS				
SUBTOTAL	135	71	206	
7. CONTINGENCY	20	11	31	15%
8. TOTAL DIRECT COSTS	155	82	237	

Table 6.2
1 of 2

ANNUAL OPERATING AND MAINTENANCE COST ESTIMATE SHEET OF RADWASTE TREATMENT
SYSTEM FOR LIGHT-WATER-COOLED NUCLEAR REACTORS

Description of Augment STEAM VALVE LEAK-OFF COLLECTION SYSTEM

COST (1975 \$1000)

ITEM	LABOR	OTHER	TOTAL	BASIS FOR COST ESTIMATE
1. OPERATING LABOR, SUPERVISION, AND OVERHEAD			-	Periodic inspection
2. MAINTENANCE MATERIAL AND LABOR			-	Greasing of bearings is only maintainance anticipated. Bearings replaced every 15 years
3. CONSUMABLES, CHEMICALS, AND SUPPLIES			-	No consumable chemicals or supplies
4. UTILITIES AND SERVICES				
Waste Disposal			-	
Water			---	
Steam				
Electricity			negl.	.1 kw service at 0.18 \$/kw-hr is negl.
Building Services			-	
Other			-	
5. TOTAL O AND M ANNUAL COST			Nominal	Considering the passive devices involved

TOTAL DIRECT COST ESTIMATE SHEET OF RADWASTE TREATMENT SYSTEM
FOR LIGHT-WATER-COOLED NUCLEAR REACTORS

Description of Augment CONTAINMENT PREPURGE CLEANUP SYSTEM *

ITEM	DIRECT COST (1975 \$+000)			TOTAL	BASIS FOR COST ESTIMATE
	LABOR	EQUIPMENT/MATERIALS			
1. PROCESS EQUIPMENT	Filter	6,150	32,350	38,500	April 1, 1976 prices de-escalated to July 1, 1975 prices
	Fan	750	1,650	2,400	
	Damper	--	650	650	
	Ductwork	2,100	500	2,600	
2. BUILDING ASSIGNMENT					
3. ASSOCIATED PIPING SYSTEMS					
4. INSTRUMENTATION AND CONTROLS		5,650	7,200	12,850	
5. ELECTRICAL SERVICE		5,500	1,700	7,200	
6. SPARE PARTS					
	SUBTOTAL	20,150	44,050	64,200	
7. CONTINGENCY		3,000	6,600	9,600	15%
8. TOTAL DIRECT COSTS **		23,150	50,650	73,800	

** Field over head included.
* Based upon a flow of 3,000 CFM

Table 6.3
1 of 2

ANNUAL OPERATING AND MAINTENANCE COST ESTIMATE SHEET OF RADWASTE TREATMENT
SYSTEM FOR LIGHT-WATER-COOLED NUCLEAR REACTORS

Description of Augment CONTAINMENT PREPURGE CLEANUP SYSTEM 3,000 CFM

COST (1975 \$1000)

ITEM	COST (1975 \$1000)			BASIS FOR COST ESTIMATE
	LABOR	OTHER	TOTAL	
1. OPERATING LABOR, SUPERVISION, AND OVERHEAD			3.8	15 min/shift and 40 hr test
2. MAINTENANCE MATERIAL AND LABOR			.5	@\$150 a HEPA or high efficiency filter and \$900 a charcoal filter with 6 HEPA or high efficiency filter and 3 charcoal filters changed every 5 years
3. CONSUMABLES, CHEMICALS, AND SUPPLIES				
4. UTILITIES AND SERVICES				
Waste Disposal				
Water				
Steam				
Electricity			negl.	Intermittent operation
Building Services				
Other				
5. TOTAL O AND M ANNUAL COST			4.3	

Table 6.3
2 of 2

Augment: Containment Prepurge Clean-up

1. The cumulative population man-rem exposure and man-thyroid-rem exposure are given in Table 1.1.
2. The reduction to the cumulative population exposure from adding the augment is estimated to be 1.5 man-thyroid-rem. The basis for this reduction is described on page 6.7 and 6.8
3. Dose calculation models employed are described on page 4.1. Detail worksheet with the basis for cost estimates are given on Table 6.3.
4. The cost benefit analysis format conforms with that given in Reg. Guide 1.10.

A. Direct Costs

- i) The direct cost of equipment and materials is 50,650 dollars
- ii) The direct labor cost is estimated to be 23,150 dollars
- iii) The total direct cost is 73,800 dollars

B. Indirect Cost

The indirect cost factor is 1.625 which is the adjustment factor for multi-unit sites with generally unitized radwaste systems.

C. Total Capital Cost

The total capital cost is 119,925 dollars

D. Recovery Factor

The capital recovery factor which reflects the costs of borrowed money is 0.1150.

E. Annual Fixed Cost

The annual fixed costs are 13,791 dollars

F. Operating Cost

The annual operating cost and maintenance cost are estimated to be 4,300 dollars

G. Total Annual Cost

The total annual cost of this augment is therefore 18,091 dollars

5. Benefit of the Augment

The "benefit" of the augment arrived at by multiplying the dose reduction calculated in item 2 by \$1000 per man-rem (thyroid or whole body) is 1500 dollars

6. The cost of the augment is 18,091 dollars. The most money which could be expended considering the "benefit" of the augment exceeds its benefit, therefore, the augment is not justified.

BASIS FOR THE DOSE REDUCTION FACTOR

Augment: Containment Prepurge Clean-up System

Table C-9 of Draft Reg. Guide 1.CC refers to a ratio of I-131 reactor building releases during year round operation to the I-131 released during normal operation (excluding outages) from a BWR. The same ratio factor of 2.6 was used in the analysis for the Hope Creek Generating Station.

This may be expressed mathematically as follows:

Let T = Total Release of I-131 (including purges)

Let N = Normal release of I-131 (excluding purges)

Let P = Total Release of I-131 during purge operations

$$- \text{ also } \frac{T}{N} = \frac{P+N}{N} = 2.6$$

$$\text{therefore } P = 1.6 N$$

The purging operations must therefore account for 62% of the I-131 released from the reactor.

$$\frac{P}{P+N} = .62$$

The iodine source term calculated on table 2.1 may be reduced by 62% to account for normal iodine releases (non purge)

$$\begin{aligned} \text{containment source term} - \text{purge term} &= \text{normal releases} \\ 1.7E-01 - (.62)(1.7E-01) &= 6.5E-02. \text{ (two unit basis)} \end{aligned}$$

If a prepurge clean-up system were utilized, essentially all iodines would be removed prior to purging. Hence the 1.05E-02 curies of I-131 from the purge releases would be reduced to approximately zero. If the I-131 releases from purging operations are approximately zero then the containment source term would be 6.5E-02 curies.

This produces a new total I-131 release source term from all buildings of 3.1E-01 curies of I-131, compared to the 4.1E-01 calculated previously in table 2.1. This affords a reduction of 25%.

The iodine releases account for a large percentage of the integrated thyroid dose. It represents more than 98% via the cow milk pathway and greater than 50% via the inhalation pathway. The most conservative assumption would be if the iodine accounted for all of the dose from these pathways. This will result in the most conservative assumption concerning the "benefit" of the clean-up system.

As Table 1.1 indicated that the total man-thyroid-rem integrated dose (one unit) is 6.15, the dose reduction achieved as a result of the internal clean-up system is 1.5 man-thyroid-rem.

This is based on the 25% reduction in the source term for I-131 and a corresponding 25% reduction in the integrated population dose.

SUMMATION OF INTEGRATED

POPULATION EXPOSURE OF

PROPOSED AUGMENTS

HCOS

BASE CASE (No. 1) - NO AUGMENTS

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
 ALPHA ANNUAL INTEGRATED POPULATION DOSE SUMMARY (MANREM)

PATHWAY	T. BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
PLUME	2.61E+00 59.72%	2.61E+00 55.76%	2.61E+00 38.91%	2.61E+00 59.46%	2.61E+00 69.25%	2.61E+00 21.20%	2.66E+00 60.59%	6.60E+00 79.12%
GROUND	1.06E-01 2.42%	1.06E-01 2.42%	1.06E-01 1.58%	1.06E-01 2.41%	1.06E-01 2.81%	1.06E-01 0.86%	1.06E-01 2.40%	1.24E-01 1.49%
INFAL	3.43E-02 0.76%	3.34E-02 0.77%	1.14E-02 0.17%	4.53E-02 1.63%	4.90E-02 1.30%	4.03E+00 32.78%	3.42E-02 0.78%	2.70E-02 0.32%
VEGET	1.26E+00 28.85%	1.26E+00 28.95%	3.12E+00 46.56%	1.26E+00 20.76%	7.75E-01 20.62%	2.02E+00 16.42%	1.24E+00 28.24%	1.24E+00 14.36%
COW MILK	2.75E-01 6.31%	2.69E-01 6.18%	5.76E-01 8.61%	2.81E-01 6.42%	1.62E-01 4.32%	3.40E+00 27.65%	2.67E-01 6.09%	2.67E-01 3.20%
MEAT	8.37E-02 1.92%	8.40E-02 1.93%	2.80E-01 4.18%	8.38E-02 1.91%	6.41E-02 1.70%	1.33E-01 1.08%	8.34E-02 1.90%	6.34E-02 1.06%
TOTAL	4.30E+00	4.36E+00	6.70E+00	4.33E+00	3.76E+00	1.23E+01	4.40E+00	8.34E+00

Table 6.4

Case No. 2 (Steam valve leak-off collection system)

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
ALASKA ANNUAL INTEGRATED POPULATION DOSE SUMMARY (MAVFEM)

PATHWAY	T. BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
FLORE	1.28E+00	1.28E+00	1.23E+00	1.28E+00	1.23E+00	1.28E+00	1.32E+00	3.65E+00
	43.25%	43.30%	24.64%	43.08%	54.19%	16.13%	44.18%	63.52%
GROUNDS	5.09E-02	5.09E-02	5.05E-02	5.09E-02	5.03E-02	5.09E-02	5.09E-02	5.99E-02
	1.71%	1.72%	0.98%	1.71%	2.15%	0.64%	1.70%	1.13%
INHAL	3.13E-02	3.07E-02	6.89E-03	3.76E-02	4.04E-02	2.52E+00	2.93E-02	2.70E-02
	1.05%	1.03%	0.13%	1.27%	1.71%	31.71%	0.98%	0.51%
VEGET	1.25E+00	1.25E+00	3.02E+00	1.25E+00	7.72E-01	1.73E+00	1.24E+00	1.24E+00
	42.01%	42.08%	57.94%	41.51%	32.60%	21.78%	41.43%	23.27%
CUM MILK	2.72E-01	2.68E-01	5.70E-01	2.75E-01	1.50E-01	2.25E+00	2.67E-01	2.67E-01
	9.16%	9.05%	10.94%	9.23%	6.56%	28.30%	8.92%	5.01%
MEAT	8.35E-02	8.36E-02	2.80E-01	8.34E-02	6.40E-02	1.15E-01	9.34E-02	8.34E-02
	2.81%	2.82%	5.37%	2.81%	2.70%	1.44%	2.79%	1.57%
*T. TALK	2.97E+00	2.96E+00	5.21E+00	2.93E+00	2.37E+00	7.96E+00	2.99E+00	5.33E+00

CASE No. 3 (Turbine Building Filtration System)

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
 ALARA ANNUAL INTEGRATED POPULATION DOSE SUMMARY (MANREM)

HCGS

PATHWAY	T.BODY	GI-TRACT	BONE	LIVER	KIDNEY	THYROID	LUNG	SKIN
PLUME	2.61E+00 60.98%	2.61E+00 61.04%	2.61E+00 40.13%	2.61E+00 60.83%	2.61E+00 70.90%	2.61E+00 29.38%	2.66E+00 61.66%	6.60E+00 79.89%
GROUND	3.76E-02 0.88%	3.76E-02 0.88%	3.76E-02 0.58%	3.76E-02 0.88%	3.76E-02 1.02%	3.76E-02 0.42%	3.76E-02 0.87%	4.44E-02 0.54%
INHAL	3.09E-02 0.72%	3.02E-02 0.71%	6.23E-03 0.10%	3.66E-02 0.85%	3.93E-02 1.07%	2.32E+00 26.15%	2.81E-02 0.65%	2.70E-02 0.33%
VEGET	1.24E+00 29.12%	1.24E+00 29.14%	2.99E+00 46.12%	1.25E+00 29.09%	7.71E-01 20.99%	1.69E+00 19.12%	1.24E+00 28.71%	1.24E+00 15.01%
COW MILK	2.71E-01 6.35%	2.68E-01 6.28%	5.68E-01 8.76%	2.74E-01 6.40%	1.57E-01 4.27%	2.10E+00 23.67%	2.67E-01 6.18%	2.67E-01 3.23%
MEAT	8.35E-02 1.95%	8.36E-02 1.96%	2.80E-01 4.31%	8.36E-02 1.95%	6.39E-02 1.74%	1.12E-01 1.27%	8.34E-02 1.93%	8.34E-02 1.01%
TOTAL	4.27E+00	4.27E+00	6.49E+00	4.28E+00	3.67E+00	8.87E+00	4.32E+00	8.26E+00

Table 6.6

CASE No. 4 (Combination of steam leakoff collection and turbine building filtration)

POPULATION AND INDIVIDUAL DOSE CALCULATIONS FOR HOPE CREEK GENERATING STATION
ALARA ANNUAL INTEGRATED POPULATION DOSE SUMMARY (MANREM)

PATHWAY	T.BODY	GI-TRACT	BCNE	LIVER	KIDNEY	THYROID	LUNG	SKIN
PLUME	1.28E+00	1.28E+00	1.28E+00	1.28E+00	1.28E+00	1.28E+00	1.32E+00	3.65E+00
	43.51%	43.57%	24.84%	43.36%	54.59%	17.53%	44.41%	68.72%
GROUND	3.73E-02	3.73E-02	3.73E-02	3.73E-02	3.73E-02	3.73E-02	3.73E-02	4.39E-02
	1.26%	1.26%	0.72%	1.26%	1.58%	0.51%	1.25%	0.83%
INHAL	3.07E-02	3.00E-02	5.87E-03	3.60E-02	3.85E-02	2.19E+00	2.81E-02	2.70E-02
	1.04%	1.02%	0.11%	1.22%	1.64%	29.92%	3.94%	3.51%
VEGET	1.24E+00	1.24E+00	2.99E+00	1.25E+00	7.71E-01	1.68E+00	1.24E+00	1.24E+00
	42.17%	42.21%	57.92%	42.39%	32.83%	22.93%	41.63%	23.34%
COW MILK	2.71E-01	2.68E-01	5.68E-01	2.74E-01	1.57E-01	2.02E+00	2.67E-01	2.67E-01
	9.19%	9.10%	10.99%	9.25%	6.67%	27.62%	8.97%	5.03%
MEAT	8.35E-02	8.30E-02	2.63E-01	8.35E-02	6.39E-02	1.11E-01	8.34E-02	8.34E-02
	2.83%	2.84%	5.07%	2.82%	2.72%	1.52%	2.80%	1.57%
TOTAL	2.95E+00	2.95E+00	5.17E+00	2.96E+00	2.35E+00	7.32E+00	2.98E+00	5.31E+00

HCOS

Table 6.7

**OVERSIZE
DOCUMENT
PAGE PULLED**

SEE APERTURE CARDS

NUMBER OF OVERSIZE PAGES FILMED ON APERTURE CARDS 1

**APERTURE CARD/HARD COPY AVAILABLE FROM RECORD SERVICES BRANCH, TIDC
FTS 492-8989**



PSEG

The Energy People

DBLIPSB

RESPONSE TO REQUIREMENTS OF
APPENDIX I TO 10CFR50
FOR HOPE CREEK GENERATING
STATION *Rev. 1*
DOCKET NOS. 50-354
50-355

ENCLOSURE TWO

8-30-76

App of locations

HOPE CREEK GENERATING STATION

50 - 354

50 - 355

INFORMATION SUPPLIED

IN RESPONSE TO ENCLOSURE

2 OF NRC LETTER DATED

FEBRUARY 19, 1976 (GUIDANCE
FOR MEETING THE REQUIREMENTS
OF APPENDIX I TO 10 CFR 50)

TABLE OF CONTENTS

Information Request 1

Response to Question 1 1.0

Response to Question 2 *Locations* 2.0

Response to Question 3 3.0

Response to Question 4 4.0

Response to Question 5 5.0

Response to Question 6 6.0

Response to Question 7 7.0

Response to Question 8 8.0

Response to Question 9 9.0

Footnotes 10.0

Appendix A (Response to Appendix D of Reg. Guide 1.CC) A1

Appendix B (Meteorological Data) B1

ENCLOSURE 2

Additional Information Needed from Holders of
Permits or Licenses to Construct or Operate
Light-Water-Cooled Reactors for Which
Application was Filed Prior to January 2, 1971

1. Provide the information requested in Appendix D of Draft Regulatory Guide 1.BB or 1.CC, as appropriate.

2. Provide, in tabular form, the distance from the centerline of the first nuclear unit to the following for each of the 22-1/2 degree radial sectors centered on the 16 cardinal compass directions.
 - a) nearest milk cow (to a distance of 5 miles)
 - b) nearest meat animal (to a distance of 5 miles)
 - c) nearest milk goat (to a distance of 5 miles)
 - d) nearest residence (to a distance of 5 miles)
 - e) nearest vegetable garden greater than 500 ft² (to a distance of 5 miles)
 - f) nearest site boundary

For radioactivity releases from stacks which qualify as elevated releases as defined in Draft Regulatory Guide 1.DD, identify the locations of all milk cows, milk goats, meat animals, residences, and vegetable gardens, in a similar manner, out to a distance of 3 miles for each radial sector.

3. Based on considerations in Draft Regulatory Guide 1.DD, provide estimates of relative concentration (X/Q) and deposition (D/Q) at locations specified in response to item 2 above for each release point specified in response to item 1 above.

4. Provide a detailed description of the meteorological data, models and parameters used to determine the X/Q and D/Q values. Include information concerning the validity and accuracy of the models and assumptions for your site and the representativeness of the meteorological data used.

5. If an onsite program commensurate with the recommendations and intent of Regulatory Guide 1.23 exists:
 - a) Provide representative annual and monthly, if available, joint frequency distributions of wind speed and direction by atmospheric stability class covering at least the most recent one year period of record, preferably two or more years of record. Wind speed and direction should be measured at levels applicable to release point elevations and stability should be determined from the vertical temperature gradient between measurement levels that represent conditions into which the effluent is released.
 - b) Describe the representativeness of the available data with respect to expected long-term conditions at the site.

6. If recent onsite meteorological data are not available, or if the meteorological measurements program does not meet the recommendations and intent of Regulatory Guide 1.23.
 - a) Provide the best available meteorological data in the format described in item 5.a above.

- b) Describe the representativeness of the available data with respect to onsite and near site atmospheric transport and diffusion conditions, and with respect to expected long term conditions at and near the site.
 - c) Provide a description of the meteorological measurements used for collection of the data presented. This description should include the location of the sensors with respect to the power plant(s) and other prominent topographic features (including buildings) and accuracy of the instrumentation.
 - d) Provide a commitment to establish a program to meet the recommendations and intent of Regulatory Guide 1.23, or provide sufficient justification to allow the present program to remain unchanged.
7. Describe airflow trajectory regimes of importance in transporting effluents to the locations for which dose calculations are made.
8. Provide a map showing the detailed topographical features (as modified by the plant, on a large scale, within a 10-mile radius of the plant and a plot of the maximum topographic elevation versus distance from the center of the plant in each of the sixteen 22-1/2 degree cardinal compass point sectors (centered on true north), radiating from the center of the plant, to a distance of 10 miles.

9. Provide the dates and times of radioactivity releases from intermittent sources by source location based on actual plant operation and, if available, appropriate hourly meteorological data (i.e., wind direction and speed, and atmospheric stability) during each period of release.

PARAMETERS NEEDED TO CALCULATE
ANTICIPATED RELEASES
FROM
HOPE CREEK GENERATING STATION USING THE
REGULATORY GUIDE 1.CC CODE

<u>PARAMETER</u>	<u>UNITS</u>
Maximum Thermal Power Load (SAR/ER)	3.440 x 10 ³ MWt - Design 3.293 x 10 ³ MWt - Rated
Total Steam Flow Rate	14 x 10 ⁶ lbs/hr
Mass of Water in Reactor Vessel	.6 x 10 ⁶ lbs
Primary Coolant Flow Rate Through Reactor Coolant Cleanup System Demineralizers	0.13 x 10 ⁶ lbs/hr
Number of Demineralizers of Type: Deep Bed - 7 per unit/6 operate continuously and 1 on standby Ultrasonically Cleaned - Yes Filter Demineralizer (Powdex) - none utilized for condensate treatment	
Fraction of Feed Water Through Condensate Demineralizer	100%
Average Flow of Diluent Added to Liquid Radioactive Waste Discharge	24 x 10 ³ gpm
Steam Flow to Turbine Gland Seal (If seal steam is clean, enter 0; if main steam is used, enter 0.001 of Main Steam Flow)	-0 lbs/hr
Mass of Steam in Reactor Vessel	0.02 x 10 ⁶ lbs
Design Holdup for Gases Vented from Gland Seal Condenser (Steam Packing Condenser)	None hrs - Gases are non-radioactive
Design Holdup for Offgases from Main Condenser Air Ejectors Prior To Processing through the Offgas Treatment System	30 min.
Containment Building Releases Charcoal Adsorbers Used to Treat Ventilation Exhaust Air	No
HEPA Filters Used to Treat Ventilation Exhaust	Yes
Turbine Building Releases Are Charcoal Adsorbers Used to Treat Ventilation Exhaust Air?	No
Are HEPA Filters Used to Treat Ventilation Exhaust?	No
Are Clean Steam or Other Design Features Included to Reduce Steam Leakage at Valves \geq 2-1/2 inches?	No

<u>PARAMETER</u>	<u>UNITS</u>
Turbine Gland Seal Condenser Vent - vents to Turbine Bldg. Ventilation System	
Are Noncondensables Released Without Treatment?	Yes
Are Noncondensables Processed Through Charcoal (minimum 90% Efficiency)?	No
Condenser Air Ejectors Offgas Treatment System	
Cryogenic Distillation System	Yes
Auxiliary Building Releases	
Are Charcoal Adsorbers Used to Treat Ventilation Exhaust Air?	No
Are HEPA Filters Used to Treat Ventilation Exhaust?	Yes
Radwaste Building Releases	
Are Charcoal Adsorption Used to Treat Ventilation Exhaust Air?	Radwaste Storage tank vents only
Are HEPA Filters Used to Treat Ventilation Exhaust?	Yes
Condenser Air Ejector Offgas Treatment System	
Utilizes Cryogenic Distillation	Yes
If Charcoal Delay System Is Used:	Not Applicable
Is Onsite Laundry Present	Yes
Are Detergent Releases Treated	Yes
If yes, What is DF Across Cartridge Filter	1

TABLE 1

	<u>High Purity Waste</u>	<u>Low Purity Waste</u>	<u>Chemical Waste</u>	<u>Detergent</u>	<u>Regenerant</u>
a) Flow Rate of Inlet Stream	121,440(gpd)	20,088(gpd)	.35gpm	900gpd	10,000(gpd)
b) Fraction of PCA	.09	3.4×10^{-5}	.16	N/A	.25
c) DF for Iodine	100	100	100	1	1,000
d) DF for Cs & Rb	10	2	100	1	10,000
e) DF (Others)	100	100	100	1	10,000
f) Waste Collection Time	5.7 - 1.4 hrs	17.9 - 6.1 hrs	8 Days	1 Day	4 hrs
Waste Processing and Discharge Time	330 - 180 min	305 - 250 min	13.3 hrs	36 min	10.4 min
h) Fraction Discharge	0	.50	1	1	0

Table 2.A

LOCATION OF NEAREST MILK COW (TO A DISTANCE OF 5 MILES)

<u>Direction</u>	<u>Distance¹ in Miles</u>
N	—
NNE	4.8
NE	—
ENE	—
E	—
ESE	—
SE	—
SSE	—
S	—
SSW	—
SW	—
WSW	—
W	5.0
WNW	—
NW	—
NNW	—

¹SEE PAGE 10.0 FOR EXPLANATION OF FOOTNOTE.

Response to Question 2.B

Animals observed around the Salem County site include rabbits, deer and pheasant. The rabbit is the most abundant species in terms of pounds and numbers. The State of New Jersey does not summarize data on a county basis and since the Salem area is relatively small and atypical, county data from Salem County would not be meaningful. The muskrat is often estimated as being trapped in higher quantities and pounds than the other species quoted above, however it should be noted that the muskrat is not truly a game species. It is trapped primarily for its fur although it's meat is also valued for consumption by individuals around the immediate area of the site.

The location of the closest beef animals has been tabulated and is presented below.

Table 2.B

NEAREST BEEF ANIMALS* WITHIN 5 MILES OF ARTIFICIAL ISLAND

<u>Direction</u>	<u>Distance in Miles</u>
N	-
NNW	4.2
NE	4.0
ENE	-
E	-
ESE	-
SE	-
SSE	-
S	-
SSW	-
SW	-
WSW	4.4
W	4.4
WNW	4.1
NW	3.9
NNW	-

*Any bovine livestock including dairy animals.

Response to Question 2.C

There are no milk goats around the Artificial Island (to a distance of 5 miles).

Response to Question 2.D

Table 2.D

LOCATION OF NEAREST RESIDENCE (TO A DISTANCE OF 5 MILES).

<u>Direction</u>	<u>Distance¹ in Miles</u>
N	— 1.5 (Summer on Boegli)
NNE	4.2
NE	4.1
ENE	3.5
E	—
ESE	—
SE	—
SSE	—
S	4.0 ✓
SSW	3.6 ✓
SW	4.3 ✓
WSW	3.7 ✓
W	3.4 ✓
WNW	3.7 Bay View Road = 3.2
NW	3.5 ✓
NNW	4.5 - Delaney

¹ SEE PAGE 10.0 FOR EXPLANATION OF FOOTNOTE.

TABLE 2.F

DISTANCE TO NEAREST SITE BOUNDARY

<u>Sector</u>	<u>Distance</u> ¹ <u>(Miles)</u>		
N	.55	885	874
NNE	.62	998	894
NE	.86	1384	1056
ENE	1.07	1722	1568
E	.93	1497	1465
ESE - Waterbound	1.11	1786	1555
SE "	.56		
SSE "	.46		
S "	.31		
SSW "	.21		
SW "	.18		
WSW "	.18		
W "	.20		
WNW "	.26		
NW "	.41		
NNW	.57		

SAR Amend 6
Fig 6.3-2
meas. to edge
of sectors

294

¹ SEE PAGE 10.0 FOR EXPLANATION ON FOOTNOTE.

Response to Question 2.E

Table 2.E

LOCATION OF NEAREST VEGETABLE ^{garden}FARM GREATER THAN 500 FT² (TO A DISTANCE OF 5 MILES).

<u>Direction</u>	<u>Distance¹ in Miles</u>
N	—
NNE	4.2
NE	4.0
ENE	—
E	—
ESE	—
SE	—
SSE	—
S	4.2
SSW	3.8
SW	4.4
WSW	4.4
W	3.8
WNW	4.0
NW	3.9
NNW	4.4

¹SEE PAGE 10.0 FOR EXPLANATION OF FOOTNOTE.

Response to Question 3.A

Table 3.A

RELATIVE CONCENTRATION X/Q AND DEPOSITION D/Q AT LOCATIONS OF NEAREST MILK COWS.

<u>Direction</u>	<u>Distance in miles</u>	<u>Undepleted X/Q (sec/m³)</u>	<u>Depleted</u>	
			<u>X/Q (sec/m³)</u>	<u>D/Q (1/m²)</u>
N	-----			
NNE	4.8	2.94E-8	1.02E-8	1.02E-10
NE	-----			
ENE	-----			
E	-----			
ESE	-----			
SE	-----			
SSE	-----			
S	-----			
SSW	-----			
SW	-----			
WSW	-----			
W	5.0	2.40E-8	5.68E-9	5.68E-11
WNW	-----			
NW	-----			
NNW	-----			

¹See Page 10.0 for explanation of footnote

Response to Question 3.B

Other than local farm animals such as fowl and beef, the Hope Creek area does not contain large areas where animals are raised for consumption. Animals such as deer, pheasant and rabbits are relatively abundant in the area. Since they may habitat at any location, specific dispersion coefficients were not calculated.

Response to Question 3.C

There are no milk goats around the Artificial Island (to a distance of 5 miles), therefore no dispersion values are calculated.

Table 3.D

RELATIVE CONCENTRATION X/Q AND DEPOSITION D/Q AT LOCATIONS OF THE NEAREST RESIDENCE

Direction	Distance ¹ in Miles	Undepleted	Depleted	
		X/Q (sec/m ³)	X/Q (sec/m ³)	D/Q (1/m ²)
N	--- * ~1.5			
NNE	4.2	3.68E-8	1.32E-8	1.32E-10
NE	4.1	4.45E-8	1.54E-8	1.54E-10
ENE	3.5	5.74E-8	1.85E-8	1.85E-10
E	---	*		
ESE	---	*		
SE	---	*		
SSE	---	*		
S	4.0	5.12E-8	1.60E-8	1.60E-10
SSW	3.6	5.33E-8	1.44E-8	1.44E-10
SW	4.3	3.43E-8	9.98E-9	9.98E-11
WSW	3.7	3.13E-8	8.66E-9	8.66E-11
W	3.4	4.59E-8	1.22E-8	1.22E-10
WNW	3.7	3.02E-8	7.10E-9	7.10E-11
NW	3.5	5.43E-8	1.72E-8	1.72E-10
NNW	4.5	4.65E-8	1.60E-8	1.60E-10

*No residence within five miles of site in this sector.

¹SEE PAGE 10.0 FOR EXPLANATION OF FOOTNOTE.

Response to Question 3.E

TABLE 3.E

RELATIVE CONCENTRATION X/Q AND DEPOSITION D/Q AT LOCATIONS OF THE NEAREST (5-MILE) VEGETABLE GARDENS (WITHIN 5 MILES).

<u>Direction</u>	<u>Distance¹ miles</u>	<u>Undepleted X/Q (sec/m³)</u>	<u>Depleted</u>	
			<u>X/Q (sec/m³)</u>	<u>D/Q (1/m²)</u>
N	---			
NNE	4.2	3.84E-8	1.47E-8	1.47E-10
NE	4.0	4.64E-8	1.62E-8	1.62E-10
ENE	---			
E	---			
ESE	---			
SE	---			
SSE	---			
S	4.2	4.72E-8	1.45E-8	1.45E-10
SSW	3.8	4.87E-8	1.28E-8	1.29E-10
SW	4.4	3.30E-8	9.54E-9	9.54E-11
WSW	4.4	2.34E-8	6.12E-9	6.12E-11
W	3.8	3.82E-8	9.82E-9	9.82E-11
WSW	4.0	2.66E-8	6.08E-9	6.08E-11
NW	3.9	4.54E-8	1.40E-8	1.40E-10
NNW	4.4	4.83E-8	1.67E-8	1.67E-10

¹SEE PAGE 10.0 FOR EXPLANATION OF FOOTNOTE.

TABLE 3.F

DISTANCE TO NEAREST SITE BOUNDARY

<u>Sector</u>	<u>Distance¹</u> <u>(Miles)</u>	<u>Undepleted</u> <u>X/Q³</u> <u>(sec/m³)</u>	<u>Depleted</u> <u>X/Q³</u> <u>sec/m³</u>	<u>D/Q</u> <u>(1/m²)</u>
N	.55	1.2E-6	7.0E-7	7.0E-9
NNE	.62	6.5E-7	3.7E-7	3.7E-9
NE	.86	5.0E-7	2.5E-7	2.5E-9
ENE	1.07	3.3E-7	1.6E-7	1.6E-9
E	.93	5.6E-7	3.0E-7	3.0E-9
ESE - Waterbound	1.11			
SE "	.56			
SSE "	.46			
S "	.31			
SSW "	.21			
SW "	.18			
WSW "	.18			
W "	.20			
WNW "	.26			
NW "	.41			
NNW	.57	9.0E-7	4.3E-7	4.3E-9

¹ SEE PAGE 10.0 FOR EXPLANATION ON FOOTNOTE.

Meteorology

From 1969 to 1971 Public Service Electric and Gas Company studied meteorological conditions at the Artificial Island site to determine atmospheric dispersion parameters. Parameters measured included wind speed and direction, ambient temperature, barometric pressure, relative humidity and precipitation. The principal source of data was 300-foot tower which was located north of Salem No. 2 Unit.

The method used to determine atmospheric stability was based upon a system developed by Smith-Singer at the Brookhaven National Laboratory.

Since all evidence suggests that the Gaussian diffusion equations are generally conservative no multiplication factor for "on site or close in" distances was used.

A description of the models employed as well as a description of the meteorological instruments utilized is in the attached report entitled Salem - Meteorology, Appendix E.

For purposes of conforming with Regulatory Guide 1.23, data on joint frequency distributions of wind speed and direction are tabulated according to vertical temperature gradients or lapse rates. Dispersion calculation, however, are based upon the Smith-Singer model.

While it appears as if diffusion rates may be altered in specific cases when air flows from one region to another, such incidents should be evaluated upon a case by case basis. At this time there appears to be no logical method of using independent wind roses for adjusting trajectories.

Representative data of the onsite meteorological data collected during 1969 to 1971 is included.

Response to Question 5.A

A computer card deck and a "hard copy" report (one copy) was transmitted under separate cover with the original submittal to respond to this question. We understand this approach was satisfactory with the regulatory staff.

Response to Question 5.B

The representativeness of the available data with respect to expected long term conditions at the site are discussed on Page B1.4 of Attachment B of this submittal which is entitled Hope Creek - Meteorology, Appendix B.

Response to Question 6

Onsite meteorological data is provided. Therefore, Question 6 is not applicable.

The post-operational meteorological data collection program for the Hope Creek Nuclear Generating Station (also located at Artificial Island Site) will meet the recommendation and intent of Regulatory Guide 1.23.

Response to Question 7


Air flow regimes of importance are discussed on Page B1.3 of the attachment entitled Hope Creek - Meteorology, Appendix B.

Response to Question 8

Two topographical maps are provided of the Artificial Island area.


Figure 1 is a detailed map of the Artificial Island area showing topographical features of the site within five miles.

Figure 2 is an expanded map of the Artificial Island area showing topographical features of the site within fifty miles.



Legend All elevations in feet
 M = Marsh
 R = River

FIGURE 1 Maximum elevations within 5 miles



Legend All elevations in feet
 M = Marsh
 R = River

FIGURE 2 Maximum elevations within 50 miles

Response to Question 9

The Hope Creek Generating Station is presently under construction.

FOOTNOT.

1. Distances are measured from the center of line drawn between the respective centroids of the containment buildings of the Salem Units No. 1 and 2, and the reactor buildings of Hope Creek Units No. 1 and 2. Distances to the site boundary (Table 2.F) are tabulated from the mid-point of the Hope Creek reactor buildings.

*Measured to what in sector?
Center, shortest point?
Appears to be center of sector!*

APPENDIX A

DATA NEEDED FOR RADIOACTIVE SOURCE TERM CALCULATIONS

This section contains questions raised by the Nuclear Regulatory Commission as presented in Draft Regulation Guide 1.CC along with Public Service Electric and Gas Co of New Jersey response.

RESPONSE TO DRAFT
REGULATORY GUIDE 1.00
APPENDIX D FOR HOPE CREEK
GENERATING STATION

Data needed for radioactive source term calculations for boiling water reactors

1. General

1.a. The maximum core thermal power evaluated for safety considerations in the PSAR is 3440 mwt. (Ref. PSAR page 1.1-1).

1.b. The total mass of uranium and plutonium in the equilibrium core is approximately 300,000 lbs.

The percent enrichment of uranium in the reload fuel shall be 2.663 w/o and 2.453 w/o.

No permits have been received for the loading of plutonium fuel.

1.c. The GALE code as presented in draft Regulatory Guide 1.00 was used to calculate the source terms in the primary coolant.

1.d. The quantity of tritium released from the Hope Creek reactor is calculated to be 43 Ci from gaseous effluents and 43 Ci from liquid effluents.

Regulatory Guide 1.00 (draft) was used as a basis for the amount of tritium produced. The Guide assumes that 0.25 Ci of tritium is produced per megawatt. It was also assumed that the plant capacity factor is 0.80, and that the noble gas isotopic release rate is 60,000 uCi/sec. The plant shall use Zircaloy-2 tubes and the activity concentrations expected in the primary coolant is presented in Table 2.2 of the Appendix I Enclosure 1 submittal.

2. Nuclear Steam Supply System

2.a. The total steam flow rate is $14 * 10^6$ lbs/hr. (Ref. PSAR Figure 1.5-4a)

2.b. The mass of reactor coolant (lbs) and steam (lbs) in the reactor vessel at full power is:

$0.6 * 10^6$ lbs of water

$.02 * 10^6$ lbs of steam (Ref. Suppl. E.R. Page 6-8)

3. Reactor Coolant Cleanup System

- 3.a. The average flow rate is 0.13×10^6 lbs/hr. (Ref. PSAR Fig. 1.5-4a)
- 3.b. Powdex demineralizers are used.
- 3.c. The regeneration frequency for each demineralizer is one backwash every 6.8 days. Since there are two demineralizers in each unit, there will be one backwash per unit every 3.4 days.
- 3.d. Regenerant volume (gal/event) and activity:

Volume	- 1000 gal/backwash
Normal liquid activity	- 1.71×10^{-2} μ Ci/cc
Maximum liquid activity	- 2.59 μ Ci/cc
Normal solid activity	- 5.22×10^7 μ Ci/batch
Maximum solid activity	- 4.52×10^9 μ Ci/batch

4. Condensate Demineralizers

- 4.a. The average flow rate is 14×10^6 lbs/hr. (Ref. Fig. 1.5-4a PSAR)
- 4.b. There are 7 demineralizers in all. 6 operate continuously and 1 operates on standby.
- 4.c. Number and size (cubic feet) of demineralizers:

Six vessels on line with one on standby.
312 cubic feet bed size each vessel.

- 4.d. Minimum regeneration frequency (no condenser inleakage) is one demineralizer every 2.5 days. Maximum regeneration frequency is 3-4 demineralizers per day.
- 4.e. The waste liquid volume generated during a URC cleaning is 16,000 gallons.
- 4.f. Regenerant volume and activity:

25,000 gal high conductivity waste with normal activity of 1.7×10^{-2} μ Ci/cc

29,000 gal low conductivity waste with normal activity of 1.2×10^{-2} μ Ci/cc

5. Liquid Waste Processing Systems

- 5.a.1 The sources of the various radwaste streams are very briefly described in Section 9.2 of the Hope Creek PSAR. A detailed description of the sources of activity is presented in the piping and instrument drawings. The flow rates and the expected activities are contained in Page 1.3 of Enclosure 2 of the Hope Creek Appendix I submittal.

D. Regenerant Waste Sub-system

1. Tanks (liquid volume)
 - a. Waste Neutralizers (2) - 25,000 gals each
 - b. Waste Evaporator Distillate Tank (2) - 1000 gals each
2. Process Equipment
 - a. Waste Evaporator (full forced circulation) (2) -40 gpm each
3. Pumps
 - a. Waste Neutralizer (2) - 176 gpm each
 - b. Waste Evaporator Feed (2) - 40 gpm each
 - c. Waste Evaporator Recirculation (2) - 90,000 gpm each
 - d. Waste Evaporator Distillate Transfer (2) - 50 gpm each

E. Detergent Drain Sub System

1. Tanks (Liquid Volume)
 - a. Detergent Drain (2 compartments) - 900 gals. each
2. Process Equipment
 - a. Detergent Drain Filter - 25 ft²
3. Pumps
 - a. Detergent Drain (2) - 25 gpm each

5.a.4 The decontamination factor for each process step are as described draft Reg. Guide 1.CC.

5.a.5 The fraction of each process stream expected to be discharged are described on Page 1.3 of Enclosure 2 of the Hope Creek Appendix I submittal.

5.a.6 Waste demineralizers are regenerated once every 52 days and Floor Drain Demineralizer once every 25.1 days (based on GE Process Diagram). Regenerant Volumes per demineralizer: 14,630 gals. (190 cubic feet at 77 gal/cu.ft.) high conductivity waste; 17,670 gals low conductivity waste (190 cu ft at 93 gal/cu ft). High conductivity waste will be processed by evaporation in the Regenerant Waste Sub-system and low conductivity will be processed by filtration and demineralization in the Eq. Drain Subsystem. Since these streams are returned for plant re-use, zero fraction

5.a.2 Effective decay times have been calculated for each stream by consideration of the waste holdup, collection, and processing time. This information is contained in page 1.3 of Enclosure 2 of the Hope Creek Appendix I submittal.

5.a.3 Liquid Radwaste System Capacities

A. Equipment Drain Sub-system

1. Tanks (Liquid Volume)
 - a. Waste Collector (2) - 29,000 gals. each
 - b. Waste surge - 66,225 gals
 - c. Waste Sample (2) - 15,000 gals each
2. Process Equipment
 - a. Waste Collector Filter - 182₃ft²
 - b. Waste Demineralizer - 190 ft³
3. Pumps
 - a. Waste Collector (2) - 182 gpm each
 - b. Waste Surge 182 gpm
 - c. Waste Sample (2) - 450 gpm

B. Floor Drain Sub-system

1. Tanks (liquid volume)
 - a. Floor Drain Collector (2) - 15,000 gals. each
 - b. Floor Drain Sample (2) - 15,000 gals. each
2. Process Equipment
 - a. Floor Drain Collector Filter - 176₃ft²
 - b. Floor Drain Demineralizer - 190 ft³
3. Pumps
 - a. Floor Drain Collector (2) - 176 gpm each
 - b. Floor Drain Sample (2) 176 gpm each

C. Chemical Waste Sub-system

1. Tanks (liquid volume)
 - a. Chemical waste - 40,000 gals
 - b. Chemical Waste Sample - 4000 gals
2. Process Equipment
 - a. Decontamination Solution Evaporator (Natural Circulation) - 5 gpm
3. Pumps
 - a. Chemical Waste - 5 gpm
 - b. Chemical Waste Sample Tank - 50gpm

is released to the environs. The high conductivity regenerant waste should have the following activities:

Waste Demineralizer:	4.7 $\mu\text{Ci/cc}$ max
	$1.72 \times 10^{-1} \mu\text{Ci/cc}$ normal
Floor Drain Demineralizer:	$2.12 \times 10^{-10} \mu\text{Ci/cc}$ normal
	$8.35 \times 10^{-9} \mu\text{Ci/cc}$ max

The regeneration frequency is based on an anion exchange capacity of 9 kgrains/cu ft and an average influent conductivity of 30 $\mu\text{mhos/cm}$ for the Waste Demineralizer and 200/ $\mu\text{mhos/cm}$ for the Floor Drain Demineralizer.

5.a.7 The liquid source term is calculated by the Gale Code, (See Table 2.2 of Enclosure 1 to the Appendix I submittal)

5.2 F&ID's are provided

6. Main Condenser and Turbine Gland Seal Air Removal Systems

6.a. The holdup time for offgases from the main condenser air ejector prior to processing by the offgas treatment system is about four seconds. This is the delay prior to entry to the recombiner preheater. Ten minute holdup is provided by a holdup pipe downstream of the recombiner. An additional ninety minutes holdup time is provided in the cryogeni portion of the offgas system before any gases are vented. The delay time used in the computer codes was 30 minutes.

6.b. There are three shells per condenser.

6.c. A charcoal delay system is not used.

6.d. A description of the cryogenic distillation system is provided on Page 9.4-5, 9.4-6 and Fig. 9.4-1 of the PSAR. Further information on the system was previously provided to the NRC as a proprietary report. (Reference Page C-110 of draft Regulatory Guide 1.00 reference number 21.)

6.e. Steam flow to the turbine gland seal is 25,000 lbs/hr normally. The source of makeup to the steam seal evaporator is condensate from downstream of the demineralizers.

6.f. Since the steam is not radioactive it is not necessary to hold up the gases. (Reference Page 9.4-1 PSAR.)

6.g. Piping and instrument drawings are provided.

7. Ventilation and Exhaust Systems

7.a. The provision incorporated to reduce radioactivity releases through the ventilation system is discussed on Page 1.1 of the Hope Creek Appendix I submittal. (Ref. Section 9 of PSAR.)

- 7.b. The decontamination factors used were taken from Reg. Guide 1.1C.
- 7.c. The estimated release rates are based upon Table 2.4 of the Appendix I submittal. The basis for these values are the Gale Code.
- 7.d. The ventilation release point for each unit is an exhaust stack of cross section dimensions 34 ft. by 9 ft. The stack is located above the roof of the auxiliary building and adjacent to the turbine building. The release elevation is 103.5 feet above grade. This is 34 ft. above the auxiliary building roof and 8 ft. above the adjacent turbine building roof.

Discharge stack dimensions: 34 ft. x 9 ft. cross section
 Unit 1 stack velocity: 1840 fpm summer/1310 fpm winter
 Unit 2 stack velocity: 1350 fpm summer/813 fpm winter

Unit 1 HVAC Sources:

	<u>CFM (Summer)</u>	<u>CFM (Winter)</u>
MG System	88,000	44,000
Oil Storage Rm.	17,500	17,500
Turbine Bldg. Exh.	130,000	53,000
T.B. Compartment Exh.	31,000	31,000
R/W Bldg.	114,000	114,000
Service Bldg.	44,100	44,100
Reactor Bldg.	139,500	96,000
	<hr/>	<hr/>
	564,100 (115°F)	399,600 (100°F)

Unit 2 HVAC Sources:

	<u>CFM (Summer)</u>	<u>CFM (Winter)</u>
MG System	88,000	44,000
Oil Storage Rm.	17,500	17,500
Turbine Bldg. Exh.	130,000	53,000
T.B. Compartment Exh.	31,000	31,000
Service Bldg. (Chem. Lab)	7,280	7,280
Reactor Bldg.	139,500	96,000
	<hr/>	<hr/>
	413,280 (120°F)	248,780 (104°F)

Maximum winter temperature difference between effluent and ambient: 95°F (Unit 1), 99°F (Unit 2).

Minimum summer temperature difference between effluent and ambient: 21°F (Unit 1), 26°F (Unit 2).

- 7.e. A description of the containment ventilation system is provided in Section 5.8.4.4 of the FSAR.

Only one purge a year is expected. Draft Reg. Guide 1.1C quotes a duration of purges of 48 hours/year.

8. Solid Waste Processing Systems

<u>Solid Radwaste Inputs</u>	<u>Expected Volume (Cu ft/yr /reactor)</u>	<u>Expected Activity (Ci/yr /reactor)</u>
1. Regenerant Waste Concentrate: 10,825 gals/45 days; $8.5 \times 10^{-1} \mu\text{Ci/cc}$	5,865	141.
2. Decon. Soln. Concentrate: 4,000 gals/yr; $5.8 \times 10^{-1} \mu\text{Ci/cc}$	267	4.4
3. Waste Sludge Phase Separator: 8,500 gals/35 days; $6.18 \times 10^{-1} \mu\text{Ci/cc}$	5,921	103.5
4. RWCU Phase Separator: 2,610 gals/60 days; $3.8 \times 10^2 \mu\text{Ci/cc}$	1,061	11,410.
5. Spent Resin: 83.5 cu ft/yr $3.3 \times 10^{-1} \mu\text{Ci/cc}$	84	0.8
TOTALS	13,200	11,660

8.b. Solid Radwaste storage is located in the auxiliary bldg. at Elev. 102.

1186 drums of HSA and 1170 drums of LSA storage capacities are provided. These relative amounts are adjustable but the total will remain the same.

It is expected that HSA material will be stored a minimum of 180 days and LSA material 30 days.

8.c. Piping and instrument diagrams are provided starting on page A.1.8 of this section)

PIPING AND INSTRUMENT DRAWINGS (P&ID's)
& PROCESS FLOW DIAGRAMS

<u>FIGURE NO.</u>	<u>TITLE</u>
P&ID #M-61-0	LIQUID RADWASTE COLLECTION
P&ID #M-61-1 (sh. 1)	LIQUID RADWASTE COLLECTION
P&ID #M-61-1 (sh. 2)	LIQUID RADWASTE COLLECTION
P&ID #M-62-0 (sh. 1)	LIQUID RADWASTE EQUIPMENT DRAIN PROCESSING
P&ID #M-62-0 (sh. 2)	LIQUID RADWASTE EQUIPMENT DRAIN PROCESSING
P&ID #M-63-0 (sh. 1)	LIQUID RADWASTE FLOOR DRAIN PROCESSING
P&ID #M-63-0 (sh. 2)	LIQUID RADWASTE FLOOR DRAIN PROCESSING
P&ID #M-64-0	LIQUID RADWASTE CHEMICAL WASTE PROCESSING
P&ID #M-65-0 (sh. 1)	LIQUID RADWASTE REGENERANT WASTE PROCESSING
P&ID #M-65-0 (sh. 2)	LIQUID RADWASTE REGENERANT WASTE PROCESSING
P&ID #M-66-0	SOLID RADWASTE COLLECTION
P&ID #M-67-0	SOLID RADWASTE COLLECTION
P&ID #M-69-0	GASEOUS RADWASTE RECOMBINATION
P&ID #M-70-0	GASEOUS RADWASTE COMPRESSOR PACKAGE
P&ID #M-71-0 (sh. 1)	GASEOUS RADWASTE CYROGENIC TREATMENT AND STORAGE
P&ID #M-71-0 (sh. 2)	GASEOUS RADWASTE CYROGENIC TREATMENT AND STORAGE

The two drawings below described the processing
of liquid and gaseous effluents.

SIMPLIFIED PROCESS DIAGRAM GASEOUS RADWASTE
RADWASTE SYSTEM DEEP BED-DUAL (Liquid and
solid waste process diagram)


**OVERSIZE
DOCUMENT
PAGE PULLED**

SEE APERTURE CARDS

NUMBER OF OVERSIZE PAGES FILMED ON APERTURE CARDS 1

**APERTURE CARD/HARD COPY AVAILABLE FROM RECORD SERVICES BRANCH, TIDC
FTS 492-8989**





KEY:

SALEM COUNTY DAIRY HERDS

TOTAL NUMBER OF COWS

1	DR. WEBSTER	50
2	A. FARN KAOPF	70
3	L. RICHIE	38
4	R. HAYNES JR.	98
5	F. SCHRIER	35
6	L. FOGG	100
7	W. DIXON	32
8	F. SMITH	34
9	L.H. GRISCOM	99
10	A. GRISCOM JR.	145
11	WALDAC FARMS INC.	207
12	C. HARRIS	15
13	W. GAVNT	58
14	H. STOMS	105
15*	F. SOWERS	3
16	N. JOHNSON	170
17	A. PETERSON	102
18	A. M. BELL	60
19	W. BRADWAY	7
20	N. N. CRUNSELLOR	39
21	W. DELLOX	86
22	H. HENDERSON, JR.	26
23	R. KEEN	55
24	R. PETERSON	25
25	V. REIMAN	16
26	B. RIDGWAY	70
27	L. STOMS	65
28	W. K. THOMASKI	50
29	A. WEIGEL	38

CUMBERLAND COUNTY DAIRY HERDS

30	A. S. FOGG	110
----	------------	-----

NEW CASTLE COUNTY DAIRY HERDS

31	C. BAXTER	80
32	W. E. BULLEN	100
33	R. CHAMBERS	120
34	W. CLEAVER	120
35	I. COVERDALE	110
36	S. COVERDALE	110
37	R. BURUS	100
38	S. DEATS	120
39	R. EMERSON	120
40	J. FENNIMORE	100
41	C. D. HAMMAN	125
42	H. VOSHILL	120
43	E. WOOD EYHAM	100
44	L. DEPORTI	100
45*	W. KID	92
46	E. DEPORTI	120
47	W. PASSMORE	110
48	T. ATKINSON	100
49	C. BLENDT, JR.	100
50	LOYD & DAVID SHEATS	250
51	DAVID REED	110
52*	PHILLIPS	30
53	NOT AVAILABLE	4
54	NOT AVAILABLE	2
55*	MCNATT - MOORE	9
56*	STELLER	2
57	VOSS	25
58	K. DAVID	1


*DAIRY HERDS 5 MILES OR LESS

SITE VICINITY MAP

SHOWING LOCATION OF DAIRY COWS

8805270103-04

TI
APERTURE
CARD



DAMES & MOORE

Also Available On
Aperture Card

W. P. 10-10-11-12

THIS MAP WAS PREPARED FROM A PORTION OF THE FSAR
LOUISIANA STATE UNIVERSITY, WILMINGTON, DELAWARE, 1965.

SALEM NUCLEAR GENERATING STATION

FSAR - AMENDMENT 27



FIG. 2.5-2


**OVERSIZE
DOCUMENT
PAGE PULLED**

SEE APERTURE CARDS


NUMBER OF OVERSIZE PAGES FILMED ON APERTURE CARDS 1

**APERTURE CARD/HARD COPY AVAILABLE FROM RECORD SERVICES BRANCH, TIDC
FTS 492-8989**





NOTE:
 1. THIS P&ID CONTAINS PORTION OF SYSTEM SHOWN



TI APERTURE CARD

Also Available On Aperture Card

880527D103-06



P&ID # M-61-0
 LIQUID RADWASTE COLLECTION

G
 F
 E
 D
 C
 B
 A


5 4 3 2 1

1-19-W


H
G
F
E
D
C
B
A



8 7 6




NOTES:
1. THIS FIELD CONTAINS PORTIONS OF SYSTEM SEE




TI APERTURE CARD

Also Available On Aperture Card


8805270103-07






**TI
APERTURE
CARD**


Also Available On
Aperture Card



8805270103-08

P&ID # M-61-1 (sh 2 of 2)
LIQUID RADWASTE COLLECTION







8805270103-09

**TI
APERTURE
CARD**

Also Available On
Aperture Card

P&ID # M-62-0 (sh 1 of 2)
LIQUID RADWASTE EQUIPMENT
DRAIN PROCESSING





8805270103-10

**TI
APERTURE
CARD**

Also Available On
Aperture Card

P&ID # M-62-0 (sh 2 of 2)
LIQUID RADWASTE EQUIPMENT
DRAIN PROCESSING

G
F
E
D
C
B
A


5


4

3

2

1






NOTE:
 THIS FIGURE ALSO CONTAINS PORTIONS OF
 SYSTEMS M-63-0 AND M-63-1

8805270103-11


TI
 APERTURE
 CARD

Also Available On
 Aperture Card

P&ID # M-63-0 (sh 1 of 2)
 LIQUID RADWASTE FLOOR
 DRAIN PROCESSING




This drawing is the property of BECHTEL. It is not to be distributed, copied, or reproduced in any form without the written consent of BECHTEL.



1


1

029-W-99



This drawing and the design it covers are the property of SECURITY. They are hereby loaned and are not to be reproduced, copied, or otherwise used in any way without the express written consent of SECURITY.

NAIPE COLLECTOR
 FILTER COLLECTOR
 (A. 5)




8805270103-12

TI
 APERTURE
 CARD

Also Available On
 Aperture Card

P&ID # M-63-0 (sh 2 of 2)
 LIQUID RADWASTE FLOOR
 DRAIN PROCESSING




NOTES:
 1. THIS FIELD ALSO CONTAINS PORTIONS OF SYSTEMS IN APERTURE CARD 8805270103-13

8805270103-13

**TI
 APERTURE
 CARD**

Also Available On
 Aperture Card

P&ID # M-64-0
 LIQUID RADWASTE CHEMICAL
 WASTE PROCESSING



NOTES:
 1. THIS P&ID ALSO CONTAINS PORTS IN
 OF THE SYSTEMS AS SHOWN


8805270103-14'

TI
 APERTURE
 CARD

Also Available On
 Aperture Card

P&ID # M-65-0 (sh 1 of 2)
 LIQUID RADWASTE REGENERANT
 WASTE PROCESSING

H
G
F
E
D
C
B
A




EVAPORATOR INLET VALUE LIST

COND	INLET	VALVE	INLET	VALVE
COND 10	100	101	100	101
COND 11	110	111	110	111
COND 12	120	121	120	121
COND 13	130	131	130	131
COND 14	140	141	140	141
COND 15	150	151	150	151
COND 16	160	161	160	161
COND 17	170	171	170	171
COND 18	180	181	180	181
COND 19	190	191	190	191
COND 20	200	201	200	201
COND 21	210	211	210	211
COND 22	220	221	220	221
COND 23	230	231	230	231
COND 24	240	241	240	241
COND 25	250	251	250	251
COND 26	260	261	260	261
COND 27	270	271	270	271
COND 28	280	281	280	281
COND 29	290	291	290	291
COND 30	300	301	300	301
COND 31	310	311	310	311
COND 32	320	321	320	321
COND 33	330	331	330	331
COND 34	340	341	340	341
COND 35	350	351	350	351
COND 36	360	361	360	361
COND 37	370	371	370	371
COND 38	380	381	380	381
COND 39	390	391	390	391
COND 40	400	401	400	401
COND 41	410	411	410	411
COND 42	420	421	420	421
COND 43	430	431	430	431
COND 44	440	441	440	441
COND 45	450	451	450	451
COND 46	460	461	460	461
COND 47	470	471	470	471
COND 48	480	481	480	481
COND 49	490	491	490	491
COND 50	500	501	500	501

EVAPORATOR INLET VALUE LIST

COND	INLET	VALVE	INLET	VALVE
COND 51	510	511	510	511
COND 52	520	521	520	521
COND 53	530	531	530	531
COND 54	540	541	540	541
COND 55	550	551	550	551
COND 56	560	561	560	561
COND 57	570	571	570	571
COND 58	580	581	580	581
COND 59	590	591	590	591
COND 60	600	601	600	601
COND 61	610	611	610	611
COND 62	620	621	620	621
COND 63	630	631	630	631
COND 64	640	641	640	641
COND 65	650	651	650	651
COND 66	660	661	660	661
COND 67	670	671	670	671
COND 68	680	681	680	681
COND 69	690	691	690	691
COND 70	700	701	700	701
COND 71	710	711	710	711
COND 72	720	721	720	721
COND 73	730	731	730	731
COND 74	740	741	740	741
COND 75	750	751	750	751
COND 76	760	761	760	761
COND 77	770	771	770	771
COND 78	780	781	780	781
COND 79	790	791	790	791
COND 80	800	801	800	801
COND 81	810	811	810	811
COND 82	820	821	820	821
COND 83	830	831	830	831
COND 84	840	841	840	841
COND 85	850	851	850	851
COND 86	860	861	860	861
COND 87	870	871	870	871
COND 88	880	881	880	881
COND 89	890	891	890	891
COND 90	900	901	900	901
COND 91	910	911	910	911
COND 92	920	921	920	921
COND 93	930	931	930	931
COND 94	940	941	940	941
COND 95	950	951	950	951
COND 96	960	961	960	961
COND 97	970	971	970	971
COND 98	980	981	980	981
COND 99	990	991	990	991
COND 100	1000	1001	1000	1001

8 7 6




8805270103-15

TI
APERTURE
CARD

Also Available On
Aperture Card

P&ID # M-65-0 (sh 2 of 2)
LIQUID RADWASTE REGENERANT
WASTE PROCESSING



ACOMIST
VENTILATION
DUNGEON
LATER


(A. 4)

CONCENTRATED
WASTE TANK
2-60-0-30
(A. 2)

SECOND SOLID
CONC. WASTE TANK
2-61-0-30
(B. 1)

WAST. RECYCLING
UNIT'S WASTE TANK
2-62-0-30
(A. 3)

CONCENTRATE
TANK
2-63-0-30
(A. 4)




NOTES:
THIS PAGE ALSO CONTAINS PORTIONS OF
TPO SYSTEMS HB AND GL

TI APERTURE CARD


Also Available On
Aperture Card


M-67-0

SOLID RADWASTE
PROCESSING



88052701D3-17





**TI
APERTURE
CARD**


Also Available On
Aperture Card


8805270103-18

P&ID # M-69-0
GASEOUS RADWASTE RECOMBINATION

G
F
E
D
C
B
A

5 | 4 | 3 | 2







TI
APERTURE
CARD

Also Available On
Aperture Card

8805270103-19

P&ID # M-70-0
GASEOUS RADWASTE COMPRESSOR
PACKAGE






TI
APERTURE
CARD

Also Available On
Aperture Card

8805270103-20

P&ID # M-71-0 (sh 1 of 2)
GASEOUS RADWASTE CYROGENIC
TREATMENT AND STORAGE




**TI
APERTURE
CARD**

Also Available On
Aperture Card


8805270103-21

P&ID # M-71-0 (sh 2 of 2)
GASEOUS RADWASTE CYROGENIC
TREATMENT AND STORAGE



TI APERTURE CARD

Also Available On Aperture Card



8805270103-22

Simplified Process Diagram
Gaseous Radwaste

**OVERSIZE
DOCUMENT
PAGE PULLED**

SEE APERTURE CARDS

NUMBER OF OVERSIZE PAGES FILMED ON APERTURE CARDS 1

**APERTURE CARD/HARD COPY AVAILABLE FROM RECORD SERVICES BRANCH, TIDC
FTS 492-8989**

APPENDIX B

METEOROLOGY

HOPE CREEK - APPENDIX I

APPENDIX B

METEOROLOGY

Request B-1

Provide the following information from the onsite meteorological program:

- a. Monthly and annual wind speed and direction data, in joint frequency form, at all heights of measurement representative of wind characteristics for points of effluent release to, and transport within, the atmosphere.
- b. Monthly and annual joint frequencies of wind direction and speed by atmospheric stability class at heights and intervals relevant to atmospheric transport of effluents.
- c. Total precipitation by month, number of hours with precipitation, rainfall rate distributions and monthly precipitation wind roses.

Note: The information based on onsite meteorological measurements, should include at least one annual cycle of data collection from the onsite program. The information should be fully documented and substantiated as to the validity of its representation of expected long-term conditions at and near the site.

Response B-1

a. Monthly and Annual Joint Frequencies of Wind Speed and Direction

Monthly and annual joint frequency distributions of wind speed and direction for the 30 and 300-foot levels for the period June, 1969 to May, 1971, are provided in Attachment 1.

In all cases calms have been distributed among the various wind sectors in the 0-3 mph category. The first calm hour within the period is placed in the first sector, the second calm hour in the second sector, and so on until all of the calm hours have been distributed. This results in essentially a uniform distribution of calm hours.

b. Monthly and Annual Joint Frequencies of Wind Speed and Direction by Atmospheric Stability

Attachment 1 also provides joint frequencies of wind speed and direction by stability for the 30 and 300-foot levels from June, 1969 to May, 1971. These distributions are based on the Smith-Singer stability categories and the standard NRC lapse rate categories. Again, the calms have been distributed in the manner described above.

c. Precipitation Data

Monthly precipitation data for the period June, 1969 to May, 1971, are provided in Attachment 2. These data include total precipitation, number of hours with precipitation, rainfall rate distributions, and precipitation wind roses.

Request B-2

Provide the following information, concerning regional meteorological conditions characterizing atmospheric transport processes within 50 miles of the plant, for as many relevant stations as practicable or necessary to define these transport processes within the region:

- a. Wind speed and direction data at all height(s) at which wind characteristic data are applicable or have been measured;
- b. Atmospheric stability data as defined by vertical temperature gradient or other well-documented parameters that have been substantiated by diffusion test data;
- c. Monthly mixing height data; and
- d. Total precipitation by month, number of hours with precipitation, rainfall rate distributions, and monthly precipitation wind roses.
- e. Describe airflow trajectory regimes of importance in transporting effluents to a distance of 50 miles from the plant, including airflow reversals.

Note: The regional meteorological information provided should be based on at least a one-year period of record and should be concurrent for each station with the period of onsite data collection. Both onsite and regional meteorological data should be presented for each hour, and if possible also be available on magnetic tapes to expedite the staff review. Sources of meteorological information, in addition to the onsite program, could include available National Weather Service (NWS) stations and other well-maintained and well-exposed (e.g. other nuclear plants, university, private meteorological programs) meteorological facilities.

Response B-2

- a. A comparison of wind roses was made for four locations: Artificial Island (6/69-5/71); Wilmington, Delaware; Philadelphia, Pennsylvania; and Baltimore, Maryland (1969-1973), Figures 1-3.

The overall comparison of directions between the site and regional meteorology stations was very good. Wilmington and Artificial Island are separated by approximately 15 miles. Differences in frequency for all sectors for both Artificial Island and Wilmington average 2.2%.

One possible explanation for the small directional differences between the site and other stations is wind shear due to differences in instrument elevation. The height of the instrument at Artificial Island is 91.4m while the instrument heights at the other locations average 17.5m with the instrument at Wilmington being the highest at 23.8m. The largest difference between Artificial Island and Wilmington is in the south and southeastern sectors.

Another possible reason for the directional differences is that the wind directions at Wilmington, Philadelphia, and Baltimore are one minute averages taken hourly; while at Artificial Island the wind direction is an average of the entire hour. At this open flat site the difference in computing average wind directions may account for more of the wind direction variance between stations than anything else.

- b. The atmospheric stability distributions as defined by the Star Program for Philadelphia 1967-1971, and Baltimore 1969-1973 are given in Figure 4.
- c. Seasonal and annual mixing height data for the Eastern United States and mixing height data for Washington, D. C. are given in Figures 5-10. These data were abstracted from Holzworth¹.

- d. Total precipitation by month, number of hours with precipitation and rainfall rate distributions, were extracted from the Climatological Summary for Philadelphia 1951-1960 shown in Figures 11-23.
- e. The terrain surrounding Artificial Island is open and extremely flat and the land-sea interaction favors a vigorous wind flow. Examination of the topography shows no terrain which would cause channeling of the winds or unusual flow trajectories. As evidenced by comparing wind roses between the site and nearby National Weather Service Stations, Figures 1-3, the distribution of wind direction is similar throughout the region. This question of the representativeness of the local wind data is important and it appears that the winds at this site are representative of the region.

Request B-4

Provide the following information concerning meteorological data:

- a. The identity of the sources of meteorological data used in the atmospheric transport models to assess the dispersion of gaseous effluents from the plant to a distance of 50 miles, and a description of the locations and elevations of all observations and the frequency and duration of the measurements made at each station.
- b. A description of the onsite pre-operational and operational meteorological programs including the instruments, performance specifications, calibration and maintenance procedures, data output and recording systems and locations, and data analysis procedures.
- c. A detailed description of any model(s) to derive estimates of basic meteorological parameters, such as atmospheric stability, and information concerning the validity and accuracy of the model(s).

Response B-4

a. Onsite Meteorological Measurements

The primary source of meteorological data for the Artificial Island Site was a 300-foot instrumented tower located north of Salem Unit 2. The measured parameters were wind speed and direction, ambient temperature, barometric pressure, relative humidity, and precipitation. The data used in this study cover a period from June, 1969 to May, 1971.

b. Onsite Meteorological Programs

1. Instrumentation

Figure 24 is a plan view of the 300-foot meteorological tower which was located at the Artificial Island Site. Bendix-Friez Model 120 Aerovanes were used to measure wind speed and direction at 30 foot, 150 foot, and 300-foot levels. The data were recorded on Bendix-Friez Model 141 strip chart recorders. Ambient temperatures were measured at 30 foot, 85 foot, 150 foot, and 300 foot using Rosemount Model 1-109MB resistance thermometers. These resistance thermometers were housed in Beckman and Whitley Model M327 aspirated solar radiation shields. The temperatures were recorded continuously on a Bristol Dynamaster multipoint recorder.

Barometric pressure was continuously recorded on a Belfort drum type microbarograph. Relative humidity was measured by a Casella hygrothermograph and precipitation was measured using a Belfort weighing rain gauge. All instrument performance specifications are provided in Figure 25.

2. Calibration and Maintenance

Data first became available from the 300-foot tower in June of 1969. The meteorological station was inspected at

least once a week by qualified instrument technicians. The charts were removed and records made of any unusual behavior of the instrument. Periodic calibration of all equipment was performed following the manufacturer's suggested maintenance and calibration procedures.

3. Data Analysis

Hourly averages were extracted from the analog strip charts, recorded on data sheets and transferred to punch cards by the Maplewood Laboratory of Public Service Electric and Gas Company. The punched cards and original strip charts were then forwarded to Smith-Singer Meteorologists, Inc. for further checking and analysis. Monthly computer summaries were generated, the data verified, and copied on magnetic tape.

c. Atmospheric Stability Estimates

The system used to determine atmospheric stability at the Artificial Island Site is based on wind gustiness. This system was developed by Smith and Singer at the Brookhaven National Laboratory and is described in detail in a paper entitled, "Relation of Gustiness to Other Meteorological Parameters"².

Between 1964 and the present many attempts have been made to develop new stability criteria for evaluating nuclear plants. The most widely used is that developed by Pasquill³. The AEC equated Pasquill's stability categories with certain lapse rate groups in Safety Guide 1.23 and this ΔT system is also specified in Safety Guide 1.111.

Smith-Singer has been convinced for some time that the NRC system produces an unrealistically large number of neutral and stable hours occasionally. Figure 26 is a comparison of the groupings produced by the NRC system with those of Smith-Singer.

The wide disparity among the unstable, neutral, and stable hours is very evident. While it is certainly not claimed that the Smith-Singer system is the best method, the differences are too important to ignore.

Our concern about the validity of the NRC stability classifications is based on several different concepts and data sets. First of all, the original Brookhaven National Laboratory studies² equated both ΔT and wind gustiness with field diffusion experiments. Here the frequency of the three main stability groups was approximately what one would expect in terms of the corresponding frequencies of sunshine, cloudiness, night and day hours, namely unstable 60%, neutral 5%, and stable 35%.

Secondly, the Brookhaven classification system has been used in many studies of fossil plants with considerable success for the prediction of ground-level concentrations. The most evidence of its value appears in two reports of the Maryland Power Plant Siting Program^{4,5}. These studies demonstrated the Smith-Singer system to be superior to those of Pasquill, TVA, and Turner.

Gifford⁶ in a recent article examined a wide variety of diffusion typing schemes, and he too made it evident that no system is an authoritative standard at present.

Request B-5

Provide the following information concerning concentration evaluations:

- a. Estimates of relative concentrations (X/Q) and/or deposition (D/Q) at points of potential maximum concentrations outside the site boundary, at points estimated maximum individual exposure, and at points within a radial grid of sixteen 22.5 degree sectors (centered on true north, etc.) and extending to a distance of 50 miles from the plant. A set of data points should be located within each sector at increments of .25 mile to a distance of 1 mile, at increments of .5 mile from a distance of 1 to 5 miles, at increments of 2.5 miles from a distance of 5 to 10 miles, and at increments of 5 miles thereafter to a distance of 50 miles.
- b. Estimates of X/Q for noble gas effluents and, if applicable, X/Q depleted by deposition and D/Q for iodine effluents at each of these grid points, as well as averages of these X/Q and/or D/Q values between all adjacent grid points along the radials.
- c. A detailed description of the model(s) and the model assumption(s) used to determine the air concentrations and/or deposition, and information concerning the validity and accuracy of the model(s) and assumptions, and the identity of the meteorological data used.

Response B-5

a. X/Q Values

X/Q values for the reactor vent for the annual case are given in Figures 27-30.

b. D/Q Values

D/Q values for the reactor vent for the annual case are given in Figures 31-34.

c. X/Q and D/Q Computations

The diffusion and deposition calculations were based on meteorological data collected from June, 1969 to May, 1971. The following formulas and assumptions were used in deriving the X/Q and D/Q estimates.

1. Plume Rise

Radioactivity will be released from two vent stacks located between the reactor and turbine buildings. The vent stacks are 103 feet above plant grade. The top of the turbine building is 21 feet lower and the top of the reactor building is 87 feet higher than the vent stacks. With moderate to strong winds these nearby structures will cause downwash.

The best guide for evaluation of downwash from these stacks is the field data from Peach Bottom⁷. There is good agreement between Peach Bottom and Hope Creek emission speeds, diameters, and flow rates.

	<u>Hope Creek</u>	<u>Peach Bottom</u>
W_e (m/sec)	7.0	12.2
D (m)	5.3	4.5
Vol (m^3 /sec)	155.0	194.0

W_e	Vertical efflux velocity at release temperature meters/second
D	Diameter, meters
Vol	Volume of effluent, meters ³ /second
u	Mean wind speed at stack height, meters/second

At Peach Bottom the plume rose freely when values of W_e/u from 3.5 to 4.0 were reached. Based on this result and similar work at Millstone⁸ total entrapment has been assumed for all values of W_e/u less than 5.0, a conservative assumption. Whenever entrapment occurs, the source height is assumed to be 10 meters above ground and a building correction factor ($CA = 2000m^2$) has been used. The wind speed as adjusted to the vent stack height was used, and is representative of the average wind speed between the ground and the top of the reactor building.

This approach is in good agreement with observed data and should be conservative. For values of W_e/u greater than or equal to 5.0 plume rise was calculated by the momentum formula in the ASME Guide⁹.

$$h_e = h_s + D \left(\frac{W_e}{u} \right)^{1.4}$$

h_e	Effective height of the plume, meters
h_s	Actual release height, meters
D	Diameter of the stack, meters
W_e	Vertical efflux velocity at release temperature, meters/second
u	Mean wind speed at stack height, meters/second

2. Diffusion Modeling

The Gaussian diffusion equation applicable to 22.5° sectors and corrected for building wake was used for the computations. The stability wind roses for the 300-foot level determined the weight for each stability, speed, and sector group.

The stability classification is that which has been used in previous Smith-Singer evaluations of nuclear plants. The four basic classes are comparable to the Pasquill categories, although the definition is somewhat simpler in both number and definition (Figure 35). The equations expressing the change in σ_z with distance are different for high and low sources as shown in the following table.

	<u>Very</u> <u>Unstable</u>	<u>Unstable</u>	<u>Neutral</u>	<u>Stable</u>
	<u>Sources Higher Than 50 Meters</u>			
σ_z	.40x ^{.91}	.33x ^{.86}	.22x ^{.78}	.06x ^{.71}
	<u>Sources Lower Than 50 Meters</u>			
σ_z	.29x ^{.91}	.25x ^{.86}	.19x ^{.78}	.08x ^{.71}

Where: σ_z Vertical standard deviation of the Gaussian plume, meters

x Distance downwind, meters

The terrain is extremely flat and the air flow patterns are simple. Therefore no adjustments have been made to account for terrain effects or air flow trajectories.

3. Wind Speed Profile

Wind speeds from the 300-foot level on the Artificial Island tower were adjusted to release heights according to the formula:

$$u_v = u_t \left(\frac{h_v}{h_t} \right)^q$$

- u_v Wind speed at vent height, meters/second
 u_t Wind speed at instrument height, meters/second
 h_v Vent height, meters
 h_t Instrument height, meters
 q Ranges from 0.16 to 0.50 and is a function of stability

4. Deposition

One of the most complex problems in reactor safety evaluations is the representation of the deposition of halogens. Considerable evidence exists, however, (Barry¹¹, Hill¹², Pelletier¹⁰) to suggest that an average deposition velocity (V_g) of .01 m/sec is often found with active chemical compounds such as iodine. Therefore, reasonable estimates of D/Q should result from the single assumption of a uniform deposition velocity of .01 m/sec. The D/Q estimates are based on this value.

Correction of the X/Q for removal by deposition has been made. The formulas for this plume depletion follow those given in Chamberlain¹³.

References

1. Holzworth, G. C.: Mixing Heights, Wind Speeds and Potential for Urban Air Pollution Throughout the Contiguous United States.
2. Singer, I. A. and Smith, M. E.: Relation of Gustiness to Other Meteorological Parameters, Journ. Met. 10, 121-126.
3. Pasquill, F. and Smith, F. B.: The Physical and Meteorological Basis for the Estimation of the Dispersion of Windborne Material. Proc. 2nd Int. Clear Air Cong., Academic Press, NY, (1971).
4. Weil, J. C.: Comparison Between Measured and Model Estimated Ground-Level SO₂ Concentrations Downwind from the Dickerson Plant; Maryland Power Plant Siting Prog., PPSP - NP - 11 (1974).
5. Weil, J.C.: Preliminary Analysis of Chalk Point Air Plume Data, Maryland Power Plant Siting Prog. (1974).
6. Gifford, F. A.: A Review of Turbulent Diffusion Typing Schemes, Nuclear Safety (in press).
7. Unit 2 Vent Plume Behavior Peach Bottom Power Station, Philadelphia Electric Company, V. 1&2, Docket No. 50-277 & 50-278.
8. Johnson, W. B., E. Shelar, R. E. Ruff, H. B. Singh, and L. Salas, 1975, Gas Tracer Study of Roof-Vent Effluent Diffusion at Millstone Nuclear Power Station, SRI Project 3588, Stanford Research Institute.
9. Smith, M. E. (ed): Recommended Guide for the Dispersion of Airborne Effluents, ASME, 1968.
10. Pelletier, C. A., J. D. Zimbrick, 1968, Kinetics of Environmental Radioiodine Transport Through the Milk-Food Chain, in Proceedings of, Environmental Surveillance in the Vicinity of Nuclear Facilities, W. C. Reinig, Editor, Thomas, Springfield, IL, 1970.
11. Barry, P. J. and Chamberlain, A. C., Deposition of Iodine onto Plant Leaves from Air, Health Phys. 9:1149 (1963).
12. Hill, Clyde, A., 1971, Vegetation: A Sink for Atmospheric Pollutants, Journ. of the Air Pollution Control Association, V. 21, No. 6, June, 1971.
13. Chamberlain, A. C., 1953, Aspects of Travel and Deposition of Aerosol and Vapour Clouds, A.E.R.E., HP/R 1261, H.M.S.O.

Figure 1

ARTIFICIAL ISLAND VS. WILMINGTON

6/69 - 5/71
HEIGHT 91.4M

1969-1973
HEIGHT 6.1M




Figure 2

ARTIFICIAL ISLAND VS. PHILADELPHIA

6/69 - 5/71
HEIGHT 91.4 M

1969 - 1973
HEIGHT 6.1 M




Figure 3

ARTIFICIAL ISLAND VS. BALTIMORE

6/69 - 5/71
HEIGHT 91.4M

1969-1973
HEIGHT 6.1M




FIGURE 4

STAR PROGRAM
STABILITY DISTRIBUTIONS
(%)

<u>Pasquill</u>	<u>Philadelphia</u> 1967-1971	<u>Baltimore</u> 1969-1973
A	.274	.4432
B } Unstable	4.3836	5.1096
C }	10.1164	11.2740
D } Neutral	57.7945	48.9178
E } Stable	15.1233	14.2808
F }	12.3082	19.9726

Figure 5

MEAN SEASONAL AND ANNUAL VALUES OF MORNING AND AFTERNOON
MIXING HEIGHT (m) AND WIND SPEED (m/sec)* FOR WASHINGTON, D.C.
1961 - 1964

	<u>Morning</u>		<u>Afternoon</u>	
	H (m)	u (m/sec)	H (m)	u (m/sec)
Winter	672	6.3	1054	7.3
Spring	585	5.4	1890	7.9
Summer	421	3.4	1924	5.6
Autumn	436	4.4	1412	6.4
Annual	528	4.9	1570	6.8

Values taken from George C. Holzworth, "Mixing Heights, Wind Speeds and Potential for Urban Air Pollution Throughout the Contiguous United States."

* Average wind speed in the mixing height layer.

MEAN ANNUAL MIXING HEIGHTS (Meters X 10²)

HCGS

B.1.21

REV. 1




FIGURE 6

MEAN WINTER MIXING HEIGHTS (Meters X 10²)




FIGURE 7

MEAN SPRING MIXING HEIGHTS (Meters X 10²)




FIGURE 8

MEAN SUMMER MIXING HEIGHTS (Meters X 10²)





FIGURE 9

MEAN AUTUMN MIXING HEIGHTS (Meters X 10²)



HCGS

B.1.25

REV. 1

FIGURE 10

A TEMPERATURE AND WIND SPEED-RELATIVE HUMIDITY OCCURRENCES

TEMPERATURE	6-11 M.P.H.		12-17 M.P.H.		18-23 M.P.H.		24-29 M.P.H.		30 M.P.H. AND OVER	
	NO.	%	NO.	%	NO.	%	NO.	%	NO.	%
64.7-65	1	2	1	2	1	2	1	2	1	2
65.7-66	1	2	1	2	1	2	1	2	1	2
66.7-67	1	2	1	2	1	2	1	2	1	2
67.7-68	1	2	1	2	1	2	1	2	1	2
68.7-69	1	2	1	2	1	2	1	2	1	2
69.7-70	1	2	1	2	1	2	1	2	1	2
70.7-71	1	2	1	2	1	2	1	2	1	2
71.7-72	1	2	1	2	1	2	1	2	1	2
72.7-73	1	2	1	2	1	2	1	2	1	2
73.7-74	1	2	1	2	1	2	1	2	1	2
74.7-75	1	2	1	2	1	2	1	2	1	2
75.7-76	1	2	1	2	1	2	1	2	1	2
76.7-77	1	2	1	2	1	2	1	2	1	2
77.7-78	1	2	1	2	1	2	1	2	1	2
78.7-79	1	2	1	2	1	2	1	2	1	2
79.7-80	1	2	1	2	1	2	1	2	1	2
TOTAL	214	222	228	247	276	421	541	726	201	216
	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5

B OF WIND DIRECTION AND SPEED: MONTHLY CHARACTERISTICS OF WIND SPEED

DIRECTION	MONTHLY CHARACTERISTICS OF WIND SPEED											
	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
N	0	0	0	0	0	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0	0	0	0	0	0
CALM	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL	11	16	33	75	7	1	1	1	1	1	1	1

C OCCURRENCES OF PRECIPITATION AMOUNTS: FREQUENCY OF OCCURRENCE FOR EACH HOUR OF THE DAY

PRECIPITATION	FREQUENCY OF OCCURRENCE FOR EACH HOUR OF THE DAY																							
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0.00-0.04	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.05-0.09	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.10-0.14	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.15-0.19	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.20-0.24	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.25-0.29	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.30-0.34	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.35-0.39	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.40-0.44	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.45-0.49	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.50-0.54	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.55-0.59	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.60-0.64	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.65-0.69	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.70-0.74	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.75-0.79	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.80-0.84	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.85-0.89	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.90-0.94	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
0.95-0.99	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
TOTAL	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48

D PERCENTAGE FREQUENCIES OF CEILING-VISIBILITY

VISIBILITY (MILES)	PERCENTAGE FREQUENCIES OF CEILING-VISIBILITY											
	1	2	3	4	5	6	7	8	9	10	11	12
0 TO 1/8	1	1	1	1	1	1	1	1	1	1	1	1
1/8 TO 1/4	1	1	1	1	1	1	1	1	1	1	1	1
1/4 TO 1/2	1	1	1	1	1	1	1	1	1	1	1	1
1/2 TO 3/4	1	1	1	1	1	1	1	1	1	1	1	1
3/4 TO 1	1	1	1	1	1	1	1	1	1	1	1	1
1 TO 1 1/2	1	1	1	1	1	1	1	1	1	1	1	1
1 1/2 TO 2	1	1	1	1	1	1	1	1	1	1	1	1
2 TO 3	1	1	1	1	1	1	1	1	1	1	1	1
3 TO 4	1	1	1	1	1	1	1	1	1	1	1	1
4 TO 5	1	1	1	1	1	1	1	1	1	1	1	1
5 TO 6	1	1	1	1	1	1	1	1	1	1	1	1
6 TO 7	1	1	1	1	1	1	1	1	1	1	1	1
7 TO 8	1	1	1	1	1	1	1	1	1	1	1	1
8 TO 9	1	1	1	1	1	1	1	1	1	1	1	1
9 TO 10	1	1	1	1	1	1	1	1	1	1	1	1
10 TO 11	1	1	1	1	1	1	1	1	1	1	1	1
11 TO 12	1	1	1	1	1	1	1	1	1	1	1	1
TOTAL	12	12	12	12	12	12	12	12	12	12	12	12

E PERCENTAGE FREQUENCIES OF SKY COVER, WIND, AND RELATIVE HUMIDITY

WIND	PERCENTAGE FREQUENCIES OF SKY COVER, WIND, AND RELATIVE HUMIDITY											
	1	2	3	4	5	6	7	8	9	10	11	12
0-10	1	1	1	1	1	1	1	1	1	1	1	1
11-20	1	1	1	1	1	1	1	1	1	1	1	1
21-30	1	1	1	1	1	1	1	1	1	1	1	1
31-40	1	1	1	1	1	1	1	1	1	1	1	1
41-50	1	1	1	1	1	1	1	1	1	1	1	1
51-60	1	1	1	1	1	1	1	1	1	1	1	1
61-70	1	1	1	1	1	1	1	1	1	1	1	1
71-80	1	1	1	1	1	1	1	1	1	1	1	1
81-90	1	1	1	1	1	1	1	1	1	1	1	1
91-100	1	1	1	1	1	1	1	1	1	1	1	1
TOTAL	12	12	12	12	12	12	12	12	12	12	12	12

A TEMPERATURE AND WIND SPEED-RELATIVE HUMIDITY OCCURRENCES

WIND	6-10 MPH	11-15 MPH	16-20 MPH	21-25 MPH	26-30 MPH	31-35 MPH	36-40 MPH	41-45 MPH	46-50 MPH	51-55 MPH	56-60 MPH	61-65 MPH	66-70 MPH	71-75 MPH	76-80 MPH	81-85 MPH	86-90 MPH	91-95 MPH	96-100 MPH	TOTAL
0-5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
6-10	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
11-15	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
16-20	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
21-25	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
26-30	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
31-35	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
36-40	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
41-45	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
46-50	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
51-55	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
56-60	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
61-65	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
66-70	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
71-75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
76-80	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
81-85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
86-90	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
91-95	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
96-100	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
TOTAL	21	20	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21

B PERCENTAGE FREQUENCIES OF WIND DIRECTION AND SPEED

WIND DIRECTION	0-5 MPH	6-10 MPH	11-15 MPH	16-20 MPH	21-25 MPH	26-30 MPH	31-35 MPH	36-40 MPH	41-45 MPH	46-50 MPH	51-55 MPH	56-60 MPH	61-65 MPH	66-70 MPH	71-75 MPH	76-80 MPH	81-85 MPH	86-90 MPH	91-95 MPH	96-100 MPH
N	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
NNE	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
NE	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
NENE	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
E	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
ESE	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
SE	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
SSE	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
S	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
SSW	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
SW	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
WSW	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
W	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
WNW	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
NW	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
NNW	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
CALM	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
TOTAL	21	20	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21

C OCCURRENCES OF PRECIPITATION AMOUNTS

PRECIPITATION AMOUNT	0.01-0.05	0.06-0.10	0.11-0.15	0.16-0.20	0.21-0.25	0.26-0.30	0.31-0.35	0.36-0.40	0.41-0.45	0.46-0.50	0.51-0.55	0.56-0.60	0.61-0.65	0.66-0.70	0.71-0.75	0.76-0.80	0.81-0.85	0.86-0.90	0.91-0.95	0.96-1.00
0.01-0.05	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.06-0.10	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.11-0.15	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.16-0.20	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.21-0.25	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.26-0.30	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.31-0.35	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.36-0.40	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.41-0.45	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.46-0.50	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.51-0.55	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.56-0.60	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.61-0.65	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.66-0.70	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.71-0.75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.76-0.80	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.81-0.85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.86-0.90	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.91-0.95	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
0.96-1.00	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
TOTAL	21	20	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21

D PERCENTAGE FREQUENCIES OF CEILING-VISIBILITY

CEILING-VISIBILITY	0-100	101-200	201-300	301-400	401-500	501-600	601-700	701-800	801-900	901-1000	1000+
0-100	1	1	1	1	1	1	1	1	1	1	1
101-200	1	1	1	1	1	1	1	1	1	1	1
201-300	1	1	1	1	1	1	1	1	1	1	1
301-400	1	1	1	1	1	1	1	1	1	1	1
401-500	1	1	1	1	1	1	1	1	1	1	1
501-600	1	1	1	1	1	1	1	1	1	1	1
601-700	1	1	1	1	1	1	1	1	1	1	1
701-800	1	1	1	1	1	1	1	1	1	1	1
801-900	1	1	1	1	1	1	1	1	1	1	1
901-1000	1	1	1	1	1	1	1	1	1	1	1
1000+	1	1	1	1	1	1	1	1	1	1	1
TOTAL	21	20	21	21	21	21	21	21	21	21	21

E PERCENTAGE FREQUENCIES OF SKY COVER, WIND, AND RELATIVE HUMIDITY

SKY COVER	0-25%	26-50%	51-75%	76-100
-----------	-------	--------	--------	--------

A TEMPERATURE AND WIND SPEED--RELATIVE HUMIDITY OCCURRENCES

TIME	TEMPERATURE		WIND SPEED		RELATIVE HUMIDITY	
	°F	°C	MPH	KPH	%	WIND DIRECTION
0000	58	14	10	16	75	000
0100	58	14	10	16	75	000
0200	58	14	10	16	75	000
0300	58	14	10	16	75	000
0400	58	14	10	16	75	000
0500	58	14	10	16	75	000
0600	58	14	10	16	75	000
0700	58	14	10	16	75	000
0800	58	14	10	16	75	000
0900	58	14	10	16	75	000
1000	58	14	10	16	75	000
1100	58	14	10	16	75	000
1200	58	14	10	16	75	000
1300	58	14	10	16	75	000
1400	58	14	10	16	75	000
1500	58	14	10	16	75	000
1600	58	14	10	16	75	000
1700	58	14	10	16	75	000
1800	58	14	10	16	75	000
1900	58	14	10	16	75	000
2000	58	14	10	16	75	000
2100	58	14	10	16	75	000
2200	58	14	10	16	75	000
2300	58	14	10	16	75	000
2400	58	14	10	16	75	000
2500	58	14	10	16	75	000
2600	58	14	10	16	75	000
2700	58	14	10	16	75	000
2800	58	14	10	16	75	000
2900	58	14	10	16	75	000
3000	58	14	10	16	75	000
3100	58	14	10	16	75	000
3200	58	14	10	16	75	000
3300	58	14	10	16	75	000
3400	58	14	10	16	75	000
3500	58	14	10	16	75	000
3600	58	14	10	16	75	000
3700	58	14	10	16	75	000
3800	58	14	10	16	75	000
3900	58	14	10	16	75	000
4000	58	14	10	16	75	000
4100	58	14	10	16	75	000
4200	58	14	10	16	75	000
4300	58	14	10	16	75	000
4400	58	14	10	16	75	000
4500	58	14	10	16	75	000
4600	58	14	10	16	75	000
4700	58	14	10	16	75	000
4800	58	14	10	16	75	000
4900	58	14	10	16	75	000
5000	58	14	10	16	75	000
5100	58	14	10	16	75	000
5200	58	14	10	16	75	000
5300	58	14	10	16	75	000
5400	58	14	10	16	75	000
5500	58	14	10	16	75	000
5600	58	14	10	16	75	000
5700	58	14	10	16	75	000
5800	58	14	10	16	75	000
5900	58	14	10	16	75	000
6000	58	14	10	16	75	000
6100	58	14	10	16	75	000
6200	58	14	10	16	75	000
6300	58	14	10	16	75	000
6400	58	14	10	16	75	000
6500	58	14	10	16	75	000
6600	58	14	10	16	75	000
6700	58	14	10	16	75	000
6800	58	14	10	16	75	000
6900	58	14	10	16	75	000
7000	58	14	10	16	75	000
7100	58	14	10	16	75	000
7200	58	14	10	16	75	000
7300	58	14	10	16	75	000
7400	58	14	10	16	75	000
7500	58	14	10	16	75	000
7600	58	14	10	16	75	000
7700	58	14	10	16	75	000
7800	58	14	10	16	75	000
7900	58	14	10	16	75	000
8000	58	14	10	16	75	000
8100	58	14	10	16	75	000
8200	58	14	10	16	75	000
8300	58	14	10	16	75	000
8400	58	14	10	16	75	000
8500	58	14	10	16	75	000
8600	58	14	10	16	75	000
8700	58	14	10	16	75	000
8800	58	14	10	16	75	000
8900	58	14	10	16	75	000
9000	58	14	10	16	75	000
9100	58	14	10	16	75	000
9200	58	14	10	16	75	000
9300	58	14	10	16	75	000
9400	58	14	10	16	75	000
9500	58	14	10	16	75	000
9600	58	14	10	16	75	000
9700	58	14	10	16	75	000
9800	58	14	10	16	75	000
9900	58	14	10	16	75	000
10000	58	14	10	16	75	000

C OCCURRENCES OF PRECIPITATION AMOUNTS:

TIME	PRECIPITATION AMOUNT	
	INCHES	MILLIMETERS
0000	0.00	0.00
0100	0.00	0.00
0200	0.00	0.00
0300	0.00	0.00
0400	0.00	0.00
0500	0.00	0.00
0600	0.00	0.00
0700	0.00	0.00
0800	0.00	0.00
0900	0.00	0.00
1000	0.00	0.00
1100	0.00	0.00
1200	0.00	0.00
1300	0.00	0.00
1400	0.00	0.00
1500	0.00	0.00
1600	0.00	0.00
1700	0.00	0.00
1800	0.00	0.00
1900	0.00	0.00
2000	0.00	0.00
2100	0.00	0.00
2200	0.00	0.00
2300	0.00	0.00
2400	0.00	0.00
2500	0.00	0.00
2600	0.00	0.00
2700	0.00	0.00
2800	0.00	0.00
2900	0.00	0.00
3000	0.00	0.00
3100	0.00	0.00
3200	0.00	0.00
3300	0.00	0.00
3400	0.00	0.00
3500	0.00	0.00
3600	0.00	0.00
3700	0.00	0.00
3800	0.00	0.00
3900	0.00	0.00
4000	0.00	0.00
4100	0.00	0.00
4200	0.00	0.00
4300	0.00	0.00
4400	0.00	0.00
4500	0.00	0.00
4600	0.00	0.00
4700	0.00	0.00
4800	0.00	0.00
4900	0.00	0.00
5000	0.00	0.00
5100	0.00	0.00
5200	0.00	0.00
5300	0.00	0.00
5400	0.00	0.00
5500	0.00	0.00
5600	0.00	0.00
5700	0.00	0.00
5800	0.00	0.00
5900	0.00	0.00
6000	0.00	0.00
6100	0.00	0.00
6200	0.00	0.00
6300	0.00	0.00
6400	0.00	0.00
6500	0.00	0.00
6600	0.00	0.00
6700	0.00	0.00
6800	0.00	0.00
6900	0.00	0.00
7000	0.00	0.00
7100	0.00	0.00
7200	0.00	0.00
7300	0.00	0.00
7400	0.00	0.00
7500	0.00	0.00
7600	0.00	0.00
7700	0.00	0.00
7800	0.00	0.00
7900	0.00	0.00
8000	0.00	0.00
8100	0.00	0.00
8200	0.00	0.00
8300	0.00	0.00
8400	0.00	0.00
8500	0.00	0.00
8600	0.00	0.00
8700	0.00	0.00
8800	0.00	0.00
8900	0.00	0.00
9000	0.00	0.00
9100	0.00	0.00
9200	0.00	0.00
9300	0.00	0.00
9400	0.00	0.00
9500	0.00	0.00
9600	0.00	0.00
9700	0.00	0.00
9800	0.00	0.00
9900	0.00	0.00
10000	0.00	0.00

D PERCENTAGE FREQUENCIES OF CEILING-VISIBILITY

TIME	CEILING		VISIBILITY	
	FEET	METERS	STATUTE MILES	KILOMETERS
0000	100	30	1.0	1.6
0100	100	30	1.0	1.6
0200	100	30	1.0	1.6
0300	100	30	1.0	1.6
0400	100	30	1.0	1.6
0500	100	30	1.0	1.6
0600	100	30	1.0	1.6
0700	100	30	1.0	1.6
0800	100	30	1.0	1.6
0900	100	30	1.0	1.6
1000	100	30	1.0	1.6
1100	100	30	1.0	1.6
1200	100	30	1.0	1.6
1300	100	30	1.0	1.6
1400	100	30	1.0	1.6
1500	100	30	1.0	1.6
1600	100	30	1.0	1.6
1700	100	30	1.0	1.6
1800	100	30	1.0	1.6
1900	100	30	1.0	1.6
2000	100	30	1.0	1.6
2100	100	30	1.0	1.6
2200	100	30	1.0	1.6
2300	100	30	1.0	1.6
2400	100	30	1.0	1.6
2500	100	30	1.0	1.6
2600	100	30	1.0	1.6
2700	100	30	1.0	1.6
2800	100	30	1.0	1.6
2900	100	30	1.0	1.6
3000	100	30	1.0	1.6
3100	100	30	1.0	1.6
3200	100	30	1.0	1.6
3300	100	30	1.0	1.6
3400	100	30	1.0	1.6
3500	100	30	1.0	1.6
3600	100	30	1.0	1.6
3700	100	30	1.0	1.6
3800	100	30	1.0	1.6
3900	100	30	1.0	1.6
4000	100	30	1.0	1.6
4100	100	30	1.0	1.6
4200	100	30	1.0	1.6
4300	100	30	1.0	1.6
4400	100	30	1.0	1.6
4500	100	30	1.0	1.6
4600	100	30	1.0	1.6
4700	100	30	1.0	1.6
4800	100	30	1.0	1.6
4900	100	30	1.0	1.6
5000	100	30	1.0	1.6
5100	100	30	1.0	1.6
5200	100	30	1.0	1.6
5300	100	30	1.0	1.6
5400	100	30	1.0	1.6
5500	100	30	1.0	1.6
5600	100	30	1.0	1.6
5700	100	30	1.0	1.6
5800	100	30	1.0	1.6
5900	100	30	1.0	1.6
6000	100	30	1.0	1.6
6100	100	30	1.0	1.6
6200	100	30	1.0	

A TEMPERATURE AND WIND SPEED--RELATIVE HUMIDITY OCCURRENCES

WIND	6-8 M.P.H.				8-14 M.P.H.				14-20 M.P.H.				20 M.P.H. AND OVER			
	0-5	5-10	10-15	15-20	0-5	5-10	10-15	15-20	0-5	5-10	10-15	15-20	0-5	5-10	10-15	15-20
REL. HUM.	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4
TEMP.	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4
TOTAL	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4

B OF WIND DIRECTION AND SPEED.

WIND	HOURS OF OCCURRENCE OF WIND SPEED															
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
WIND	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
REL. HUM.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
TEMP.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
TOTAL	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16

C OCCURRENCES OF PRECIPITATION AMOUNTS.

PRECIPITATION	FREQUENCY OF OCCURRENCE FOR EACH HOUR OF THE DAY																							
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0.01-0.05	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0.06-0.10	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0.11-0.20	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0.21-0.50	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0.51-1.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1.01-2.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
2.01-5.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
5.01-10.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
10.01-20.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
20.01-50.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
50.01-100.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
100.01-200.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
200.01-500.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
500.01-1000.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
TOTAL	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24

D PERCENTAGE FREQUENCIES OF CEILING-VISIBILITY.

PRECIPITATION	PERCENTAGE FREQUENCIES OF CEILING-VISIBILITY															
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
0.01-0.05	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
0.06-0.10	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
0.11-0.20	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
0.21-0.50	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
0.51-1.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
1.01-2.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2.01-5.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
5.01-10.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
10.01-20.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
20.01-50.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
50.01-100.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
100.01-200.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
200.01-500.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
500.01-1000.00	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
TOTAL	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16

E PERCENTAGE FREQUENCIES OF SKY COVER, WIND, AND RELATIVE HUMIDITY.

WIND	PERCENTAGE FREQUENCIES OF SKY COVER, WIND, AND RELATIVE HUMIDITY															
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
WIND	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
REL. HUM.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
TEMP.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
TOTAL	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16

A TEMPERATURE AND WIND SPEED--RELATIVE HUMIDITY OCCURRENCES

WIND	5-10 M.P.H.		11-15 M.P.H.		16-20 M.P.H.		21-25 M.P.H.		26-30 M.P.H.		31 M.P.H. AND OVER	
	NO.	%	NO.	%	NO.	%	NO.	%	NO.	%	NO.	%
120-1/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
99/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
98/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
97/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
96/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
95/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
94/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
93/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
92/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
91/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
90/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
89/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
88/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
87/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
86/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
85/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
84/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
83/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
82/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
81/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
80/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
79/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
78/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
77/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
76/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
75/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
74/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
73/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
72/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
71/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
70/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
69/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
68/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
67/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
66/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
65/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
64/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
63/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
62/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
61/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
60/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
59/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
58/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
57/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
56/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
55/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
54/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
53/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
52/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
51/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
50/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
49/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
48/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
47/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
46/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
45/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
44/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
43/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
42/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
41/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
40/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
39/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
38/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
37/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
36/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
35/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
34/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
33/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
32/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
31/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
30/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
29/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
28/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
27/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
26/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
25/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
24/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
23/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
22/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
21/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
20/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
19/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
18/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
17/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
16/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
15/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
14/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
13/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
12/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
11/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
10/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
9/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
8/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
7/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
6/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
5/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
4/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
3/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
2/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
1/100	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0	1	1.0
TOTAL	100	100.0	100	100.0	100	100.0	100	100.0	100	100.0	100	100.0

In Tables A and C, occurrences are for the average year (10-year total divided by 10). Values are rounded to the nearest whole, but not adjusted to make their sums exactly equal to column or row totals. "-", indicates zero then 0.5.

C OCCURRENCES OF PRECIPITATION AMOUNTS

PRECIPITATION	0.00-0.09 IN.		0.10-0.19 IN.		0.20-0.29 IN.		0.30-0.39 IN.		0.40-0.49 IN.	
---------------	---------------	--	---------------	--	---------------	--	---------------	--	---------------	--

PLAN VIEW OF METEOROLOGICAL TOWER ARTIFICIAL ISLAND




FIGURE 4

FIGURE 25

METEOROLOGICAL INSTRUMENTATION

ARTIFICIAL ISLAND

1969 - 1971

Ambient Temperature

Rosemount Resistance Thermometers
Model 1-109MB

Beckman and Whitley Aspirated
Thermal Radiation Shields
Model M327

Bristol Dynamaster 6 Point Recorder
M. 64A-6P 1570-33

Range: -30°F - +120°F

Wind Speed and Direction

Bendix-Friez Aerovane
Model 120

Bendix-Friez Recorder
Model 141

Wind Speed - Distance Constant: 15'

Range: 0-100 mph

Wind Direction - Distance Constant: 34'

Range: 0-540°

Barometric Pressure

Belfort Drum Type Microbarograph

Range: 28.50-31.00" Hg

Relative Humidity

Casella Hygrothermograph

Range: 0-100%

Precipitation

Belfort Weighing Rain Gauge

Range: 0-12"

SAMPLE COMPARISONS OF STABILITY ESTIMATES

Site Characteristics

<u>Stability</u>	<u>Shore</u>	<u>Shore</u>	<u>Shore</u>	<u>Estuary</u>	<u>Inland</u>
<u>Unstable</u>					
Smith-Singer *	45	68	46	64	67
(Pasq. A, B, C)†	12	16	8	10	18
<u>Neutral</u>					
Smith-Singer	28	13	19	14	16
(Pasq. D)	64	29	31	46	36
<u>Stable</u>					
Smith-Singer	28	19	35	22	17
(Pasq. E, F, G)	23	55	61	44	46

B.1.41

REV. 1

* Smith-Singer Gustiness or Lapse Rate Equivalent

† NRC Lapse Rate Categories

FIGURE 27

HOPE CREEK
BUILDING VENT
DEPLETED X/Q AT GROUND LEVEL APPLICABLE TO
LONG-TERM (ROUTINE) GASEOUS RELEASES
(SECONDS/H)
SECTOR ANNUAL X/Q AT GROUND LEVEL

DISTANCE MILES	SECTION BEARING (DEGREES)							
	22.5	45.0	67.5	90.0	112.5	135.0	157.5	180.0
0.25	1.085E+06	1.134E+06	8.918E+07	1.539E+06	1.397E+06	2.011E+06	1.383E+06	1.302E+06
0.50	5.043E+07	5.454E+07	4.599E+07	7.033E+07	5.896E+07	8.094E+07	5.614E+07	5.821E+07
0.75	2.873E+07	3.159E+07	2.747E+07	4.005E+07	3.243E+07	4.354E+07	3.053E+07	3.294E+07
1.00	1.829E+07	2.026E+07	1.784E+07	2.545E+07	2.031E+07	2.697E+07	1.902E+07	2.086E+07
1.25	1.562E+07	1.733E+07	1.530E+07	2.172E+07	1.728E+07	2.287E+07	1.615E+07	1.778E+07
1.50	1.348E+07	1.496E+07	1.325E+07	1.875E+07	1.486E+07	1.963E+07	1.388E+07	1.541E+07
1.75	1.175E+07	1.306E+07	1.157E+07	1.631E+07	1.292E+07	1.702E+07	1.204E+07	1.335E+07
2.00	1.032E+07	1.149E+07	1.019E+07	1.431E+07	1.132E+07	1.490E+07	1.055E+07	1.169E+07
2.25	9.155E+06	1.017E+07	9.029E+06	1.266E+07	1.000E+07	1.315E+07	9.312E+06	1.033E+07
2.50	8.141E+06	9.069E+06	8.052E+06	1.127E+07	8.902E+06	1.168E+07	8.278E+06	9.190E+06
2.75	7.298E+06	8.132E+06	7.223E+06	1.009E+07	7.970E+06	1.045E+07	7.406E+06	8.226E+06
3.00	6.579E+06	7.352E+06	6.512E+06	9.041E+06	7.175E+06	9.398E+06	6.664E+06	7.403E+06
3.25	5.960E+06	6.642E+06	5.900E+06	8.277E+06	6.494E+06	8.498E+06	6.027E+06	6.646E+06
3.50	5.423E+06	6.044E+06	5.368E+06	7.480E+06	5.904E+06	7.720E+06	5.476E+06	6.084E+06
3.75	4.955E+06	5.523E+06	4.903E+06	6.828E+06	5.390E+06	7.044E+06	4.997E+06	5.552E+06
4.00	4.545E+06	5.065E+06	4.496E+06	6.257E+06	4.940E+06	6.432E+06	4.578E+06	5.083E+06
4.25	4.183E+06	4.661E+06	4.136E+06	5.754E+06	4.545E+06	5.932E+06	4.209E+06	4.678E+06
4.50	3.863E+06	4.304E+06	3.817E+06	5.309E+06	4.194E+06	5.472E+06	3.883E+06	4.310E+06
4.75	3.577E+06	3.985E+06	3.533E+06	4.913E+06	3.882E+06	5.063E+06	3.593E+06	3.986E+06
5.00	3.322E+06	3.700E+06	3.279E+06	4.559E+06	3.604E+06	4.698E+06	3.334E+06	3.696E+06
5.25	3.093E+06	3.445E+06	3.051E+06	4.241E+06	3.355E+06	4.371E+06	3.102E+06	3.439E+06
5.50	2.887E+06	3.214E+06	2.848E+06	3.955E+06	3.130E+06	4.077E+06	2.893E+06	3.202E+06
5.75	2.701E+06	3.006E+06	2.663E+06	3.697E+06	2.927E+06	3.811E+06	2.704E+06	2.995E+06
6.00	2.537E+06	2.818E+06	2.492E+06	3.463E+06	2.743E+06	3.571E+06	2.534E+06	2.803E+06
6.25	2.378E+06	2.646E+06	2.339E+06	3.251E+06	2.576E+06	3.352E+06	2.379E+06	2.632E+06
6.50	2.238E+06	2.489E+06	2.200E+06	3.057E+06	2.424E+06	3.153E+06	2.237E+06	2.474E+06
6.75	2.110E+06	2.346E+06	2.072E+06	2.880E+06	2.285E+06	2.971E+06	2.108E+06	2.330E+06
7.00	1.993E+06	2.215E+06	1.955E+06	2.717E+06	2.157E+06	2.805E+06	1.990E+06	2.196E+06
7.25	1.885E+06	2.094E+06	1.848E+06	2.568E+06	2.040E+06	2.652E+06	1.881E+06	2.076E+06
7.50	1.785E+06	1.983E+06	1.749E+06	2.431E+06	1.932E+06	2.511E+06	1.781E+06	1.965E+06

FIGURE 28

HOPE CREEK
BUILDING VENT

DEPLETED X/Q AT GROUND LEVEL APPLICABLE TO
LONG-TERM (ROUTINE) GASEOUS RELEASES
(SECONDS/M³)
SECTOR ANNUAL X/Q AT GROUND LEVEL

DISTANCE MILES	SECTOR BEARING(DEGREES)							
	22.5	45.0	67.5	90.0	112.5	135.0	157.5	180.0
3.70	1.695E-08	1.881E-08	1.657E-08	2.304E-08	1.832E-08	2.581E-08	1.689E-08	1.862E-08
3.80	1.608E-08	1.786E-08	1.573E-08	2.187E-08	1.740E-08	2.261E-08	1.603E-08	1.767E-08
3.90	1.524E-08	1.698E-08	1.495E-08	2.079E-08	1.655E-08	2.149E-08	1.524E-08	1.679E-08
4.00	1.456E-08	1.616E-08	1.422E-08	1.978E-08	1.575E-08	2.046E-08	1.451E-08	1.597E-08
4.10	1.388E-08	1.540E-08	1.354E-08	1.885E-08	1.502E-08	1.930E-08	1.383E-08	1.521E-08
4.20	1.323E-08	1.469E-08	1.291E-08	1.797E-08	1.433E-08	1.860E-08	1.319E-08	1.450E-08
4.30	1.266E-08	1.403E-08	1.233E-08	1.716E-08	1.369E-08	1.777E-08	1.260E-08	1.384E-08
4.40	1.210E-08	1.342E-08	1.178E-08	1.640E-08	1.309E-08	1.699E-08	1.205E-08	1.323E-08
4.50	1.159E-08	1.284E-08	1.127E-08	1.569E-08	1.253E-08	1.624E-08	1.153E-08	1.265E-08
4.60	1.110E-08	1.250E-08	1.078E-08	1.503E-08	1.201E-08	1.558E-08	1.104E-08	1.211E-08
4.70	1.065E-08	1.179E-08	1.033E-08	1.440E-08	1.151E-08	1.494E-08	1.059E-08	1.160E-08
4.80	1.022E-08	1.131E-08	9.910E-09	1.381E-08	1.105E-08	1.433E-08	1.016E-08	1.113E-08
4.90	9.813E-09	1.086E-08	9.512E-09	1.326E-08	1.061E-08	1.377E-08	9.757E-09	1.068E-08
5.00	9.435E-09	1.044E-08	9.136E-09	1.274E-08	1.020E-08	1.323E-08	9.378E-09	1.026E-08
5.10	9.077E-09	1.004E-08	8.782E-09	1.225E-08	9.815E-09	1.273E-08	9.020E-09	9.864E-09
5.20	8.739E-09	9.662E-09	8.448E-09	1.179E-08	9.450E-09	1.225E-08	8.682E-09	9.489E-09
5.30	8.419E-09	9.306E-09	8.133E-09	1.135E-08	9.104E-09	1.180E-08	8.363E-09	9.135E-09
5.40	8.115E-09	8.969E-09	7.834E-09	1.094E-08	8.777E-09	1.138E-08	8.062E-09	8.801E-09
5.50	7.830E-09	8.650E-09	7.552E-09	1.055E-08	8.467E-09	1.098E-08	7.776E-09	8.484E-09
6.00	6.601E-09	7.282E-09	6.342E-09	8.870E-09	7.139E-09	9.252E-09	6.551E-09	7.128E-09
7.50	4.253E-09	4.672E-09	4.042E-09	5.678E-09	3.602E-09	5.961E-09	4.216E-09	4.552E-09
10.00	2.407E-09	2.628E-09	2.252E-09	3.186E-09	2.610E-09	3.377E-09	2.385E-09	2.546E-09
15.00	1.122E-09	1.189E-09	1.008E-09	1.433E-09	1.198E-09	1.541E-09	1.094E-09	1.146E-09
20.00	6.748E-10	7.184E-10	6.110E-10	8.540E-10	7.311E-10	9.256E-10	6.916E-10	7.184E-10
25.00	4.769E-10	5.041E-10	4.325E-10	5.903E-10	5.166E-10	6.418E-10	4.779E-10	4.963E-10
30.00	3.500E-10	3.746E-10	3.234E-10	4.344E-10	3.860E-10	4.735E-10	3.589E-10	3.640E-10
35.00	2.728E-10	2.834E-10	2.448E-10	3.272E-10	2.935E-10	3.581E-10	2.734E-10	2.740E-10
40.00	2.085E-10	2.199E-10	1.857E-10	2.499E-10	2.248E-10	2.746E-10	2.094E-10	2.047E-10
45.00	1.606E-10	1.660E-10	1.417E-10	1.925E-10	1.739E-10	2.134E-10	1.616E-10	1.605E-10
50.00	1.252E-10	1.292E-10	1.092E-10	1.508E-10	1.362E-10	1.684E-10	1.263E-10	1.246E-10

HCOS

B.1.43

REV. 1

FIGURE 29

HOPE CREEK
BUILDING VENT

DEPLETED X/Q AT GROUND LEVEL APPLICABLE TO
LONG-TERM (ROUTINE) GASEOUS RELEASES
(SECONDS/M³)
SECTOR ANNUAL X/Q AT GROUND LEVEL.

DISTANCE MILFS	SECTION BEARING(DEGREES)								
	202.5	225.0	247.5	270.0	292.5	315.0	337.5	360.0	
.25	7.305E-07	8.610E-07	5.707E-07	6.810E-07	3.592E-07	6.965E-07	1.170E-06	1.685E-06	
.50	3.904E-07	4.029E-07	2.687E-07	3.260E-07	2.013E-07	4.012E-07	6.143E-07	7.567E-07	
.75	2.334E-07	2.345E-07	1.550E-07	1.861E-07	1.219E-07	2.463E-07	3.697E-07	4.287E-07	
1.00	1.511E-07	1.493E-07	9.876E-08	1.179E-07	7.920E-08	1.618E-07	2.415E-07	2.718E-07	
1.25	1.294E-07	1.277E-07	8.424E-08	1.005E-07	6.756E-08	1.393E-07	2.077E-07	2.318E-07	
1.50	1.119E-07	1.099E-07	7.260E-08	8.652E-08	5.872E-08	1.209E-07	1.802E-07	1.999E-07	
1.75	9.756E-08	9.567E-08	6.314E-08	7.520E-08	5.121E-08	1.059E-07	1.577E-07	1.740E-07	
2.00	8.573E-08	8.397E-08	5.536E-08	6.591E-08	4.501E-08	9.335E-08	1.391E-07	1.528E-07	
2.25	7.587E-08	7.425E-08	4.890E-08	5.820E-08	3.983E-08	8.288E-08	1.235E-07	1.352E-07	
2.50	6.757E-08	6.609E-08	4.347E-08	5.174E-08	3.547E-08	7.403E-08	1.104E-07	1.204E-07	
2.75	6.052E-08	5.918E-08	3.889E-08	4.628E-08	3.177E-08	6.649E-08	9.915E-08	1.078E-07	
3.00	5.449E-08	5.328E-08	3.497E-08	4.162E-08	2.860E-08	6.003E-08	8.955E-08	9.716E-08	
3.25	4.930E-08	4.821E-08	3.161E-08	3.762E-08	2.587E-08	5.444E-08	8.125E-08	8.796E-08	
3.50	4.480E-08	4.381E-08	2.869E-08	3.416E-08	2.350E-08	4.958E-08	7.404E-08	8.000E-08	
3.75	4.088E-08	3.993E-08	2.616E-08	3.118E-08	2.144E-08	4.534E-08	6.773E-08	7.307E-08	
4.00	3.744E-08	3.663E-08	2.394E-08	2.850E-08	1.963E-08	4.161E-08	6.219E-08	6.699E-08	
4.25	3.440E-08	3.367E-08	2.198E-08	2.618E-08	1.803E-08	3.831E-08	5.729E-08	6.163E-08	
4.50	3.172E-08	3.106E-08	2.026E-08	2.413E-08	1.662E-08	3.538E-08	5.294E-08	5.688E-08	
4.75	2.934E-08	2.873E-08	1.872E-08	2.231E-08	1.536E-08	3.277E-08	4.907E-08	5.266E-08	
5.00	2.719E-08	2.665E-08	1.735E-08	2.068E-08	1.424E-08	3.044E-08	4.560E-08	4.888E-08	
5.25	2.528E-08	2.479E-08	1.612E-08	1.922E-08	1.323E-08	2.834E-08	4.248E-08	4.550E-08	
5.50	2.353E-08	2.311E-08	1.502E-08	1.791E-08	1.232E-08	2.645E-08	3.966E-08	4.245E-08	
5.75	2.200E-08	2.159E-08	1.402E-08	1.672E-08	1.151E-08	2.474E-08	3.712E-08	3.970E-08	
6.00	2.059E-08	2.022E-08	1.312E-08	1.565E-08	1.076E-08	2.319E-08	3.481E-08	3.720E-08	
6.25	1.931E-08	1.897E-08	1.230E-08	1.468E-08	1.009E-08	2.177E-08	3.271E-08	3.493E-08	
6.50	1.814E-08	1.784E-08	1.153E-08	1.379E-08	9.479E-09	2.048E-08	3.079E-08	3.286E-08	
6.75	1.708E-08	1.680E-08	1.087E-08	1.298E-08	8.919E-09	1.930E-08	2.903E-08	3.097E-08	
7.00	1.610E-08	1.585E-08	1.025E-08	1.224E-08	8.406E-09	1.822E-08	2.742E-08	2.924E-08	
7.25	1.520E-08	1.497E-08	9.674E-09	1.156E-08	7.935E-09	1.723E-08	2.595E-08	2.765E-08	
7.50	1.438E-08	1.417E-08	9.147E-09	1.094E-08	7.502E-09	1.631E-08	2.457E-08	2.618E-08	

FIGURE 30

HOPE CREEK
BUILDING VENT

DEPLETED X/Q AT GROUND LEVEL APPLICABLE TO
LONG-TERM (ROUTINE) GASEOUS RELEASES
(SECONDS/M³)
SECTOR ANNUAL X/Q AT GROUND LEVEL

DISTANCE MILES	SECTOR BEARING(DEGREES)							
	202.5	225.0	247.5	270.0	292.5	315.0	337.5	360.0
3.70	1.362E-08	1.343E-08	8.662E-09	1.036E-08	7.103E-09	1.546E-08	2.331E-08	2.462E-08
3.80	1.291E-08	1.274E-08	8.214E-09	9.825E-09	6.734E-09	1.468E-08	2.214E-08	2.357E-08
3.90	1.226E-08	1.210E-08	7.799E-09	9.332E-09	6.392E-09	1.396E-08	2.105E-08	2.241E-08
4.00	1.166E-08	1.152E-08	7.414E-09	8.874E-09	6.075E-09	1.328E-08	2.005E-08	2.133E-08
4.10	1.110E-08	1.097E-08	7.037E-09	8.449E-09	5.781E-09	1.265E-08	1.911E-08	2.033E-08
4.20	1.058E-08	1.046E-08	6.724E-09	8.055E-09	5.508E-09	1.207E-08	1.824E-08	1.940E-08
4.30	1.009E-08	9.981E-09	6.414E-09	7.684E-09	5.252E-09	1.153E-08	1.742E-08	1.853E-08
4.40	9.636E-09	9.537E-09	6.125E-09	7.340E-09	5.014E-09	1.102E-08	1.666E-08	1.771E-08
4.50	9.211E-09	9.121E-09	5.855E-09	7.018E-09	4.792E-09	1.054E-08	1.595E-08	1.695E-08
4.60	8.813E-09	8.732E-09	5.601E-09	6.716E-09	4.583E-09	1.009E-08	1.528E-08	1.624E-08
4.70	8.440E-09	8.366E-09	5.364E-09	6.434E-09	4.388E-09	9.673E-09	1.465E-08	1.557E-08
4.80	8.089E-09	8.023E-09	5.141E-09	6.168E-09	4.204E-09	9.278E-09	1.406E-08	1.494E-08
4.90	7.760E-09	7.701E-09	4.932E-09	5.919E-09	4.032E-09	8.907E-09	1.350E-08	1.435E-08
5.00	7.450E-09	7.397E-09	4.735E-09	5.684E-09	3.870E-09	8.558E-09	1.298E-08	1.379E-08
5.10	7.158E-09	7.111E-09	4.549E-09	5.463E-09	3.717E-09	8.228E-09	1.248E-08	1.326E-08
5.20	6.883E-09	6.840E-09	4.374E-09	5.254E-09	3.573E-09	7.917E-09	1.202E-08	1.277E-08
5.30	6.622E-09	6.585E-09	4.209E-09	5.057E-09	3.437E-09	7.623E-09	1.158E-08	1.230E-08
5.40	6.376E-09	6.344E-09	4.052E-09	4.870E-09	3.308E-09	7.345E-09	1.116E-08	1.185E-08
5.50	6.144E-09	6.115E-09	3.904E-09	4.694E-09	3.186E-09	7.081E-09	1.076E-08	1.143E-08
6.00	5.149E-09	5.137E-09	3.272E-09	3.939E-09	2.667E-09	5.953E-09	9.066E-09	9.628E-09
7.50	3.264E-09	3.278E-09	2.076E-09	2.509E-09	1.664E-09	3.802E-09	5.823E-09	6.187E-09
10.00	1.808E-09	1.833E-09	1.153E-09	1.401E-09	9.263E-10	2.124E-09	3.277E-09	3.490E-09
15.00	8.094E-10	8.315E-10	5.295E-10	6.421E-10	3.941E-10	9.544E-10	1.474E-09	1.576E-09
20.00	4.997E-10	5.167E-10	3.475E-10	4.117E-10	2.159E-10	5.817E-10	8.753E-10	9.396E-10
25.00	3.619E-10	3.751E-10	2.675E-10	3.089E-10	1.346E-10	4.141E-10	6.023E-10	6.464E-10
30.00	2.749E-10	2.853E-10	2.108E-10	2.399E-10	9.144E-11	3.107E-10	4.415E-10	4.746E-10
35.00	2.045E-10	2.180E-10	1.634E-10	1.850E-10	6.591E-11	2.355E-10	3.314E-10	3.575E-10
40.00	1.590E-10	1.661E-10	1.245E-10	1.411E-10	4.963E-11	1.786E-10	2.520E-10	2.728E-10
45.00	1.208E-10	1.267E-10	9.399E-11	1.072E-10	3.864E-11	1.360E-10	1.939E-10	2.112E-10
50.00	9.245E-11	9.756E-11	7.111E-11	8.162E-11	3.088E-11	1.046E-10	1.514E-10	1.660E-10

FIGURE 31

HOPE CREEK
BUILDING VENT
D/Q AT GROUND LEVEL APPLICABLE TO
LONG-TERM (ROUTINE) GASEOUS RELEASES
(M⁻²)

SECTOR ANNUAL D/Q AT GROUND LEVEL

DISTANCE MILES	SECTOR BEARING (DEGREES)									
	22.5	45.0	67.5	90.0	112.5	135.0	157.5	180.0		
.25	1.045E-08	1.138E-08	8.914E-09	1.534E-08	1.397E-08	2.011E-08	1.383E-08	1.302E-08		
.50	5.045E-09	5.454E-09	4.599E-09	7.033E-09	5.896E-09	8.094E-09	5.614E-09	5.821E-09		
.75	2.873E-09	3.159E-09	2.747E-09	4.005E-09	3.243E-09	4.344E-09	3.053E-09	3.294E-09		
1.00	1.729E-09	2.026E-09	1.784E-09	2.545E-09	2.031E-09	2.697E-09	1.902E-09	2.086E-09		
1.20	1.262E-09	1.733E-09	1.530E-09	2.172E-09	1.728E-09	2.287E-09	1.615E-09	1.776E-09		
1.40	1.248E-09	1.498E-09	1.252E-09	1.873E-09	1.486E-09	1.943E-09	1.386E-09	1.532E-09		
1.50	1.175E-09	1.506E-09	1.157E-09	1.631E-09	1.292E-09	1.702E-09	1.204E-09	1.333E-09		
1.60	1.032E-09	1.149E-09	1.019E-09	1.431E-09	1.132E-09	1.490E-09	1.055E-09	1.169E-09		
1.70	9.135E-10	1.017E-09	9.029E-10	1.266E-09	1.000E-09	1.313E-09	9.312E-10	1.033E-09		
1.80	7.911E-10	9.069E-10	8.052E-10	1.127E-09	8.902E-10	1.188E-09	8.278E-10	9.190E-10		
1.90	7.298E-10	8.132E-10	7.223E-10	1.009E-09	7.970E-10	1.045E-09	7.406E-10	8.268E-10		
2.00	6.579E-10	7.332E-10	6.512E-10	9.091E-10	7.175E-10	9.398E-10	6.664E-10	7.403E-10		
2.10	5.960E-10	6.642E-10	5.900E-10	8.227E-10	6.494E-10	8.498E-10	6.027E-10	6.896E-10		
2.20	5.423E-10	6.044E-10	5.365E-10	7.480E-10	5.904E-10	7.720E-10	5.476E-10	6.084E-10		
2.30	4.955E-10	5.523E-10	4.903E-10	6.828E-10	5.390E-10	7.044E-10	4.997E-10	5.552E-10		
2.40	4.545E-10	5.065E-10	4.466E-10	6.257E-10	4.940E-10	6.452E-10	4.578E-10	5.085E-10		
2.50	4.183E-10	4.661E-10	4.136E-10	5.754E-10	4.545E-10	5.932E-10	4.209E-10	4.674E-10		
2.60	3.863E-10	4.304E-10	3.817E-10	5.309E-10	4.197E-10	5.472E-10	3.883E-10	4.310E-10		
2.70	3.577E-10	3.985E-10	3.533E-10	4.913E-10	3.882E-10	5.063E-10	3.593E-10	3.986E-10		
2.80	3.322E-10	3.700E-10	3.279E-10	4.559E-10	3.604E-10	4.698E-10	3.334E-10	3.698E-10		
2.90	3.093E-10	3.445E-10	3.051E-10	4.241E-10	3.358E-10	4.371E-10	3.102E-10	3.439E-10		
3.00	2.867E-10	3.214E-10	2.846E-10	3.955E-10	3.130E-10	4.077E-10	2.893E-10	3.206E-10		
3.10	2.701E-10	3.006E-10	2.661E-10	3.697E-10	2.927E-10	3.811E-10	2.704E-10	2.995E-10		
3.20	2.552E-10	2.818E-10	2.492E-10	3.463E-10	2.743E-10	3.571E-10	2.534E-10	2.805E-10		
3.30	2.378E-10	2.646E-10	2.339E-10	3.251E-10	2.576E-10	3.352E-10	2.379E-10	2.632E-10		
3.40	2.238E-10	2.489E-10	2.200E-10	3.057E-10	2.424E-10	3.153E-10	2.237E-10	2.474E-10		
3.50	2.110E-10	2.346E-10	2.072E-10	2.880E-10	2.287E-10	2.971E-10	2.108E-10	2.350E-10		
3.60	1.995E-10	2.213E-10	1.955E-10	2.717E-10	2.137E-10	2.805E-10	1.990E-10	2.196E-10		
3.70	1.895E-10	2.093E-10	1.846E-10	2.568E-10	2.040E-10	2.652E-10	1.891E-10	2.076E-10		
3.80	1.795E-10	1.983E-10	1.749E-10	2.431E-10	1.932E-10	2.511E-10	1.781E-10	1.965E-10		

FIGURE 32

HOPE CREEK
 BUILDING VENT
 D/Q AT GROUND LEVEL APPLICABLE TO
 LONG-TERM (ROUTINE) GASEOUS RELEASES
 (M^{-2})
 SECTOR ANNUAL D/Q AT GROUND LEVEL

DISTANCE MILES	SECTOR BEARING(DEGREES)				
	22.5	45.0	67.5	90.0	112.5
5.70	1.693E-10	1.681E-10	1.657E-10	2.504E-10	1.632E-10
5.80	1.663E-10	1.786E-10	1.735E-10	2.187E-10	1.740E-10
5.90	1.529E-10	1.693E-10	1.495E-10	2.079E-10	1.655E-10
6.00	1.456E-10	1.616E-10	1.422E-10	1.974E-10	1.575E-10
6.10	1.368E-10	1.540E-10	1.354E-10	1.869E-10	1.502E-10
6.20	1.325E-10	1.469E-10	1.291E-10	1.797E-10	1.433E-10
6.30	1.266E-10	1.403E-10	1.233E-10	1.716E-10	1.369E-10
6.40	1.210E-10	1.342E-10	1.178E-10	1.640E-10	1.309E-10
6.50	1.159E-10	1.284E-10	1.127E-10	1.569E-10	1.253E-10
6.60	1.110E-10	1.230E-10	1.078E-10	1.503E-10	1.201E-10
6.70	1.065E-10	1.179E-10	1.035E-10	1.440E-10	1.151E-10
6.80	1.022E-10	1.131E-10	9.910E-11	1.381E-10	1.105E-10
6.90	9.815E-11	1.086E-10	9.512E-11	1.326E-10	1.061E-10
7.00	9.435E-11	1.044E-10	9.136E-11	1.274E-10	1.020E-10
7.10	9.077E-11	1.004E-10	8.782E-11	1.225E-10	9.819E-11
7.20	8.739E-11	9.662E-11	8.448E-11	1.179E-10	9.450E-11
7.30	8.419E-11	9.306E-11	8.133E-11	1.135E-10	9.104E-11
7.40	8.116E-11	8.969E-11	7.834E-11	1.094E-10	8.777E-11
7.50	7.835E-11	8.650E-11	7.552E-11	1.055E-10	8.467E-11
7.60	7.561E-11	8.342E-11	7.282E-11	1.019E-10	8.173E-11
7.70	7.295E-11	8.042E-11	6.982E-11	9.830E-11	7.903E-11
7.80	7.035E-11	7.746E-11	6.682E-11	9.566E-11	7.646E-11
7.90	6.780E-11	7.462E-11	6.392E-11	9.305E-11	7.392E-11
8.00	6.529E-11	7.190E-11	6.112E-11	9.048E-11	7.141E-11
8.10	6.282E-11	6.930E-11	5.842E-11	8.794E-11	6.892E-11
8.20	6.039E-11	6.682E-11	5.582E-11	8.542E-11	6.646E-11
8.30	5.799E-11	6.446E-11	5.332E-11	8.292E-11	6.402E-11
8.40	5.562E-11	6.222E-11	5.092E-11	8.044E-11	6.160E-11
8.50	5.328E-11	6.008E-11	4.862E-11	7.800E-11	5.920E-11
8.60	5.097E-11	5.804E-11	4.642E-11	7.560E-11	5.682E-11
8.70	4.869E-11	5.610E-11	4.432E-11	7.324E-11	5.446E-11
8.80	4.644E-11	5.426E-11	4.232E-11	7.092E-11	5.212E-11
8.90	4.422E-11	5.252E-11	4.042E-11	6.864E-11	4.980E-11
9.00	4.204E-11	5.088E-11	3.862E-11	6.640E-11	4.760E-11
9.10	3.990E-11	4.934E-11	3.692E-11	6.420E-11	4.550E-11
9.20	3.780E-11	4.790E-11	3.532E-11	6.204E-11	4.350E-11
9.30	3.574E-11	4.656E-11	3.382E-11	6.000E-11	4.160E-11
9.40	3.372E-11	4.532E-11	3.242E-11	5.808E-11	3.980E-11
9.50	3.174E-11	4.418E-11	3.112E-11	5.628E-11	3.810E-11
9.60	2.980E-11	4.314E-11	2.992E-11	5.450E-11	3.650E-11
9.70	2.790E-11	4.220E-11	2.882E-11	5.284E-11	3.500E-11
9.80	2.604E-11	4.136E-11	2.782E-11	5.130E-11	3.360E-11
9.90	2.422E-11	4.062E-11	2.692E-11	4.988E-11	3.230E-11
10.00	2.244E-11	4.000E-11	2.612E-11	4.858E-11	3.110E-11
10.10	2.070E-11	3.948E-11	2.542E-11	4.738E-11	2.998E-11
10.20	1.900E-11	3.906E-11	2.482E-11	4.628E-11	2.894E-11
10.30	1.734E-11	3.874E-11	2.432E-11	4.528E-11	2.798E-11
10.40	1.572E-11	3.852E-11	2.392E-11	4.438E-11	2.710E-11
10.50	1.414E-11	3.840E-11	2.362E-11	4.358E-11	2.630E-11
10.60	1.260E-11	3.838E-11	2.342E-11	4.288E-11	2.558E-11
10.70	1.110E-11	3.846E-11	2.332E-11	4.228E-11	2.494E-11
10.80	1.000E-11	3.864E-11	2.332E-11	4.178E-11	2.438E-11
10.90	9.00E-12	3.892E-11	2.342E-11	4.138E-11	2.388E-11
11.00	8.10E-12	3.930E-11	2.362E-11	4.108E-11	2.344E-11
11.10	7.30E-12	3.978E-11	2.392E-11	4.088E-11	2.306E-11
11.20	6.60E-12	4.036E-11	2.432E-11	4.078E-11	2.274E-11
11.30	6.00E-12	4.104E-11	2.482E-11	4.078E-11	2.248E-11
11.40	5.50E-12	4.182E-11	2.542E-11	4.088E-11	2.228E-11
11.50	5.10E-12	4.270E-11	2.612E-11	4.108E-11	2.214E-11
11.60	4.70E-12	4.368E-11	2.692E-11	4.138E-11	2.206E-11
11.70	4.40E-12	4.476E-11	2.782E-11	4.178E-11	2.204E-11
11.80	4.10E-12	4.594E-11	2.882E-11	4.228E-11	2.208E-11
11.90	3.80E-12	4.722E-11	2.992E-11	4.288E-11	2.218E-11
12.00	3.50E-12	4.860E-11	3.112E-11	4.358E-11	2.234E-11
12.10	3.20E-12	5.008E-11	3.242E-11	4.438E-11	2.256E-11
12.20	2.90E-12	5.166E-11	3.382E-11	4.528E-11	2.284E-11
12.30	2.60E-12	5.334E-11	3.532E-11	4.628E-11	2.318E-11
12.40	2.30E-12	5.512E-11	3.692E-11	4.738E-11	2.358E-11
12.50	2.00E-12	5.700E-11	3.862E-11	4.858E-11	2.404E-11
12.60	1.70E-12	5.900E-11	4.042E-11	4.988E-11	2.456E-11
12.70	1.40E-12	6.112E-11	4.232E-11	5.130E-11	2.514E-11
12.80	1.10E-12	6.336E-11	4.432E-11	5.284E-11	2.578E-11
12.90	8.00E-13	6.572E-11	4.642E-11	5.450E-11	2.648E-11
13.00	5.00E-13	6.820E-11	4.862E-11	5.628E-11	2.724E-11
13.10	2.00E-13	7.080E-11	5.092E-11	5.818E-11	2.806E-11
13.20	0.00E-13	7.352E-11	5.332E-11	6.020E-11	2.894E-11
13.30	0.00E-13	7.636E-11	5.582E-11	6.234E-11	2.988E-11
13.40	0.00E-13	7.932E-11	5.842E-11	6.460E-11	3.088E-11
13.50	0.00E-13	8.240E-11	6.112E-11	6.698E-11	3.194E-11
13.60	0.00E-13	8.560E-11	6.392E-11	6.958E-11	3.306E-11
13.70	0.00E-13	8.892E-11	6.682E-11	7.238E-11	3.434E-11
13.80	0.00E-13	9.236E-11	6.982E-11	7.538E-11	3.578E-11
13.90	0.00E-13	9.592E-11	7.292E-11	7.858E-11	3.738E-11
14.00	0.00E-13	9.960E-11	7.612E-11	8.198E-11	3.914E-11
14.10	0.00E-13	1.034E-10	7.942E-11	8.558E-11	4.106E-11
14.20	0.00E-13	1.074E-10	8.282E-11	8.938E-11	4.314E-11
14.30	0.00E-13	1.116E-10	8.632E-11	9.338E-11	4.538E-11
14.40	0.00E-13	1.160E-10	8.992E-11	9.758E-11	4.778E-11
14.50	0.00E-13	1.206E-10	9.362E-11	1.0198E-10	5.034E-11
14.60	0.00E-13	1.254E-10	9.742E-11	1.0688E-10	5.306E-11
14.70	0.00E-13	1.304E-10	1.014E-10	1.1208E-10	5.594E-11
14.80	0.00E-13	1.356E-10	1.062E-10	1.1758E-10	5.898E-11
14.90	0.00E-13	1.410E-10	1.112E-10	1.2338E-10	6.218E-11
15.00	0.00E-13	1.466E-10	1.164E-10	1.2948E-10	6.554E-11
15.10	0.00E-13	1.524E-10	1.218E-10	1.3588E-10	6.906E-11
15.20	0.00E-13	1.584E-10	1.274E-10	1.4258E-10	7.274E-11
15.30	0.00E-13	1.646E-10	1.332E-10	1.4958E-10	7.658E-11
15.40	0.00E-13	1.710E-10	1.392E-10	1.5688E-10	8.068E-11
15.50	0.00E-13	1.776E-10	1.454E-10	1.6448E-10	8.504E-11
15.60	0.00E-13	1.844E-10	1.518E-10	1.7238E-10	8.966E-11
15.70	0.00E-13	1.914E-10	1.584E-10	1.8058E-10	9.454E-11
15.80	0.00E-13	1.986E-10	1.652E-10	1.8908E-10	9.968E-11
15.90	0.00E-13	2.060E-10	1.722E-10	1.9788E-10	1.0508E-10
16.00	0.00E-13	2.136E-10	1.794E-10	2.0698E-10	1.1054E-10
16.10	0.00E-13	2.214E-10	1.868E-10	2.1638E-10	1.1616E-10
16.20	0.00E-13	2.294E-10	1.944E-10	2.2608E-10	1.2194E-10
16.30	0.00E-13	2.376E-10	2.022E-10	2.3608E-10	1.2788E-10
16.40	0.00E-13	2.460E-10	2.102E-10	2.4638E-10	1.3398E-10
16.50	0.00E-13	2.546E-10	2.184E-10	2.5698E-10	1.4024E-10
16.60	0.00E-13	2.634E-10	2.268E-10	2.6788E-10	1.4666E-10
16.70	0.00E-13	2.724E-10	2.354E-10	2.7908E-10	1.5324E-10
16.80	0.00E-13	2.816E-10	2.442E-10	2.9058E-10	1.6000E-10
16.90	0.00E-13	2.910E-10	2.532E-10	3.0238E-10	1.6694E-10
17.00	0.00E-13	3.006E-10	2.624E-10	3.1448E-10	1.7406E-10
17.10	0.00E-13	3.104E-10	2.718E-10	3.2688E-10	1.8136E-10
17.20	0.00E-13	3.204E-10	2.814E-10	3.3958E-10	1.8884E-10
17.30	0.00E-13	3.306E-10	2.912E-10	3.5258E-10	1.9650E-10
17.40	0.00E-13	3.410E-10	3.012E-10	3.6588E-10	2.0434E-10
17.50	0.00E-13	3.516E-10	3.114E-10	3.7948E-10	2.1236E-10
17.60	0.00E-13	3.624E-10	3.218E-10	3.9338E-10	2.2056E-10
17.70	0.00E-13	3.734E-10	3.324E-10	4.0758E-10	2.2894E-10
17.80	0.00E-13	3.846E-10	3.432E-10	4.2208E-10	2.3750E-10
17.90	0.00E-13	3.960E-10	3.542E-10	4.3688E-10	2.4624E-10
18.00	0.00E-13	4.076E-10	3.654E-10	4.5198E-10	2.5516E-10
18.10	0.00E-13	4.194E-10	3.768E-10	4.6738E-10	2.6426E-10
18.20	0.00E-13	4.314E-10	3.884E-10	4.8308E-10	2.7354E-10
18.30	0.00E-13	4.436E-10	4.002E-10	4.9908E-10	2.8300E-10
18.40	0.00E-13	4.560E-10	4.122E-10	5.1538E-10	2.9264E-10
18.50	0.00E-13	4.686E-10	4.244E-10	5.3198E-10	3.0246E-10
18.60	0.00E-13	4.814E-10	4.368E-10	5.4888E-10	3.1246E-10
18.70	0.00E-13	4.944E-10	4.494E-10	5.6608E-10	3.2264E-10
18.80	0.00E-13	5.076E-10	4.622E-10	5.8358E-10	3.3298E-10
18.90	0.00E-13	5.210E-10	4.752E-10	6.0138E-10	3.4348E-10
19.00	0.00E-13	5.346E-10	4.884E-10	6.1948E-10	3.5414E-10
19.10	0.00E-13	5.484E-10	5.018E-10	6.3788E-10	3.6496E-10
19.20	0.00E-13	5.624E-10	5.154E-10	6.5658E-10	3.7594E-10
19.30	0.00E-13	5.766E-10	5.292E-10	6.7568E-10	3.8708E-10
19.40	0.00E-13	5.910E-10	5.432E-10	6.9508E-10	3.9838E-10
19.50	0.00E-13	6.056E-10	5.574E-10	7.1478E-10	4.0984E-10
19.60	0.00E-13	6.204E-10	5.718E-10	7.3478E-10	4.2146E-10
19.70	0.00E-13	6.354E-10	5.864E-10	7.5508E-10	4.3324E-10
19.80	0.00E-13	6.506E-10	6.012E-10	7.7568E-10	4.4518E-10
19.90	0.				

FIGURE 33

HOPE CREEK
BUILDING VENT

D/Q AT GROUND LEVEL APPLICABLE TO
LONG-TERM (ROUTINE) GASEOUS RELEASES

$$\frac{(H^{-2})}{(H^{-2})}$$

SECTOR ANNUAL D/Q AT GROUND LEVEL

DISTANCE MILES	202.5	225.0	247.5	270.0	292.5	315.0	337.5	360.0
0.25	7.385E-09	6.610E-09	5.707E-09	6.810E-09	3.592E-09	6.965E-09	1.170E-08	1.685E-08
0.50	3.904E-09	4.009E-09	2.687E-09	3.260E-09	2.013E-09	4.012E-09	6.143E-09	7.587E-09
0.75	2.534E-09	2.345E-09	1.550E-09	1.861E-09	1.219E-09	2.463E-09	3.697E-09	4.207E-09
1.00	1.511E-09	1.493E-09	9.876E-10	1.179E-09	7.920E-10	1.618E-09	2.815E-09	2.716E-09
1.10	1.294E-09	1.274E-09	8.424E-10	1.005E-09	6.788E-10	1.393E-09	2.077E-09	2.318E-09
1.20	1.119E-09	1.094E-09	7.260E-10	8.652E-10	5.872E-10	1.209E-09	1.802E-09	1.999E-09
1.30	9.756E-10	9.567E-10	6.314E-10	7.520E-10	5.121E-10	1.059E-09	1.577E-09	1.740E-09
1.40	8.573E-10	8.397E-10	5.536E-10	6.591E-10	4.501E-10	9.335E-10	1.391E-09	1.528E-09
1.50	7.587E-10	7.425E-10	4.890E-10	5.820E-10	3.983E-10	8.286E-10	1.235E-09	1.352E-09
1.60	6.757E-10	6.609E-10	4.347E-10	5.174E-10	3.547E-10	7.403E-10	1.104E-09	1.204E-09
1.70	6.022E-10	5.918E-10	3.889E-10	4.628E-10	3.177E-10	6.649E-10	9.915E-10	1.078E-09
1.80	5.449E-10	5.328E-10	3.497E-10	4.162E-10	2.860E-10	6.003E-10	8.955E-10	9.716E-10
1.90	4.930E-10	4.821E-10	3.161E-10	3.762E-10	2.587E-10	5.444E-10	8.125E-10	8.796E-10
2.00	4.480E-10	4.381E-10	2.869E-10	3.416E-10	2.350E-10	4.958E-10	7.404E-10	8.002E-10
2.10	4.068E-10	3.990E-10	2.616E-10	3.114E-10	2.144E-10	4.534E-10	6.773E-10	7.307E-10
2.20	3.744E-10	3.663E-10	2.394E-10	2.850E-10	1.963E-10	4.161E-10	6.219E-10	6.699E-10
2.30	3.440E-10	3.367E-10	2.198E-10	2.618E-10	1.803E-10	3.831E-10	5.729E-10	6.163E-10
2.40	3.172E-10	3.106E-10	2.026E-10	2.417E-10	1.662E-10	3.538E-10	5.294E-10	5.688E-10
2.50	2.935E-10	2.873E-10	1.872E-10	2.247E-10	1.536E-10	3.277E-10	4.907E-10	5.266E-10
2.60	2.719E-10	2.665E-10	1.735E-10	2.098E-10	1.424E-10	3.044E-10	4.560E-10	4.886E-10
2.70	2.528E-10	2.479E-10	1.612E-10	1.922E-10	1.323E-10	2.834E-10	4.248E-10	4.550E-10
2.80	2.355E-10	2.311E-10	1.502E-10	1.791E-10	1.232E-10	2.645E-10	3.966E-10	4.245E-10
2.90	2.200E-10	2.159E-10	1.402E-10	1.672E-10	1.151E-10	2.474E-10	3.712E-10	3.970E-10
3.00	2.059E-10	2.022E-10	1.312E-10	1.565E-10	1.076E-10	2.319E-10	3.481E-10	3.720E-10
3.10	1.931E-10	1.897E-10	1.230E-10	1.468E-10	1.009E-10	2.177E-10	3.271E-10	3.493E-10
3.20	1.814E-10	1.784E-10	1.155E-10	1.379E-10	9.479E-11	2.046E-10	3.079E-10	3.286E-10
3.30	1.708E-10	1.680E-10	1.087E-10	1.298E-10	8.919E-11	1.930E-10	2.903E-10	3.097E-10
3.40	1.610E-10	1.585E-10	1.023E-10	1.224E-10	8.406E-11	1.822E-10	2.742E-10	2.924E-10
3.50	1.520E-10	1.497E-10	9.674E-11	1.156E-10	7.935E-11	1.723E-10	2.593E-10	2.765E-10
3.60	1.434E-10	1.417E-10	9.147E-11	1.094E-10	7.502E-11	1.631E-10	2.457E-10	2.616E-10

FIGURE 34

HOPE CREEK
BUILDING VENT

D/Q AT GROUND LEVEL APPLICABLE TO
LONG-TERM (ROUTINE) GASEOUS RELEASES
(M⁻²)

SECTOR ANNUAL D/Q AT GROUND LEVEL

DISTANCE MILES	202.5	225.0	247.5	270.0	292.5	315.0	337.5	360.0
3.70	1.362E-10	1.343E-10	8.662E-11	1.036E-10	7.103E-11	1.546E-10	2.351E-10	2.482E-10
3.80	1.291E-10	1.274E-10	8.214E-11	9.825E-11	6.734E-11	1.469E-10	2.214E-10	2.357E-10
3.90	1.226E-10	1.210E-10	7.799E-11	9.332E-11	6.392E-11	1.396E-10	2.109E-10	2.241E-10
4.00	1.166E-10	1.152E-10	7.419E-11	8.874E-11	6.075E-11	1.328E-10	2.005E-10	2.133E-10
4.10	1.110E-10	1.097E-10	7.057E-11	8.444E-11	5.781E-11	1.263E-10	1.911E-10	2.033E-10
4.20	1.059E-10	1.046E-10	6.724E-11	8.033E-11	5.505E-11	1.207E-10	1.824E-10	1.940E-10
4.30	1.009E-10	9.981E-11	6.414E-11	7.644E-11	5.252E-11	1.153E-10	1.742E-10	1.853E-10
4.40	9.636E-11	9.537E-11	6.125E-11	7.280E-11	5.014E-11	1.102E-10	1.666E-10	1.771E-10
4.50	9.211E-11	9.121E-11	5.855E-11	7.018E-11	4.792E-11	1.054E-10	1.595E-10	1.695E-10
4.60	8.813E-11	8.732E-11	5.601E-11	6.716E-11	4.583E-11	1.009E-10	1.528E-10	1.624E-10
4.70	8.440E-11	8.366E-11	5.364E-11	6.434E-11	4.388E-11	9.675E-11	1.463E-10	1.557E-10
4.80	8.099E-11	8.023E-11	5.141E-11	6.168E-11	4.204E-11	9.278E-11	1.406E-10	1.494E-10
4.90	7.780E-11	7.701E-11	4.932E-11	5.919E-11	4.032E-11	8.907E-11	1.350E-10	1.435E-10
5.00	7.480E-11	7.397E-11	4.735E-11	5.684E-11	3.870E-11	8.558E-11	1.294E-10	1.379E-10
5.10	7.199E-11	7.111E-11	4.549E-11	5.463E-11	3.717E-11	8.228E-11	1.248E-10	1.326E-10
5.20	6.933E-11	6.840E-11	4.374E-11	5.254E-11	3.573E-11	7.917E-11	1.202E-10	1.277E-10
5.30	6.682E-11	6.585E-11	4.209E-11	5.057E-11	3.437E-11	7.623E-11	1.158E-10	1.230E-10
5.40	6.446E-11	6.344E-11	4.052E-11	4.870E-11	3.308E-11	7.345E-11	1.116E-10	1.185E-10
5.50	6.224E-11	6.115E-11	3.904E-11	4.694E-11	3.186E-11	7.081E-11	1.076E-10	1.143E-10
6.00	5.149E-11	5.137E-11	3.272E-11	3.939E-11	2.667E-11	5.953E-11	9.066E-11	9.628E-11
7.50	3.264E-11	3.278E-11	2.076E-11	2.509E-11	1.684E-11	3.802E-11	5.823E-11	6.187E-11
10.00	1.808E-11	1.853E-11	1.153E-11	1.401E-11	9.265E-12	2.124E-11	3.277E-11	3.490E-11
15.00	6.094E-12	6.313E-12	3.295E-12	6.421E-12	3.961E-12	9.544E-12	1.474E-11	1.578E-11
20.00	4.997E-12	5.167E-12	3.475E-12	4.117E-12	2.159E-12	3.817E-12	8.753E-12	9.396E-12
25.00	3.619E-12	3.751E-12	2.673E-12	3.089E-12	1.346E-12	4.141E-12	6.023E-12	6.469E-12
30.00	2.749E-12	2.853E-12	2.108E-12	2.599E-12	9.144E-13	3.107E-12	4.415E-12	4.746E-12
35.00	2.095E-12	2.180E-12	1.634E-12	1.830E-12	6.591E-13	2.355E-12	3.314E-12	3.573E-12
40.00	1.590E-12	1.661E-12	1.245E-12	1.411E-12	4.963E-13	1.786E-12	2.520E-12	2.726E-12
45.00	1.209E-12	1.267E-12	9.399E-13	1.072E-12	3.864E-13	1.360E-12	1.939E-12	2.112E-12
50.00	9.245E-13	9.756E-13	7.111E-13	8.182E-13	3.088E-13	1.046E-12	1.514E-12	1.660E-12

HOPE CREEK
BUILDING VENT

UNDEPLETED X/Q AT GROUND LEVEL APPLICABLE TO

LONG-TERM (ROUTINE) GASEOUS RELEASES

(SECONDS/M³)

SECTOR ANNUAL X/Q AT GROUND LEVEL

DISTANCE FEET	22.5	45.0	67.5	90.0	112.5	135.0	157.5	180.0
25	1.590E-06	1.476E-06	1.195E-06	1.908E-06	1.728E-06	2.481E-06	1.719E-06	1.698E-06
30	7.948E-07	8.878E-07	6.023E-07	1.170E-06	8.960E-07	1.243E-06	8.630E-07	9.847E-07
35	3.155E-07	5.827E-07	5.461E-07	7.660E-07	5.590E-07	7.667E-07	5.349E-07	6.441E-07
1.00	3.554E-07	4.052E-07	5.878E-07	5.522E-07	3.800E-07	5.189E-07	3.627E-07	4.476E-07
1.10	3.113E-07	3.557E-07	3.491E-07	4.671E-07	3.57E-07	4.524E-07	3.164E-07	3.926E-07
1.20	2.749E-07	3.146E-07	3.035E-07	4.132E-07	2.920E-07	3.980E-07	2.784E-07	3.475E-07
1.30	2.445E-07	2.802E-07	2.712E-07	3.661E-07	2.591E-07	3.530E-07	2.470E-07	3.095E-07
1.40	2.190E-07	2.512E-07	2.457E-07	3.300E-07	2.315E-07	3.153E-07	2.204E-07	2.774E-07
1.50	1.972E-07	2.265E-07	2.202E-07	2.973E-07	2.082E-07	2.834E-07	1.963E-07	2.502E-07
1.60	1.768E-07	2.054E-07	2.000E-07	2.697E-07	1.863E-07	2.562E-07	1.793E-07	2.268E-07
1.70	1.626E-07	1.871E-07	1.825E-07	2.457E-07	1.711E-07	2.328E-07	1.629E-07	2.065E-07
1.80	1.466E-07	1.712E-07	1.672E-07	2.248E-07	1.563E-07	2.126E-07	1.488E-07	1.890E-07
1.90	1.365E-07	1.572E-07	1.538E-07	2.065E-07	1.435E-07	1.949E-07	1.364E-07	1.756E-07
2.00	1.256E-07	1.450E-07	1.419E-07	1.904E-07	1.319E-07	1.794E-07	1.256E-07	1.600E-07
2.10	1.165E-07	1.341E-07	1.314E-07	1.762E-07	1.219E-07	1.658E-07	1.160E-07	1.461E-07
2.20	1.079E-07	1.245E-07	1.221E-07	1.635E-07	1.150E-07	1.536E-07	1.075E-07	1.374E-07
2.30	1.004E-07	1.159E-07	1.138E-07	1.522E-07	1.051E-07	1.428E-07	9.997E-08	1.279E-07
2.40	9.367E-08	1.082E-07	1.063E-07	1.421E-07	9.798E-08	1.332E-07	9.320E-08	1.194E-07
2.50	8.762E-08	1.012E-07	9.952E-08	1.329E-07	9.159E-08	1.245E-07	8.732E-08	1.117E-07
2.60	8.216E-08	9.495E-08	9.341E-08	1.247E-07	8.563E-08	1.167E-07	8.184E-08	1.046E-07
2.70	7.721E-08	8.926E-08	8.786E-08	1.172E-07	8.062E-08	1.096E-07	7.667E-08	9.850E-08
2.80	7.271E-08	8.408E-08	8.281E-08	1.104E-07	7.568E-08	1.031E-07	7.216E-08	9.279E-08
2.90	6.860E-08	7.935E-08	7.819E-08	1.042E-07	7.156E-08	9.726E-08	6.805E-08	8.757E-08
3.00	6.485E-08	7.503E-08	7.397E-08	9.854E-08	6.762E-08	9.189E-08	6.429E-08	8.279E-08
3.10	6.140E-08	7.106E-08	7.009E-08	9.335E-08	6.400E-08	8.697E-08	6.051E-08	7.841E-08
3.20	5.824E-08	6.741E-08	6.652E-08	8.853E-08	6.067E-08	8.245E-08	5.763E-08	7.458E-08
3.30	5.532E-08	6.405E-08	6.311E-08	8.411E-08	5.761E-08	7.829E-08	5.477E-08	7.067E-08
3.40	5.262E-08	6.094E-08	6.016E-08	8.003E-08	5.478E-08	7.444E-08	5.207E-08	6.725E-08
3.50	5.013E-08	5.806E-08	5.736E-08	7.625E-08	5.216E-08	7.089E-08	4.958E-08	6.405E-08
3.60	4.781E-08	5.539E-08	5.473E-08	7.274E-08	4.974E-08	6.759E-08	4.727E-08	6.110E-08

HOPE CREEK
BUILDING VENT

UNDEPLETED X/Q AT GROUND LEVEL APPLICABLE TO
LONG-TERM (ROUTINE) GASEOUS RELEASES
(SECONDS/M³)

SECTOR ANNUAL X/Q AT GROUND LEVEL

DISTANCE MILES	SECTOR ANNUAL X/Q AT GROUND LEVEL					
	22.5	45.0	67.5	112.5	155.0	197.5
5.70	4.506E-08	5.290E-08	6.947E-08	4.748E-08	6.452E-08	4.513E-08
5.80	4.565E-08	5.759E-08	6.454E-08	4.538E-08	6.167E-08	4.313E-08
5.90	4.174E-08	4.843E-08	6.790E-08	4.343E-08	5.901E-08	4.127E-08
6.00	4.903E-08	4.641E-08	6.095E-08	4.160E-08	5.652E-08	3.953E-08
6.10	3.640E-08	4.452E-08	5.846E-08	3.959E-08	5.420E-08	3.790E-08
6.20	3.606E-08	4.274E-08	5.614E-08	3.828E-08	5.202E-08	3.637E-08
6.30	3.542E-08	4.108E-08	5.395E-08	3.678E-08	4.997E-08	3.494E-08
6.40	3.447E-08	3.951E-08	5.190E-08	3.536E-08	4.805E-08	3.360E-08
6.50	3.279E-08	3.804E-08	4.996E-08	3.403E-08	4.624E-08	3.233E-08
6.60	3.159E-08	3.665E-08	4.814E-08	3.278E-08	4.454E-08	3.114E-08
6.70	3.046E-08	3.534E-08	4.641E-08	3.159E-08	4.293E-08	3.001E-08
6.80	2.939E-08	3.410E-08	4.479E-08	3.048E-08	4.141E-08	2.895E-08
6.90	2.837E-08	3.293E-08	4.325E-08	2.942E-08	3.998E-08	2.795E-08
7.00	2.742E-08	3.182E-08	4.179E-08	2.842E-08	3.862E-08	2.699E-08
7.10	2.651E-08	3.077E-08	4.041E-08	2.747E-08	3.733E-08	2.609E-08
7.20	2.564E-08	2.977E-08	3.910E-08	2.657E-08	3.611E-08	2.524E-08
7.30	2.482E-08	2.882E-08	3.785E-08	2.572E-08	3.494E-08	2.443E-08
7.40	2.404E-08	2.792E-08	3.666E-08	2.490E-08	3.384E-08	2.365E-08
7.50	2.330E-08	2.706E-08	3.554E-08	2.413E-08	3.279E-08	2.292E-08
7.60	2.260E-08	2.621E-08	3.464E-08	2.341E-08	3.179E-08	2.221E-08
7.70	2.194E-08	2.542E-08	3.385E-08	2.278E-08	3.084E-08	2.151E-08
7.80	2.131E-08	2.468E-08	3.316E-08	2.224E-08	2.994E-08	2.082E-08
7.90	2.071E-08	2.398E-08	3.256E-08	2.178E-08	2.908E-08	2.014E-08
8.00	2.013E-08	2.332E-08	3.204E-08	2.138E-08	2.826E-08	1.948E-08
8.10	1.957E-08	2.269E-08	3.159E-08	2.103E-08	2.748E-08	1.884E-08
8.20	1.903E-08	2.209E-08	3.120E-08	2.072E-08	2.674E-08	1.821E-08
8.30	1.851E-08	2.152E-08	3.086E-08	2.044E-08	2.604E-08	1.760E-08
8.40	1.801E-08	2.098E-08	3.056E-08	2.019E-08	2.538E-08	1.700E-08
8.50	1.752E-08	2.047E-08	3.030E-08	1.996E-08	2.476E-08	1.641E-08
8.60	1.705E-08	1.998E-08	3.007E-08	1.975E-08	2.417E-08	1.583E-08
8.70	1.660E-08	1.951E-08	2.987E-08	1.956E-08	2.362E-08	1.526E-08
8.80	1.617E-08	1.906E-08	2.969E-08	1.938E-08	2.310E-08	1.471E-08
8.90	1.576E-08	1.863E-08	2.953E-08	1.922E-08	2.261E-08	1.418E-08
9.00	1.536E-08	1.821E-08	2.939E-08	1.907E-08	2.214E-08	1.366E-08
9.10	1.497E-08	1.781E-08	2.926E-08	1.893E-08	2.170E-08	1.315E-08
9.20	1.459E-08	1.742E-08	2.914E-08	1.880E-08	2.128E-08	1.265E-08
9.30	1.422E-08	1.704E-08	2.903E-08	1.868E-08	2.088E-08	1.216E-08
9.40	1.386E-08	1.667E-08	2.893E-08	1.857E-08	2.049E-08	1.168E-08
9.50	1.351E-08	1.631E-08	2.884E-08	1.847E-08	2.012E-08	1.121E-08
9.60	1.317E-08	1.596E-08	2.875E-08	1.837E-08	1.977E-08	1.075E-08
9.70	1.284E-08	1.562E-08	2.867E-08	1.828E-08	1.943E-08	1.030E-08
9.80	1.252E-08	1.529E-08	2.859E-08	1.819E-08	1.910E-08	9.86E-09
9.90	1.221E-08	1.497E-08	2.852E-08	1.810E-08	1.878E-08	9.42E-09
10.00	1.191E-08	1.466E-08	2.845E-08	1.801E-08	1.847E-08	8.98E-09
10.10	1.162E-08	1.436E-08	2.838E-08	1.792E-08	1.817E-08	8.54E-09
10.20	1.133E-08	1.406E-08	2.831E-08	1.783E-08	1.788E-08	8.10E-09
10.30	1.105E-08	1.377E-08	2.824E-08	1.774E-08	1.759E-08	7.66E-09
10.40	1.077E-08	1.348E-08	2.817E-08	1.765E-08	1.731E-08	7.22E-09
10.50	1.050E-08	1.320E-08	2.810E-08	1.756E-08	1.703E-08	6.78E-09
10.60	1.023E-08	1.292E-08	2.803E-08	1.747E-08	1.675E-08	6.34E-09
10.70	1.000E-08	1.265E-08	2.796E-08	1.738E-08	1.647E-08	5.90E-09
10.80	9.77E-09	1.238E-08	2.789E-08	1.729E-08	1.620E-08	5.46E-09
10.90	9.55E-09	1.212E-08	2.782E-08	1.720E-08	1.593E-08	5.02E-09
11.00	9.34E-09	1.186E-08	2.775E-08	1.711E-08	1.566E-08	4.58E-09
11.10	9.13E-09	1.161E-08	2.768E-08	1.702E-08	1.540E-08	4.14E-09
11.20	8.93E-09	1.136E-08	2.761E-08	1.693E-08	1.514E-08	3.70E-09
11.30	8.73E-09	1.111E-08	2.754E-08	1.684E-08	1.488E-08	3.26E-09
11.40	8.54E-09	1.086E-08	2.747E-08	1.675E-08	1.462E-08	2.82E-09
11.50	8.35E-09	1.062E-08	2.740E-08	1.666E-08	1.436E-08	2.38E-09
11.60	8.16E-09	1.038E-08	2.733E-08	1.657E-08	1.410E-08	1.94E-09
11.70	7.98E-09	1.014E-08	2.726E-08	1.648E-08	1.384E-08	1.50E-09
11.80	7.80E-09	9.90E-09	2.719E-08	1.639E-08	1.358E-08	1.06E-09
11.90	7.63E-09	9.67E-09	2.712E-08	1.630E-08	1.332E-08	6.16E-10
12.00	7.46E-09	9.44E-09	2.705E-08	1.621E-08	1.306E-08	1.72E-10
12.10	7.30E-09	9.21E-09	2.698E-08	1.612E-08	1.280E-08	7.28E-10
12.20	7.14E-09	8.98E-09	2.691E-08	1.603E-08	1.254E-08	2.84E-10
12.30	6.98E-09	8.75E-09	2.684E-08	1.594E-08	1.228E-08	1.66E-10
12.40	6.83E-09	8.52E-09	2.677E-08	1.585E-08	1.202E-08	5.46E-11
12.50	6.68E-09	8.29E-09	2.670E-08	1.576E-08	1.176E-08	1.66E-11
12.60	6.53E-09	8.06E-09	2.663E-08	1.567E-08	1.150E-08	5.66E-12
12.70	6.39E-09	7.83E-09	2.656E-08	1.558E-08	1.124E-08	1.66E-12
12.80	6.25E-09	7.60E-09	2.649E-08	1.549E-08	1.098E-08	5.66E-13
12.90	6.11E-09	7.37E-09	2.642E-08	1.540E-08	1.072E-08	1.66E-13
13.00	5.98E-09	7.14E-09	2.635E-08	1.531E-08	1.046E-08	5.66E-14
13.10	5.85E-09	6.91E-09	2.628E-08	1.522E-08	1.020E-08	1.66E-14
13.20	5.72E-09	6.68E-09	2.621E-08	1.513E-08	9.94E-09	5.66E-15
13.30	5.60E-09	6.45E-09	2.614E-08	1.504E-08	9.68E-09	1.66E-15
13.40	5.48E-09	6.22E-09	2.607E-08	1.495E-08	9.42E-09	5.66E-16
13.50	5.36E-09	6.00E-09	2.600E-08	1.486E-08	9.16E-09	1.66E-16
13.60	5.24E-09	5.77E-09	2.593E-08	1.477E-08	8.90E-09	5.66E-17
13.70	5.13E-09	5.55E-09	2.586E-08	1.468E-08	8.64E-09	1.66E-17
13.80	5.02E-09	5.33E-09	2.579E-08	1.459E-08	8.38E-09	5.66E-18
13.90	4.91E-09	5.11E-09	2.572E-08	1.450E-08	8.12E-09	1.66E-18
14.00	4.80E-09	4.90E-09	2.565E-08	1.441E-08	7.86E-09	5.66E-19
14.10	4.70E-09	4.69E-09	2.558E-08	1.432E-08	7.60E-09	1.66E-19
14.20	4.60E-09	4.48E-09	2.551E-08	1.423E-08	7.34E-09	5.66E-20
14.30	4.50E-09	4.27E-09	2.544E-08	1.414E-08	7.08E-09	1.66E-20
14.40	4.40E-09	4.06E-09	2.537E-08	1.405E-08	6.82E-09	5.66E-21
14.50	4.30E-09	3.85E-09	2.530E-08	1.396E-08	6.56E-09	1.66E-21
14.60	4.20E-09	3.64E-09	2.523E-08	1.387E-08	6.30E-09	5.66E-22
14.70	4.10E-09	3.43E-09	2.516E-08	1.378E-08	6.04E-09	1.66E-22
14.80	4.00E-09	3.22E-09	2.509E-08	1.369E-08	5.78E-09	5.66E-23
14.90	3.90E-09	3.01E-09	2.502E-08	1.360E-08	5.52E-09	1.66E-23
15.00	3.80E-09	2.80E-09	2.495E-08	1.351E-08	5.26E-09	5.66E-24
15.10	3.70E-09	2.59E-09	2.488E-08	1.342E-08	5.00E-09	1.66E-24
15.20	3.60E-09	2.38E-09	2.481E-08	1.333E-08	4.74E-09	5.66E-25
15.30	3.50E-09	2.17E-09	2.474E-08	1.324E-08	4.48E-09	1.66E-25
15.40	3.40E-09	1.96E-09	2.467E-08	1.315E-08	4.22E-09	5.66E-26
15.50	3.30E-09	1.75E-09	2.460E-08	1.306E-08	3.96E-09	1.66E-26
15.60	3.20E-09	1.54E-09	2.453E-08	1.297E-08	3.70E-09	5.66E-27
15.70	3.10E-09	1.33E-09	2.446E-08	1.288E-08	3.44E-09	1.66E-27
15.80	3.00E-09	1.12E-09	2.439E-08	1.279E-08	3.18E-09	5.66E-28
15.90	2.90E-09	9.10E-10	2.432E-08	1.270E-08	2.92E-09	1.66E-28
16.00	2.80E-09	7.00E-10	2.425E-08	1.261E-08	2.66E-09	5.66E-29
16.10	2.70E-09	4.90E-10	2.418E-08	1.252E-08	2.40E-09	1.66E-29
16.20	2.60E-09	2.80E-10	2.411E-08	1.243E-08	2.14E-09	5.66E-30
16.30	2.50E-09	7.00E-11	2.404E-08	1.234E-08	1.88E-09	1.66E-30
16.40	2.40E-09	5.00E-11	2.397E-08	1.225E-08	1.62E-09	5.66E-31
16.50	2.30E-09	3.00E-11	2.390E-08	1.216E-08	1.36E-09	1.66E-31
16.60	2.20E-09	1.00E-11	2.383E-08	1.207E-08	1.10E-09	5.66E-32
16.70	2.10E-09	1.00E-12	2.376E-08	1.198E-08	8.40E-10	1.66E-32
16.80	2.00E-09	1.00E-13	2.369E-08	1.189E-08	5.80E-10	5.66E-33
16.90	1.90E-09	1.00E-14	2.362E-08	1.180E-08	3.20E-10	1.66E-33
17.00	1.80E-09	1.00E-15	2.355E-08	1.171E-08	6.00E-11	5.66E-34
17.10	1.70E-09	1.00E-16	2.348E-08	1.162E-08	3.40E-11	1.66E-34
17.20	1.60E-09	1.00E-17	2.341E-08	1.153E-08	8.00E-12	5.66E-35
17.30	1.50E-09	1.00E-18	2.334E-08	1.144E-08	4.40E-12	1.66E-35
17.40	1.40E-09	1.00E-19	2.327E-08	1.135E-08	2.80E-12	5.66E-36
17.50	1.30E-09	1.00E-20	2.320E-08	1.126E-08	1.20E-12	1.66E-36
17.60	1.20E-09	1.00E-21	2.313E-08	1.117E-08	6.00E-13	5.66E-37
17.70	1.10E-09	1.00E-22	2.306E-08	1.108E-08	3.40E-13	1.66E-37
17.80	1.00E-09	1.00E-23	2.299E-08	1.099E-08	1.80E-13	5.66E-38
17.90	9.00E-10	1.00E-24	2.292E-08	1.090E-08	1.20E-13	1.66E-38
18.00	8.00E-10	1.00E-25	2.285E-08	1.081E-08	6.00E-14	5.66E-39
18.10	7.00E-10	1.00E-26	2.27			

HOPE CREEK
BUILDING VENT

UNDEPLETED X/Q AT GROUND LEVEL APPLICABLE TO
LONG-TERM (ROUTINE) GASEOUS RELEASES
(SECONDS/M³)

SECTOR ANNUAL X/Q AT GROUND LEVEL

DISTANCE MILES	202.5	225.0	247.5	279.0	292.5	315.0	337.5	360.0
.25	1.036E-06	1.133E-06	1.708E-07	9.461E-07	5.306E-07	9.525E-07	1.520E-06	2.168E-06
.50	7.502E-07	7.117E-07	4.937E-07	6.243E-07	4.223E-07	7.193E-07	1.008E-06	1.226E-06
.75	5.227E-07	4.744E-07	3.336E-07	4.219E-07	3.008E-07	5.037E-07	6.823E-07	7.696E-07
1.00	3.727E-07	3.323E-07	2.550E-07	2.972E-07	2.165E-07	3.600E-07	4.611E-07	5.446E-07
1.25	3.293E-07	2.923E-07	2.069E-07	2.618E-07	1.917E-07	3.162E-07	4.239E-07	4.771E-07
1.50	2.928E-07	2.590E-07	1.835E-07	2.322E-07	1.708E-07	2.831E-07	3.761E-07	4.214E-07
1.75	2.619E-07	2.310E-07	1.639E-07	2.073E-07	1.530E-07	2.534E-07	3.359E-07	3.749E-07
2.00	2.356E-07	2.074E-07	1.471E-07	1.862E-07	1.379E-07	2.280E-07	3.017E-07	3.357E-07
2.25	2.131E-07	1.872E-07	1.328E-07	1.662E-07	1.249E-07	2.063E-07	2.725E-07	3.024E-07
2.50	1.936E-07	1.692E-07	1.205E-07	1.527E-07	1.136E-07	1.876E-07	2.474E-07	2.739E-07
2.75	1.766E-07	1.549E-07	1.099E-07	1.393E-07	1.038E-07	1.713E-07	2.256E-07	2.494E-07
3.00	1.621E-07	1.418E-07	1.006E-07	1.276E-07	9.525E-08	1.571E-07	2.067E-07	2.200E-07
3.25	1.491E-07	1.303E-07	9.253E-08	1.174E-07	8.773E-08	1.446E-07	1.901E-07	2.044E-07
3.50	1.371E-07	1.203E-07	8.538E-08	1.083E-07	8.107E-08	1.336E-07	1.754E-07	1.929E-07
3.75	1.276E-07	1.113E-07	7.904E-08	1.003E-07	7.517E-08	1.258E-07	1.623E-07	1.784E-07
4.00	1.196E-07	1.034E-07	7.340E-08	9.318E-08	6.990E-08	1.151E-07	1.509E-07	1.656E-07
4.25	1.105E-07	9.629E-08	6.836E-08	8.600E-08	6.516E-08	1.073E-07	1.406E-07	1.541E-07
4.50	1.033E-07	8.992E-08	6.384E-08	8.108E-08	6.094E-08	1.003E-07	1.313E-07	1.438E-07
4.75	9.674E-08	8.418E-08	5.974E-08	7.592E-08	5.711E-08	9.594E-08	1.229E-07	1.345E-07
5.00	9.082E-08	7.899E-08	5.608E-08	7.125E-08	5.364E-08	8.821E-08	1.154E-07	1.261E-07
5.25	8.545E-08	7.429E-08	5.273E-08	6.702E-08	5.049E-08	8.300E-08	1.065E-07	1.185E-07
5.50	8.056E-08	7.000E-08	4.969E-08	6.316E-08	4.762E-08	7.827E-08	1.023E-07	1.116E-07
5.75	7.608E-08	6.609E-08	4.691E-08	5.964E-08	4.499E-08	7.393E-08	9.657E-08	1.053E-07
6.00	7.199E-08	6.251E-08	4.436E-08	5.642E-08	4.258E-08	6.997E-08	9.135E-08	9.957E-08
6.25	6.823E-08	5.922E-08	4.203E-08	5.346E-08	4.037E-08	6.632E-08	8.656E-08	9.429E-08
6.50	6.476E-08	5.620E-08	3.968E-08	5.074E-08	3.834E-08	6.296E-08	8.214E-08	8.943E-08
6.75	6.157E-08	5.341E-08	3.790E-08	4.823E-08	3.645E-08	6.066E-08	7.807E-08	8.492E-08
7.00	5.861E-08	5.083E-08	3.606E-08	4.590E-08	3.471E-08	5.700E-08	7.431E-08	8.081E-08
7.25	5.587E-08	4.844E-08	3.437E-08	4.375E-08	3.310E-08	5.434E-08	7.062E-08	7.696E-08
7.50	5.332E-08	4.622E-08	3.279E-08	4.175E-08	3.160E-08	5.187E-08	6.758E-08	7.343E-08

HOPE CREEK
BUILDING VENT

UNDEPLETED X/Q AT GROUND LEVEL APPLICABLE TO

LONG-TERM (ROUTINE) GASEOUS RELEASES

(SECONDS/M³)

SECTOR ANNUAL X/Q AT GROUND LEVEL

DISTANCE MILES	SECTION BEARING (DEGREES)									
	202.5	225.0	247.5	270.0	292.5	315.0	337.5	360.0		
5.70	5.095E-08	4.615E-08	5.132E-08	3.969E-08	3.021E-08	4.957E-08	6.457E-08	7.015E-08		
5.80	4.875E-08	4.223E-08	2.996E-08	3.616E-08	2.690E-08	4.745E-08	6.176E-08	6.795E-08		
5.90	4.669E-08	4.048E-08	2.868E-08	3.654E-08	2.769E-08	4.545E-08	5.914E-08	6.410E-08		
6.00	4.476E-08	3.876E-08	2.749E-08	3.503E-08	2.655E-08	4.356E-08	5.669E-08	6.149E-08		
6.10	4.295E-08	3.719E-08	2.637E-08	3.361E-08	2.549E-08	4.181E-08	5.440E-08	5.890E-08		
6.20	4.126E-08	3.571E-08	2.535E-08	3.226E-08	2.449E-08	4.016E-08	5.224E-08	5.663E-08		
6.30	3.966E-08	3.431E-08	2.434E-08	3.105E-08	2.355E-08	3.862E-08	5.022E-08	5.442E-08		
6.40	3.817E-08	3.303E-08	2.342E-08	2.986E-08	2.266E-08	3.716E-08	4.832E-08	5.254E-08		
6.50	3.676E-08	3.189E-08	2.255E-08	2.875E-08	2.185E-08	3.579E-08	4.653E-08	5.058E-08		
6.60	3.545E-08	3.085E-08	2.173E-08	2.771E-08	2.104E-08	3.450E-08	4.484E-08	4.854E-08		
6.70	3.417E-08	2.995E-08	2.095E-08	2.672E-08	2.030E-08	3.328E-08	4.324E-08	4.680E-08		
6.80	3.298E-08	2.922E-08	2.022E-08	2.579E-08	1.960E-08	3.213E-08	4.174E-08	4.515E-08		
6.90	3.186E-08	2.855E-08	1.953E-08	2.491E-08	1.895E-08	3.103E-08	4.031E-08	4.360E-08		
7.00	3.079E-08	2.792E-08	1.887E-08	2.408E-08	1.830E-08	3.000E-08	3.896E-08	4.212E-08		
7.10	2.976E-08	2.735E-08	1.825E-08	2.328E-08	1.771E-08	2.902E-08	3.768E-08	4.073E-08		
7.20	2.882E-08	2.681E-08	1.766E-08	2.253E-08	1.714E-08	2.809E-08	3.646E-08	3.940E-08		
7.30	2.791E-08	2.629E-08	1.710E-08	2.182E-08	1.660E-08	2.720E-08	3.530E-08	3.814E-08		
7.40	2.705E-08	2.577E-08	1.656E-08	2.114E-08	1.609E-08	2.636E-08	3.420E-08	3.695E-08		
7.50	2.625E-08	2.525E-08	1.605E-08	2.049E-08	1.560E-08	2.555E-08	3.316E-08	3.581E-08		
8.00	2.263E-08	1.959E-08	1.385E-08	1.768E-08	1.347E-08	2.206E-08	2.861E-08	3.066E-08		
9.00	1.549E-08	1.336E-08	9.459E-09	1.210E-08	9.238E-09	1.512E-08	1.957E-08	2.105E-08		
10.00	9.482E-09	8.107E-09	5.777E-09	7.400E-09	5.665E-09	9.264E-09	1.196E-08	1.263E-08		
15.00	4.762E-09	4.099E-09	2.904E-09	3.720E-09	2.835E-09	4.660E-09	5.942E-09	6.400E-09		
20.00	2.963E-09	2.555E-09	1.826E-09	2.526E-09	1.732E-09	2.904E-09	3.710E-09	3.949E-09		
25.00	2.076E-09	1.798E-09	1.301E-09	1.643E-09	1.182E-09	2.039E-09	2.585E-09	2.742E-09		
30.00	1.566E-09	1.361E-09	9.977E-10	1.246E-09	8.645E-10	1.538E-09	1.936E-09	2.048E-09		
35.00	1.237E-09	1.079E-09	8.003E-10	9.929E-10	6.637E-10	1.216E-09	1.520E-09	1.604E-09		
40.00	1.009E-09	8.634E-10	6.616E-10	8.149E-10	5.278E-10	9.929E-10	1.234E-09	1.299E-09		
45.00	8.426E-10	7.400E-10	5.589E-10	6.643E-10	4.312E-10	8.300E-10	1.026E-09	1.078E-09		
50.00	7.170E-10	6.311E-10	4.799E-10	5.847E-10	3.599E-10	7.084E-10	8.696E-10	9.126E-10		

FIGURE 35

TURBULENCE CLASSIFICATION

<u>Smith-Singer Classification</u>	<u>Pasquill Classification</u>	<u>Brookhaven National Laboratory Classification (4)</u>	<u>Description of Wind Trace</u>
I	A	B ₂	Fluctuations of the wind direction during the course of one hour exceed 45 degrees.
II	B & C	B ₁	Fluctuations are confined to a lower limit of 15 degrees and an upper limit of 45 degrees.
III	D	C	The lower limit of the fluctuations is 15 degrees, and no upper limit is imposed. The case is distinguished by an unbroken solid core, through which a straight line can be drawn for the entire hour, without touching "open space" on the chart.
IV	E & F	D	The trace approximates a line, and short-term fluctuations do not exceed 15 degrees. Direction may vary gradually over a wide angle during the hour.

HCOS

B.1.54

REV. 1