

September 15, 1988

Docket No. 50-267

Mr. R. O. Williams, Jr.  
Vice President, Nuclear Operations  
Public Service Company of Colorado  
Post Office Box 840  
Denver, Colorado 80201-0840

Dear Mr. Williams:

SUBJECT: FORT ST. VRAIN NUCLEAR GENERATING STATION, AMENDMENT NO. 64  
TO FACILITY OPERATING LICENSE NO. DPR-34 (TAC NO. 67933)

The Commission has issued the enclosed Amendment No. 64 to Facility Operating License No. DPR-34 for the Fort St. Vrain Nuclear Generating Station. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated April 20, 1988 (P-88116), as supplemented July 1 (P-88232) and August 5, 1988 (P-88285).

The amendment makes certain changes to the Technical Specifications for the plant's DC power systems. It also allows for future changes to the station batteries. The staff has approved the use of a five day equalizing charge at Fort St. Vrain. However, the staff requests that you report on the use of this provision within 45 days after the first year of operation is complete.

A copy of the Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next Bi-weekly Federal Register notice.

The information requested in this letter affects 10 or fewer respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

/s/

Kenneth L. Heitner, Project Manager  
Project Directorate - IV  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 64 to DPR-34
2. Safety Evaluation

cc w/enclosures:  
See next page

8809230131 880915  
PDR ADDCK 05000267  
P PNU

DISTRIBUTION:

<b>Docket File</b>	JPartlow	NRC PDR	TBarnhart (4)
Local PDR	Wanda Jones	PD4 Reading	EButcher
PNr nan (3)	ACRS (10)	KHeitner	GPA/PA
JCaivo	ARM/LFMB	OGC-Rockville	DHagan
EJordan	Plant File		

PD4/LA *PH*  
PNoonan  
08/18/88

PD4/PM *KH* OGC-Rockville  
KHeitner:sr  
08/18/88 *909/1/88*

PD4/D *MC*  
JCaivo  
08/15/88

*FR*  
SES/BC  
FRosa  
08/29/88

*DFol*  
*11*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

September 15, 1988

Docket No. 50-267

Mr. R. O. Williams, Jr.  
Vice President, Nuclear Operations  
Public Service Company of Colorado  
Post Office Box 840  
Denver, Colorado 80201-0840

Dear Mr. Williams:

SUBJECT: FORT ST. VRAIN NUCLEAR GENERATING STATION, AMENDMENT NO. 64  
TO FACILITY OPERATING LICENSE NO. DPR-34 (TAC NO. 67933)

The Commission has issued the enclosed Amendment No. 64 to Facility Operating License No. DPR-34 for the Fort St. Vrain Nuclear Generating Station. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated April 20, 1988 (P-88116), as supplemented July 1 (P-88232) and August 5, 1988 (P-88285).

The amendment makes certain changes to the Technical Specifications for the plant's DC power systems. It also allows for future changes to the station batteries. The staff has approved the use of a five day equalizing charge at Fort St. Vrain. However, the staff requests that you report on the use of this provision within 45 days after the first year of operation is complete.

A copy of the Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next Bi-weekly Federal Register notice.

The information requested in this letter affects 10 or fewer respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

A handwritten signature in cursive script that reads "Kenneth L. Heitner".

Kenneth L. Heitner, Project Manager  
Project Directorate - IV  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 64 to DPR-34
2. Safety Evaluation

cc w/enclosures:  
See next page

Mr. R. O. Williams, Jr.  
Public Service Company of Colorado

Fort St. Vrain

cc:

Mr. D. W. Warembourg, Manager  
Nuclear Engineering Division  
Public Service Company  
of Colorado  
P. O. Box 840  
Denver, Colorado 80201-0840

Albert J. Hazle, Director  
Radiation Control Division  
Department of Health  
4210 East 11th Avenue  
Denver, Colorado 80220

Mr. David Alberstein, 14/159A  
GA Technologies, Inc.  
Post Office Box 85608  
San Diego, California 92138

Mr. R. O. Williams, Jr., Acting Manager  
Nuclear Production Division  
Public Service Company of Colorado  
16805 Weld County Road 19-1/2  
Platteville, Colorado 80651

Mr. H. L. Brey, Manager  
Nuclear Licensing and Fuel Division  
Public Service Company of Colorado  
P. O. Box 840  
Denver, Colorado 80201-0840

Mr. P. F. Tomlinson, Manager  
Quality Assurance Division  
Public Service Company of Colorado  
16805 Weld County Road 19-1/2  
Platteville, Colorado 80651

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 640  
Platteville, Colorado 80651

Mr. R. F. Walker  
Public Service Company of Colorado  
Post Office Box 840  
Denver, Colorado 80201-0840

Kelley, Stansfield & O'Donnell  
Public Service Company Building  
Room 900  
550 15th Street  
Denver, Colorado 80202

Commitment Control Program  
Coordinator  
Public Service Company of Colorado  
2420 W. 26th Ave. Suite 100-D  
Denver, Colorado 80211

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Chairman, Board of County Commissioners  
of Weld County, Colorado  
Greeley, Colorado 80631

Regional Representative  
Radiation Programs  
Environmental Protection Agency  
1 Denver Place  
999 18th Street, Suite 1300  
Denver, Colorado 80202-2413