

Public Service  
Electric and Gas  
Company

Corbin A. McNeill, Jr.  
Vice President  
Nuclear

Public Service Electric and Gas Company P.O. Box 236, Hancocks Bridge, NJ 08038 609 339-4800

March 7, 1986

Director of Nuclear Reactor Regulation  
United States Nuclear Regulatory Commission  
7920 Norfolk Avenue  
Bethesda, Maryland 20814

Attention: Ms. Elinor Adensam, Director  
Project Directorate 3  
Division of BWR Licensing

Dear Ms. Adensam:

SPDS TELECON OF MARCH 6, 1986  
HOPE CREEK GENERATING STATION  
DOCKET NO. 50-354


Pursuant to the telephone conversation of March 6, 1986 between representatives of Public Service Electric and Gas Company (PSE&G) and the NRC concerning the Hope Creek Safety Parameter Display System (SPDS), PSE&G will, prior to restart following the first refueling outage, add to the SPDS, and have operational the following SPDS parameters:

- (i) Primary Containment Radiation
- (ii) Primary Containment Isolation Status
- (iii) Combustible Gas Concentration in the Primary Containment
- (iv) Source Range Neutron Flux

The subject SPDS parameters will be included in the Hope Creek SPDS Verification and Validation Program and operators will be trained accordingly.

In the event there are any questions with respect to the above, do not hesitate to contact us.

Sincerely,



8603110058 860307  
PDR ADOCK 05000354  
A PDR

Boo!  
/10

Director of Nuclear  
Reactor Regulation

2

3-7-86

C D.H. Wagner  
USNRC Licensing Project Manager

R.W. Borchardt  
USNRC Senior Resident Inspector