

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555



SEP 19 1988

Docket Nos. 50-445
and 50-446

APPLICANT: Texas Utilities Electric Company (TU Electric)
FACILITY: Comanche Peak Steam Electric Station (CPSES), Units 1 and 2
SUBJECT: SUMMARY OF MEETING ON SEPTEMBER 7, 1988 - BOUNDING ANALYSIS
FOR STRESS CONDITION OF THE PRESSURIZER SURGE LINE

At a meeting held on August 18, 1988 in Rockville, Maryland between NRC staff and representatives of TU Electric concerning the proposed application of advanced fracture mechanics analyses (also referred to as "leak-before-break methodology") to the pressurizer surge line at CPSES.* It was decided at that meeting that a follow-up meeting should be held within about two weeks to discuss (1) what specific thermal stratification data are available and why they characterize the pressurizer surge line at Comanche Peak; (2) what instrumentation TU Electric would install to collect Comanche Peak-specific data and how those data compare to other available data; and (3) what operational method (start-up) is planned for the Comanche Peak pressurizer. These discussions were planned to provide the NRC staff with a basis for deciding whether the data collection and analysis approach proposed by the applicant is appropriate and whether the staff could give further consideration to applying leak-before-break (LBB) methodology to the pressurizer surge line.

The follow-up meeting was held on September 7, 1988 in Rockville, Maryland. The meeting notice and the list of attendees are provided as Enclosures 1 and 2. The presentation slides are provided as Enclosures 3 and 4. A portion of the meeting concerned discussions of proprietary data. Presentation slides for that portion of the meeting are likewise proprietary and have been excluded from this meeting summary.

Data from instrumented pressurizer surge lines at the Trojan Nuclear Plant and the Beaver Valley Power Station Unit 2 was discussed together with the applicability of these data to the CPSES. The proposed instrumentation for the CPSES Unit 1 pressurizer surge line was discussed as well as the schedule for conduct of hot functional testing. In addition, the operational methods for start-up and shutdown and their influence on thermal stratification in the CPSES pressurizer surge line were discussed.


* See Summary of Meeting on August 18, 1988 - Application of Leak-Before-Break (LBB) Methodology to the Pressurizer Surge Line dated August 31, 1988.

BB09230170 BB0919
PDR ADOCK 05000445
A PNU

DFP L
1/1

The applicant discussed with the staff in more detail the proposal presented at the meeting on August 18, 1988 to instrument the Unit 1 surge line and analyze the effects of thermal stratification on the piping. The applicant feels that the proposed analysis methodology is likely to result in conservatively bounding the stress condition in the pressurizer surge line at CPSES and establishing the surge line's integrity for approximately 5 to 10 years. For a long-term resolution, the applicant proposes to supplement the bounding analysis with a plant-specific analysis using data obtained during hot functional testing from the instrumented CPSES Unit 1 pressurizer surge line and with the results of the Westinghouse Owners Group surge line stratification program. The staff indicated that the applicant's plans for analyzing the effects of thermal stratification in the surge line was proceeding in a technically sound manner.

The decision as to whether to permit application of leak-before-break methodology to the pressurizer surge line in the event that the applicant's analyses demonstrate a service life less than 40 years will be further evaluated by the staff. The staff recognizes that not allowing the application of LBB methodology to the pressurizer surge line will likely result in a significant impact on the CPSES licensing schedule while plant modifications are made. The staff indicated that it would provide additional feedback to the applicant in approximately a week.



Melinda Malloy, Project Manager
Comanche Peak Project Division
Office of Special Projects

Enclosures:

1. Meeting Notice
2. List of Attendees
3. TU Electric Presentation Slides
4. Duquesne Light Presentation Slides
5. Proprietary Presentation Slides
(NRC Docket File copy only)

cc: See next page

Summary of 9/7/88 meeting

- 2 -

The applicant discussed with the staff in more detail the proposal presented at the meeting on August 18, 1988 to instrument the Unit 1 surge line and analyze the effects of thermal stratification on the piping. The applicant feels that the proposed analysis methodology is likely to result in conservatively bounding the stress condition in the pressurizer surge line at CPSES and establishing the surge line's integrity for approximately 5 to 10 years. For a long-term resolution, the applicant proposes to supplement the bounding analysis with a plant-specific analysis using data obtained during hot functional testing from the instrumented CPSES Unit 1 pressurizer surge line and with the results of the Westinghouse Owners Group surge line stratification program. The staff indicated that the applicant's plans for analyzing the effects of thermal stratification in the surge line was proceeding in a technically sound manner.

The decision as to whether to permit application of leak-before-break methodology to the pressurizer surge line in the event that the applicant's analyses demonstrate a service life less than 40 years will be further evaluated by the staff. The staff recognizes that not allowing the application of LBB methodology to the pressurizer surge line will likely result in a significant impact on the CPSES licensing schedule while plant modifications are made. The staff indicated that it would provide additional feedback to the applicant in approximately a week.

Original signed by:

Melinda Malloy, Project Manager
Comanche Peak Project Division
Office of Special Projects


Enclosures:

1. Meeting Notice
2. List of Attendees
3. TU Electric Presentation Slides
4. Duquesne Light Presentation Slides
5. Proprietary Presentation Slides
(NRC Docket File copy only)

cc: See next page

Distribution w/ Enclosure 5:

NRC PDR	RWarnick	K. Wichman
Local PDR	JWiebe	SLee
OSP Reading	MMalloy	TMarsh
CPPD Reading	DTerao	PKuo
JPartlow	OGC	SNHou
CGrimes	DCrutchfield	GDick
PMcKee	EJordan	PTam
JHWilson	BGrimes	TChan
JLyons	CCheng	ACRS(10)


CPPD:OSP
MMalloy
09/19/88

CPPD:OSP
DTerao
09/19/88

AD:CPPD:OSP
JHWilson
09/19/88

Distribution w/Enclosure 5:
Docket File

DFPI
1/1

W. G. Council
Texas Utilities Electric Company

cc:

Jack R. Newman, Esq.
Newman & Holtzinger, P.C.
Suite 1000
1615 L Street, N.W.
Washington, D.C. 20036

Robert A. Wooldridge, Esq.
Worsham, Forsythe, Sampels &
Wooldridge
2001 Bryan Tower, Suite 2500
Dallas, Texas 75201

Mr. Homer C. Schmidt
Director of Nuclear Services
Texas Utilities Electric Company
Skyway Tower
400 North Olive Street, L.B. 81
Dallas, Texas 75201

Mr. R. W. Ackley
Stone & Webster
Comanche Peak Steam Electric Station
P. O. Box 1002
Glen Rose, Texas 76043

Mr. J. L. Vota
Westinghouse Electric Corporation
P. O. Box 355
Pittsburgh, Pennsylvania 15230

Susan M. Theisen
Assistant Attorney General
Environmental Protection Division
P. O. Box 12548, Capitol Station
Austin, Texas 78711-1548

Mrs. Juanita Ellis, President
Citizens Association for Sound Energy
1426 South Polk
Dallas, Texas 75224

Ms. Nancy H. Williams
CYGNA Energy Services
2121 N. California Blvd., Suite 390
Walnut Creek, CA 94596

Comanche Peak Steam Electric Station
Units 1 and 2

Asst. Director for Inspec. Programs
Comanche Peak Project Division
U.S. Nuclear Regulatory Commission
P. O. Box 1029
Granbury, Texas 76048

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Lanny A. Sinkin
Christic Institute
1324 North Capitol Street
Washington, D.C. 20002

Ms. Billie Pirner Garde, Esq.
Government Accountability Project
Midwest Office
104 East Wisconsin Avenue
Appleton, Wisconsin 54911

David R. Pigott, Esq.
Orrick, Herrington & Sutcliffe
600 Montgomery Street
San Francisco, California 94111

Anthony Z. Roisman, Esq.
Suite 600
1401 New York Avenue, NW
Washington, D.C. 20005

Robert Jablon
Bonnie S. Blair
Spiegel & McDiarmid
1350 New York Avenue, NW
Washington, D.C. 20005-4798

George A. Parker, Chairman
Public Utility Committee
Senior Citizens Alliance Of
Tarrant County, Inc.
6048 Wonder Drive
Fort Worth, Texas 76133

W. G. Council
Texas Utilities Electric Company

- 2 - Comanche Peak Electric Station
Units 1 and 2

cc:

Joseph F. Fulbright
Fulbright & Jaworski
1301 McKinney Street
Houston, Texas 77010

Roger D. Walker
Manager, Nuclear Licensing
Texas Utilities Electric Company
Skyway Tower
400 North Olive Street, L.B. 81
Dallas, Texas 75201

Texas Utilities Electric Company
c/o Bethesda Licensing
3 Metro Center, Suite 610
Bethesda, Maryland 20814

William A. Burchette, Esq.
Counsel for Tex-La Electric Cooperative
of Texas
Heron, Burchette, Ruckert & Rothwell
Suite 700
1025 Thomas Jefferson Street, NW
Washington, D.C. 20007

GDS ASSOCIATES, INC.
Suite 720
1850 Parkway Place
Marietta, Georgia 30067-8237

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

~~August 25, 1988~~

Change Notice # 1 August 30, 1988

Docket Nos. 50-445
and 50-446

MEMORANDUM FOR:

Christopher I. Grimes, Director
Comanche Peak Project Division
Office of Special Projects

FROM:

James H. Wilson, Assistant Director
for Projects
Comanche Peak Project Division
Office of Special Projects

SUBJECT:

FORTHCOMING MEETING WITH TU ELECTRIC

Date and Time:

~~Thursday, September 1, 1988~~ Wednesday, September 7, 1988
9:00 am - ~~4:00 pm~~ 3:00 pm

Location:

One White Flint North
11555 Rockville Pike
Rockville, MD 20855
Room No. 88-11

Purpose:

Review of Comanche Peak pressurizer surge
line stratification

Participants:

NRC	TU Electric	Westinghouse	R. L. Cloud
C. Grimes	R. Walker	G. Antaki	W. Server
J. Lyons	J. Muffett	D. Poarty	R. Beaudoin
J. H. Wilson	D. Rencher	R. Carlson	
D. Terao	H. Marvray	R. Brice-Nash	
C. Cheng	R. Flores	R. Coffield	
K. Wichman		S. Swamy	
M. Hodges		B. Maurer	
L. Marsh			

James H. Wilson
James H. Wilson, Assistant Director
for Projects
Comanche Peak Project Division
Office of Special Projects

Enclosure: Proposed agenda

cc: See next page

* Meetings between NRC technical staff and applicants for licenses are open for interested members of the public, petitioners, intervenors, or other parties to attend as observers pursuant to "Open Meetings and Statement of NRC Staff Policy," 43 Federal Register 28058, 6/28/78. However, portions of this meeting will be closed to the general public due to the presentation and discussion of proprietary information.

~~8809010330~~ 5pp

ENCLOSURE

Proposed Agenda

1. Introduction and Agenda
2. Background
3. Description
 - a. Systems Operation
 - b. Stratification in Pressurizer Surge Line
4. Engineering Evaluation
 - a. Monitoring Program
 - b. Definition of Transients
 - c. Heat Transfer
 - d. Piping Global Effects
 - e. Piping Local Effects
 - f. Piping System and Compartment Qualification
5. Leak-Before-Break
6. Summary

August 20, 1988
Change Notice #1,
August 30, 1988

C. J. Grimes

Forthcoming meeting with TU Electric on September 1, 1988 to review of the Comanche Peak pressurizer surge line stratification

DISTRIBUTION

- Docket File
- NRC PDR
- Local PDR
- OSP Reading
- CPPD Reading
- J. Partlow
- C. Grimes
- P. McKee
- J. H. Wilson
- J. Lyons
- R. Warnick
- B. Zalcman
- F. Miraglia
- M. Malloy
- D. Terao
- W. Lanning
- OGC
- E. Jordan
- B. Grimes
- Receptionist (WF)
- NRC Participants
- ACRS(10)
- GPA/PA
- J. Sutton
- J. Gilliland, RIV/PA
- S. Matthews
- J. Bradfute
- T. Char
- SHERRY

AD:CPPD:DSB
 JHWilson: [initials]
 CB/25/88

W. G. Council
Texas Utilities Electric Company

cc:
Jack R. Newman, Esq.
Newman & Holtzinger, P.C.
Suite 1000
1615 L Street, N.W.
Washington, D.C. 20036

Robert A. wooldridge, Esq.
Worsham, Forsythe, Sampels &
wooldridge
2001 Bryan Tower, Suite 2500
Dallas, Texas 75201

Mr. Homer C. Schmidt
Director of Nuclear Services
Texas Utilities Electric Company
Skyway Tower
400 North Olive Street, L.B. 81
Dallas, Texas 75201

Mr. R. W. Ackley
Store & Webster
Comanche Peak Steam Electric Station
P. O. Box 1002
Glen Rose, Texas 76043

Mr. J. L. Vota
Westinghouse Electric Corporation
P. O. Box 355
Pittsburgh, Pennsylvania 15230

Susan M. Theisen
Assistant Attorney General
Environmental Protection Division
P. O. box 12548, Capitol Station
Austin, Texas 78711-1548

Mrs. Juanita Ellis, President
Citizens Association for Sound Energy
1426 South Polk
Dallas, Texas 75224

Ms. Nancy H. Williams
CYGNA Energy Services
2121 N. California Blvd., Suite 390
Walnut Creek, CA 94596

Comanche Peak Steam Electric Station
Units 1 and 2

Asst. Director for Inspec. Programs
Comanche Peak Project Division
U.S. Nuclear Regulatory Commission
P. O. Box 1029
Granbury, Texas 76048

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Lanny A. Sinkin
Christic Institute
1324 North Capitol Street
Washington, D.C. 20002

Ms. Billie Pirner Garde, Esq.
Government Accountability Project
Midwest Office
104 East Wisconsin Avenue
Appleton, Wisconsin 54911

David R. Pigott, Esq.
Orrick, Herrington & Sutcliffe
600 Montgomery Street
San Francisco, California 94111

Anthony Z. Roisman, Esq.
Suite 600
1401 New York Avenue, NW
Washington, D.C. 20005

Robert Jablon
Bonnie S. Blair
Spiegel & McDiarmid
1350 New York Avenue, NW
Washington, D.C. 20005-4748

George A. Parker, Chairman
Public Utility Committee
Senior Citizens Alliance Of
Tarrant County, Inc.
6048 Wonder Drive
Fort Worth, Texas 76133

W. G. Council
Texas Utilities Electric Company

- 2 - Comanche Peak Electric Station
Units 1 and 2

CC:
Joseph F. Fulbright
Fulbright & Jaworski
1301 McKinney Street
Houston, Texas 77010

Roger D. Walker
Manager, Nuclear Licensing
Texas Utilities Electric Company
Skyway Tower
400 North Olive Street, L.C. 81
Dallas, Texas 75201

Texas Utilities Electric Company
c/o Bethesda Licensing
3 Metro Center, Suite 610
Bethesda, Maryland 20814

William A. Burchette, Esq.
Counsel for Tex-La Electric Cooperative
of Texas
Peron, Burchette, Ruckert & Rothwell
Suite 700
1025 Thomas Jefferson Street, NW
Washington, D.C. 20007

GDS ASSOCIATES, INC.
Suite 720
1850 Parkway Place
Marietta, Georgia 30067-8237

LIST OF ATTENDEES AT MEETING HELD IN
ROCKVILLE, MD ON SEPTEMBER 7, 1988 -
PRESSURIZER SURGE LINE

NRC

°P. McKee
°J. Lyons
°J. Wilson
°J. Wiebe
°M. Malloy
°J. Moore
°C. Cheng
°K. Wichman
°S. Lee
°L. Marsh
°S. Hou
°G. Dick
°P. Tam
°T. Chan
°P. T. Kuo

BNL

°G. DeGrassi

TU ELECTRIC

°R. Walker
°J. Muffett
°J. Redding
°A. Marvray
°R. Flores
°D. Rencher

STONE & WEBSTER

°S. Greer

WESTINGHOUSE

°G. Antaki
°D. Roarty
°E. Johnson
°R. Brice-Nash
°S. Swamy
°M. Barlow
°G. Ellis
°B. Maurer
°C. Benton
°H. Sandner
°J. Vota
°R. Carlson
°R. Coffield

DUQUESNE LIGHT

°S. Mukherjee
°M. Testa
°G. Kammerdeiner
°N. Tonet

HOUSTON LIGHTING AND POWER

°A. Harrison
°J. Bailey



TU ELECTRIC
COMANCHE PEAK STEAM
ELECTRIC STATION

PRESSURIZER SURGE LINE STRATIFICATION

LEAK - BEFORE - BREAK

PRESENTATION TO THE
NUCLEAR REGULATORY COMMISSION

ROCKVILLE, MD
SEPTEMBER 7, 1988

PRESSURIZER SURGE LINE
STRATIFICATION

AGENDA

SEPTEMBER 7, 1988 @ 10:00 A.M.

- | | |
|-------------------------------------------------|----------------------------------------------------------------------|
| 1. INTRODUCTION AND AGENDA | R. WALKER (TU ELECTRIC) |
| 2. BACKGROUND | J. MUFFETT (TU ELECTRIC)
G. ANTAKI (W) |
| 3. DESCRIPTION | |
| A. SYSTEMS OPERATION | R. CARLSON (W) |
| B. STRATIFICATION IN PRESSURIZER
SURGE LINE | D. ROARTY (W) |
| C. UTILITY EXPERIENCE | |
| 4. ENGINEERING EVALUATION (CPSES SPECIFIC) | |
| A. MONITORING PROGRAM | R. FLORES (TU ELECTRIC)
D. ROARTY (W)
D. RENCHER (TU ELECTRIC) |
| B. DEFINITION OF TRANSIENTS | D. ROARTY (W) |
| C. HEAT TRANSFER | D. ROARTY (W) |
| D. PIPING GLOBAL EFFECTS | G. ANTAKI (W) |
| E. PIPING LOCAL EFFECTS | D. ROARTY (W) |
| F. PIPING SYSTEM AND COMPONENT
QUALIFICATION | G. ANTAKI (W) |
| 5. LEAK-BEFORE-BREAK (CPSES SPECIFIC) | S. SWAMY (W) |
| 6. SUMMARY | J. MUFFETT (TU ELECTRIC) |

**TU ELECTRIC
COMANCHE PEAK STEAM
ELECTRIC STATION**

LEAK - BEFORE - BREAK


BACKGROUND

- APRIL 15, 1988:** CPSES WHIPJET REPORT ON
LEAK-BEFORE-BREAK SUBMITTED TO NRC
- JUNE 22, 1988:** CONFERENCE CALL WITH NRC, TU ELECTRIC,
AND CONSULTANTS TO DISCUSS WHIPJET REPORT
- JUNE 22, 1988:** IE BULLETIN NO. 88-08 ISSUED
- JUNE 24, 1988:** IE BULLETIN NO. 88-08 SUPPLEMENT 1 ISSUED
- JULY 20, 1988:** CONFERENCE CALL WITH NRC, TU ELECTRIC,
AND CONSULTANTS TO DISCUSS THE
PRESSURIZER SURGE LINE
- AUGUST 4, 1988:** IE BULLETIN NO. 88-08 SUPPLEMENT 2 ISSUED
- AUGUST 18, 1988:** NRC/TU ELECTRIC MEETING TO DISCUSS
LEAK-BEFORE-BREAK

SUMMARY


- RCL-PRESSURIZER ΔT OCCUR DURING CERTAIN MODES OF OPERATION, WHICH CAN RESULT IN STRATIFICATION OF FLOW IN SURGER LINE.
- EXTENSIVE DATA FROM REFERENCE PLANT AND LABORATORY TESTS ALLOW US TO UNDERSTAND STRATIFICATION.
- STRATIFICATION CAN BE PREDICTED AND ANALYZED.
- DESIGN TRANSIENTS WILL BE ADJUSTED TO INCORPORATE STRATIFICATION.
- STRESS ANALYSIS (ASME QUALIFICATION AND LBB) WILL INCORPORATE SURGE LINE STRATIFICATION TRANSIENTS.
- PROGRESS REPORTS WILL BE PROVIDED TO NRC. A FINAL REPORT (WCAP) WILL BE SUBMITTED.

Surge Line Stratification




D013 D26914 021


CPSES Pressurizer Surge Line Stratification ASME III and LBB Qualification Program



WESTINGHOUSE PWR'S SURGE LINE STRATIFICATION - WJOG




PRESSURIZER SURGE LINE




1320 D25829 001


Surge Line Stratification



RCS Pressurizer



RCS Loop



1340 D26914.018


PRESSURIZER

PROVIDES A POINT IN THE RCS WHERE LIQUID AND VAPOR CAN BE MAINTAINED IN EQUILIBRIUM UNDER SATURATED CONDITIONS FOR PRESSURE CONTROL PURPOSES.


FUNCTIONS:

- 0 TO PROVIDE A MEANS FOR ATTAINING OPERATING PRESSURE DURING PLANT HEATUP.
- 0 TO MAINTAIN THE REQUIRED RCS PRESSURE DURING STEADY STATE OPERATION.
- 0 TO LIMIT PRESSURE CHANGES DURING NORMAL PLANT OPERATION TO WITHIN AN ALLOWABLE RANGE.
- 0 TO PREVENT ^{THE} ~~TO~~ RCS PRESSURE FROM EXCEEDING ITS DESIGN VALUE.

RCS Mass and Energy Interfaces



Steam Bubble Mode Heatup



STEAM BUBBLE MODE HEATUP


ORIGIN OF LARGE PZR - HOT LEG TEMPERATURE DIFFERENTIAL

THE LARGE DIFFERENTIAL TEMPERATURE RESULTS FROM THE REQUIREMENT THAT A STEAM BUBBLE BE PRESENT IN THE PRESSURIZER BEFORE THE RCP'S ARE STARTED.

PROCEDURE:

- 0 THE RCS IS PRESSURIZED TO 325 PSIA, THE PRESSURE REQUIRED FOR RCP OPERATION.
- 0 THE PRESSURIZER COOLANT IS THEN HEATED WITH PRESSURIZER HEATERS TO 425°F, THE SATURATION TEMPERATURE, AND A STEAM BUBBLE DRAWN.
- 0 THE RCP'S ARE THEN STARTED TO BEGIN HEATING UP THE RCS COOLANT. AT THIS TIME THE PZR - HOT LEG TEMPERATURE DIFFERENTIAL IS APPROXIMATELY 320°F.

Steam Bubble Mode Cooldown



COOLDOWN

ACCOMPLISHED IN TWO PHASES, USING STEAM SYSTEM DOWN TO 350°F AND 400 PSIG AND THEN RHRS.

FOR BOTH STEAM BUBBLE AND WATER SOLID MODES, PZR IS COOLED DOWN TO 425°F WITH PRESSURE AT 325 PSIA.

STEAM BUBBLE MODE

- 0 WHEN RCS REACHES 160°F, OPERATING RCP IS SHUTOFF.
- 0 SHUTDOWN STEAM BUBBLE CONDITIONS ACHIEVED WITH AUXILIARY SPRAY.

WATER SOLID MODE

- 0 CHARGING FLOW IS INCREASED AND PRESSURIZER SPRAY OPERATED TO FILL PRESSURIZER AND COLLAPSE BUBBLE.

3A. SUMMARY: SYSTEM OPERATION

- MAXIMUM ΔT OF 320°F FOR CPSES
- SIGNIFICANT ΔT ONLY OCCURS DURING CERTAIN MODES OF OPERATION
- DURING POWER OPERATION ΔT LESS THAN 50°F
- OPERATIONS OF CPSES AND REFERENCE PLANT ARE VERY SIMILAR

Outline

- Criterion to establish stratification
- Spatial variations in stratified flow
- Thermal striping potential associated with stratification

TABLE 4-II
IMPORTANT DIMENSIONLESS GROUPS FOR SIMILITUDE
IN HYDRODYNAMIC TESTING

Parameter	Symbol	Definition	Significance
1. Weisbach friction factor	f	$D\Delta P/2\rho V^2 L$	Pressure force/inertia force
2. Cavitation number	b	$(P_s - P_v)/\rho V^2$	Pressure difference/inertia force
3. Reynolds number	Re	$\rho V D/\mu$	Inertia force/viscous force
4. Strouhal number	Sr	$\eta D/V$	Vortex shedding frequency/inertia force
5. Weber number	We	$\rho D V^2/\sigma$	Inertia force/surface-tension force
6. Froude number	Fr	V^2/gD	Inertia force/gravity force
7. Richardson number (Modified Froude number)	Ri	$\Delta\rho g D/\rho V^2$	Buoyancy force/inertia force
8. Euler number	Eu	$\Delta P/\rho V^2$	Pressure force/inertia force
9. Prandtl number	Pr	$\mu C/k$	Momentum diffusivity/thermal diffusivity
10. Peclet number	Pe	$\rho V D C/k$ ($Re \times Pr$)	Convective heat transfer/ conductive heat transfer
11. Grashof number	Gr	$L^3 \rho^2 g \beta \Delta T/\mu^2$	Buoyancy force/viscous force
12. Rayleigh number	Ra	$L^3 \rho^2 C g \beta \Delta T/\mu k$ ($Gr \times Pr$)	—

NOMENCLATURE:

- | | |
|--------------------------------------------|------------------------------------|
| C = specific heat | g = acceleration of gravity |
| ρ = density | P = pressure |
| σ = surface tension | P_s = static fluid pressure |
| k = thermal conductivity | P_v = fluid vapor pressure |
| β = volumetric expansion coefficient | L, D = characteristic dimensions |
| ΔT = fluid temperature change | V = fluid velocity |
| η = vortex shedding frequency | μ = viscosity |

Stratification Potential Based on Richardson Number

- Stratification potential exists if $Ri > 1$
- Example: 90 GPM in 14" schedule 140 pipe with 300°F hot-to-cold temperature difference gives

$$Ri = \frac{\Delta \rho g D}{V^2} = \frac{g \beta \Delta T D}{V^2} \approx 60$$

OR if ~ 700 GPM

$$Ri = 1$$

OR if $\Delta T \sim 5^\circ\text{F}$

$$Ri = 1$$

SPATIAL VARIATIONS IN STRATIFIED FLOW

- 0 LIMITED HEAT EXCHANGE BETWEEN HOT AND COLD FLUID LAYERS; EARLIER EXAMPLE WOULD ONLY ATTENUATE ΔT BY 10% AFTER 70 FEET (USING STANDARD SEMI-INFINITE BODY SOLUTION).
- 0 STRATIFIED FLOW COULD PERSIST IN THE STRATIFIED STATE FOR LONG PERIODS AFTER FLOW STOPS.
- 0 BASED ON OBSERVATIONS FROM SMALL AND LARGE DIAMETER WESTINGHOUSE TESTS, FLOW IN 90° ELBOW WOULD BE EXPECTED TO HAVE PATTERN SHOWN BY ATTACHED FIGURE.
- 0 HOT-TO-COLD INTERFACE CAN BE STEEP AS SHOWN BY ATTACHED DATA FROM WESTINGHOUSE TESTS.

Thermal Striping Associated with Stratification

- Hot-to-cold interfacial surface oscillation in range of 0.1 to 10 hertz (Westinghouse tests + Japanese tests).
- Heat transfer coefficient, BTU/HR-FT²-°F, in range (for earlier example).


$$263 \leq H_{MAX} < 1052$$

Based on boundary layer development arguments (fully developed, classical entrance region or limited Bergles data for vibrating plates).

Estimate of Flow Stratification Pattern in Elbow Under Pressurizer

Hot Flow from Pressurizer

$T_{\text{hot}} = 425^{\circ}\text{F}$



3B. SUMMARY: STRATIFICATION

- STRATIFICATION CAN BE PREDICTED
- THERMAL HYDRAULIC PARAMETERS (ρT , D AND v) SIMILAR FOR CPSE3 AND REFERENCE PLANT.
- EXISTING TEST DATA GENERALLY APPLICABLE TO SURGE LINE.

TU ELECTRIC

**IPO-001A/IPO-005A
HEATUP/COOLDOWN
PROCEDURES**

**COMANCHE PEAK
STEAM ELECTRIC
STATION**

RALPH FLORES

IPC-001A

PLANT HEATUP PROCEDURE


MAJOR EVOLUTIONS PERTAINING TO HEATUP


INITIAL CONDITIONS

- o RCS TEM. 170°F, 170°F
- o RCS PRESS. 5 PSIG
- o PRZR TEM. 170°F, 170°F

PROCEDURAL GUIDANCE

- o START NO 1 AND 4 REACTOR COOLANT PUMPS INITIATING PLANT HEATUP. (ONLY IF RCS TEMPS. 170°F)
- o INITIATE PRESSURIZER HEATUP.
- o DRAW PRESSURIZER BUBBLE.
- o CHEMISTRY PARAMETERS IN SPEC.
- o START NO 1 AND 4 REACTOR COOLANT PUMPS TO INITIATE RCS HEATUP. IF NOT PREVIOUSLY DONE.
- o RHR OUT OF SERVICE.
- o START NO 2 AND 3 REACTOR COOLANT PUMPS TO ASSIST IN RCS HEATUP.
- o INITIATE PRESSURIZER HEATUP AND PRESSURE INCREASE.
- o START REMAINING REACTOR COOLANT IF NOT PREVIOUSLY DONE.





IPO-001A

PLANT HEATUP PROCEDURE

	INITIAL CONDITIONS	BUBBLE 50°F/HR	RCP START 50°F/HR	PRZR H/U 50°F/HR	FINAL CONDITION
RCS TEMP	BETWEEN 130-170	BETWEEN 130-170	HEATUP 130-300	HEATUP 300-557	
TIME DURATION	N/A	N/A	4 HRS	6 HRS	557
PRESSURIZER	BETWEEN 130-170	HEATUP 130 to 440	440	440 to 657	
TIME DURATION	N/A	7 HRS	N/A	5 HRS	657
PRESSURIZER PRESSURE	325	325	325	PRESSURIZE 325 to 2235	
TIME DURATION	N/A	7 HRS	N/A	5 HRS	2235
DELTA T (PRZR, RCS)	0	0 to 310	310 to 140	140 to 100	
TIME DURATION		7 HRS	4 HRS	6 HRS	

IPO-005A

PLANT COOLDOWN PROCEDURE





MAJOR EVOLUTIONS PERTAINING TO COOLDOWN

INITIAL CONDITIONS

- o RCS TEMP 557°F
- o RCS PRESS 2235 PSIG
- o PRZR TEMP 657°F

PROCEDURAL GUIDANCE

- o STOP NO. 2 AND 3 REACTOR COOLANT PUMPS TO INITIATE RCS COOLDOWN.
- o INITIATE RCS DEPRESSURIZATION AND PRESSURIZER COOLDOWN.
- o INITIATE RHR COOLING.
- o STOP NO. 1 AND 4 REACTOR COOLANT PUMPS.
- o FILL, COOLDOWN AND DEPRESSURIZE PRESSURIZER.
- o CONTINUE PRESSURIZER COOL. WN.



IPO-005A

PLANT COOLDOWN PROCEDURE

	INITIAL CONDITIONS	BEGIN RCS COOLDOWN 50°F/HR	BEGIN RCS DEPRESS & 100°F/HR	RHR IN SERVICE	FILL,C/D PRZR & DEPRESSURIZE	FINAL CONDITIONS
RCS TEMP	557	COOLDOWN 557 to 530	COOLDOWN 530 to 500	COOLDOWN 500 to 300	COOLDOWN 300 to 140	
TIME DURATION	N/A	1 HR	1 HR	5 HRS	4 HRS	140
PRESSURIZER TEMP	657	657	COOLDOWN 657 to 630	COOLDOWN 630 to 440	COOLDOWN 440 to 140	
TIME DURATION	N/A	N/A	1 HR	3 HRS	4 HRS	140
PRESSURIZER	2235	2235	DEPRESSURIZE 2235 to 1960	DEPRESSURIZE 1960 to 350	DEPRESSURIZE 325 to 50	
TIME DURATION	N/A	N/A	1 HR	3 HRS	4 HRS	ATMOS.
DELTA T (PRZR, RCS)	100	127	130	130	300 to 0	
TIME DURATION		1 HR	1 HR	5 HRS	5 HRS	


PROCEDURAL CONTROLS
FOR TEMPERATURE
AND PRESSURE LIMITS

- o PROCEDURAL STEP SEQUENCING (BUBBLE CHARTS)
- o PRECAUTIONS
 - SUBCOOLING MINIMUM
 - 320 DELTA T LIMIT
 - COOLDOWN/HEATUP LIMITS (ADMINISTRATIVE)
 - SUBCOOLING DELTA T LIMIT (RCS, PRZR)
 - LOGGING TEMPERATURES
 - TECH SPEC CURVES

PRESSURIZER SURGE LINE MONITORING LOCATIONS

PRESSURIZER
TBX-RCPCPR-01

STEAM GENERATOR
TBX-RCPCSG-4



CONT. ON DRAWING 520-001

PRESSURIZER SURGE LINE MONITORING PARAMETERS

- LOCATIONS/DIRECTIONS

- LOCATIONS D1 THROUGH D4 AND T1 THROUGH T4 ($\pm 6''$)
- LATERAL AND VERTICAL READINGS AT ALL LOCATIONS

- RECORDING INTERVALS

- EVERY 10 MINUTES DURING HEATUP
- EVERY 60 MINUTES AT EACH TEMPERATURE PLATEAU

- RECORDING SYSTEM CAPABILITIES

- 10 SECOND INTERVALS FOR A PERIOD OF 10 MINUTES
- PROVIDE LABELED PLOTS OF TEMPERATURES AND DISPLACEMENTS AS A FUNCTION OF TIME
- AVERAGE ALL TEMPERATURE READINGS AT EACH MEASUREMENT TIME

DUQUESNE LIGHT COMPANY

BEAVER VALLEY UNIT 2

***PRESSURIZER SURGE LINE
STRATIFICATION***

***S. K. MUKHERJEE
NUCLEAR ENGINEERING
DEPARTMENT***

BACKGROUND

- ORIGINAL CONFIGURATION OF SURGE LINE (PRE HFT)
 - TANDEM 6 KIP MECH. SNUBBERS INSTALLED
 - WHIP RESTRAINTS REMOVED PER WHIPJET PROGRAM
 - 2 VARIABLE SPRING HANGERS INSTALLED
 - 1 PERMANENT RTD INSTALLED
 - OPERATING LIMITS - MAX TEMP. DIFF. 300°F

- STRATIFICATION FIRST BECAUSE APPARENT DURING HFT
 - UNUSUAL MOVEMENT OF SNUBBERS NOTED
 - ADDITIONAL INSTRUMENTATION INSTALLED TO REMOTELY MONITOR DISPLACEMENT DURING FUTURE TESTING

- DURING PREOP AND POWER ASCENSION TESTING FURTHER DISPLACEMENT OF A CYCLIC NATURE WERE OBSERVED
 - MAX. RECORDED DISPLACEMENT WAS ~ 3.0 INCHES VERSUS .4 IN. CALCULATED DISPLACEMENT
 - MAX. DISPLACEMENT OCCURRED DURING HEAT UP AND COOL DOWN

- FROM EVALUATION OF DATA CONCLUDED THAT HIGH DISPLACEMENTS WERE A RESULT OF FLUID THERMAL STRATIFICATION

DATA COLLECTION

- - PIPING DISPLACEMENTS APPEARED TO VARY AS A FUNCTION OF TEMPERATURE DIFFERENTIAL BETWEEN THE PRESSURIZER AND THE RCS HOT LEG
- - ADDITIONAL INSTRUMENTATION INSTALLED TO REMOTELY MONITOR TEMPERATURE
- - CONTINUED PLANT TESTING WITH CONTINUOUS MONITORING OF DISPLACEMENTS AND TEMPERATURE

ACTIONS

- - IMPOSED HEAT UP/COOL DOWN LIMITATION OF $\Delta T \leq 200^{\circ}\text{F}$ BETWEEN PRESSURIZER AND RCS HOT LEG
- - REMOVED SNUBBER TRAPEZE ON SURGE LINE UTILIZING ASME CODE CASE N-411
- - ANALYSIS CONDUCTED TO QUANTIFY EFFECTS OF STRATIFICATION

SPECIFIC ANALYSIS

- - SIMPLIFIED 'ANSYS' MODEL OF SURGE LINE GENERATED
 - MODEL COMPRISED OF ELASTIC BEAM ELEMENTS
 - FIRST BENCH MARKED 'ANSYS' MODEL TO ORIGINAL 'NUPIPE' MODEL
 - ALL THERMAL CONDITIONS APPLICABLE TO SURGE LINE WERE REVIEWED TO DETERMINE THE PRESENCE OF THERMAL STRATIFICATION AND POTENTIAL EFFECTS ON THE EXISTING PIPING ANALYSIS
 - THESE THERMAL CONDITIONS INCLUDED
 - NORMAL POWER OPERATION
 - HEAT UP AND COOL DOWN
 - MAXIMUM STRATIFICATION FOLLOWING PLANT EXCURSION/TRIP

- - 'ANSYS' MODEL INCORPORATED ACTUAL RECORDED IN-PLANT TEMPERATURE DATA DURING THE ABOVE THERMAL CONDITIONS TO QUANTIFY THERMAL STRATIFICATION EFFECTS

- - RESULTS OF 'ANSYS' MODEL (FORCES, MOMENTS) FOR EACH APPLICABLE THERMAL CONDITION WAS RE-EVALUATED BY THE ORIGINAL 'NUPIPE' MODEL

- - NUPIPE MODEL THEREFORE COMBINED THE EFFECTS OF THERMAL STRATIFICATION WITH ALL OTHER LOADING CONDITIONS

WHIPJET REVIEW

- EFFECT OF REVISED ANALYSIS ON SURGE LINE EVALUATED
 - LEAKAGE SIZE FLAW RECALCULATED
 - STABILITY EVALUATION CONDUCTED
 - FATIGUE CRACK GROWTH RATE ANALYSIS REVIEWED

- MAINTAINED MARGINS PER NUREG 1061 VOL. 3

BV-1 SURGE LINE REVIEW

- GEOMETRY CLOSELY APPROXIMATES BV-2
 - THIS INCLUDES PIPE ROUTING, SIZE, ENTRANCE
INTO HOT LEG AND SLOPE

- SUPPORTING ARRANGEMENT SIMILAR TO BV-2
 - NO RUPTURE RESTRAINTS ON SURGE LINE

 - PIPING SUPPORTED BY TWO VARIABLE SPRING HANGERS


- OPERATIONAL RESTRICTIONS IMPOSED DURING HEATUP/
COOLDOWN SIMILAR TO SV-2

- PIPING LOADS DUE TO STRATIFICATION FROM BV-2
ANALYSIS BEING EVALUATED

CONCLUSIONS


- STRATIFICATION EFFECTS WERE QUALIFIED AND INCORPORATED INTO THE ANALYSIS
- ANALYSIS SHOWS THAT CODE ACCEPTABILITY MAINTAINED UNDER ALL CASES
- WHIPJET REANALYSIS OF SURGE LINE DEMONSTRATES PIPE LBB CAPABILITY UNDER REVISED LOADING
- OPERATIONAL RESTRICTIONS OF $\Delta T \leq 200^{\circ}\text{F}$ IMPOSED DURING HEATUP AND COOLDOWN ON BOTH BV-1 AND BV-2
- SIMILARITY OF BOTH UNITS SHOWS BV-2 STRATIFICATION EFFECTS/LOADS CAN BE APPLIED TO BV-1

- * LANYARD RCS-TE01-076P Y - VERTICAL DEFLECTION MONITOR ▲▲
- * LANYARD RCS-TE02-077P L - LATERAL DEFLECTION MONITOR
- * LANYARD RCS-TE03-078P A - AXIAL DEFLECTION MONITOR
- * * LANYARD RCS-TE04-079P Y - VERTICAL DEFLECTION MONITOR



▲ SNUBBER PSSPO01 DELETED PER EIDCR No DCP-1015-02
SHOWN FOR REFERENCE ONLY

▲▲ LANYARD RCS-TE01-076P IS ALSO IDENTIFIED AS LAN. 43



PIPE DEFLECTION AT LANYARD N276

DATE
9/21/87

11:00
11:05 (3 HEATERS ON)
12:00
START PRESS. HEATERS
(3 HEATERS ON)

14:00
15:00
15:53 (3 HEATERS ON)
START LETDOWN
(3 HEATERS ON)


16:00
16:18 (HEATERS OFF)
16:30
17:00
17:46 (ONE HEATER ON)

18:00
TERMINATE
LETDOWN


50 G.P.M.
20 G.P.M.

SURGE LINE
FLOW RATE

NOTE: RCS-RTD003 & 004 ARE ON THE BOTTOM OF THE SURGE LINE AND GRAPH THE SAME AS RTD002. THEY ARE NOT SHOWN HERE FOR CLARITY.



PRESSURIZER AND SURGE LINE TEMPERATURE



CHECKED		TITLE PRESSURIZER SURGE LINE BEAVER VALLEY UNIT 2	SCALE: $\frac{1}{4}'' = 1'-0''$
CORRECT			DATE:
APPROVED			SKETCH NUMBER
REVISIONS	③ ③ ④ ③		

BVPS-2
 PRESSURIZER
 SURGE LINE
 THERMAL
 STRATIFICATION
 STUDY

