

DMB

March 5, 1986

Docket No. 50-255

Consumers Power Company
ATTN: Dr. F. W. Buckman
Vice President
Nuclear Operations
212 West Michigan Avenue
Jackson, MI 49201

Gentlemen:

This confirms a telephone conversation between Mr. K. W. Berry of your staff and Mr. C. W. Hehl of my staff on March 4, 1986, in which it was confirmed that an Enforcement Conference will be held beginning at 10:00 a.m. on Thursday, March 13, 1986 at the NRC's Region III Office in Glen Ellyn, Illinois. The purpose of this meeting is to discuss information regarding Licensee Event Report No. (LER) 85029 in which a local leak rate test dated December 4, 1985 on containment penetration 40 exceeded the Technical Specification (TS) allowable limit of 0.60 La.

We will gladly discuss any questions you may have concerning this matter.

Sincerely,

"Original Signed by C. E. Norelius"

C. E. Norelius, Director
Division of Reactor Projects

cc: J. F. Firlit, General Manager
DCS/RSB (RIDS)
Licensing Fee Management Branch
Resident Inspector, RIII
Ronald Callen, Michigan
Public Service Commission
Nuclear Facilities and
Environmental Monitoring
Section

[Signature]
RIII
Wolfsen/qg
03/04/86

[Signature]
RIII
Hehl

[Signature]
RIII
Chrystosimos
3/5/86

[Signature]
RIII
Norelius
3/5/86

8603110170 860305
PDR ADOCK 05000255
S PDR

10 LE01