



South Carolina Electric & Gas Company  
P.O. Box 88  
Jenkinsville, SC 29065  
(803) 345-4040

Ollie S. Bradham  
Vice President  
Nuclear Operations

September 16, 1988

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Subject: Virgil C. Summer Nuclear Station  
Docket No. 50/395  
Operating License No. NPF-12  
Technical Specification Change  
VANTAGE 5 Reload Corrections

Gentlemen:


This letter forwards corrections to the South Carolina Electric & Gas Company VANTAGE 5 Technical Specifications submittals dated May 20, 1988 and August 31, 1988. These typographical corrections were discussed with your staff in a telephone conversation dated September 9, 1988.

Attachment I corrects Figure 3.2-1 which depicts  $K(z)$  as a function of core height. This Figure was provided in Attachment 2 to the May 20, 1988 submittal and although the graph of  $K(z)$  versus core height provided in the original submittal is correct, the superimposed table incorrectly lists a  $K(z)$  of 1.9 at a core height of 6.0 feet. This value of  $K(z)$  should be 1.0.

Attachment II corrects Table 4, "Reactor Coolant Equilibrium Fission Product Activities," provided in the August 31, 1988 letter. This Table incorrectly lists the Iodine-131 activity of 3.9 micro-curies per gram. This value should be corrected to 2.8 micro-curies per gram.

Should you have any questions concerning this manner, please call at your convenience. We regret any inconvenience these errors may have caused.

Very truly yours,

  
O. S. Bradham

MDB/OSB:1cd  
Attachments

c: D. A. Nauman/J. G. Connelly, Jr./O. W. Dixon, Jr./T. C. Nichols, Jr.  
E. C. Roberts  
W. A. Williams, Jr.  
J. N. Grace  
J. J. Hayes, Jr.  
General Managers  
C. A. Price/R. M. Campbell, Jr.  
R. B. Clary  
K. E. Nodland  
J. C. Snelson  
G. O. Percival  
R. L. Prevatte  
J. B. Knotts, Jr.  
H. G. Shealy  
NSRC  
RTS (TSP 880013)  
NPCF  
File (813.20)

8809230231 880916  
PDR ADOCK 05000395  
P PNU

Acc 1  
11