

October 12, 1998
PY-CEI/NRR-2329L

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Perry Nuclear Power Plant
Docket No. 50-440
License No. NPF-58
Monthly Operating Report

Ladies and Gentlemen:

Attached is the September 1998 Monthly Operating Report for Perry Unit 1. Page 1 is the Operating Data Report and page 2 is the Unit Shutdowns Chart. This report is submitted in accordance with Technical Specification 5.6.4 and Generic Letter 97-02, "Revised Contents of the Monthly Operating Report."

If you have questions or require additional information, please contact Ms. Penny Johnson at (440) 280-5342.

Very truly yours,



Henry L. Hegrat
Manager - Regulatory Affairs

PMJ:s

Attachment

cc: NRC Region III Administrator
NRC Project Manager
NRC Resident Inspector

9810160212 980930
PDR ADOCK 05000440
R PDR

11
10/24

OPERATING DATA REPORT

UNIT: Perry
DATE: 10/7/98

1. Docket: 50-440
2. Unit Name: Perry Nuclear Power Plant
3. Reporting Period: September 1998
4. Utility Contact: P. Johnson
5. Telephone: 440-280-5342
6. Design Electrical Rating (Net MWe): 1191
7. Maximum Dependable Capacity (Net MWe): 1160

	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
8. Hours Reactor was Critical	<u>720.0</u>	<u>6,492.6</u>	<u>70,997.3</u>
9. Hours Generator On-Line	<u>720.0</u>	<u>6,475.9</u>	<u>68,795.3</u>
10. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
11. Net Electrical Energy (MWeH)	<u>819,082</u>	<u>7,605,345</u>	<u>77,026,775</u>

UNIT SHUTDOWNS REPORT MONTH - SEPTEMBER 1998

DOCKET NO: 50-440
 NAME: Perry Nuclear Power Plant
 DATE: 10/7/98
 CONTACT: P. Johnson
 TELEPHONE: (440) 280-5342

No.	Date	Type 1	Duration Hours	Reason 2	Method 3	Cause and Corrective Action to Prevent Recurrence

SUMMARY: Perry Unit One remained on line for the entire month of September. During the month of September a suspected leaking fuel bundle was identified and suppressed. The unit continues to run at full power output.

1. TYPE:

F: Forced
 S: Scheduled

2. REASON:

A - Equipment Failure (explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operating Training &
 License Examination
 F - Administrative
 G - Operational Error (explain)
 H - Other (explain)

3. METHOD:

1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continuation
 5 - Other